



3 9999 06588 185 4

**1572**

SL OK

**THE COMMONWEALTH OF MASSACHUSETTS**

**DEPARTMENT OF PUBLIC SAFETY**

**BOARD OF FIRE PREVENTION REGULATIONS**


**MASSACHUSETTS ELECTRICAL CODE**

**RULES AND REGULATIONS**

**GOVERNING THE**

**INSTALLATION, REPAIR AND MAINTENANCE  
OF ELECTRICAL WIRING AND ELECTRICAL  
FIXTURES USED FOR LIGHT, HEAT AND POWER  
IN BUILDINGS AND STRUCTURES SUBJECT  
TO THE PROVISIONS OF SECTIONS 3 TO 60,  
CHAPTER 143, G. L., TER. ED., AS AMENDED**

**FORM FPR-11**



# BOSTON PUBLIC LIBRARY



# *The Commonwealth of Massachusetts*

## OFFICE OF THE SECRETARY STATE HOUSE, BOSTON, MASS.

*Rules and Regulations filed in this Office under the provisions of  
CHAPTER 30A as amended.*

DEPARTMENT OF PUBLIC SAFETY  
Filed by BOARD OF FIRE PREVENTION REGULATIONS - FPR-11  
MASSACHUSETTS ELECTRICAL CODE

Date Filed NOVEMBER 9, 1972


Date Published DECEMBER 20, 1972

### Chapter 233, sec. 75

Printed copies of rules and regulations purporting to be issued by authority of any department, commission, board or Officer of the Commonwealth or any city or town having authority to adopt them, or printed copies of any ordinances or town by-laws, shall be admitted without certification or attestations, but if this genuineness is questioned, the court may require such certifications or attestations thereof as it deems necessary.

Attested as a true copy

JOHN F. X. DAVOREN

Handwritten signature of John F. X. Davoren in cursive script.

SECRETARY OF THE COMMONWEALTH

**Chap. 617** AN ACT TO PROVIDE FOR RULES AND REGULATIONS RELATIVE TO THE INSTALLATION, REPAIR AND MAINTENANCE OF ELECTRICAL WIRING AND ELECTRICAL FIXTURES USED FOR LIGHT, HEAT AND POWER PURPOSES.

*Be it enacted, etc., as follows:*

G. L. (Ter. Ed.), 143, new § 3L, added.

Board to make rules and regulations, etc., relative to installation, repair, etc., of electrical wiring, etc.

SECTION 1. Chapter 143 of the General Laws is hereby amended by inserting after section 3K the following section: — *Section 3L.* The board of fire prevention regulations shall make and promulgate, and from time to time may alter, amend and repeal, rules and regulations relative to the installation, repair and maintenance of electrical wiring and electrical fixtures used for light, heat and power purposes in buildings and structures subject to the provisions of sections three to sixty, inclusive. Such regulations shall be in accordance with generally accepted standards of engineering practice, and shall be designed to provide reasonable uniform requirements of safety in relation to life, fire and explosion.

Upon the making of such rules and regulations and prior to their promulgation, the board shall hold a public hearing thereon, notice of which shall be given by advertising in at least one newspaper in each of the cities of Boston, Worcester, Springfield, Fall River, Lowell and Lynn, at least ten days before said hearing. If, subsequent to their being deposited with the state secretary, as provided herein, the board on its own initiative contemplates changes in said rules and regulations, or if a petition is filed by any other person for changes therein, like notice and a hearing shall be given and held before the adoption thereof.

Rules, etc., to be deposited with state secretary.

Such rules and regulations, and any alterations, amendments or repeals thereof shall be deposited with the state secretary, and the same shall become effective when so deposited.

By-laws and ordinances to be annulled, etc.

SECTION 2. Upon the filing with the state secretary of the rules and regulations referred to in section three L of chapter one hundred and forty-three of the General Laws, inserted by section one of this act, all by-laws and ordinances of cities and towns relating to the installation, repair and maintenance of electrical wiring and electrical fixtures used for light, heat and power purposes in buildings and structures subject to the provisions of sections three to sixty, inclusive, of said chapter one hundred and forty-three shall be annulled.

*Approved July 11, 1950.*



## TABLE OF CONTENTS

ARTICLE	PAGE	ARTICLE	PAGE
90 Introduction .....	1	358 Cellular Concrete Floor Raceways .....	157
<b>Chapter 1. General</b>		362 Wireways .....	158
100 Definitions .....	4	363 Flat Cable Assemblies .....	159
110 General .....	13	364 Busways .....	161
<b>Chapter 2. Wiring Design and Protection</b>		365 Cablebus .....	163
200 Use and Identification of Grounded Conductors ....	18	370 Outlet, Switch and Junction Boxes, and Fittings .....	164
210 Branch Circuits .....	21	373 Cabinets and Cutout Boxes .....	171
215 Feeders .....	29	374 Auxiliary Gutters .....	174
220 Branch-Circuit and Feeder Calculations .....	30	380 Switches .....	176
230 Services .....	42	384 Switchboards and Panelboards .....	179
240 Overcurrent Protection .....	58	390 Prefabricated Buildings .....	183
250 Grounding .....	66	<b>Chapter 4. Equipment for General Use</b>	
280 Lightning Arresters .....	89	400 Flexible Cords and Cables .....	184
<b>Chapter 3. Wiring Methods and Materials</b>		402 Fixture Wires .....	194
300 Wiring Methods—General Requirements .....	91	410 Lighting Fixtures, Lamp-holders, Lamps, Receptacles and Rosettes .....	198
305 Temporary Wiring .....	97	422 Appliances .....	213
310 Conductors for General Wiring .....	98	424 Fixed Electric Space Heating Equipment .....	219
318 Continuous Rigid Cable Supports .....	121	426 Fixed Outdoor Electric De-Icing and Snow-Melting Equipment .....	227
320 Open Wiring on Insulators .....	123	430 Motors, Motor Circuits and Controllers .....	229
324 Concealed Knob-and-Tube Work .....	126	440 Air Conditioning and Refrigerating Equipment ....	263
330 Mineral Insulated-Metal Sheathed Cable .....	128	445 Generators .....	272
331 Aluminum Sheathed Cable .....	129	450 Transformers and Transformer Vaults .....	273
334 Metal-Clad Cable .....	130	460 Capacitors .....	280
336 Nonmetallic Sheathed Cable .....	133	470 Resistors and Reactors.....	282
337 Shielded Nonmetallic Sheathed Cable .....	135	480 Storage Batteries .....	283
338 Service-Entrance Cable .....	136	<b>Chapter 5. Special Occupancies</b>	
339 Underground Feeder and Branch Circuit Cable ....	137	500 Hazardous Locations .....	286
342 Nonmetallic Extensions ....	138	501 Class I Installations—Hazardous Locations .....	293
344 Underplaster Extensions ....	140	502 Class II Installations—Hazardous Locations .....	303
346 Rigid Metal Conduit .....	141	503 Class III Installations—Hazardous Locations .....	312
347 Rigid Nonmetallic Conduit .....	143	510 Hazardous Locations—Specific .....	316
348 Electrical Metallic Tubing ..	146	511 Commercial Garages, Repair and Storage .....	316
350 Flexible Metal Conduit .....	148	512 Residential Storage Garages .....	319
351 Liquidtight Flexible Metal Conduit .....	149	513 Aircraft Hangars .....	319
352 Surface Raceways .....	150	514 Gasoline Dispensing and Service Stations .....	323
353 Multioutlet Assembly .....	152	515 Bulk-Storage Plants .....	325
354 Underfloor Raceways .....	152	516 Finishing Processes .....	328
356 Cellular Metal Floor Raceways .....	154	517 Health Care Facilities .....	333
357 Structural Raceways .....	155	520 Theaters and Assembly Halls .....	351

ARTICLE	PAGE	ARTICLE	PAGE
530 Motion-Picture Studios and Similar Locations .....	358	730 Outside Branch Circuits and Feeders .....	456
540 Motion-Picture Projectors ..	361	750 Stand-By Power Generation Systems .....	460
550 Mobile Homes and Mobile Home Parks .....	363		
551 Recreational Vehicles and Recreational Vehicle Parks .....	375	<b>Chapter 8. Communication Systems</b>	
555 Marinas and Boatyards .....	392	800 Communication Circuits ....	462
<b>Chapter 6. Special Equipment</b>		810 Radio and Television Equipment .....	467
600 Electric Signs and Outline Lighting .....	394	820 Community Antenna Tele- vision and Radio Distribu- tion Systems .....	473
610 Cranes and Hoists .....	400		
620 Elevators, Dumbwaiters, Escalators, and Moving Walks .....	405	<b>Chapter 9. Tables and Examples</b>	
630 Electric Welders .....	411	Tables .....	477
640 Sound-Recording and Similar Equipment .....	415	Examples .....	489
645 Data Processing Systems ....	418		
650 Organs .....	419	<b>Index</b>	
660 X-Ray Equipment .....	420	Index .....	499
665 Induction and Dielectric Heating Equipment .....	425		
670 Metal Working Machine Tools .....	430		
680 Swimming and Wading Pools .....	431		
<b>Chapter 7. Special Conditions</b>			
700 Emergency Systems .....	438		
710 Over 600 Volts—General ....	442		
720 Circuits and Equipment Operating at Less Than 50 Volts .....	449		
725 Remote-Control, Low- Energy Power, Low-Voltage Power and Signal Circuits .....	450		

THE COMMONWEALTH OF MASSACHUSETTS  
DEPARTMENT OF PUBLIC SAFETY  
BOARD OF FIRE PREVENTION REGULATIONS

**MASSACHUSETTS ELECTRICAL CODE  
FORM FPR-11**

In accordance with the provisions of G. L., C. 143, s. 3L, the Board of Fire Prevention Regulations herewith makes the following rules and regulations relative to the installation, repair and maintenance of electrical wiring and electrical fixtures used for light, heat and power purposes in buildings and structures subject to the provisions of G. L., C. 143, ss. 3 to 60, inclusive.

**Rule 1.** All installations, repairs and maintenance of electrical wiring and electrical fixtures used for light, heat and power purposes in buildings and structures subject to the provisions of Sections 3 to 60, Chapter 143, G. L., Ter. Ed., as amended, shall be reasonably safe to persons and property.

**Rule 2.** Conformity of installations, repairs and maintenance of electrical wiring and electrical fixtures used for light, heat and power with applicable regulations set forth in the code which is filed herewith with the Secretary of the Commonwealth shall be considered as complying with these requirements.

**Rule 3.** Additions or modifications to an existing installation shall be made in accordance with this code without bringing the remaining part of the installation to meet the requirements of this code.

**Rule 4.** Where an actual hazard exists, the owner of the property shall be notified in writing by the authority enforcing this code.

**Rule 5.** All references in this code to other standards shall be considered as advisory and not mandatory.

**Rule 6.** The approving authority may be guided in his approval of specific items of equipment and materials contemplated by the code, by proof that such equipment and materials have been tested and conform to suitable recognized industry standards.

**Note:** With reference to the approval of specific items of equipment and materials contemplated by the code, it is pointed out that in order to avoid the necessity for repetition of examinations by different examiners, frequently with inadequate facilities for such work, and to avoid the confusion which would result from conflicting reports as to the suitability of devices and materials examined for a given purpose, it is necessary that such examinations should be made under standard conditions, and the record made generally available through promulgation by organizations properly equipped and qualified for experimental testing, inspections of the run of goods at factories, and service-value determination through field inspections.

## ARTICLE 90 — INTRODUCTION

### 90-1. Purpose.

(a) The purpose of this Code is the practical safeguarding of persons and of buildings and their contents from hazards arising from the use of electricity for light, heat, power, radio, signalling and for other purposes.

(b) This Code contains provisions considered necessary for safety. Compliance therewith and proper maintenance will result in an installation essentially free from hazard, but not necessarily efficient, convenient, or adequate for good service or future expansion of electrical use.

Hazards often occur because of overloading of wiring systems by methods or usage not in conformity with the Code. This occurs because initial wiring did not provide for increases in use of electricity. For this reason it is recommended that the initial installation be adequate and that reasonable provisions for system changes be made as may be required for future increase in the use of electricity.

(c) This Code is not intended as a design specification nor an instruction manual for untrained persons.

### 90-2. Scope.

(a) **Covered.** It covers the electric conductors and equipment installed within or on public and private buildings and other premises, including yards, carnival and parking lots, and industrial substations; also the conductors that connect the installations to a supply of electricity, and other outside conductors adjacent to the premises; also mobile homes and recreational vehicles.

(b) **Not covered.** It does not cover:

(1) Installations in ships, watercraft, railway rolling stock, aircraft or automotive vehicles (except mobile homes and recreational vehicles).

(2) Installations underground in mines.

(3) Installations of railways for generation, transformation, transmission or distribution of power used exclusively for operation of rolling stock or installations used exclusively for signaling and communication purposes.

(4) Installations of communication equipment under exclusive control of communication utilities, located outdoors or in building spaces used exclusively for such installations.

(5) Installations under the exclusive control of electric utilities for the purpose of communication, metering or for the generation, control, transformation, transmission and distribution of electric energy

located in buildings used exclusively by utilities for such purposes or located outdoors on property owned or leased by the utility or on public highways, streets, roads, etc., or outdoors by established rights on private property.

**(c) Special Permission.** The authority having jurisdiction for enforcing the Code may grant exception for the installation of conductors and equipment, not under the exclusive control of the electric utilities and used to connect the electric utility supply system to the service entrance conductors of the premises served, provided such installations are outside a building or terminate immediately inside a building wall.

**90-3. Code Arrangement.** This Code is divided into nine chapters. Chapters 1, 2, 3 and 4 apply generally; Chapters 5, 6 and 7 apply to special occupancies, special equipment, or other special conditions. The latter chapters supplement or amend the general rules. Chapters 1 through 4 apply except as amended by Chapters 5, 6 and 7 for the particular conditions.

Chapter 8 covers communications systems and is independent of the other chapters except where they are specifically referenced therein.

Chapter 9 consists of tables and examples.

**90-4. Definitions.** Article 100 contains definitions of a number of terms that are used in two or more Articles. In general, terms used only in a single Article are defined in the Article concerned. For electrical terms not defined in the Code, refer to the ANSI Standard Definitions of Electrical Terms, ANSI C-42 series.

**90-5. Fundamental Rules.** Throughout the Code are paragraphs which state only fundamentals or objectives of safeguarding. These are followed by paragraphs setting forth the recognized methods and detail by which the purpose and intent of the fundamental may be satisfied. Accordingly, when employed, the rules stating a fundamental only will appear as the first paragraph of an Article or Section.

**90-6.** DELETED

## **90--7. Enforcement.**

This code shall be used by the authority enforcing the code. The administrative authority supervising such enforcement of the code shall have the responsibility for making interpretations of the rules and shall accept approved or labeled equipment and materials suitable for the purpose for which they are to be used. He may decide on the approval of unlisted equipment and may grant special permission contemplated in a number of the rules.

**90-8. Examination of Equipment for Safety.** For approval of specific items of equipment and materials covered by the Code, examinations for safety should be made under standard conditions, and the record made generally available through promulgation by organizations properly equipped and qualified for experimental testing, inspections of the

run of goods at factories, and service-value determination through field inspections. This avoids the necessity for repetition of examinations by different examiners, frequently with inadequate facilities for such work, and the confusion that would result from conflicting reports as to the suitability of devices and materials examined for a given purpose. It is the intent of the Code that factory-installed internal wiring or the construction of equipment need not be inspected at the time of installation of the equipment except to detect alterations or damage if the equipment has been listed by an electrical testing laboratory, which is nationally recognized as having the facilities described above and which requires suitability for installation in accordance with the Code.

#### **90-9. Wiring Planning.**

(a) Electrical engineers and others when drawing plans and specifications shall make provision for ample raceways for wiring, spaces for equipment, and allowances for future increases in the use of electricity. In laying out an installation for constant-potential systems, provision shall be made for distribution centers located in easily accessible places for convenience and safety of operation.

(b) It is elsewhere provided in this Code that the number of wires and circuits confined in a single enclosure be varyingly restricted. It is strongly recommended that electrical engineers and others who are planning installations provide similar restrictions wherever practicable, to the end that the effects of breakdowns from short circuits or grounds, even though resulting fire and similar damage are confined to wires, their insulation and enclosures, may not involve entire services to premises nor interruptions of essential and independent services.

**90-10. Revisions.** It is customary to revise this Code periodically to conform with developments in the art and the result of experience, and the latest edition of the Code should always be used.

## Chapter 1. General

### ARTICLE 100 — DEFINITIONS

General guides for this Article on Definitions include: (1) for simplicity, only definitions essential to the proper use of this Code are included; (2) only those terms used in two or more Articles are defined in full in Article 100, other definitions being defined in the individual Article where they apply; (3) in general, **MASSACHUSETTS ELECTRICAL CODE** definitions will be the same as definitions in the latest revision of ASA C-42, "Definitions of Electrical Terms," and are so identified by an asterisk\*.

**Accessible:** (As applied to wiring methods.) Capable of being removed or exposed without damaging the building structure or finish, or not permanently closed in by the structure or finish of the building. (See "Concealed" and "Exposed.")

**\*Accessible:** (As applied to equipment.) Admitting close approach because not guarded by locked doors, elevation or other effective means. (See "Readily Accessible.")

**Ampacity:** Current-carrying capacity expressed in amperes.

**Anesthetizing Location:** See Section 517-2.

**Appliance:** An appliance is utilization equipment, generally other than industrial, normally built in standardized sizes or types, which is installed or connected as a unit to perform one or more functions such as clothes washing, air conditioning, food mixing, deep frying, etc.

**Appliance — Fixed:** An appliance which is fastened or otherwise secured at a specific location.

**Appliance — Portable:** An appliance which is actually moved or can easily be moved from one place to another in normal use.

**Appliance — Stationary:** An appliance which is not easily moved from one place to another in normal use.

**Approved:** Acceptable to the authority enforcing this Code.

**\*Askarel:** A synthetic nonflammable insulating liquid which, when decomposed by the electric arc, evolves only nonflammable gaseous mixtures.

**\*Attachment Plug (Plug Cap) (Cap):** An attachment plug is a device which, by insertion in a receptacle, establishes connection between the conductors of the attached flexible cord and the conductors connected permanently to the receptacle.

**\*Automatic:** Automatic means self-acting, operating by its own mechanism when actuated by some impersonal influence, as for example, a change in current strength, pressure, temperature, or mechanical configuration. (See "Nonautomatic.")

**Block (City, Town, or Village):** See Section 800-2.



**Bonding Jumper:** A reliable conductor to assure the required electrical conductivity between metal parts required to be electrically connected.

**Bonding Jumper, Circuit:** The connection between portions of a conductor in a circuit to maintain required ampacity of the circuit.

**Bonding Jumper, Equipment:** The connection between two or more portions of the equipment grounding conductor.

**Bonding Jumper, Main:** The connection between the grounded circuit conductor and the equipment grounding conductor at the service.

**Branch Circuit:** A branch circuit is that portion of the wiring system between the final overcurrent device protecting the circuit and the outlet(s).

A device not approved for branch-circuit protection such as a thermal cutoff or motor overload protective device is not considered as the overcurrent device protecting the circuit.

**\* Branch Circuit—Appliance:** An appliance branch circuit is a circuit supplying energy to one or more outlets to which appliances are to be connected; such circuits to have no permanently connected lighting fixtures not a part of an appliance.

**Branch Circuit — General Purpose:** A branch circuit that supplies a number of outlets for lighting and appliances.

**Branch Circuit — Individual:** A branch circuit that supplies only one utilization equipment.

**Branch Circuit, Multiwire:** A multiwire branch circuit is a circuit consisting of two or more ungrounded conductors having a potential difference between them, and an identified grounded conductor having equal potential difference between it and each ungrounded conductor of the circuit and which is connected to the neutral conductor of the system.

**Branch-Circuit Selection Current:** See Section 440-3(c) Note.

**Building:** A combination of any materials, whether portable or fixed, having a roof, to form a structure for the shelter of persons, animals or property. For the purpose of this definition "roof" shall include an awning or any similar covering, whether or not permanent in nature. The word "building" shall be construed where the context requires as though followed by the words "or part or parts thereof." Building, a structure which stands alone or which is cut off from adjoining structures by fire walls with all openings therein protected by approved fire doors.

**\*Cabinet:** An enclosure designed either for surface or flush mounting, and provided with a frame, mat or trim in which swinging doors are hung.

**Cell (As Applied to Raceways):** See Sections 356-1 and 358-1.

**Circuit Breaker:** A device designed to open and close a circuit by nonautomatic means, and to open the circuit automatically on a predetermined overload of current, without injury to itself when properly applied within its rating.

**Communication Circuit:** See Section 800-1.

**Concealed:** Rendered inaccessible by the structure or finish of the building. Wires in concealed raceways are considered concealed, even though they may become accessible by withdrawing them. [See "Accessible — (As applied to wiring methods)"]

**Conductor:**

**BARE:** A bare conductor is one having no covering or insulation whatsoever. (See "Conductor, Covered.")

**COVERED:** A covered conductor is one having one or more layers of nonconducting materials that are not recognized as insulation under the Code. (See "Conductor, Bare.")

**INSULATED:** An insulated conductor is one covered with material recognized as insulation.

**\*Connector, Pressure (Solderless):** A pressure wire connector is a device which establishes the connection between two or more conductors or between one or more conductors and a terminal by means of mechanical pressure and without the use of solder.

**Continuous Load:** A load where the maximum current is expected to continue for three hours or more.

**Control Circuit:** See Section 430-71.

**Controller:** A device, or group of devices, which serves to govern, in some predetermined manner, the electric power delivered to the apparatus to which it is connected. See also Section 430-81(a).

**Cooking Unit, Counter-Mounted:** An assembly of one or more domestic surface heating elements for cooking purposes designed for flush mounting in, or supported by, a counter, and which assembly is complete with inherent or separately mountable controls and internal wiring. (See "Oven, Wall-Mounted.")

**Current Limiting Overcurrent Protective Device:** (See Section 240-27.)

**\*Cutout Box:** An enclosure designed for surface mounting and having swinging doors or covers secured directly to and telescoping with the walls of the box proper. (See "Cabinet.")

**\*Demand Factor:** The demand factor of any system, or part of a system, is the ratio of the maximum demand of the system, or part of a system, to the total connected load of the system, or of the part of the system under consideration.

**Device:** A unit of an electrical system which is intended to carry but not utilize electric energy.

**Disconnecting Means:** A device, or group of devices, or other means whereby the conductors of a circuit can be disconnected from their source of supply.

**Dry:** (See "Location — Dry.")

**Dust-Ignition-Proof:** See Section 502-1.

**\*Dustproof:** So constructed or protected that dust will not interfere with its successful operation.

**\*Dust-tight:** So constructed that dust will not enter the enclosing case.

**Duty:**

**\*CONTINUOUS:** Continuous duty is a requirement of service that demands operation at a substantially constant load for an indefinitely long time.

**\*INTERMITTENT:** Intermittent duty is a requirement of service that demands operation for alternate intervals of (1) load and no load; or (2) load and rest; or (3) load, no load and rest.

**\*PERIODIC:** Periodic duty is a type of intermittent duty in which the load conditions are regularly recurrent.

**\*SHORT TIME:** Short-time duty is a requirement of service that demands operation at a substantially constant load for a short and definitely specified time.

**\*VARYING:** Varying duty is a requirement of service that demands operations at loads, and for intervals of time, both of which may be subject to wide variation.

See Table 430-22 (a — Exception) for illustration of various types of duty.

**Duty Cycle (Welding):** See Section 630-31(c).

**\*Electric Sign:** A fixed, stationary or portable, self-contained, electrically illuminated utilization equipment with words or symbols designed to convey information or attract attention.

**\*Enclosed:** Surrounded by a case which will prevent a person from accidentally contacting live parts.

**Equipment:** A general term including material, fittings, devices, appliances, fixtures, apparatus and the like used as a part of, or in connection with, an electrical installation.

**\* Explosion-Proof Apparatus:** Apparatus enclosed in a case which is capable of withstanding an explosion of a specified gas or vapor which may occur within it and of preventing the ignition of a specified gas or vapor surrounding the enclosure by sparks, flashes, or explosion of the gas or vapor within, and which operates at such an external temperature that a surrounding flammable atmosphere will not be ignited thereby.

**Exposed:** (As applied to live parts.) Exposed means that a live part can be inadvertently touched or approached nearer than a safe distance by a person. It is applied to parts not suitably guarded, isolated or insulated. (See “Accessible” and “Concealed.”)

**Exposed:** (As applied to wiring methods.) On or attached to the surface or behind panels designed to allow access. [See “Accessible — (As applied to wiring methods)”]

**\*Externally Operable:** Externally operable means capable of being operated without exposing the operator to contact with live parts.

This term is applied to equipment, such as a switch, that is enclosed in a case or cabinet.

**Feeder:** A feeder is the circuit conductors between the service equipment, or the generator switchboard of an isolated plant, and the branch-circuit overcurrent device.

**Festoon Lighting:** See Section 730-6(b).

**Fitting:** An accessory such as a locknut, bushing or other part of a wiring system which is intended primarily to perform a mechanical rather than an electrical function.

**Garage:** A building or portion of a building in which one or more self-propelled vehicles carrying volatile, flammable liquid for fuel or power are kept for use, sale, storage, rental, repair, exhibition or demonstrating purposes, and all that portion of a building which is on or below the floor or floors in which such vehicles are kept and which is not separated therefrom by suitable cutoffs.

**Ground:** A ground is a conducting connection, whether intentional or accidental, between an electrical circuit or equipment and earth, or to some conducting body which serves in place of the earth.

**Grounded:** Grounded means connected to earth or to some conducting body which serves in place of the earth.

**Grounded (Effectively Grounded Communication System):** See Section 800-2(c)(1).

**Grounded Conductor:** A system or circuit conductor which is intentionally grounded.

**Grounding Conductor:** A conductor used to connect equipment or the grounded circuit of a wiring system to a grounding electrode or electrodes.

**Grounding Conductor, Equipment:** The conductor used to connect noncurrent-carrying metal parts of equipment, raceways and other enclosures to the system grounded conductor at the service and/or the grounding electrode conductor.

**Grounding Electrode Conductor:** The conductor used to connect the grounding electrode to the equipment grounding conductor and/or to the grounded conductor of the circuit at the service.

**Guarded:** Covered, shielded, fenced, enclosed or otherwise protected, by means of suitable covers or casings, barriers, rails or screens, mats or platforms, to remove the liability of dangerous contact or approach by persons or objects to a point of danger.

**Hazardous Locations:** See Article 500.

**Header:** See Section 356-1.

**Header Ducts:** See Section 358-1.

**Hoistway:** Any shaftway, hatchway, well hole, or other vertical opening or space in which an elevator or dumbwaiter is designed to operate.

**Identified:** Identified, as used in this Code in reference to a conductor or its terminal, means that such conductor or terminal is to be recognized as grounded. See Article 200.

**\*Isolated:** Isolated means that an object is not readily accessible to persons unless special means for access are used.

**\*Lighting Outlet:** An outlet intended for the direct connection of a lampholder, a lighting fixture or a pendant cord terminating in a lampholder.

**Location:**

**DAMP LOCATION:** Partially protected locations under canopies, marquees, roofed open porches, and like locations, and interior locations subject to moderate degrees of moisture, such as some basements, some barns, and some cold-storage warehouses.

**DRY LOCATION:** A location not normally subject to dampness or wetness. A location classified as dry may be temporarily subject to dampness or wetness, as in the case of a building under construction.

**WET LOCATION:** Installations underground or in concrete slabs or masonry in direct contact with the earth, and locations subject to saturation with water or other liquids, such as vehicle washing areas, and locations exposed to weather and unprotected.

**Low-Energy Power Circuit:** A circuit which is not a remote-control or signal circuit but which has the power supply limited in accordance with the requirements of Class 2 remote-control circuits. See Article 725.

Such circuits include electric door openers and circuits used in the operation of coin-operated phonographs.

**Multioutlet Assembly:** A type of surface or flush raceway designed to hold conductors and attachment-plug receptacles, assembled in the field or at the factory.

**\*Nonautomatic:** Nonautomatic means that the implied action requires personal intervention for its control. (See "Automatic.")

As applied to an electric controller, nonautomatic control does not necessarily imply a manual controller, but only that personal intervention is necessary.

**\*Outlet:** A point on the wiring system at which current is taken to supply utilization equipment.

**\*Outline Lighting:** An arrangement of incandescent lamps or gaseous tubes to outline and call attention to certain features such as the shape of a building or the decoration of a window.

**Oven, Wall-Mounted:** A domestic oven for cooking purposes designed for mounting in or on a wall or other surface.

**Panelboard:** A single panel or group of panel units designed for assembly in the form of a single panel; including buses, and with or without switches and/or automatic overcurrent protective devices for the control of light, heat or power circuits of small individual as well as aggregate capacity; designed to be placed in a cabinet or cutout box placed in or against a wall or partition and accessible only from the front. (See "Switchboard.")

**Projector, Nonprofessional:** See Section 540-30.

**Projector, Professional:** See Section 540-10.

**Qualified Person:** One familiar with the construction and operation of the apparatus and the hazards involved.

**Raceway:** Any channel for holding wires, cables or bus-bars, which is designed expressly for, and used solely for, this purpose.

Raceways may be of metal or insulating material and the term includes rigid metal conduit, rigid nonmetallic conduit, flexible metal conduit, electrical metallic tubing, underfloor raceways, cellular concrete floor raceways, cellular metal floor raceways, surface raceways, structural raceways, wireways and busways.

**Rainproof:** So constructed, protected or treated as to prevent rain from interfering with successful operation of the apparatus.

**\*Raintight:** So constructed or protected that exposure to a beating rain will not result in the entrance of water.

**Rated-Load Current:** See Section 440-3(a) Note.

**\*Readily Accessible:** Capable of being reached quickly, for operation, renewal, or inspections, without requiring those to whom ready access is requisite to climb over or remove obstacles or to resort to portable ladders, chairs, etc. (See "Accessible.")

**Receptacle:** A receptacle is a contact device installed at the outlet for the connection of a single attachment plug.

A single receptacle is a single contact device with no other contact device on the same yoke. A multiple receptacle is a single device containing two or more receptacles.

**\*Receptacle Outlet:** An outlet where one or more receptacles are installed.

**Remote-Control Circuit:** Any electrical circuit which controls any other circuit through a relay or an equivalent device.

**Sealable Equipment:** Equipment enclosed in a case or cabinet that is provided with means of sealing or locking so that live parts cannot be made accessible without opening the enclosure. The equipment may or may not be operable without opening the enclosure.

**Sealed (Hermetic Type) Motor Compressor:** A mechanical compressor consisting of a compressor and a motor, both of which are enclosed in the same sealed housing, with no external shaft nor shaft seals, the motor operating in the refrigerant atmosphere.

**Service:** The conductors and equipment for delivering energy from the electricity supply system to the wiring system of the premises served.

**\*Service Cable:** The service cable is the service conductors made up in the form of a cable.

**Service Conductors:** The supply conductors which extend from the street main, or from transformers to the service equipment of the premises supplied.

**Service Drop:** The overhead service conductors from the last pole or other aerial support to and including the splices, if any, connecting to the service entrance conductors at the building or other structure.

**Service-Entrance Conductors, Overhead System:** The service conductors between the terminals of the service equipment and a point usually outside the building, clear of building walls, where joined by tap or splice to the service drop.

**Service-Entrance Conductors, Underground System:** The service conductors between the terminals of the service equipment and the point of connection to the service lateral.

Where service equipment is located outside the building walls, there may be no service-entrance conductors, or they may be entirely outside the building.

**Service Equipment:** The necessary equipment, usually consisting of a circuit breaker or switch and fuses, and their accessories, located near the point of entrance of supply conductors to a building or other structure, or an otherwise defined area, and intended to constitute the main control and means of cutoff of the supply.

**Service Lateral:** The underground service conductors between the street main, including any risers at a pole or other structure or from transformers, and the first point of connection to the service-entrance conductors in a terminal box or meter or other enclosure with adequate space, inside or outside the building wall. Where there is no terminal box, or meter or other enclosure with adequate space, the point of connection shall be considered to be the point of entrance of the service conductors into the building.

**Service Raceway:** The rigid metal conduit, electrical metallic tubing, or other raceway, that encloses the service-entrance conductors.

**Setting: (Of Circuit-breaker.)** The value of the current at which it is set to trip.

**Show Window:** A show window is any window used or designed to be used for the display of goods or advertising material, whether it is fully or partly enclosed or entirely open at the rear, and whether or not it has a platform raised higher than the street floor level.

**Sign:** See "Electric Sign."

**Signal Circuit:** Any electrical circuit which supplies energy to an appliance which gives a recognizable signal.

Such circuits include circuits for door bells, buzzers, code-calling systems, signal lights, and the like.

**Special Permission:** The written consent of the authority enforcing this Code.

#### **Switches:**

**\*GENERAL-USE SWITCH:** A general-use switch is a switch intended for use in general distribution and branch circuits. It is rated in amperes, and it is capable of interrupting its rated current at its rated voltage.

**GENERAL-USE SNAP SWITCH:** A form of general-use switch so constructed that it can be installed in flush device boxes, or on outlet

box covers, or otherwise used in conjunction with wiring systems recognized by this Code.

**AC GENERAL-USE SNAP SWITCH:** A form of general-use snap switch suitable only for use on alternating-current circuits for controlling the following:

(a) Resistive and inductive loads (including electric-discharge lamps) not exceeding the ampere rating at the voltage involved.

(b) Tungsten-filament lamp loads not exceeding the ampere rating at 120 volts.

(c) Motor loads not exceeding 80 percent of the ampere rating of the switches at the rated voltage.

All AC general-use snap switches are marked "AC" in addition to their electrical rating.

**AC-DC GENERAL-USE SNAP SWITCH:** A form of general-use snap switch suitable for use on either direct- or alternating-current circuits for controlling the following:

(a) Resistive loads not exceeding the ampere rating at the voltage involved.

(b) Inductive loads not exceeding one-half the ampere rating at the voltage involved, except that switches having a marked horsepower rating are suitable for controlling motors not exceeding the horsepower rating of the switch at the voltage involved.

(c) Tungsten-filament lamp loads not exceeding the ampere rating at 125 volts, when marked with the letter "T".

AC-DC general-use snap switches are not generally marked AC-DC, but are always marked with their electrical rating.

**\*ISOLATING SWITCH:** An isolating switch is a switch intended for isolating an electric circuit from the source of power. It has no interrupting rating, and it is intended to be operated only after the circuit has been opened by some other means.

**MOTOR-CIRCUIT SWITCH:** A switch, rated in horsepower, capable of interrupting the maximum operating overload current of a motor of the same horsepower rating as the switch at the rated voltage.

**Switchboard:** A large single panel, frame, or assembly of panels, on which are mounted, on the face or back or both, switches, overcurrent and other protective devices, buses and usually instruments. Switchboards are generally accessible from the rear as well as from the front and are not intended to be installed in cabinets. (See "Panelboard.")

**Thermal Cutout:** An overcurrent protective device which contains a heater element in addition to and affecting a renewable fusible member which opens the circuit. It is not designed to interrupt short-circuit currents.

**Thermally Protected:** (As applied to motors.) The words "Thermally Protected" appearing on the nameplate of a motor or motor-compressor indicate that the motor is provided with a thermal protector.

**Thermal Protector:** (As applied to motors.) A thermal protector is a protective device for assembly as an integral part of a motor or



motor-compressor and which, when properly applied, protects the motor against dangerous overheating due to overload and failure to start.

The thermal protector may consist of one or more sensing elements integral with the motor or motor-compressor and an external control device.

**\*Utilization Equipment:** Utilization equipment is equipment which utilizes electric energy for mechanical, chemical, heating, lighting, or similar useful purposes.

**\*Ventilated:** Provided with a means to permit circulation of air sufficient to remove an excess of heat, fumes or vapors.

**Volatile Flammable Liquid:** A flammable liquid having a flash point below 100°F or whose temperature is above its flash point.

**\* Voltage (of a circuit):** Voltage is the greatest root-mean-square (effective) difference of potential between any two conductors of the circuit concerned.

On various systems such as 3-phase 4-wire, single-phase 3-wire and 3-wire direct-current, there may be various circuits of various voltages.

**Voltage to Ground:** In grounded circuits the voltage between the given conductor and that point or conductor of the circuit which is grounded; in ungrounded circuits, the greatest voltage between the given conductor and any other conductor of the circuit.

**Watertight:** So constructed that moisture will not enter the enclosing case.

**\*Weatherproof:** Weatherproof means so constructed or protected that exposure to the weather will not interfere with successful operation.

Rainproof, raintight or watertight equipment may fulfill the requirements for "weatherproof." However, weather conditions vary and consideration should be given to conditions resulting from snow, ice, dust, or temperature extremes.

**Welder, Electric:**

RATED PRIMARY CURRENT: Section 630-31(c).

ACTUAL PRIMARY CURRENT: Section 630-31(c).

**Wet:** (See "Location — Wet.")

**X-ray:**

LONG TIME RATING: Section 660-1.

MOMENTARY RATING: Section 660-1.

## ARTICLE 110 — GENERAL

**110-1. Scope.** This Article provides the general requirements for electrical installations.

**110-2. Approval.** The conductors and equipment required or permitted by this Code shall be acceptable only when approved. See definition of "Approved" in Article 100.

**110-3. Mandatory and Advisory Rules.** Mandatory rules of this Code are characterized by the use of the word, "shall." Advisory rules are

characterized by the use of the word, "should," or are stated as recommendations of that which is advised but not required.

**110-4. Examination of Equipment.** Materials, devices, fittings, apparatus and appliances designed for use under this Code shall be judged chiefly with reference to the following considerations which also determine the classification by types, size, voltages, current capacities, and specific use.

(a) Suitability for installation and use in conformity with the provisions of this Code.

(b) Mechanical strength and durability, including, for parts designed to enclose and protect other equipment, the adequacy of the protection thus provided.

(c) Electrical insulation.

(d) Heating effects under normal conditions of use and also under abnormal conditions likely to arise in service.

(e) Arcing effects.

**110-5. Voltages.** Throughout this Code the voltage considered shall be that at which the circuit operates, whether the current is supplied by a battery, generator, transformer, rectifier, or a thermopile.

**110-6. Conductor Gages.** Conductor sizes are given in American Wire Gage (AWG).

**110-7. Conductors.** Conductors normally used to carry current shall be of copper unless otherwise provided in this Code. Where the conductor material is not specified, the sizes given in this Code shall apply to copper conductors. Where other materials are used, the size shall be changed accordingly.

For aluminum and copper-clad aluminum conductors, see Tables 310-14 and 310-15.

**110-8. Wiring Methods.** Only wiring methods recognized as suitable are included in this Code. The recognized methods of wiring may be installed in any type of building or occupancy except as otherwise provided in this Code.

**110-9. Interrupting Capacity.** Devices intended to break current shall have an interrupting capacity sufficient for the voltage employed and for the current which must be interrupted.

**110-10. Circuit Impedance and Other Characteristics.** The overcurrent protective devices, the total impedance and other characteristics of the circuit to be protected shall be so selected and coordinated as to permit the circuit protective devices used to clear a fault without the occurrence of extensive damage to the electrical components of the circuit. This fault may be assumed to be between two or more of the circuit conductors; or between any circuit conductor and the grounding conductor or enclosing metal raceway.

**110-11. Deteriorating Agencies.** Unless approved for the purpose, no conductors or equipment shall be located in damp or wet locations; where exposed to gases, fumes, vapors, liquids or other agents having a deteriorating effect on the conductors or equipment; nor where exposed to excessive temperatures.

Control equipment, utilization equipment and busways approved for use in dry locations only, should be protected against permanent damage from weather during building construction.

**110-12. Mechanical Execution of Work.** Electrical equipment shall be installed in a neat and workmanlike manner.

**110-13. Mounting of Equipment.** Electrical equipment shall be firmly secured to the surface on which it is mounted. Wooden plugs driven into holes in masonry, concrete, plaster or similar materials shall not be depended on for security.

**110-14. Electrical Connections.** Because of different characteristics of copper and aluminum, devices such as pressure terminal or pressure splicing connectors and soldering lugs shall be suitable for the material of the conductor and shall be properly installed and used. Conductors of dissimilar metals shall not be intermixed in a terminal or splicing connector where physical contact occurs between dissimilar conductors (such as copper and aluminum, copper and copper-clad aluminum, or aluminum and copper-clad aluminum), unless the device is suitable for the purpose and conditions of use. Materials such as solder, fluxes, inhibitors, and compounds, where employed, shall be suitable for the use and shall be of a type which will not adversely affect the conductors, installation, or equipment.

(a) **Terminals.** Connection of conductors to terminal parts shall insure a thoroughly good connection without damaging the conductors and shall be made by means of pressure connectors (including set-screw type), solder lugs or splices to flexible leads except that No. 8 or smaller solid conductors and No. 10 or smaller stranded conductors may be connected by means of wire-binding screws or studs and nuts having upturned lugs, or the equivalent. Terminals for more than one conductor and terminals used to connect aluminum shall be of a type suitable for the purpose.

(b) **Splices.** Conductors shall be spliced or joined with splicing devices suitable for the use or by brazing, welding, or soldering with a fusible metal or alloy. Soldered splices shall first be so spliced or joined as to be mechanically and electrically secure without solder and then soldered. All splices and joints and the free ends of conductors shall be covered with an insulation equivalent to that of the conductors or with an insulating device suitable for the purpose.

**110-16. Working Space about Electrical Equipment (600 Volts or Less).** Sufficient access and working space shall be provided and maintained about all electrical equipment to permit ready and safe operation and maintenance of such equipment.

(a) **Working Clearances.** Except as elsewhere required or permitted in this Code, the dimension of the working space in the direction of access to live parts, operating at not more than 600 volts, which are likely to require examination, adjustment, servicing or maintenance while alive, shall not be less than indicated in Table 110-16(a). In addition to the dimensions shown in Table 110-16(a) the work space shall be at least 30 inches wide in front of the electrical equipment. Distances are to be measured from the live parts if such are exposed or from the enclosure front or opening when such are enclosed. Concrete, brick or tile walls shall be considered as grounded.

**Table 110-16(a). Working Clearances**

Voltage to Ground	Minimum clear distance		
	Condition: 1	2	3
0-150	2½ ft.	2½ ft.	3 ft.
151-600	2½	3½	4

Where the "Conditions" are as follows:

1. Exposed live part on one side and no live or grounded part on the other side of the working space or exposed live parts on both sides effectively guarded by suitable wood or other insulating materials. Insulated wire or insulated bus bars operating at not more than 300 volts shall not be considered live parts.

2. Exposed live parts on one side and grounded parts on the other side.

3. Exposed live parts on both sides of the work space (not guarded as provided in Condition 1) with the operator between.

*Exception No. 1: Working space is not required in back of assemblies such as dead-front switchboards or control centers when there are no renewable or adjustable parts such as fuses or switches on the back and when all connections are accessible from other locations than the back.*

*Exception No. 2: Smaller spaces may be permitted by the authority having jurisdiction where it is judged that the particular arrangement of the installation will provide adequate accessibility.*

**(b) Clear Spaces.** Working space required by this Section shall not be used for storage. When normally enclosed live parts are exposed for inspection or servicing, the working space, if in a passageway or general open space, shall be suitably guarded.

**(c) Access and Entrance to Working Space.** At least one entrance of sufficient area shall be provided to give access to the working space about electrical equipment.

**(d) Front Working Space.** In all cases where there are live parts normally exposed on the front of switchboards or control centers, the working space in front of such boards or panels shall be not less than 3 feet.

**(e) Illumination.** Adequate illumination shall be provided for all working spaces about switchboards and control centers.

**(f) Headroom.** The minimum headroom of working spaces about switchboards or control centers where there are live parts exposed at any time, shall be 6¼ feet.

For higher voltages, see Article 710.

#### **110-17. Guarding of Live Parts.** (Not more than 600 Volts)

(a) Except as elsewhere required or permitted by this Code, live parts of electrical equipment operating at 50 volts or more shall be guarded against accidental contact by approved cabinets or other forms of approved enclosures, or any of the following means:

(1) By location in a room, vault, or similar enclosure which is accessible only to qualified persons.

(2) By suitable permanent, substantial partitions or screens so arranged that only qualified persons will have access to the space within reach of the live parts. Any openings in such partitions or screens shall be so sized and located that persons are not likely to come into accidental contact with the live parts or to bring conducting objects into contact with them.

(3) By location on a suitable balcony, gallery, or platform so elevated and arranged as to exclude unqualified persons.

(4) By elevation at least 8 feet above the floor or other working surface.

(b) In locations where electrical equipment would be exposed to physical damage, enclosures or guards shall be so arranged and of such strength as to prevent such damage.

(c) Entrances to rooms and other guarded locations containing exposed live parts shall be marked with conspicuous warning signs forbidding unqualified persons to enter.

For motors see Sections 430-132 and 430-133. For additional requirements at voltages over 600 see Article 710.

**110-18. Arcing Parts.** Parts of electrical equipment which in ordinary operation produce arcs, sparks, flames or molten metal, shall be enclosed unless separated and isolated from all combustible material. For hazardous locations see Articles 500-517 inclusive. For motors see Section 430-14.

**110-19. Light and Power from Railway Conductors.** Circuits for lighting and power shall not be connected to any system containing trolley wires with a ground return, except in electric railway cars, car houses, power houses, or passenger and freight stations operated in connection with electric railways.

**110-20. Insulation Resistance.** All wiring shall be so installed that when completed the system will be free from short circuits and from grounds other than as provided in Article 250.

**110-21. Marking.** The manufacturer's name, trademark, or other descriptive marking by which the organization responsible for the product may be identified, shall be placed on all electrical equipment. Other markings shall be provided giving voltage, current, wattage, or other ratings as are prescribed elsewhere in this Code. The marking shall be of sufficient durability to withstand the environment involved.

**110-22. Identification.** Each disconnecting means required by this Code for motors and appliances, and each service, feeder or branch circuit at the point where it originates, shall be legibly marked to indicate its purpose unless located and arranged so the purpose is evident. The marking shall be of sufficient durability to withstand the environment involved.

## Chapter 2. Wiring Design and Protection

### ARTICLE 200 — USE AND IDENTIFICATION OF GROUNDED CONDUCTORS

**200-1. Scope.** This Article provides requirements for the use and identification of a grounded conductor in interior wiring systems. (See definitions of “grounded conductor” and “grounding conductor” in Article 100.)

**200-2. General.** All interior wiring systems shall have a grounded conductor which is continuously identified throughout the system except as follows:

*Exception No. 1: A grounded conductor is not required in certain circuits or systems as provided in Sections 200-5, 250-3, 250-5, 250-7, 503-13, and 517-63.*

*Exception No. 2: Continuous identification throughout a length of a conductor between terminals is not required for certain conductors under Section 200-6(a) and (b).*

**200-3. Connection to Grounded System.** No interior wiring shall be electrically connected to a supply system unless the latter contains, for any grounded conductor of the interior system, a corresponding conductor which is grounded.

Electrically connected implies connection capable of carrying current as distinguished from connection through electromagnetic induction.

**200-4. Circuits Derived from Autotransformers.** Branch circuits as described in Article 210 shall not be supplied through autotransformers (transformers in which a part of the winding is common to both primary and secondary circuits) unless the system supplied has an identified grounded conductor which is solidly connected to a similar identified grounded conductor of the system supplying the autotransformer.

*Exception: An autotransformer may be used to extend or add an individual branch circuit in an existing installation for an equipment load without the connection to a similar identified grounded conductor when transforming from a nominal 208 volts to a nominal 240 volts supply or similarly from 240 volts to 208 volts.*

**200-5. Unidentified Circuits.**

(a) Two-wire branch circuits and AC circuits of two or more conductors may be tapped from the ungrounded conductors of circuits having identified grounded neutrals. Switching devices in each tapped circuit shall have a pole in each ungrounded conductor. These poles shall manually switch together where the switching devices serve as the disconnecting means required by Sections 422-21 and 422-23.

*Exception: For motor controllers see Section 430-84, for heating equipment see Section 424-20, and for de-icing equipment, see Section 426-21.*

(b) Polyphase circuits need not have one conductor grounded and identified, except as required by Section 250-5, but where one conductor is grounded it shall be identified.

(c) Other unidentified ungrounded systems or circuits may be used only by special permission.

**200-6. Means of Identification of Grounded Conductors.** Identification for grounded conductors shall be as follows:

(a) Insulated conductors of No. 6 or smaller, except conductors of Type MI cable, shall have an outer identification of white or natural gray color as specified in 310-2(c). The grounded conductors of Type MI cable shall be identified by distinctive marking at the terminals during the process of installation.

(b) Insulated conductors larger than No. 6, shall have an outer identification of white or natural gray color, or shall be identified by distinctive white marking at terminals during process of installation.

(c) Where, on a 4-wire delta-connected secondary, the midpoint of one phase is grounded to supply lighting and similar loads, that phase conductor having the higher voltage to ground shall be orange in color or be indicated by tagging or other effective means at any point where a connection is to be made if the neutral conductor is present.

**200-7. Identified Conductor in Grounded Circuits Only.** Conductors having white or natural gray covering shall not be used other than as conductors for which identification is required by Section 200-2, except under the following conditions, and then only where they are, in other respects, suitable for use as ungrounded conductors in the circuit:

*Exception No. 1: Identified conductors, rendered permanently unidentified by painting or other effective means at each outlet where the conductors are visible and accessible, may be used as unidentified conductors.*

*Exception No. 2: Cable containing an identified conductor may be used for single-pole, 3-way or 4-way switch loops where the connections are so made that the unidentified conductor is the return conductor from the switch to the outlet.*

This exception makes it unnecessary to paint the terminal of the identified conductor at the switch outlet.

*Exception No. 3: A flexible cord for connecting a portable or stationary appliance, having one conductor identified with a white or natural gray outer finish or by any other means permitted by Section 400-13, may be used whether or not the outlet to which it is connected is supplied by a circuit having a grounded conductor.*

*Exception No. 4: A white or natural gray conductor of circuits less than 50 volts need only be grounded as required by Section 250-5(a).*

**200-8. Connections to Screw Shells.** An identified conductor, where run to a screw-shell lampholder, shall be connected to the screw shell.

**200-9. Means of Identification of Terminals.** The identification of terminals to which a grounded conductor is to be connected shall be by

means of a metallic plated coating substantially white in color, such as nickel or zinc, or the terminals may be of material substantially white in color. The other terminals shall be of a readily distinguishable different color.

#### **200-10. Identification of Terminals.**

**(a) Device Terminals.** All devices provided with terminals for the attachment of conductors and intended for connection to more than one side of the circuit shall have terminals properly marked for identification except as follows:

*Exception No. 1: Marking may be omitted where the electrical connection of a terminal intended to be connected to the grounded conductor is clearly evident.*

*Exception No. 2: Single-Pole Devices.* Devices to the terminals of which only one side of the line is connected need not have terminals marked for identification.

*Exception No. 3: Panelboards and Devices.* The terminals of lighting panelboards and of devices having a normal current rating of over 30 amperes need not be marked for identification, except as required in Section 200-10(b) for polarized receptacles for attachment plugs and polarized attachment plugs.

**(b) Plugs, Receptacles, and Connectors.** Polarized attachment plugs, receptacles and cord connectors for plugs and polarized plugs shall have the terminal intended for connection to the grounded (white) conductor identified by a metal or metal coating substantially white in color.

If the terminal for the grounded conductor is not visible, the conductor entrance hole for the connection shall be marked with the word "white."

The terminal for the connection of the equipment grounding conductor shall be identified by: (1) A green colored, not readily removable terminal screw with hexagonal head; or (2) A green colored, hexagonal, not readily removable terminal nut; or (3) A green colored pressure wire connector. If the terminal for the grounding conductor is not visible, the conductor entrance hole shall be marked with the word "green" or otherwise identified by a distinctive green color.

*Exception: Two-wire attachment plugs, unless of the polarity type, need not have their terminals marked for identification.*

**(c) Screw Shells.** In the case of devices with screw shells, the identified terminal shall be the one connected to the screw shell. This does not apply to screw shells which serve as fuseholders.

**(d) Screw-Shell Devices with Leads.** In the case of screw-shell devices with attached leads, the conductor attached to the screw shell shall have white or natural gray finish. The outer finish of the other conductor shall be of a solid color that will not be confused with the white or natural-gray finish which is to identify the grounded conductor.

**(e) Fixed Appliances.** The terminals of fixed appliances need not be marked to indicate the proper connection to the grounded conduc-



tor unless a single-pole switch forms an integral part, then the terminal connected to the switch shall be the unidentified terminal.

(f) **Portable Appliances.** The terminals of portable appliances need not be marked for identification.

## ARTICLE 210 — BRANCH CIRCUITS

**210-1. Scope.** The provisions of this Article shall apply to branch circuits supplying lighting or appliance loads or combinations of such loads. Where motors, or motor-operated appliances, are connected to any circuit supplying lighting or other appliance loads, the provisions of both this Article and Article 430 shall apply. Article 430 shall apply where branch circuit supplies only motor loads.

**210-2. Specific Purpose Branch Circuit.** The provisions applying to branch circuits referred to in the following list are exceptions to the provisions of this Article or are supplementary thereto, and shall apply to branch circuits supplying the loads referred to therein:

Air Conditioning and Refrigerating Equipment .....	Sections 440-5, 440-31, 440-32
Busways .....	Section 364-8
Cranes and Hoists .....	Section 610-42
Data Processing Systems .....	Section 645-2
Elevators, Dumbwaiters, and Escalators .....	Section 620-61
Fixed Electric Space Heating Equipment .....	Section 424-3
Fixed Outdoor De-icing and Snow Melting Equipment .....	Section 426-3
Infrared Industrial Heating Equipment ...	Sections 422-15, 424-3
Induction and Dielectric Heating Equipment .....	Article 665
Instruments .....	Section 384-22
Marinas and Boatyards .....	Section 555-4
Mobile Homes and Parks .....	Article 550
Motion Picture Studios and Similar Locations .....	Article 530
Motors and Motor Controllers .....	Article 430
Organs .....	Section 650-6
Recreational Vehicles and Parks .....	Article 551
Remote-Control, Low-Energy Power, Low-Voltage Power and Signal Circuits .....	Article 725
Signs and Outline Lighting .....	Section 600-6
Sound Recording and Reproduction .....	Section 640-6
Systems over 600 Volts .....	Article 710
Systems under 50 Volts .....	Article 720
Theaters and Assembly Halls .....	Sections 520-41, 520-52, and 520-62
Welders .....	Article 630
X-ray Equipment .....	Section 660-3

**210-3. Classifications.** Branch circuits recognized by this Article shall be classified in accordance with the maximum permitted rating or setting of the overcurrent device, and the classification for other than individual branch circuits shall be 15, 20, 30, 40 and 50 amperes. When conductors of higher capacity are used for any reason, the rating or setting of the specified overcurrent device shall determine the circuit classification.

#### **A. General Provisions**

**210-4. Multiwire Branch Circuits.** Branch circuits recognized by this Article may be installed as multiwire circuits.

See Article 100 for Definition.

#### **210-5. Color Code for Branch Circuits.**

**(a) Grounded Conductor.** The grounded conductor of a branch circuit shall be identified by a continuous white or natural-gray color. Where conductors of different systems are installed in the same raceway, box, gutter or other types of enclosures, one system shall have a neutral, if required, having an outer covering of white or natural gray. Each other system having a neutral, if required, shall have an outer covering of white with an identifiable colored stripe (not green) running along the insulation or other suitable and different means of identification.

*Exception: The grounded conductors of Type MI cable shall be identified by distinctive marking at the terminals during the process of installation.*

**(b) Grounding Conductor.** The grounding conductor of a branch circuit shall be identified by a continuous green color or a continuous green color with one or more yellow stripes unless it is bare.

The above is not intended to prohibit the use of a conductor having a continuous green color or a continuous green color with one or more yellow stripes as insulation for internal wiring of equipment, except where such wiring serves as the lead wires to which the branch-circuit conductors attach.

**(c) Ungrounded Conductor.** Where installed in raceways, as open work or as concealed knob-and-tube work, the ungrounded conductor shall be identified by any color other than as specified in (a) and (b) above. All ungrounded conductors of the same color shall be connected to the same ungrounded feeder conductor and the conductors for systems of different voltages shall be of different colors.

*Exception: As permitted in Section 200-7.*

For a basic single wiring system the following colors shall be used: 3-wire circuits, 1 black, 1 white and 1 red; 4-wire circuits, 1 black, 1 white, 1 red, and 1 blue.

#### **210-6. Voltage.**

**(a) Voltage to Ground.** The voltage to ground on branch circuits supplying lampholders, fixtures, or standard receptacles of 15-ampere or less rating shall not exceed 150 volts, except as follows:

*Exception No. 1: In industrial establishments where the conditions of*

*maintenance and supervision assure that only competent individuals will service the lighting fixtures, the voltage of branch circuits may be as high as 300 volts to ground provided that such branch circuits:*

*(1) Supply only lighting fixtures which are equipped with mogul-base screw-shell lampholders or with lampholders of other types approved for the application.*

*(2) The lighting fixtures are mounted not less than 8 feet from the floor, and*

*(3) The lighting fixtures do not have switch control as an integral part of the fixture.*

*Exception No. 2: In industrial establishments, office buildings, schools, stores, and public and commercial areas of other buildings, such as hotels or transportation terminals, the voltage of branch circuits which supply only the ballasts for electric-discharge lamps mounted in permanently installed fixtures, by other than screw-shell type lampholders, which do not have manual switch control as an integral part of the fixture shall not exceed 300 volts to ground. Where screw-shell type lampholders are used for electric-discharge lamps the fixtures shall be installed not less than 8 feet from the floor.*

*Exception No. 3: For infrared industrial heating appliances as described in Section 422-15;*

*Exception No. 4: In railway properties as described in Section 110-19;*

*Exception No. 5: The branch circuits supplying the ballasts for electric-discharge lamps mounted in permanently installed fixtures on poles for the illumination of areas such as highways, bridges, athletic fields, parking lots, at a height not less than 22 feet, or on other structures such as tunnels at a height not less than 18 feet, shall not exceed 500 volts between conductors when installed as provided in Section 730-7 (c).*

**(b) Voltage Between Conductors — Dwellings.** In dwelling occupancies, the voltage between conductors supplying lampholders of the screw-shell type, receptacles, or appliances, shall not exceed 150 volts, except as follows:

*Exception: The voltage between conductors may exceed 150 volts when supplying only:*

*(1) Permanently connected appliances,*

*(2) Portable and stationary appliances of more than 1,380 watts.*

*(3) Portable motor-operated appliances of  $\frac{1}{4}$  horsepower or greater rating.*

**(c) Voltage Between Conductors — Nondwelling Occupancies.** In nondwelling occupancies other than the industrial establishments referred to in Exception No. 1 of Section 210-6(a) the voltage between conductors of branch circuits that supply screw-shell lampholders of the medium size shall not exceed 150 volts.

**(d) Voltage Drop.** The size of the conductors for branch circuits as defined in Article 100 should be such that the voltage drop would

(210-6(d) continued)

not exceed 3 percent to the farthest outlet for power, heating, lighting, or combinations thereof. Providing further that the maximum total voltage drop for feeders and branch circuits should not exceed 5 percent over all.

**210-7. Grounding-Type Receptacles and Protection.** Receptacles and cord connectors equipped with grounding contacts shall have those contacts effectively grounded. The branch circuit or branch-circuit raceway shall include or provide a grounding conductor to which the grounding contacts of the receptacle or cord connector shall be connected. Acceptable grounding means are outlined in Section 250-91(b).

*Note — For extensions only in existing installations which do not have a grounding conductor in the branch circuit, the grounding conductor of a grounding type receptacle outlet shall be grounded to a grounded cold water pipe near the equipment.*

All 15- and 20-ampere receptacle outlets on single-phase circuits for construction sites shall have approved ground-fault circuit protection for personnel. This requirement shall become effective on January 1, 1974.

**210-8. Heavy-Duty Lampholders.** Heavy-duty lampholders referred to in this Article shall include lampholders rated at not less than 750 watts.

*Exception: Admedium lampholders rated at 660 watts shall be considered to be heavy-duty types.*

#### **B. Specific Requirements.**

**210-19. Conductors.** Circuit conductors shall conform to the following:

(a) **Ampacity.** Shall have an ampacity of not less than the rating of the branch circuit and not less than the maximum load to be served.

(b) **Minimum Size.** Shall not be smaller than No. 8 for ranges of 8¾ kW or more rating, nor smaller than No. 14 for other loads.

(c) **Exceptions:**

*Exception No. 1: Range Loads. See Note 5 of Table 220-5. Where the maximum demand of a range of 8¾ kW or more rating is computed according to Column A of Table 220-5, the neutral conductor of a 3-wire branch circuit supplying a household electric range, a wall-mounted oven or a counter-mounted cooking unit may be smaller than the ungrounded conductors but shall have an ampacity at least 70 percent of the ampacity of the ungrounded conductors and shall not be smaller than No. 10.*

Cable assemblies with the neutral conductor smaller than the ungrounded conductors shall be so marked.

*Exception No. 2: Tap Conductors. Tap conductors may be of less capacity than the branch-circuit rating provided no tap conductor is of less capacity than the load to be served and provided the rating is not less than 20 amperes for 40- or 50-ampere circuits or 15 amperes for*

*circuits rated less than 40 amperes and only when these tap conductors supply either:*

*(a) Individual lampholders or fixtures with taps extending not longer than 18 inches beyond any portion of the lampholder or fixture, except as required in Section 410-65(b)(2); or,*

*(b) Individual outlets with taps not over 18 inches long; or,*

*(c) Infrared lamp industrial heating appliances.*

*(d) Nonheating leads of snow and de-icing cables and mats.*

*Exception No. 3: Fixture Wires and Cords. Fixture wires and cords may be of smaller size, but not less than the size specified in Exception No. 2 of Section 240-5(a).*

See Tables 400-9(b) and 402-4.

*Exception No. 4: Outlet Devices. Outlet devices may have less carrying capacity than the branch-circuit rating, but not less than the types and ratings specified in Sections 210-21(a), (b), and (c).*

*Exception No. 5: Where tap conductors supply electric ranges, wall-mounted electric ovens and counter-mounted electric cooking units from 50-ampere branch circuits they shall be of suitable capacity for the load to be served, not less than 20 amperes in rating and no longer than necessary for servicing the appliance.*

**210-20. Overcurrent Protection.** The rating or setting of overcurrent devices shall conform to the following:

**(a) Rating.** Shall not be in excess of the value specified in Section 240-5.

*Exception: Tap Conductors and Fixture Wires. Tap conductors, fixture wire and cords as permitted in Section 210-19(c) may be considered as protected by the circuit overcurrent device.*

**(b) Single Appliance.** Shall not exceed 150 percent of the rating of the appliance, where the circuit supplies only a single appliance of 10-ampere or more rating.

**(c) Continuous Loads.** Where loads other than motor loads will constitute continuous loads see Sections 210-23(b), 220-2 and 240-2.

**210-21. Outlet Devices.** Outlet devices shall have a rating not less than the load to be served and shall conform to the following:

**(a) Lampholders.** Lampholders when connected to circuits having a rating of over 20 amperes shall be of the heavy-duty type.

**(b) Receptacles.** Receptacles installed on 15-ampere and 20-ampere branch circuits shall be of the grounding type and they shall be installed in accordance with Section 210-7. Grounding-type receptacles which are of a type that rejects nongrounding-type attachment plugs or which are of the locking-type may be used for specific purposes or in special locations.

A single receptacle installed on an individual branch circuit shall have a rating of not less than the rating of the branch circuit.

Grounding-type receptacles shall be used as replacements for existing nongrounding types and shall be connected to a grounding conductor installed in accordance with Section 250-57.

*Exception: If it is impractical to reach a source of ground, a non-grounding-type receptacle shall be used.*

The installation of grounding-type receptacles shall not be used as a requirement that all portable equipment be of the grounded type. See Article 250 for requirements for the grounding of portables.

Receptacles required in Sections 517-61(d) and 517-62(e) are considered as meeting the requirements of this Section.

When connected to circuits having two or more outlets, receptacles shall conform to the following:

15-amp circuits	.....	Not over 15-amp rating
20-amp circuits	.....	15- or 20-amp rating
30-amp circuits	.....	30-amp rating
40-amp circuits	.....	40- or 50-amp rating
50-amp circuits	.....	50-amp rating

For receptacle rating of cord-connected electric-discharge lighting fixtures see Section 410-14.

Receptacles connected to circuits having different voltages, frequencies or types of current (AC or DC) on the same premises shall be of such design that attachment plugs used on such circuits are not interchangeable.

Grounding-type receptacles shall be installed only on circuits of the voltage class and current for which they have been approved.

Receptacles rated at 15 amperes connected to 15- or 20-ampere branch circuits serving two or more outlets shall not supply a total load in excess of 12 amperes for portable and stationary appliances. Receptacles rated at 20 amperes connected to 20-ampere branch circuits serving two or more outlets shall not supply a total load in excess of 16 amperes for portable and stationary appliances.

(c) Capacity of range receptacles may be based on single range loads as computed from Table 220-5.

**210-22. Receptacle Outlets Required.** Receptacle outlets shall be installed as follows:

(a) **General.** Where portable cords are used, except where the attachment of cords by other means is specifically permitted.

A cord connector that is supported by a permanently connected cord pendant is considered a receptacle outlet.

(b) **Dwelling-Type Occupancies.** In every kitchen, family room, dining room, breakfast room, living room, parlor, library, den, sun room, recreation room and bedroom, receptacle outlets shall be installed so that no point along the floor line in any wall space is more than 6 feet, measured horizontally, from an outlet in that space, including any wall space 2 feet wide or greater and the wall space occupied by sliding

panels in exterior walls. The wall space afforded by fixed room dividers, such as free-standing bar-type counters, shall be included in the 6-foot measurement.

In kitchen and dining areas a receptacle outlet shall be installed at each counter space wider than 12 inches. Counter top spaces separated by range tops, refrigerators or sinks shall be considered as separate counter top spaces. Receptacles rendered inaccessible by the installation of stationary appliances will not be considered as these required outlets.

Receptacle outlets shall, insofar as practicable, be spaced equal distances apart. Receptacle outlets in floors shall not be counted as part of the required number of receptacle outlets unless located close to the wall. At least one wall receptacle outlet shall be installed in the bathroom adjacent to the basin location.

Outlets in other sections of the dwelling for special appliances such as laundry equipment, shall be placed within 6 feet of the intended location of the appliance. At least one receptacle outlet shall be installed for the laundry.

*Exception No. 1: A dwelling unit that is an apartment or living area in a multi-family building where laundry facilities are provided on the premises that are available to all building occupants need not be provided with a laundry receptacle.*

*Exception No. 2: In other than single-family dwellings where laundry facilities are not to be installed or permitted, a laundry receptacle need not be provided.*

*Exception No. 3: A dwelling that is a unit in a hotel, motel, motor court, or motor hotel, need not be provided with a laundry receptacle.*

**(c) Guest Rooms in Hotels, Motels, and Similar Occupancies.** These shall have receptacles installed in accordance with Section 210-22(b).

*Exception: In rooms of hotels and motels receptacles may be located convenient for the permanent furniture layout.*

**(d) Ground-Fault Circuit Protection.** For residential occupancies all 120-volt, single-phase, 15- and 20-ampere receptacle outlets installed outdoors shall have approved ground-fault circuit protection for personnel. The effective date of this requirement shall be January 1, 1973.

Such ground-fault circuit protection may be provided for other circuits, locations and occupancies, and where used will provide additional protection against line-to-ground shock hazard. See Section 215-8.

**(e) Show Windows.** At least one receptacle shall be installed directly above a show window for each 12 linear feet or major fraction thereof of show window area, measured horizontally at the base.

**210-23. Maximum Load.** The maximum load shall conform to the following:

**(a) Appliances Consisting of Motors and Other Loads.** Where a circuit supplies only motor-operated appliance loads, Article 430 shall apply. Where a circuit supplies only air conditioning and/or refrigerat-

ing equipment, Article 440 shall apply. For other than a portable or stationary appliance, the branch-circuit size shall be calculated on the basis of 125 percent of motor load where the motor is larger than 1/8 hp plus the sum of the other loads.

**(b) Other Loads.** The total load shall not exceed the branch-circuit rating, and shall not exceed 80 percent of the rating when load will constitute a continuous load such as store lighting and similar loads. In computing the load of lighting units which employ ballasts, transformers or autotransformers, the load shall be based on the total of the ampere rating of such units and not on the wattage of the lamps.

*Exception No. 1: When the assembly including the overcurrent device protecting the branch circuit is approved for continuous operation at 100 percent of its rating, the total load may equal the branch-circuit rating.*

*Exception No. 2: Where branch circuits are derated in accordance with Note 8 to Tables 310-12 through 310-15 an additional derating factor for continuous loading shall not apply.*

*Exception No. 3: Range Loads. See Note 5 of Table 220-5.*

**210-24. Permissible Loads.** Individual branch circuits may supply any loads.

Branch circuits having two or more outlets may supply only loads as follows:

**(a) 15- and 20-Ampere Branch Circuits.** Lighting units and/or appliances. The rating of any one portable or stationary appliance shall not exceed 80 percent of the branch-circuit rating. The total rating of fixed appliances shall not exceed 50 percent of the branch-circuit rating when lighting units or portable or stationary appliances are also supplied. Small appliance branch circuits shall supply only the loads stipulated in Section 220-3(b).

**(b) 30-Ampere Branch Circuits.** Fixed lighting units with heavy-duty lampholders in other than dwelling occupancies; or appliances in any occupancy. The rating of any one portable or stationary appliance shall not exceed 24 amperes.

**(c) 40-Ampere Branch Circuits.** Fixed lighting units with heavy-duty lampholders in other than dwelling occupancies; or fixed cooking appliances; or infrared heating units.

**(d) 50-Ampere Branch Circuits.** Fixed lighting units with heavy-duty lampholders in other than dwelling occupancies; or fixed cooking appliances; or infrared heating units.

The term "fixed" as used in this Section recognizes cord connections where otherwise permitted.

Fixed outdoor electric snow melting and de-icing installations may be supplied by any of the branch circuits described herein provided the circuit supplies no other load.

**210-25. Table of Requirements.** The requirements for circuits having two or more outlets [other than the receptacle circuits of Section 220-3(b)] as specifically provided for above are summarized in Table 210-25.



**Table 210-25**  
**Branch-Circuit Requirements**

(Type FEP, FEPB, RUW, SA, T, TW, RH, RUH, RHW, RHH, THHN, THW, THWN, and XHHW conductors in raceway or cable.)

CIRCUIT RATING	15 Amp.	20 Amp.	30 Amp.	40 Amp.	50 Amp.
<b>CONDUCTORS:</b> (Min. Size)					
Circuit Wires*	14	12	10	8	6
Taps	14	14	14	12	12
Fixture Wires and Cords	Refer to Section 240-5(a), Exception No. 3				
OVERCURRENT PROTECTION	15 Amp.	20 Amp.	30 Amp.	40 Amp.	50 Amp.
<b>OUTLET DEVICES:</b>					
Lampholders	Any	Any	Heavy	Heavy	Heavy
Permitted	Type	Type	Duty	Duty	Duty
Receptacle	15 Max.	15 or 20	30	40 or 50	50
Rating**	Amp.	Amp.	Amp.	Amp.	Amp.
MAXIMUM LOAD	15 Amp.	20 Amp.	30 Amp.	40 Amp.	50 Amp.
PERMISSIBLE LOAD	Refer to Section 210-24(a)	Refer to Section 210-24(a)	Refer to Section 210-24(b)	Refer to Section 210-24(c)	Refer to Section 210-24(d)

\* These ampacities are for copper conductors where derating is not required. See Tables 310-12 through 310-15.

\*\* For receptacle rating of cord-connected electric-discharge lighting fixtures see Section 410-14.

## ARTICLE 215 — FEEDERS

**215-1. Scope.** This Article deals with installation requirements for, and, the size of conductors in the feeders needed to supply power to branch circuits and, the loads as calculated under Article 220.

**215-2. Conductor Size.** Feeder conductors shall have a current rating not smaller than the feeder load as determined by Section 220-4. A 2-wire feeder supplying two or more 2-wire branch circuits, or a 3-wire feeder supplying more than two 2-wire branch circuits, or two or more 3-wire branch circuits, shall be not smaller than No. 10. Where a feeder carries the total current supplied by the service-entrance conductors, such feeder, for services of No. 6 and smaller, shall be of the same size as the service-entrance conductors.

Where at any time it is found that feeder conductors are, or will be, overloaded, the feeder conductors shall be increased in capacity to accommodate the actual load served.

See Example Nos. 1 to 7 of Chapter 9.

**215-3. Voltage Drop.** The size of the conductors for feeders should be such that the voltage drop for the load as computed by Section 220-4

would not be more than 3 percent for power, heating or lighting loads or combinations thereof. Providing further that the maximum total voltage drop for conductors for feeders and branch circuits should not exceed 5 percent over all.

**215-4. Overcurrent Protection.** Feeders shall be protected against overcurrent in accordance with the provisions of Article 240.

**215-5. Common Neutral Feeder.** A common neutral feeder may be employed for two or three sets of 3-wire feeders, or two sets of 4-wire or 5-wire feeders. When in metal enclosures, all conductors of feeder circuits employing a common neutral feeder shall be contained within the same enclosure as provided in Section 300-20.

**215-6. Diagram of Feeders.** If required by the authority having jurisdiction, a diagram showing feeder details shall be supplied previous to installation. This diagram should show: Area in square feet; load (before applying demand factors); demand factors selected; computed load (after applying demand factors); and the size of conductors.

**215-7. Installation Requirements.** Where a feeder supplies branch circuits in which grounding conductors are required, the feeder shall include or provide a grounding means to which the grounding conductor of the branch circuit shall be connected.

**215-8. Ground-Fault Personnel Protection.** Feeders supplying power to 15- and 20-ampere receptacle branch circuits may be protected by a ground-fault circuit-interrupter approved for the purpose in lieu of the provisions of Section 210-22(d).

## ARTICLE 220 — BRANCH-CIRCUIT AND FEEDER CALCULATIONS

**220-1. Scope.** This Article provides the basis for calculating the expected branch-circuit and feeder loads and for determining the number of branch circuits required.

**220-2. Calculation of Branch-Circuit Loads.** The load for branch circuits shall be computed in accordance with the provisions of this Section.

The continuous load supplied by a branch circuit shall not exceed 80 percent of the branch-circuit rating.

*Exception No. 1: Where the assembly, including the overcurrent devices protecting the branch circuit and feeder is approved for operation at 100 percent of their rating, the continuous load supplied by the branch circuit may equal the ampacity of the branch-circuit conductors.*

*Exception No. 2: Where branch circuits are derated in accordance with Note 8 to Tables 310-12 through 310-15, branch-circuit loads shall not exceed the derated ampacity of the conductors.*

### (a) General Lighting Load.

(1) **In Listed Occupancies.** In the occupancies listed in Table 220-2(a), a load of not less than the unit load specified shall be included for each square foot of floor area.

In determining the load on the “watts per square foot” basis, the floor area shall be computed from the outside dimensions of the building, apartment or area involved, and the number of floors; not including open porches, garages in connection with dwelling occupancies, nor unfinished spaces and unused spaces in dwellings unless adaptable for future use.

The unit values herein are based on minimum load conditions and 100 percent power factor, and may not provide sufficient capacity for the installation contemplated.

(continued on page 70-32)

**Table 220-2(a). General Lighting Loads by Occupancies**

Type of Occupancy	Unit Load per Sq. Ft. (Watts)
Armories and Auditoriums	1
Banks	5
Barber Shops and Beauty Parlors	3
Churches	1
Clubs	2
Court Rooms	2
*Dwellings (Other Than Hotels)	3
Garages—Commercial (storage)	1½
Hospitals	2
*Hotels and Motels, including apartment houses without provisions for cooking by tenants	2
Industrial Commercial (Loft) Buildings	2
Lodge Rooms	1½
Office Buildings	5
Restaurants	2
Schools	3
Stores	3
Warehouses Storage	1¼
In any of the above occupancies except single- family dwellings and individual apartments of multi-family dwellings:	
Assembly Halls and Auditoriums	1
Halls, Corridors, Closets	1½
Storage Spaces	1¼

\*All receptacle outlets of 15-ampere or less rating in single-family and multi-family dwellings and in guest rooms of hotels and motels [except those connected to the receptacle circuits specified in Section 220-3(b)] may be considered as outlets for general illumination, and no additional load need be included for such outlets.

(220-2(a-1) continued)

In view of the trend toward higher intensity lighting systems and increased loads due to more general use of fixed and portable appliances, each installation should be considered as to the load likely to be imposed and the capacity increased to insure safe operation.

Where electric-discharge lighting systems are to be installed, high-power-factor type should be used or the conductor capacity may need to be increased.

**(2) In Other Occupancies.** In other occupancies, a load of not less than the unit load specified in Section 220-2(b) shall be included for each outlet.

**(b) Other Loads.** For lighting other than general illumination and for appliances other than motors, a load of not less than the unit load specified below shall be included for each outlet. The loads indicated below are based on nominal branch-circuit voltages.

\*Outlets supplying specific appliances and other loads ..... Ampere rating of appliance

Outlets supplying heavy-duty lampholders ..... 600 volt-amperes

‡Other outlets ..... 180 volt-amperes

\*For motors, see Sections 430-22 and 430-24.

‡This provision shall not be applicable to receptacle outlets connected to the circuit specified in Section 220-3(b) nor to receptacle outlets provided for the connection of stationary equipment as provided for in Section 400-3.

**(c) Exceptions.** The minimum load for outlets specified in Section 220-2(b) shall be modified as follows:

*Exception No. 1: Ranges. For household electric ranges, the branch-circuit load may be computed in accordance with Table 220-5.*

*Exception No. 2: Show-Window Lighting. For show-window lighting a load of not less than 200 watts for each linear foot of show window, measured horizontally along its base, may be allowed in lieu of the specified load per outlet.*

*Exception No. 3: Multioutlet Assemblies. Where fixed multioutlet assemblies are employed, each 5 feet or fraction thereof of each separate and continuous length shall be considered as one outlet of not less than 1½ ampere capacity; except in locations where a number of appliances are likely to be used simultaneously, when each one foot or fraction thereof shall be considered as an outlet of not less than 1½ amperes. The requirements of this Section are not applicable to dwellings or the guest rooms of hotels.*

*Exception No. 4: Telephone Exchanges. Shall be waived for manual switchboards and switching frames in telephone exchanges.*

The provisions of Section 220-2(b) shall apply to all other receptacle outlets.

**(d) Existing Installations.** Additions to existing installations shall conform to the following:

**(1) Dwelling Occupancies.** New circuits or extensions to existing circuits may be determined in accordance with Sections 220-2(a) or (b); except that portions of existing structures not previously wired, or

additions to the building structure, either of which exceeds 500 square feet in area, shall be determined in accordance with Section 220-2(a).

**(2) Other Than Dwelling Occupancies.** When adding new circuits or extensions to existing circuits in other than dwelling occupancies, the provisions of Section 220-2(a) or (b) shall apply.

**220-3. Branch Circuits Required.** Branch circuits shall be installed as follows:

**(a) Lighting and Appliance Circuits.** For lighting, and for appliances, including motor-operated appliances, not specifically provided for in Section 220-3(b), branch circuits shall be provided for a computed load not less than that determined by Section 220-2.

The number of circuits shall be not less than that determined from the total computed load and the capacity of circuits to be used. In every case the number shall be sufficient for the actual load to be served, and the branch circuit loads shall not exceed the maximum loads specified in Section 210-23.

Where the load is computed on a "watts per square foot" basis, the total load, in so far as practical, shall be evenly proportioned among the branch circuits according to their capacity.

When lighting units to be installed operate at other than 100 percent power factor, see Section 210-23(b) for maximum ampere load permitted on branch circuits.

For general illumination in dwelling occupancies, not less than one branch circuit shall be installed for each 500 square feet of floor area in addition to the receptacle circuits called for in Section 220-3(b).

**(b) Small Appliance Branch Circuits, Dwelling Occupancies.** For the small appliance load, including refrigeration equipment, in kitchen, pantry, family room, dining room, and breakfast room of dwelling occupancies, two or more 20-ampere appliance branch circuits in addition to the branch circuits specified in Section 220-3(a) shall be provided for all receptacle outlets in these rooms, and such circuits shall have no other outlets.

Receptacle outlets supplied by at least two appliance receptacle branch circuits shall be installed in the kitchen.

At least one 20-ampere branch circuit shall be provided for laundry receptacle(s) required in Section 210-22(b).

Receptacle outlets installed solely for the support of and the power supply for electric clocks may be installed on lighting branch circuits.

A 3-wire 115/230-volt branch circuit is the equivalent of two 115-volt receptacle branch circuits.

**(c) Other Circuits.** For specific loads not otherwise provided for in Section 220-3(a) or (b), branch circuits shall be as required by other sections of the Code.

**220-4. Calculation of Feeder Loads.** The computed load of a feeder shall be not less than the sum of all branch-circuit loads supplied by the feeder, as determined by Section 220-2, subject to the following provisions:

(Exception on page 72-34)

(220-4 continued)

*Exception: When the calculated load for multi-family dwellings under this Section without electric cooking exceeds that calculated under Section 220-9 for the identical load plus electric cooking (based on 8 kW per unit), the lesser of the two loads may be used.*

**(a) Continuous and Noncontinuous Loads.** When a feeder supplies continuous loads or any combination of continuous and noncontinuous load the rating of the overcurrent devices shall not be less than the noncontinuous load plus 125 percent of the continuous load.

*Exception: When the assembly including the overcurrent devices protecting the feeder(s) are approved for operation at 100 percent of their rating, the ampacity of the feeder may equal the sum of the continuous load plus the noncontinuous load.*

**(b) General Lighting.** The demand factors listed in Table 220-4(b) may be applied to that portion of the total branch-circuit load computed for general illumination. These demand factors shall not be applied in determining the number of branch circuits for general illumination supplied by the feeders.

See Sections 220-4(h) and (i).

The demand factors herein are based on minimum load conditions and 100 percent power factor, and in specific instances may not provide sufficient capacity for the installation contemplated. In view of the trend toward higher intensity lighting systems and increased loads due to more general use of fixed and portable appliances, each installation should be considered as to the load likely to be imposed and the capacity increased to insure safe operation. Where electric-discharge lighting systems are to be installed, high-power-factor type should be used or the conductor capacity may need to be increased.

**Table 220-4(b). Calculation of Feeder Loads by Occupancies**

Type of Occupancy	Portion of Lighting Load to which Demand Factor Applies (wattage)	Feeder Demand Factor
Dwellings—other than Hotels	First 3000 or less at Next 3001 to 120,000 at Remainder over 120,000 at	100% 35% 25%
*Hospitals	First 50,000 or less at Remainder over 50,000 at	40% 20%
*Hotels and Motels—including Apartment Houses without provision for cooking by tenants	First 20,000 or less at Next 20,001 to 100,000 at Remainder over 100,000 at	50% 40% 30%
Warehouses (Storage)	First 12,500 or less at Remainder over 12,500 at	100% 50%
All Others	Total Wattage	100%

\* The demand factors of this Table shall not apply to the computed load of sub-feeders to areas in hospitals, hotels and motels where entire lighting is likely to be used at one time; as in operating rooms, ballrooms, or dining rooms.

**(c) Show-Window Lighting.** For show-window lighting, a load of not less than 200 watts shall be included for each linear foot of show window measured horizontally along its base.

(d) **Motors.** For motors, a load computed according to the provisions of Sections 430-24, 430-25 and 430-26 shall be included.

(e) **Feeder Neutral Load.** The feeder neutral load shall be the maximum unbalance of the load determined by Section 220-4. The maximum unbalanced load shall be the maximum connected load between the neutral and any one ungrounded conductor; except that the load thus obtained shall be multiplied by 140 percent for 5-wire, 2-phase systems. For a feeder supplying household electric ranges, wall-mounted ovens and counter-mounted cooking units, the maximum unbalanced load shall be considered as 70 percent of the load on the ungrounded conductors, as determined in accordance with Table 220-5. For 3-wire DC or single-phase AC, 4-wire 3-phase and 5-wire 2-phase systems, a further demand factor of 70 percent may be applied to that portion of the unbalanced load in excess of 200 amperes. There shall be no reduction of the neutral capacity for that portion of the load which consists of electric-discharge lighting.

See Examples 1, 1a, 1b, 1c, 2, 3, 4 and 5, Chapter 9.

(f) **Fixed Electrical Space Heating.** The computed load of a feeder supplying fixed electrical space heating equipment shall be the total connected load on all branch circuits.

*Exception No. 1: Where reduced loading of the conductors results from units operating on duty-cycle, intermittently, or from all units not operating at one time, the authority enforcing this code may grant permission for feeder conductors to be of a capacity less than 100 percent, provided the conductors are of sufficient capacity for the load so determined.*

*Exception No. 2: Section 220-4(f) does not apply when feeder capacity is calculated in accordance with the optional methods in Section 220-7 for a single-family dwelling or an individual apartment of a multi-family dwelling and in Section 220-9 for multi-family dwellings.*

(g) **Noncoincident Load.** In adding the branch-circuit loads to determine the feeder load, the smaller of two dissimilar loads may be omitted from the total where it is unlikely that both of the loads will be served simultaneously.

(h) **Small Appliances.** The computed branch-circuit load for receptacle outlets in other than dwelling occupancies, for which the allowance is not more than  $1\frac{1}{2}$  amperes per outlet, may be included with the general lighting load and subject to the demand factors in Section 220-4(b).

#### **Dwelling Occupancies**

The requirements in following Sections 220-4(i) through (l) apply to dwelling-type occupancies and are supplemental to the preceding Sections 220-4(a) through (h).

(i) **1. Small Appliances.** In single-family dwellings, in individual apartments of multi-family dwellings having provisions for cooking by tenants, and in each hotel suite having a serving pantry, a feeder load of not less than 1500 watts for each two-wire circuit installed as required by Section 220-3(b) shall be included for small appliances (portable appliances supplied from receptacles of 15- or 20-ampere rating) in kitchen, pantry, family room, dining room, and breakfast room. Where the load is subdivided through two or more feeders, the computed load

(220-4(i-1) continued)

for each shall include not less than 1500 watts for each 2-wire circuit for small appliances. These loads may be included with the general lighting load and subject to the demand factors in Section 220-4(b).

**2. Laundry Circuit.** A feeder load of not less than 1500 watts shall be included for each 2-wire laundry circuit installed as required by Section 220-3(c). This load may be included with the general lighting load and subject to the demand factors in Section 220-4(b).

**(j) Electric Ranges.** The feeder load for household electric ranges and other cooking appliances, individually rated more than 1¾ kW, may be calculated in accordance with Table 220-5.

In order to provide for possible future installation of ranges of higher ratings, it is recommended that where ranges of less than 8¾ kW ratings or wall-mounted ovens and counter-mounted cooking units are to be installed, the feeder capacity be not less than the maximum demand value specified in Column A of Table 220-5.

Where a number of single-phase ranges are supplied by a 3-phase, 4-wire feeder, the current shall be computed on the basis of the demand of twice the maximum number of ranges connected between any two phase wires.

See Example 7, Chapter 9.

**(k) Fixed Electrical Appliances (Other than Ranges, Clothes Dryers, Air-Conditioning Equipment or Space Heating Equipment).** Where 4 or more fixed electrical appliances other than electric ranges, clothes dryers, air-conditioning equipment or space heating equipment are connected to the same feeder in a single- or multi-family dwelling, a demand factor of 75 percent may be applied to the fixed appliance load.

**(l) Space Heating and Air Cooling.** In adding branch-circuit loads for space heating and air cooling in dwelling occupancies, the smaller of the two loads may be omitted from the total where it is unlikely that both of the loads will be served simultaneously.

**(m) Farm Buildings.** Feeders supplying farm buildings (excluding dwellings) or loads consisting of two or more branch circuits shall have minimum capacity computed in accordance with the following table:

**Table 220-4(m)**  
**Demand Computation for Farm Buildings or Loads**

<u>Load in Amperes at 230 Volts</u>	<u>Percent of Connected Load</u>
Loads expected to operate without diversity, but not less than 125 percent full-load current of the largest motor and not less than first 60 amperes.	100%
Next 60 Amperes of all other loads	50%
Remainder of other load	25%

Note 1: For services to farm dwellings, see Sections 220-2 through 220-7.

Note 2: For service at main point of delivery to farmstead, see Section 220-4(n).



**Table 220-5. Demand Loads for Household Electric Ranges, Wall-Mounted Ovens, Counter-Mounted Cooking Units and Other Household Cooking Appliances over 1 $\frac{3}{4}$  kW Rating**  
**Column A to be used in all cases except as otherwise permitted in Note 4 below.**

NUMBER OF APPLIANCES	Maximum Demand (See Notes)	Demand Factors (See Note 4)	
	COLUMN A (Not over 12 kW Rating)	COLUMN B (Less than 3 $\frac{1}{2}$ kW Rating)	COLUMN C (3 $\frac{1}{2}$ kW to 8 $\frac{3}{4}$ kW Rating)
1	8 kW	80%	80%
2	11 kW	75%	65%
3	14 kW	70%	55%
4	17 kW	66%	50%
5	20 kW	62%	45%
6	21 kW	59%	43%
7	22 kW	56%	40%
8	23 kW	53%	36%
9	24 kW	51%	35%
10	25 kW	49%	34%
11	26 kW	47%	32%
12	27 kW	45%	32%
13	28 kW	43%	32%
14	29 kW	41%	32%
15	30 kW	40%	32%
16	31 kW	39%	28%
17	32 kW	38%	28%
18	33 kW	37%	28%
19	34 kW	36%	28%
20	35 kW	35%	28%
21	36 kW	34%	26%
22	37 kW	33%	26%
23	38 kW	32%	26%
24	39 kW	31%	26%
25	40 kW	30%	26%
26-30	{ 15 kW plus 1 kW for each range }	30%	24%
31-40		30%	22%
41-50	{ 25 kW plus $\frac{3}{4}$ kW for each range }	30%	20%
51-60		30%	18%
61 & over		30%	16%

Note 1. Over 12 kW to 27 kW ranges all of same rating. For ranges, individually rated more than 12 kW but not more than 27 kW, the maximum demand in Column A shall be increased 5 percent for each additional kW of rating or major fraction thereof by which the rating of individual ranges exceeds 12 kW.

Note 2. Over 12 kW to 27 kW ranges of *unequal ratings*. For ranges individually rated more than 12 kW and of different ratings but none exceeding 27 kW an average value of rating shall be calculated by adding together the ratings of all ranges to obtain the total connected load (using 12 kW for any range rated less than 12 kW) and dividing by the total number of ranges; and then the maximum demand in Column A

shall be increased 5 percent for each kW or major fraction thereof by which this average value exceeds 12 kW.

Note 3. This table does not apply to commercial ranges. See Table 220-6(a) for demand factors for commercial cooking equipment.

Note 4. Over  $1\frac{3}{4}$  kW to  $8\frac{3}{4}$  kW. In lieu of the method provided in Column A, loads rated more than  $1\frac{3}{4}$  kW but not more than  $8\frac{3}{4}$  kW may be considered as the sum of the nameplate ratings of all the loads, multiplied by the demand factors specified in Columns B or C for the given number of loads.

Note 5. Branch-Circuit Load. Branch-circuit load for one range may be computed in accordance with Table 220-5. The branch-circuit load for one wall-mounted oven or one counter-mounted cooking unit shall be the nameplate rating of the appliance. The branch-circuit load for a counter-mounted cooking unit and not more than two wall-mounted ovens, all supplied from a single branch circuit and located in the same room shall be computed by adding the nameplate ratings of the individual appliances and treating this total as equivalent to one range.

(220-4 continued)

#### (n) Farm Services.

(1) Service equipment and service-entrance conductors for individual farm buildings (excluding dwellings) shall have minimum capacity computed in accordance with Section 220-4(m).

(2) Minimum capacity of service conductors and service equipment, if any, at the main point of delivery to farms (including dwellings) shall be determined in accordance with the following formula:

100 percent of the largest demand computed in accordance with Section 220-4(m).

75 percent of the second largest demand computed in accordance with Section 220-4(m).

65 percent of the third largest demand computed in accordance with Section 220-4(m).

50 percent of the demands of remaining loads computed in accordance with Section 220-4(m).

Note 1: Consider as a single computed demand the total of the computed demands of all buildings or loads having the same function.

Note 2: The demand of the farm dwelling, if included in the demands of this formula, should be computed in accordance with Note 1 of Table 220-4(m).

(o) **Electric Clothes Dryers.** When feeder capacity and circuits are installed for one or more electric clothes dryers, a feeder load of 5,000 watts or the nameplate rating of the appliance, whichever is larger, shall be included for each dryer, subject to the demand factors of Table 220-6(b).

**Table 220-6(a)**  
**Feeder Demand Factors for Commercial Electric Cooking Equipment;**  
**including Dishwasher Booster Heaters, Water Heaters, and Other Kitchen**  
**Equipment.**

Number of Units of Equipment	Demand Factors (percent)
1	100
2	100
3	90
4	80
5	70
6 & over	65

**Table 220-6(b)**  
**Demand Factors for Household Electric Clothes Dryers**

Number of Dryers	Demand Factor (percent)
1	100
2	100
3	100
4	100
5	80
6	70
7	65
8	60
9	55
10	50
11-13	45
14-19	40
20-24	35
25-29	32.5
30-34	30
35-39	27.5
40 & over	25

**220-7. Optional Calculation for Single-Family Dwelling or Individual Apartment of Multi-Family Dwelling.** For a single-family dwelling or individual apartment of a multi-family dwelling served by a 115/230-volt, 3-wire, 100-ampere or larger service where the total load is supplied by one feeder or one set of service-entrance conductors, the percentages shown in Table 220-7 may be used in lieu of the method of determining feeder and service loads detailed in Section 220-4.

All other load shall include 1500 watts for each 20-ampere appliance circuit [Section 220-3(b)]; lighting and portable appliances at 3 watts per square foot; all fixed appliances, (including 4 or more separately controlled space heating units [see Section 220-4(1)], ranges, wall-mounted ovens and counter-mounted cooking units) at nameplate rated load (kVA for motors and other low-power-factor loads).

See Examples 1(b) and 1(c) of Chapter 9.

**Table 220-7**  
**Optional Calculation for Single-Family Dwelling or Individual**  
**Apartment of Multi-Family Dwelling**

<b>LOAD (in kW or kVA)</b>	<b>Percent of Load</b>
Air conditioning and cooling including heat pump compressors* . . .	100%
Central electric space heating or less than 4 separately controlled electric space heating units . . . . .	65%
First 10 kW of all other load . . . . .	100%
Remainder of other load . . . . .	40%

\*Use the larger of the air-conditioning load or the diversified demand of the heating load when applying Section 220-4(1).

The required demand load for each feeder and for the service-entrance conductors shall not be less than the connected load of the space heating or air conditioning, whichever is greater.

**220-8. Optional Calculation for Additional Loads in Existing Single-Family Dwelling Occupancy.** Load calculations for an existing single-family dwelling occupancy now served by an existing 115/230-volt or 120/208-volt, 3-wire, 60-ampere service may be computed as follows:

<b>Load in kW or kVA</b>	<b>Percent of Load</b>
First 8 kW of load at	100%
Remainder of load at	40%

Load calculation shall include lighting and portable appliances at 3 watts per square foot; 1500 watts for each 20-ampere appliance circuit; range or wall-mounted oven and counter-mounted cooking unit, and other fixed or stationary appliances, at nameplate rating.

If air conditioning equipment or electric space heating equipment is to be installed the following formula shall be applied to determine if the existing service is of sufficient size.

Air conditioning equipment* . . . . .	100%
Central electrical space heating* . . . . .	100%
Less than four separately controlled space heating units* . . . .	100%
First 8 kW of all other load . . . . .	100%
Remainder of all other load . . . . .	40%

Other loads shall include:

1500 watts for each 20-ampere appliance circuit.

Lighting and portable appliances at 3 watts per sq. ft.

Household range or wall-mounted oven and counter-mounted cooking unit.

All other fixed appliances including 4 or more separately controlled space heating units, at nameplate rating.

\*Use larger connected load of air conditioning and space heating, but not both.

**220-9. Optional Calculation for Multi-Family Dwellings.**

(a) For multi-family dwellings equipped with electric cooking equipment, and electric space heating or air conditioning or both, the required demand load for each feeder and for the service-entrance con-

ductors may be determined by the following method in lieu of the method of determining feeder (and service) loads detailed in Section 220-4, provided that no individual dwelling unit is supplied by more than one feeder. Any house loads on such feeders shall be calculated in accordance with applicable Sections of Article 220 and shall be added to loads as determined by this Section.

(b) The connected load to which the demand factor applies shall include:

(1) 1500 watts for each 2-wire 20-ampere appliance circuit required by Section 220-3(b) and 1500 watts for each 2-wire 20-ampere laundry circuit installed in accordance with Section 220-3(b).

(2) Lighting and portable appliances at 3 watts per square foot.

(3) All fixed or stationary appliances including ranges, wall-mounted ovens, counter-mounted cooking units, and laundry dryers at nameplate rated load (kVA for motors and other low-power-factor loads).

(4) Water heaters at nameplate rated load, using only the maximum possible at one time in the case of a water heater with interlocked elements.

(5) The larger load of all space heating units or all air conditioning units, per Section 220-4(1).

(c) The required demand load for each feeder and for the service-entrance conductors shall not be less than the connected load of the space heating or air conditioning, whichever is greater.

**Table 220-9**  
**Demand Factors for Feeders and Service-Entrance Conductors**  
**for Multi-Family Dwelling**

Number of Dwelling Units	Demand Factor (percent)
3-5	45
6-7	44
8-10	43
11	42
12-13	41
14-15	40
16-17	39
18-20	38
21	37
22-23	36
24-25	35
26-27	34
28-30	33
31	32
32-33	31
34-36	30
37-38	29
39-42	28
43-45	27
46-50	26
51-55	25
56-61	24
62 & over	23

## ARTICLE 230 — SERVICES

### A. General Requirements

**230-1. Scope.** The provisions of this Article shall apply to the conductors and equipment for control and protection of services — circuits that conduct electric power from the supply system or plant to the premises to be served.

**230-2. Number of Services to a Building or Other Premises Served.** In general, a building or other premises served shall be supplied through only one set of service conductors, except as follows:

*Exception No. 1: Fire Pumps. Where a separate service is required for fire pumps.*

*Exception No. 2: Emergency Lighting. Where a separate service is required for emergency lighting and power purposes.*

*Exception No. 3: Multiple-Occupancy Buildings.*

(a) *By special permission, in multiple-occupancy buildings where there is no available space for service equipment accessible to all the occupants.*

(b) *Buildings of multiple occupancy may have two or more separate sets of service-entrance conductors which are tapped from one service drop or lateral, or two or more sub-sets of service-entrance conductors may be tapped from a single set of main service-entrance conductors.*

**DEFINITION:** Sub-sets of service-entrance conductors are taps from main service conductors run to service equipment.

*Exception No. 4: Capacity Requirements. By special permission, or where capacity requirements are in excess of 3,000 amperes, two or more services may be installed.*

*Exception No. 5: Buildings of Large Area. By special permission, where more than one service is necessary due to the area over which a single building extends.*

*Exception No. 6: Different Characteristics or Classes of Use. Where additional services are required for different voltages, frequency, or phase, or different classes of use. Different classes of use could be because of needs for different characteristics, or because of rate schedule as in the case of controlled water heater service.*

*Exception No. 7: Separate Enclosures. Where two to ten service disconnecting means in separate enclosures supply separate loads from one service drop or lateral, one set of service-entrance conductors may supply each or several such service enclosures.*

**230-3. Supply to a Building from Another.** The service conductors supplying each building or structure shall not pass through the inside of another building unless these buildings are under single occupancy or management. See Section 230-45.

**B. Insulation and Size of Service Conductors**

**230-4. Insulation of Service Conductors.** Service conductors shall normally withstand exposure to atmospheric and other conditions of use without detrimental leakage of current to adjacent conductors, objects, or the ground.

For Service Drops — See Section 230-22.

For Service-Entrance Conductors — See Section 230-40.

For Underground Services — See Section 230-30.

**230-5. Size of Service Conductors.** Service conductors shall have adequate ampacity to safely conduct the current for the loads supplied without a temperature rise detrimental to the insulation or covering of the conductors, and shall have adequate mechanical strength.

Minimum sizes are given in the following references:

For Service Drops — Section 230-23.

For Service-Entrance Conductors — Section 230-41.

For Underground Service Conductors — Section 230-31.

For Farmstead Service Conductors — See Section 220-4(n).

**C. Service Drops**

**230-21. Number of Drops.** No building shall be supplied through more than one service drop, except for the purposes listed in Section 230-2.

**230-22. Service-Drop Conductors.**

(a) **Cable.** Individual conductors of multi-conductor cable shall be insulated or covered with thermoplastic, rubber or other vulcanizable material.

*Exception: A grounded conductor may be bare.*

(b) All open, individual conductors shall be insulated or covered.

**230-23. Minimum Size of Service-Drop Conductors.** Conductors shall have sufficient ampacity to carry the load. They shall have adequate mechanical strength and shall not be smaller than No. 8 copper or No. 6 aluminum.

*Exception: For installations to supply only limited loads of a single branch circuit such as small polyphase power, controlled water heaters and the like; they shall not be smaller than No. 12 hard-drawn copper or equivalent.*

Overhead conductors to a building or other structure from another building or other structure (such as a pole) on which a meter or disconnecting means is installed shall be considered as a service drop and installed accordingly.

The grounded conductor shall not be less than the minimum size required by Section 250-23(b).

Conductors having extruded covering used for service drops have the same ampacities as covered conductors listed in Tables 310-13 and 310-15.

**230-24. Clearance of Service Drops.** Service-drop conductors shall not be readily accessible and when not in excess of 600 volts, shall conform to the following:

**(a) Clearance Over Roof.** Conductors shall have a clearance of not less than 8 ft. from the highest point of roofs over which they pass with the following exceptions:

*Exception No. 1: Where the voltage between conductors does not exceed 300 and the roof has a slope of not less than 4 inches in 12 inches the clearance may be not less than 3 feet.*

*Exception No. 2: Service-drop conductors of 300 volts or less which do not pass over other than a maximum of 4 feet of the overhang portion of the roof for the purpose of terminating at a (through-the-roof) service raceway or approved support may be maintained at a minimum of 18 inches from any portion of the roof over which they pass.*

**(b) Clearance from Ground.** Service-drop conductors when not in excess of 600 volts, shall have the following minimum clearance from ground.

10 feet — above finished grade, sidewalks or from any platform or projection from which they might be reached;

12 feet — over residential driveways and commercial areas such as parking lots and drive-in establishments not subject to truck traffic;

15 feet — over commercial areas, parking lots, agricultural or other areas subject to truck traffic;

18 feet — over public streets, alleys, roads and driveways on other than residential property.

**(c) Clearance from Building Openings.** Conductors shall have a clearance of not less than 36 inches from windows, doors, porches, fire escapes, or similar locations.

Conductors run above the top level of a window are considered out of reach from that window.

For clearances of conductors of over 600 volts see National Electrical Safety Code ANSI C2-1960. (Available from Superintendent of Documents, Government Printing Office, Washington, D.C. 20401.)

**230-25. Supports Over Buildings.** Where practicable, conductors passing over a building shall be supported on structures which are independent of the building. Where necessary to attach conductors to roof they shall be supported on substantial structures.

**230-26. Point of Attachment.** The point of attachment of a service drop to a building or other structure shall be not less than 10 feet above finished grade and shall be at a height to permit the minimum clearance requirements of Section 230-24.

In the event a mast-type riser is required to attain the required height, it shall be of such construction and so supported that it will withstand the strain imposed by the service drop. Raceway fittings shall be of a type approved for the purpose.

**230-27. Means of Attachment.** Multiple-conductor cables used for service drops shall be attached to buildings or other structures by fittings approved for the purpose. Open conductors shall be attached to non-combustible, nonabsorptive insulators securely attached to the building or other structure or by fittings approved for the purpose.



**D. Underground Services**

**230-30. Insulation.** Service lateral conductors shall be insulated for the applied voltage.

*Exception: A grounded conductor may be:*

- (1) Bare copper used in a raceway.
- (2) Bare copper for direct burial where bare copper is judged to be suitable for the soil conditions.
- (3) Bare copper for direct burial without regard to soil conditions where part of an approved cable assembly with a moisture- and fungus-resistant outer covering.
- (4) Aluminum or copper-clad aluminum without individual insulation or covering used in a raceway or for direct burial when:
  - a. Part of an approved cable assembly with a moisture- and fungus-resistant outer covering, and when:
  - b. The nominal voltage to ground of any conductor is not over 300 volts.

**230-31. Size of Underground Service Conductors.**

(a) **Size of Underground Service Lateral.** Conductors shall have sufficient ampacity to carry the load. They shall not be smaller than No. 8 copper or No. 6 aluminum or copper-clad aluminum. The grounded conductor shall be not less than the minimum size required by Section 250-23(b).

*Exception: For installations to supply only limited loads of a single branch circuit such as small polyphase power, controlled water heaters and the like, they shall not be smaller than No. 12 copper or No. 10 aluminum or copper-clad aluminum.*

(b) **Size of Underground Service-Entrance Conductors.** Same as required for overhead service-entrance conductors. See Section 230-41.

(c) **Number of Service Laterals.** No building or other structure shall be supplied through more than one service lateral, except for the purposes listed in Section 230-2.

**230-32. Protection Against Damage.**

(a) **In the Ground.** Underground service conductors shall be protected against physical damage by being installed:

- (1) in duct;
- (2) in rigid metal conduit or electrical metallic tubing made of a material suitable for the condition, or provided with corrosion protection suitable for the condition;
- (3) in rigid nonmetallic conduit if installed in accordance with Sections 347-2 and 347-3;
- (4) by direct burial in the earth. Conductors buried directly in the earth, whether as single conductors or as multi-conductor cable, shall be of a type approved for the purpose. Where necessary to prevent physical damage to the conductors from rocks, slate, etc., or from vehicular traffic, etc., direct buried conductors shall be provided with supplementary protection, such as sand, sand and suitable running

boards, suitable sleeves, or other approved means. Conductors under a building shall be in a raceway that is extended to the outer perimeter of the building.

(5) other approved means.

(b) **On Poles.** Where underground service conductors are carried up a pole the mechanical protection shall be installed to a point at least 8 feet above the ground. Such mechanical protection may be provided by the use of approved cable, pipe, or other approved means.

(c) **Where Entering Building.** Underground service conductors shall have mechanical protection in the form of rigid or flexible conduit, electrical metallic tubing, auxiliary gutters, the metal tape of an approved service cable, or other approved means. The mechanical protection shall extend to the enclosure for the service equipment unless the service switch is installed on a switchboard, in which case a bushing shall be provided which, except where lead-covered conductors are used, shall be of the insulating type.

**230-33. Raceway Seal.** Where a service raceway or duct enters from an underground distribution system, the end within the building shall be sealed with suitable compound so as to prevent the entrance of moisture or gases. Spare or unused ducts shall also be sealed.

#### **E. Service-Entrance Conductors**

##### **230-40. Insulation of Service-Entrance Conductors.**

(a) Service-entrance conductors entering buildings or other structures shall be insulated. Where only on the exterior of buildings or other structures the conductors shall be insulated or covered.

*Exception: A grounded conductor may be:*

- (1) *Bare copper used in a raceway.*
- (2) *Bare copper for direct burial where bare copper is judged to be suitable for the soil conditions.*
- (3) *Bare copper for direct burial without regard to soil conditions where part of an approved cable assembly with a moisture- and fungus-resistant outer covering.*
- (4) *Aluminum or copper-clad aluminum without individual insulation or covering used in a raceway or for direct burial when:*
  - a. Part of an approved cable assembly with a moisture- and fungus-resistant outer covering, and when:*
  - b. The nominal voltage to ground of any conductor is not over 300 volts.*

(b) Open individual conductors which enter the building or other structure shall be rubber-covered or thermoplastic-covered.

**230-41. Size of Service-Entrance Conductors, Overhead System and Underground System.** Service-entrance conductors shall have sufficient ampacity to carry the load as determined by Article 220 and in accordance with Tables 310-12, 310-13, 310-14, 310-15. Service-entrance conductors shall not be smaller than No. 6 except:

Service-entrance conductors shall not be run within the hollow spaces of frame buildings unless provided with overcurrent protection at their outer end.

*Exception No. 1: For single-family residences with an initial load of 10 kW or more computed in accordance with Article 220, or if the initial installation has more than five 2-wire branch circuits, the service-entrance conductors shall have an ampacity of not less than 100 amperes 3-wire.*

Service-entrance conductors shall have sufficient ampacity to carry the load as determined by Article 220 and in accordance with Tables 310-12, 310-13, 310-14, 310-15. There shall be a minimum of 100 ampere 3-wire service for all individual residences except:

*Exception No. 2: For installations consisting of not more than two 2-wire branch circuits they shall not be smaller than No. 8.*

*Exception No. 3: By special permission due to limitations of supply source or load requirements they shall not be smaller than No. 8.*

*Exception No. 4: For installations to supply only limited loads of a single branch circuit, such as small polyphase power, controlled water heaters and the like, they shall not be smaller than the conductors of the branch circuit and in no case smaller than No. 12.*

*Exception No. 5: The grounded (neutral) conductor shall have an ampacity in conformity with Section 220-4(e), and shall not be less than the minimum size required by Section 250-23(b).*

**230-42. Service-Entrance Conductors without Splice.** Service-entrance conductors shall be without splice except as follows:

*Exception No. 1: Clamped or bolted connections in a meter enclosure are permitted.*

*Exception No. 2: Taps to main service conductors are permitted as provided in Section 230-2 Exception No. 3(b) or to individual sets of service equipment as provided in Section 230-70(g).*

*Exception No. 3: At a properly enclosed junction point where an underground wiring method is changed to another type of wiring method.*

*Exception No. 4: A connection is permitted where service conductors are extended from a service drop to an outside meter location and returned to connect to the service-entrance conductors of an existing installation.*

**230-43. Other Conductors in Service Raceway.** Conductors other than service conductors, grounding conductors, or control conductors from time switches having overcurrent protection, shall not be installed in the same service raceway or service-entrance cable.

#### F. Installation of Service-Entrance Conductors

**230-44. Wiring Methods.** Service-entrance conductors extending along the exterior, or entering buildings or other structures may be installed as follows:

(a) As separate conductors, in cables approved for the purpose, cablebus, or enclosed in rigid conduit.

(b) For circuits not exceeding 600 volts the conductors may be installed in electrical metallic tubing, wireways, auxiliary gutters, or busways.

**230-45. Conductor Considered Outside Building.** Conductors placed under at least 2 inches of concrete beneath a building, or conductors within a building in conduit or duct and enclosed by concrete or brick not less than 2 inches thick shall be considered outside the building.

**230-46. Mechanical Protection.** Individual open conductors or cables other than approved service-entrance cables, shall not be installed within 8 feet of the ground or where exposed to physical damage. Service-entrance cables, where liable to contact with awnings, shutters, swinging signs, installed in exposed places in driveways, near coal chutes or otherwise exposed to physical damage, shall be of the protected type or be protected by conduit, electrical metallic tubing or other approved means.

**230-47. Individual Open Conductors Exposed to Weather.** Individual open conductors exposed to weather shall be supported on insulators, racks, brackets, or other means, placed at intervals not exceeding 9 feet and separating the conductors at least 6 inches from each other and 2 inches from the surface wired over; or at intervals not exceeding 15 feet if they maintain the conductors at least 12 inches apart. For 300 volts or less, conductors may have a separation of not less than 3 inches where supports are placed at intervals not exceeding 4½ feet and conductors are not less than 2 inches from the surface wired over.

**230-48. Individual Open Conductors Not Exposed to Weather.** Individual open conductors not exposed to the weather may be supported on glass or porcelain knobs placed at intervals not exceeding 4½ feet and maintaining the conductors at least one inch from the surface wired over and a separation of at least 2½ inches between conductors.

**230-49. Individual Conductors Entering Buildings or Other Structures.** Where individual open conductors enter a building or other structure, they shall enter through roof bushings or enter through the wall in an upward slant through individual, noncombustible, nonabsorptive, insulating tubes. Drip loops shall be formed on the conductors before they enter the tubes.

**230-50. Service Cables.**

(a) **Approved Service-Entrance Cables.** Approved service-entrance cables shall be supported by straps or other approved means within 12 inches of every service head, gooseneck, or connection to a raceway or enclosure and at intervals not exceeding 4½ feet.

(b) **Other Cables.** Cables that are not approved for mounting in contact with a building or other structure shall be mounted on insulating supports installed at intervals not exceeding 15 feet and in a manner that will maintain a clearance of not less than 2 inches from the surface over which they pass.

**230-51. Connections at Service Head.**

(a) Service raceways shall be equipped with a raintight service head.

(b) Service cables, unless continuous from pole to service equipment or meter, shall be either:

(1) equipped with a raintight service head, or

(2) formed in a gooseneck, taped and painted or taped with a self-sealing weather-resistant thermoplastic.

(c) Service heads and goosenecks in service-entrance cables shall be located above the point of attachment of the service-drop conductors to the building or other structure.

*Exception: Where it is impracticable to locate the service head above the point of attachment, the service head may be located not farther than 24 inches from the point of attachment.*

(d) Service cables shall be held securely in place by connection to service-drop conductors below the gooseneck or by a fitting approved for the purpose.

(e) Service heads shall have conductors of opposite polarity brought out through separately bushed holes.

(f) Drip loops shall be formed on individual conductors. To prevent the entrance of moisture, service-entrance conductors shall be connected to the service-drop conductors either:

(1) below the level of the service head, or

(2) below the level of the termination of the service-entrance cable sheath.

(g) Service-drop conductors and service-entrance conductors shall be so arranged that water will not enter service raceway or equipment.

**230-52. Raceways to Drain.** Where exposed to the weather, raceways enclosing service-entrance conductors shall be raintight and arranged to drain. Where embedded in masonry, raceways shall be arranged to drain.

**230-53. Termination at Service Equipment.** Any service raceway or cable shall terminate at the inner end in a box, cabinet, or equivalent fitting that effectively encloses all live metal parts.

*Exception: Where the service disconnecting means is mounted on a switchboard having exposed bus-bars on the back, a raceway may terminate at a bushing.*

### G. Service Equipment

**230-60. Hazardous Locations.** Service equipment installed in hazardous locations shall comply with the requirements of Articles 500 through 517.

**230-61. Service Equipment Grouped.** Where supplied at the same side of the building by more than one overhead service drop or more than one set of underground service conductors, the service equipment, except for services as permitted in Section 230-2, shall be grouped and equipment marked to indicate the load it serves.

The one or more additional service disconnecting means for fire pumps or for emergency services shall be installed sufficiently remote from the one to 6 service disconnecting means for normal services to minimize the possibility of simultaneous interruption of supply.

See Sections 700-9 and 700-10 for emergency system services.

### H. Grounding and Guarding

**230-62. Guarding.** Live parts of service equipment shall be enclosed so that they will not be exposed to accidental contact, unless mounted on a switchboard, panelboard or controller accessible to qualified persons only and located in a room or enclosure free from easily ignitable material. Such an enclosure shall be provided with means for locking or sealing doors giving access to live parts.

**230-63. Grounding and Bonding.** Service equipment shall be grounded as follows:

(a) **Equipment.** The enclosure for service equipment shall be grounded in the manner specified in Article 250, unless (1) the voltage does not exceed 150 volts to ground and such enclosures are (2) isolated from conducting surfaces, and (3) unexposed to contact by persons or materials that may also be in contact with other conducting surfaces.

(b) **Raceways and Cable Armor.** Service raceways, cable armor and the metal sheath of service cables, shall be grounded. Conduit and metal pipe from underground supply shall be considered sufficiently grounded where containing lead-sheathed cable bonded to a continuous underground lead-sheathed cable system.

(c) **Flexible Metal Conduit.** Where a rigid metal raceway containing service conductors is interrupted by flexible metal conduit, whether between two sections of the raceway or between the end of the raceway and the service-equipment enclosure, the sections of raceway and the equipment enclosure so interrupted shall be bonded together by an equipment bonding jumper sized in accordance with Table 250-94(a) and attached by means of pressure connectors, clamps, or other approved means. The bonding jumper and attachment means shall be protected from physical damage.

### J. Disconnecting Means

**230-70. General.**

(a) **Disconnection from Service Conductors.** Means shall be provided for disconnecting all conductors in the building or other structure from the service-entrance conductors.

(b) **Location.** The disconnecting means shall be located at a readily accessible point nearest to the entrance of the conductors, either inside or outside the building or structure. Sufficient access and working space shall be provided about the disconnecting means.

In a multiple-occupancy building, each occupant shall have access to his disconnecting means. A multiple-occupancy building having individual occupancy above the second floor shall have service equipment grouped in a common accessible place, the disconnecting means consisting of not more than 10 switches or 10 circuit breakers. Multiple occupancy buildings that do not have individual occupancy above the second floor may have service conductors run to each occupancy in accordance with Section 230-2, Exception No. 3 and each such service may have not more than 10 switches or circuit breakers.

(c) **Approval.** The disconnecting means shall be of a type approved for service equipment and for prevailing conditions.

(d) **Types Permitted.** The disconnecting means for ungrounded conductors shall consist of either:

(1) A manually operable switch or circuit breaker equipped with a handle or other suitable operating means positively identified and marked for mechanical operation by hand.

(2) An electrically operated switch or circuit breaker provided the switch or circuit breaker can be opened by hand in event of a failure of the power supply and the open and closed positions are clearly indicated to the operator.

(e) **Externally Operable.** An enclosed service disconnecting means shall be externally operable without exposing the operator to contact with live parts.

*Exception: An electrically operated switch or circuit breaker need not be capable of being externally operable by hand to the closed position.*

(f) **Indicating.** The disconnecting means shall plainly indicate whether it is in the open or closed position.

(g) **Switch and Circuit Breaker.** The service disconnecting means for each set or for each sub-set of service-entrance conductors shall consist of not more than 10 switches or 10 circuit breakers mounted in a single enclosure, grouped together in separate enclosures, or in or on a switchboard. Where 2 to 10 service disconnects are installed at one service location, each such disconnecting device shall be permanently marked to identify it as a service disconnecting means.

Two or 3 single-pole switches or breakers, capable of individual operation, may be installed on multiwire circuits, one pole for each ungrounded conductor, as one multipole disconnect provided they are equipped with "handle ties" or a "master handle" to disconnect all conductors of the service with no more than 10 operations of the hand.

See Section 384-16(a) for service equipment in panelboards.

(h) **Simultaneous Openings.** Each disconnecting means shall simultaneously disconnect all ungrounded conductors.

See Section 200-5(a).

(i) **Disconnection of Grounded Conductor.** Where the switch or circuit breaker does not interrupt the grounded conductor, other means shall be provided in the service cabinet or on the switchboard for disconnecting the grounded conductor from the interior wiring.

### 230-71. Rating of Service Equipment.

(a) The service equipment shall have a rating not less than the load to be carried determined in accordance with Article 220. The service disconnecting means shall have a rating of not less than 60 amperes except:

*Exception No. 1: For single-family residences with an initial load of 10 kW or more computed in accordance with Article 220, or if the*

*initial installation has more than five 2-wire branch circuits, the service equipment shall have a rating of not less than 100 amperes 3-wire.*

*Exception No. 2: For installations consisting of not more than two 2-wire branch circuits a service equipment of 30-ampere minimum rating may be used.*

**(b) Where multiple switches or circuit breakers are used in accordance with Section 230-70(g) the combined rating shall not be less than required for a single switch or breaker.**

**230-72. Connection to Terminals.** The service conductors shall be attached to the disconnecting means by pressure connectors, clamps or other approved means, except that connections which depend upon solder shall not be used.

**230-73. Equipment Connected to the Supply Side of Service Disconnect.** Equipment shall not be connected to the supply side of the service disconnecting means.

*Exception No. 1: Service Fuses.*

*Exception No. 2: Fuses and disconnecting means or circuit breakers, in meter pedestals, connected in series with the ungrounded service conductors and located away from the building supplied.*

*Exception No. 3: Meters nominally rated not in excess of 600 volts, provided all metal housings and service enclosures are grounded in accordance with Article 250.*

*Exception No. 4: Instrument transformers (current and potential), high-impedance shunts, surge-protective capacitors, time switches and lightning arresters.*

*Exception No. 5: Taps used only to supply time switches, circuits for emergency systems, fire pump equipment, fire and sprinkler alarms if provided with service equipment and installed in accordance with requirements for service-entrance conductors.*

**230-74. Safeguarding Emergency Supply.** Where an emergency supply is provided to feed the conductors controlled by the service disconnecting means, the disconnecter shall be of a design that will open all ungrounded conductors from the usual supply before connection is made to the emergency supply, unless agreed upon arrangements have been made for parallel operation and suitable automatic control equipment provided. See Article 700.

**230-76. More than One Building or Other Structure.**

**(a) Disconnect Required for Each.** Where more than one building or other structure is on the same property and under single management, each building or other structure served shall be provided with a readily accessible disconnecting means within, on, or adjacent to the building or other structure for disconnecting all ungrounded conductors.

**(b) Suitable for Service Equipment.** The disconnecting means specified in (a) above shall be suitable for use as service equipment.

*Exception: For garages and outbuildings on residential property, the disconnecting means may consist of a snap switch or of a set of 3-way or 4-way snap switches suitable for use on branch circuits.*



**K. Overcurrent Protection**

**230-90. Where Required.** Each ungrounded service-entrance conductor shall have overcurrent protection.

**(a) Ungrounded Conductor.** Such protection shall be provided by an overcurrent device in series with each ungrounded service conductor, having a rating or setting not higher than the allowable ampacity of the conductor, except as follows:

*Exception No. 1: For motor-starting currents, ratings in conformity with Sections 430-52, 430-62, or 430-63 may be used.*

*Exception No. 2: Fuses and circuit breakers may have a rating or setting in conformity with Section 240-5(a), Exception No. 1, and Section 240-5(b).*

*Exception No. 3: Not more than 10 circuit breakers or 10 sets of fuses may serve as the overcurrent device.*

*Exception No. 4: In a multiple-occupancy building each occupant shall have access to his overcurrent protective devices. A multiple-occupancy building having individual occupancy above the second floor shall have service equipment grouped in a common accessible place, the overcurrent protection consisting of not more than 10 circuit breakers or 10 sets of fuses. Multiple-occupancy buildings that do not have individual occupancy above the second floor may have service conductors run to each occupancy and each such service may have not more than 10 circuit breakers or 10 sets of fuses.*

*Exception No. 5: Fire Pumps. Where the service to the fire pump room is judged to be outside of buildings, these provisions shall not apply. Service equipment for fire pump services shall be selected or set to carry locked-rotor current of the motor(s) indefinitely (See NFPA No. 20 — 1970, Standard for Centrifugal Fire Pumps).*

A set of fuses is all the fuses required to protect all the ungrounded conductors of a circuit. Single-pole breakers may be grouped as in Section 230-70(g) as one multiple protective device.

**(b) Not in Grounded Conductor.** No overcurrent device shall be inserted in a grounded service conductor except a circuit breaker which simultaneously opens all conductors of the circuit.

**(c) More Than One Building.** In a property comprising more than one building under single management, the ungrounded conductors supplying each building served shall be protected by overcurrent devices, which may be located in the building served or in another building on the same property, provided they are accessible to the occupants of the building served.

**230-91. Location.** The service overcurrent device shall be an integral part of the service disconnecting means or shall be located immediately adjacent thereto, unless located at the outer end of the entrance.

**230-92. Location of Branch-Circuit Overcurrent Devices.** Where the service overcurrent devices are locked or sealed, or otherwise not readily accessible, branch-circuit overcurrent devices shall be installed on the load side, shall be mounted in an accessible location and shall be of lower rating than the service overcurrent device.

**230-93. Protection of Specific Circuits.** Where necessary to prevent tampering, an automatic overcurrent device protecting service conductors supplying only a specific load such as a water heater, may be locked or sealed where located so as to be accessible.

**230-94. Relative Location of Overcurrent Device and Other Service Equipment.** The overcurrent device shall protect all circuits and devices except as follows:

(a) The service switch may be placed on the supply side.

(b) High-impedance shunt circuits, lightning arresters, surge protective capacitors, instrument transformers, (current and potential), may be connected and installed on the supply side of the service disconnecting means as permitted in Section 230-73.

(c) Circuits for emergency supply and time switches may be connected on the supply side of the service overcurrent device where separately provided with overcurrent protection.

(d) Circuits used only for the operation of fire alarm, other protective signalling systems, or the supply to fire pump equipment may be connected on the supply side of the service overcurrent device where separately provided with overcurrent protection.

(e) Meters nominally rated not in excess of 600 volts, provided all metal housings and service enclosures are grounded in accordance with Article 250.

(f) Where service equipment is operated electrically, the control circuit may be connected ahead of the service equipment if suitable overcurrent protection and disconnecting means are provided.

**230-95. Ground-Fault Protection of Equipment.** Ground-fault protection of equipment shall be provided for grounded wye electrical services of more than 150 volts to ground, but not exceeding 600 volts phase-to-phase for any service disconnecting means rated 1,000 amperes or more. The ground-fault protection may consist of overcurrent devices or combination of overcurrent devices and current transformers or other equivalent protective equipment which shall operate to cause the service disconnecting means to open all ungrounded conductors of the faulted circuit at fault current values of 1,200 amperes or more.

When a switch and fuse combination is used, the fuses employed shall be capable of interrupting any current higher than the interrupting capacity of the switch during a time when the ground-fault protective system will not cause the switch to open.

It is recognized that ground-fault protection is desirable for service disconnecting means rated less than 1000 amperes on grounded systems having more than 150 volts to ground, not exceeding 600 volts phase-to-phase.

Ground-fault protection that functions to open the service disconnecting means will not protect service conductors or the service disconnecting means but will limit the damage to conductors and equipment on the load side of the ground-fault protection.

This added protective equipment at the service equipment will make it necessary to review the over-all wiring system for proper selective overcurrent protection coordination. Additional installations of ground-fault pro-

protective equipment will be needed on feeders and branch circuits where maximum continuity of electrical service is necessary.

**230-96. Working Space.** Sufficient working space shall be provided in the vicinity of the service overcurrent devices to permit safe operation, replacements, inspection, and repairs. In no case shall this be less than that specified by Section 110-16.

**230-98. Available Short-Circuit Current.** Service equipment and its overcurrent protective devices shall have short-circuit current rating equal to or not less than the available short-circuit current at its supply terminal.

### L. Services Exceeding 600 Volts

**230-100. Scope.** Service conductors and equipment used on circuits exceeding 600 volts shall comply with the applicable provisions of the preceding Sections of this Article and with the following Sections which are additions to or modifications of the preceding Sections.

Secondary conductors, not the primary conductors, are the service conductors to the building proper in the following cases:

1. Where step-down transformers are located outdoors.
2. Where step-down transformers are located in a separate building from the one served.
3. Where step-down transformers are located in the building served in transformer vaults, locked rooms or locked enclosures in accordance with Article 450 and accessible only to qualified persons.

In all other cases, the primary conductors are the service conductors.

In no case will the provisions of this Article apply to equipment connected ahead of the service conductors.

### **230-101. Service-Entrance Conductors.**

**(a) Conductor Size.** Service conductors shall be not smaller than No. 6 unless in cable. Conductors in cable shall be not smaller than No. 8.

**(b) Wiring Methods.** Service-entrance conductors shall be installed by means of one of the following wiring methods:

- (1) In rigid metal conduit.
- (2) In rigid nonmetallic conduit where encased in not less than 2 inches of concrete.
- (3) As multi-conductor cable approved for the purpose.
- (4) As open conductors where supported on insulators approved for the purpose and where either accessible only to qualified persons or where effectively guarded against accidental contact.
- (5) In cablebus.

See Table 710-5 for shielding of solid dielectric insulated conductors.

(c) **Open Work.** Open wire services over 600 volts shall be installed in accordance with the provisions of Article 710, Part D.

(d) **Supports.** Service conductors and their supports, including insulators, shall have strength and stability sufficient to insure maintenance of adequate clearance with abnormal currents in case of short circuits.

(e) **Guarding.** Open wires shall be guarded where accessible to unqualified persons.

(f) **Service Cable.** Where cable conductors emerge from a metal sheath or raceway, the insulation of the conductors shall be protected from moisture and physical damage by a pothead or other approved means.

(g) **Draining Raceways.** Unless conductors specifically approved for the purpose are used, raceways embedded in masonry, or exposed to the weather, or in wet locations shall be arranged to drain.

(h) **Over 15,000 Volts.** Where the voltage exceeds 15,000 volts between conductors they shall enter either metal-enclosed switchgear or a transformer vault conforming to the requirements of Section 450-41 through 450-48.

(i) **Conductor Considered Outside Building.** Conductors placed under at least 2 inches of concrete beneath a building, or conductors within a building in conduit or duct and enclosed by concrete or brick not less than 2 inches thick shall be considered outside the building.

**230-102. Warning Signs.** High-voltage signs shall be posted where unauthorized persons might come in contact with live parts.

**230-103. Disconnecting Means.** The circuit breaker or the alternatives for it specified in Section 230-106 will constitute the disconnecting means required by Section 230-70 and shall comply with Section 230-70(h). The disconnecting means shall be capable of being closed on a fault within the maximum interrupting rating of the overcurrent protection.

**230-104. Isolating Switches.** Isolating switches shall be provided as follows:

(a) Air-break isolating switches shall be installed between oil switches or air or oil circuit breakers used as service switches and the supply conductor, except where such equipment is mounted on removable truck panels or metal-enclosed switchgear units which cannot be opened unless the circuit is disconnected, and which, when removed from the normal operating position, automatically disconnect the circuit breaker or switch from all live parts.

(b) When the fuses used with nonautomatic oil switches in accordance with Section 230-106 are of a type that may be operated as a disconnect switch, they may serve as the isolating switch when they completely disconnect the oil switch and all service equipment from the source of supply.

(c) Air-break isolating switches shall be accessible to qualified attendants only. They shall be arranged so that a grounding connection on

the load side can readily be made. Such grounding means need not be provided for duplicate isolating switches, if any, installed and maintained by the supply company.

**230-105. Equipment in Secondaries.** Where the primary service equipment supplies one or more transformers whose secondary windings connect to a single set of mains, and the primary load-interrupter switch or circuit breaker is capable of being opened and closed from a point outside the transformer vault, the disconnecting means and overcurrent protection may be omitted from the secondary circuit provided the primary fuse or circuit breaker is rated or set to protect the secondary circuit.

**230-106. Overcurrent Protection.** Overcurrent devices shall be provided in accordance with the following:

**(a) In Vault or Consisting of Metal-Enclosed Switchgear.** Where the service equipment is installed in a transformer vault meeting the provisions of Sections 450-41 through 450-48, or consists of metal-enclosed switchgear, the requirements for overcurrent protection and disconnecting means may be fulfilled by the following:

(1) A nonautomatic oil switch, oil fuse cutout, air load-interrupter switch, or other approved switch, capable of interrupting the rated circuit load, and suitable fuses may be used.

(2) An automatic trip circuit breaker of suitable current-carrying and interrupting capacity with an overcurrent unit in each ungrounded conductor may be used.

(3) A switch capable of interrupting the no-load current of the transformer supplied through the switch and suitable fuses may be used, provided the switch is interlocked with a single switch or circuit breaker on the secondary circuit of the transformer so that the primary switch cannot be opened when the secondary circuit is closed.

(4) Metal-enclosed switchgear shall consist of a substantial metal structure and a sheet metal enclosure. Barriers between adjacent switchgear units and internal metal barriers shall be not less than  $\frac{1}{8}$  inch of metal or No. 11 MSG. All other covers, panels and doors shall be not less than No. 14 MSG. Where installed over a wood floor, suitable protection thereto shall be provided.

**(b) Not in Vault or Not Consisting of Metal-Enclosed Switchgear.** Where the service equipment is not in a vault or metal-enclosed switchgear, the requirements for the overcurrent protection and disconnecting means may be fulfilled by the following:

(1) Air load-interrupter switches, or other approved switches, capable of interrupting the rated circuit load may be used with suitable fuses on a pole or elevated structure outside the building provided the switch may be operated by persons using the building.

(2) On circuits of any voltage, an automatic trip circuit breaker of suitable ampacity and interrupting capacity with an overcurrent unit in each ungrounded conductor may be used. The circuit breaker shall be located outside the building as near as practicable to where the service

(230-106(b-2) continued)

conductors enter the building. The location may be on a pole, roof, foundation, or other structure.

(c) **Fuses.** Fuses shall have an interrupting rating at least equal to the maximum short-circuit current possible in the circuit.

(d) **Circuit Breakers.** Circuit breakers shall be free to open in case the circuit is closed on an overload. This can be accomplished by means such as trip-free breakers or by multiple breakers having an operating handle per pole. A service circuit breaker shall indicate clearly whether it is open or closed, and shall be capable of interrupting the maximum short-circuit current to which it may be subjected.

(e) **Enclosed Overcurrent Devices.** The restriction to 80 percent of rating for an enclosed overcurrent device on continuous loads shall not apply to overcurrent devices installed in services operating at over 600 volts.

**230-107. Lightning Arresters.** Lightning arresters installed in accordance with the requirements of Article 280 shall be placed on each ungrounded overhead service conductor on the supply side of the service equipment, when called for by the authority having jurisdiction.

ARTICLE 240 — OVERCURRENT PROTECTION

A. Installation

**240-1. Scope.** This Article provides the general requirements for the application of overcurrent protective devices.

**240-2. Purpose of Overcurrent Protection.** Overcurrent protection for conductors and equipment is provided for the purpose of opening the electric circuit if the current reaches a value which will cause an excessive or dangerous temperature in the conductor or conductor insulation.

**240-3. Protection of Equipment.** Equipment shall be protected against overcurrent as specified in the references in the following list:

Equipment	Article No.
Air-Conditioning and Refrigerating Equipment .....	440
Appliances .....	422
Capacitors .....	460
Cranes and Hoists .....	610
Electric Signs and Outline Lighting .....	600
Electric Welders .....	630
Elevators, Dumbwaiters, Escalators, and Moving Walks ....	620
Emergency Systems .....	700
Fixed Electric Space Heating Equipment .....	424
Fixed Outdoor Electric De-Icing and Snow Melting Equipment .....	426
Generators .....	445
Induction and Dielectric Heating Equipment .....	665
Metalworking Machine Tools .....	670

Equipment	Article No.
Motion Picture Studios and Similar Locations .....	530
Motors, Motor Circuits and Controllers .....	430
Organs .....	650
Over 600 Volts — General .....	710
Remote-Control, Low-Energy Power, Low-Voltage Power and Signal Circuits .....	725
Services .....	230
Sound-Recording and Similar Equipment .....	640
Switchboards and Panelboards .....	384
Theaters and Assembly Halls .....	520
Transformers and Transformer Vaults .....	450
X-ray Equipment .....	660

#### 240-5. Overcurrent Protection.

(a) **Conductors.** Conductors shall be protected in accordance with their ampacities, as given in Tables 310-12 through 310-15, except as follows:

*Exception No. 1: Rating of Nonadjustable Overcurrent Protection of 800 Amperes or Less.* Where the standard ampere ratings of fuses and nonadjustable circuit breakers do not correspond with the allowable ampacities of conductors, the next higher standard rating may be used, only where the rating is 800 amperes or less.

*Exception No. 2: Fixture Wires and Cords.* Fixture wire or flexible cord, Size No. 16 or No. 18, and tinsel cord shall be considered as protected by 20-ampere overcurrent devices except as provided in Section 620-61. Fixture wires of the sizes permitted for taps in Section 210-19(c) (2) shall be considered as protected by the overcurrent protection of the 30- 40- and 50-ampere branch circuits of Article 210. Flexible cord approved for use with specific appliances shall be considered as protected by the overcurrent device of the branch circuit of Article 210 when conforming to the following:

20-ampere circuits, No. 18 cord and larger.

30-ampere circuits, cord of 10-ampere capacity and over.

40-ampere circuits, cord of 20-ampere capacity and over.

50-ampere circuits, cord of 20-ampere capacity and over.

*Exception No. 3: Motor Circuits.* Motor and motor-control circuit conductors protected in accordance with Parts C, D, E, and F of Article 430. Motor-operated appliance circuit conductors protected in accordance with Parts B and D of Article 422. Air-conditioning and refrigerating equipment circuit conductors protected in accordance with Parts C and F of Article 440.

*Exception No. 4: Control Circuits.* Where not in the same cable with communication circuits, as provided in Section 725-7, conductors of control circuits other than motor-control circuits shall be considered as protected by overcurrent devices that are rated or set at not more than 300 percent of the ampacity of the remote-control conductors.

*Exception No. 5: Transformer Secondary Conductors.* Conductors supplied by the secondary side of a single-phase transformer having a 2-wire (single-voltage) secondary shall be considered as protected by

*overcurrent protection provided on the primary (supply) side of the transformer, provided this protection is in accordance with Section 450-3(a)(1) or (b)(1) and does not exceed the value determined by multiplying the secondary conductor ampacity by the secondary-to-primary transformer voltage ratio.*

*Exception No. 6: Tap Conductors. Tap conductors as permitted in Sections 210-19(c); 240-15, Exception Nos. 3, 5, 6 and 7; 364-9 and 364-10; and Part D of Article 430.*

**(b) Standard Ratings.** Standard ampere ratings for fuses and non-adjustable circuit breakers are 15, 20, 25, 30, 35, 40, 45, 50, 60, 70, 80, 90, 100, 110, 125, 150, 175, 200, 225, 250, 300, 350, 400, 450, 500, 600, 700, 800, 1000, 1200, 1600, 2000, 2500, 3000, 4000, 5000, and 6000.

#### **240-6. Fuses.**

**(a)** Plug fuses and fuseholders shall not be used in circuits exceeding 125 volts between conductors except in circuits supplied from a system having a grounded neutral and no conductor in such circuits operating at more than 150 volts to ground.

**(b)** Cartridge fuses and fuseholders rated at 300 volts shall not be used in circuits exceeding 300 volts between conductors except in circuits supplied from a system having a grounded neutral and no conductor in such circuits operating at more than 300 volts to ground.

**(c)** The screw shell of plug-type fuseholders shall be connected to the load side of the circuit.

**240-8. Thermal Devices.** Thermal cutouts, thermal relays and other devices not designed to open short circuits, shall not be used for protection of conductors against overcurrent due to short circuits or grounds but may be used to protect motor branch-circuit conductors from overload if protected in accordance with Section 430-40.

#### **240-11. Ungrounded Conductors.**

**(a)** An overcurrent device (fuse or overcurrent trip unit of a circuit breaker) shall be placed in each ungrounded conductor. For motor circuits see Article 430.

**(b)** Circuit breakers shall open all ungrounded conductors of the circuit, except as follows:

*Exception: Individual single-pole circuit breakers may be used for the protection of each conductor of ungrounded 2-wire circuits, each ungrounded conductor of 3-wire direct-current or single-phase circuits, or for each ungrounded conductor of lighting or appliance branch circuits connected to 4-wire 3-phase systems, or 5-wire 2-phase systems, provided such lighting or appliance circuits are supplied from a system having a grounded neutral and no conductor in such circuits operates at a voltage greater than permitted in Section 210-6.*

**240-12. Grounded Conductor.** No overcurrent device shall be placed in any permanently grounded conductor, except as follows:

*Exception No. 1: Where the overcurrent device simultaneously opens all conductors of the circuit.*



*Exception No. 2: For motor-running protection as provided in Sections 430-36 and 430-37.*

**240-13. Change in Size of Grounded Conductor.** Where a change occurs in the size of the ungrounded conductor, a similar change may be made in the size of the grounded conductor.

**240-14. Fuses or Circuit Breakers in Parallel.** Overcurrent devices consisting of fuses and/or circuit breakers shall not be arranged or installed in parallel.

*Exception: Circuit breakers assembled in parallel which are tested and approved as a single unit.*

#### B. Location

**240-15. Location in Circuit.** Overcurrent devices shall be located at the point where the conductor to be protected receives its supply, except as follows:

*Exception No. 1: Service Conductors. An overcurrent protective device for service conductors may be located as specified in Section 230-91.*

*Exception No. 2: Smaller Conductor Protected. Where the overcurrent device protecting the larger conductors also protects the smaller conductors in accordance with Tables 310-12 through 310-15.*

*Exception No. 3: Branch Circuits. Taps to individual outlets and circuit conductors supplying a single household electric range shall be considered as protected by the branch-circuit overcurrent devices when in accordance with the requirements of Sections 210-19, 210-20 and 210-25.*

*Exception No. 4: Feeder Taps. A conductor tapped from a feeder shall be considered as properly protected from overcurrent when installed in accordance with Sections 364-8 and 430-59.*

*Exception No. 5: Feeder Taps Not Over 10 Feet Long. For conductors tapped to a feeder where all of the following conditions are met:*

*(a) The length of each tap conductor does not exceed 10 feet; (b) the ampacity of the tap conductors is (1) not less than the combined computed loads of the circuits supplied by the tap conductors, and (2) not less than the ampere rating of the switchboard or panelboard supplied by the tap conductors; (c) the tap conductors do not extend beyond the switchboard, panelboard, or control devices they supply; (d) except at the point of connection to the feeder the tap conductors are enclosed in a raceway, which shall extend from the tap to the enclosure of an enclosed switchboard, panelboard, or control devices or to the back of an open switchboard.*

*Exception No. 6: Feeder Taps Not Over 25 Feet Long. Where the smaller conductor has an ampacity at least one-third that of the conductor from which it is supplied, and provided the tap is suitably protected from physical damage, is not over 25 feet long, and terminates in a single circuit breaker or set of fuses which will limit the load on the tap to that allowed by Tables 310-12 through 310-15. Beyond this point the conductors may supply any number of circuit breakers or sets of fuses.*

*Exception No. 7: Transformer Feeder Taps with Primary Plus Secondary Not Over 25 Feet Long. Where all of the following conditions are met: (1) the conductors supplying the primary of a transformer have an ampacity at least one-third that of the conductors or overcurrent protection from which they are tapped, and (2) the conductors supplied by the secondary of the transformer have an ampacity that, when multiplied by the ratio of the secondary-to-primary voltage, is at least one-third the ampacity of the conductors or overcurrent protection from which the primary conductors are tapped, and (3) the total length of one primary plus one secondary conductor, excluding any portion of the primary conductor that is protected at its ampacity, is not over 25 feet, and (4) the primary and secondary conductors are suitably protected from physical damage, and (5) the secondary conductors terminate in a single circuit breaker or set of fuses which will limit the load to that allowed in Tables 310-12 through 310-15.*

**240-16. Location in Premises.** Overcurrent devices shall be located where they will be:

(a) Readily accessible, except as provided in Sections 230-91 and 230-92 for service equipment and Section 364-11 for busways.

(b) Not exposed to physical damage.

(c) Not in the vicinity of easily ignitable material.

(d) **Occupant to Have Ready Access.** Each occupant shall have ready access to all overcurrent devices protecting the conductors supplying his occupancy.

*Exception: In a multiple-occupancy building where electric service and electrical maintenance are provided by the building management and where these are under continuous building management supervision, the service overcurrent devices and feeder overcurrent devices supplying more than one occupancy may be accessible to authorized management personnel only.*

### C. Enclosures

#### **240-17. Enclosures for Overcurrent Devices.**

(a) **General.** Overcurrent devices shall be enclosed in cutout boxes or cabinets, unless a part of a specially approved assembly which affords equivalent protection, or unless mounted on switchboards, panelboards or controllers located in rooms or enclosures free from easily ignitable material and dampness. The operating handle of a circuit breaker may be accessible without opening a door or cover.

(b) **Damp or Wet Locations.** Enclosures for overcurrent devices in damp or wet locations shall be of a type approved for such locations and shall be mounted so there is at least 1/4-inch air space between the enclosure and the wall or other supporting surface.

(c) **Vertical Position.** Enclosures for overcurrent devices shall be mounted in a vertical position unless in individual instances this is shown to be impracticable.

(d) **Rosettes.** Fuses shall not be mounted in rosettes.

**D. Disconnecting and Guarding**

**240-18. Disconnection of Fuses and Thermal Cutouts Before Handling.** Disconnecting means shall be provided on the supply side of all fuses or thermal cutouts in circuits of more than 150 volts to ground and cartridge fuses in circuits of any voltage, where accessible to other than qualified persons, so that each individual circuit containing fuses or thermal cutouts can be independently disconnected from the source of electrical energy, except as provided in Section 230-73 and except that a single disconnecting means may be used to control a group of circuits each protected by fuses or thermal cutouts under the conditions described in Section 430-112.

**240-19. Arcing or Suddenly Moving Parts.** Arcing or suddenly moving parts shall comply with the following:

(a) **Location.** Fuses and circuit breakers shall be so located or shielded that persons will not be burned or otherwise injured by their operation.

(b) **Suddenly Moving Parts.** Handles or levers of circuit breakers, and similar parts which may move suddenly in such a way that persons in the vicinity are liable to be injured by being struck by them, shall be guarded or isolated.

**E. Plug Fuses and Fuseholders**

**240-20. Plug Fuses of the Edison-Base Type.** Plug fuses of the Edison-base type shall conform to the following:

(a) **Classification.** Plug fuses of this type shall be classified at not over 125 volts, 0 to 30 amperes.

(b) **Live Parts.** Fuses and fuseholders when installed and assembled together shall have no live parts exposed.

(c) **Marking.** Plug fuses of 15-ampere rating or less shall be distinguished from those of larger rating by an hexagonal opening in the cap through which the mica or similar window shows, or by some other prominent hexagonal feature such as the form of the top or cap itself, or an hexagonal recess or projection in the top or cap.

Plug fuses of the Edison-base type shall be used only for replacements in existing installations where there is no evidence of overfusing or tampering.

**240-21. Fuseholders for Plug Fuses.** Fuseholders for plug fuses of 30 amperes or less shall not be installed unless they comply with Section 240-22 or are made to comply with Section 240-22 by the insertion of an adapter.

**240-22. Plug Fuses and Fuseholders of Type S.** Where Type S plug-fuses are to be used as the overcurrent device required by this Code, the fuses and fuseholders shall conform to the following requirements:

(a) **Classification.** Plug fuses and fuseholders of Type S shall be classified at not over 125 volts; 0 to 15 amperes, 16 to 20 amperes, and 21 to 30 amperes.

(b) **Use of Fuses in a Fuseholder of a Different Classification.** Fuses

of the 16- to 20-ampere and the 21- to 30-ampere classification shall not be usable with fuseholders or adapters of a lower ampere classification.

**(c) Fuseholders and Adapters.** Fuses, fuseholders, and adapters shall be so designed that a fuse other than a Type S fuse cannot be used in a fuseholder or adapter designed for Type S fuses.

**(d) Tamperability.** Fuses, fuseholders and adapters shall be so designed as to be subject to tampering or bridging only with difficulty.

**(e) Adapters to be Nonremovable.** Fuse adapters shall be so designed that when once inserted in a fuseholder they cannot be removed.

**(f) Interchangeability.** Fuses, fuseholders and adapters of various manufacturers shall be interchangeable with each other, and the plugs with adapters shall be suitable for use in the Edison-base type fuseholder.

**(g) Plug Type.** Fuses and fuseholders shall be of the plug type.

**(h) Ampere Rating.** Each fuse, fuseholder and adapter shall be marked with its ampere rating.

**(i) Marking.** Fuses of the 0 to 15-ampere rating shall be distinguished from those of larger rating by an hexagonal opening in the cap through which the mica or similar window shows, or some other prominent hexagonal feature such as the form of the top or cap itself, or an hexagonal recess or projection in the top or cap.

## F. Cartridge Fuses and Fuseholders

**240-23. Cartridge Fuses and Fuseholders.** Cartridge fuses and fuseholders shall conform to the following:

### (a) Classification.

**(1)** 0-600 ampere cartridge fuses and fuseholders shall be classified as regards current and voltage as follows:

Not over 250 volts Amperes	Not over 300 volts Amperes	Not over 600 volts Amperes
0- 30	0-15	0- 30
31- 60	16-20	31- 60
61-100	21-30	61-100
101-200	31-60	101-200
201-400	-	201-400
401-600	-	401-600

**(2)** 601-6000 ampere cartridge fuses and fuseholders shall be classified at 600 volts as follows:

601- 800	1601-2000	3001-4000
801-1200	2001-2500	4001-5000
1201-1600	2501-3000	5001-6000

There are no 250-volt ratings over 600 amperes, but 600-volt fuses may be used for lower voltages.

**(b) Noninterchangeable—0-6000 Ampere Cartridge Fuseholders.** Fuseholders shall be so designed that it will be difficult to put a fuse of any given class into a fuseholder which is designed for a current lower, or voltage higher, than that of the class to which it belongs. Fuseholders for current-limiting fuses shall not permit insertion of fuses which are not current-limiting.

**(c) Marking.** Fuses shall be plainly marked, either by printing on the fuse barrel or by a label attached to the barrel, showing the following: (1) ampere rating, (2) voltage rating, (3) interrupting rating where other than 10,000 amperes, (4) "current limiting" where applicable, (5) the name or trademark of the manufacturer.

*Exception: Interrupting rating marking may be omitted on fuses used for supplementary protection.*

### G. Circuit Breakers

**240-25. Circuit Breakers.** Circuit breakers shall conform to the following:

**(a) Method of Operation.** In general, circuit breakers shall be capable of being closed and opened by hand without employing any other source of power, although normal operation may be by other power such as electrical, pneumatic, and the like. Large circuit breakers which are to be closed and opened by electrical, pneumatic, or other power shall be capable of being closed by hand for maintenance purposes and shall also be capable of being tripped by hand under load without the use of power.

**(b) Injury to Operator.** Circuit breakers shall be arranged and mounted so that their operation is not likely to injure the operator.

**(c) Indication.** Circuit breakers shall indicate whether they are in the open or closed position.

**(d) Nontamperable.** An air circuit breaker, used for the branch circuits described in Article 210, shall be of such design that any alteration of its trip point (calibration), or in the time required for its operation, will be difficult.

**(e) Marking.** Circuit breakers shall be marked with their rating in such a manner that the marking will be durable and visible after installation except that it may be necessary to remove a trim or cover. The ampere rating of circuit breakers rated 100 amperes or less and 600 volts or less shall be molded, stamped, etched, or similarly marked into the handle or the escutcheon area of the circuit breaker. Each circuit breaker rated 240 volts or less and 100 amperes or less and having an interrupting rating other than 5,000 amperes shall have its interrupting rating shown on the circuit breaker or on its label. Each circuit breaker rated more than 240 volts or more than 100 amperes and having an interrupting rating other than 10,000 amperes shall have its interrupting rating shown on the circuit breaker or on its label.

*Exception: Interrupting rating marking may be omitted on circuit breakers used for supplementary protection.*

### H. General

**240-27. Current-Limiting Overcurrent Protective Device.** A current-limiting overcurrent protective device is a device which, when interrupting a specified circuit, will consistently limit the short-circuit current in that circuit to a specified magnitude substantially less than that obtainable in the same circuit if the device were replaced with a solid conductor having comparable impedance.

**240-30. Supplementary Overcurrent Protection.** Where supplementary overcurrent protection is utilized in connection with appliances or other utilization equipment to provide individual protection for specific components or internal circuits within the equipment itself, this does not abrogate any of the requirements applicable to branch circuits and is not to be used as a substitute for branch-circuit protection.

It is not the intent of the above requirement that supplementary overcurrent protective devices be subject to the accessibility requirements as given elsewhere in this code for branch-circuit overcurrent protective devices.

## ARTICLE 250—GROUNDING

### A. General

**250-1. Scope.** This Article covers general requirements for grounding and bonding of electrical installations, and specific requirements for the following:

- (a) Systems, circuits, and equipment required, permitted, or not permitted to be grounded.
- (b) Circuit conductor to be grounded on grounded systems.
- (c) Location of grounding connections.
- (d) Types and sizes of grounding and bonding conductors and electrodes.
- (e) Methods of grounding and bonding.
- (f) Conditions under which guards, isolation, or insulation may be substituted for grounding.
- (g) Connections for lightning arresters.

Circuits are grounded to limit excessive voltages from lightning, line surges, or unintentional contact with higher voltage lines and to limit the voltage to ground during normal operation.

Conductive materials enclosing electric conductors or equipment, or forming part of such equipment, are grounded for the purpose of preventing a voltage above ground on these materials.

Circuits and enclosures are grounded to facilitate overcurrent device operation in case of insulation failure or ground faults. See Section 110-10.

**250-2. Other Articles.** In other Articles, applying to particular cases of installation of conductors and equipment, there are requirements

that are in addition to those of this Article or are modifications of them:

	Article	Section
Appliances .....		422-16
Branch Circuits .....		210-5
		210-6,
		210-7
Cablebus .....		365-9
Communications Circuits .....	800	
Community Antenna Television and Radio Dis- tribution Systems .....		820-3
		820-8
		820-9
Conductors .....	310	
Conductors (Grounded) .....	200	
Cranes and Hoists .....	610	
Data Processing Systems .....		645-4
Elevators, Dumbwaiters, Escalators, and Moving Walks .....	620	
Fixed Electric Space Heating Equipment .....		424-14
Fixed Outdoor Electric De-Icing and Snow-Melt- ing Equipment .....		426-28
Fixtures and Lighting Equipment .....		410-91
		410-92
		410-93
		410-94
		410-95
		410-96
Flexible Cords .....		400-13
		400-14
Generators .....		445-8
Grounding-Type Receptacles (Outlets) .....		210-7
		210-21
		210-22
Hazardous Locations .....	500-517	
Induction and Dielectric Heating Equipment ...	665	
Less Than 50 Volts .....	720	
Lighting Fixtures .....	410	
Marinas and Boatyards .....		555-7
Metalworking Machine Tools .....	670	
Mobile Homes and Parks .....	550	
Motion Picture Studios .....		530-20
		530-66
Motors and Controllers .....	430	
Organs .....	650	
Outlet, Switch and Junction Boxes, and Fittings		370-4
		370-15
		384-27
Panelboards .....		
Radio and Television .....	810	
Receptacles and Attachment Plugs .....		410-55

	Article	Section
Recreational Vehicles and Parks .....	551	
Remote-Control Circuits .....		725-21
Services .....	230	
Service Equipment .....		230-63
Signs and Outline Lighting .....	600	
Sound Recording Equipment .....		640-4
Swimming and Wading Pools .....	680	
Switchboards .....		384-3(c), 384-11
Switches .....		380-1 380-12
Theaters and Assembly Halls .....		520-81
Transformers .....		450-9
X-ray Equipment .....	660	

## B. Circuit and System Grounding

### 250-3. Direct-Current Systems.

(a) **Two-Wire Direct Current—300 Volts or Less.** Two-wire DC systems operating at not more than 300 volts between conductors supplying interior wiring and including wiring installed as overhead conductors outside of buildings shall be grounded.

*Exception No. 1: A system equipped with a ground detector and supplying only industrial equipment in limited areas.*

*Exception No. 2: A system operating at not more than 50 volts between conductors.*

**250-3. Two-Wire Direct-Current Systems.** Two-wire direct-current systems supplying interior wiring, and operating at not more than 300 volts between conductors, shall be grounded, unless such system is used for supplying industrial equipment in limited areas and the circuit is equipped with a ground detector.

All two-wire direct-current systems operating at more than 300 volts between conductors shall be grounded when a neutral point can be established such that the maximum difference of potential between the neutral point and any other point on the system does not exceed 300 volts. All two-wire direct-current systems shall not be grounded when the voltage to ground of either conductor would exceed 300 volts after grounding.

**250-5. Alternating-Current Circuits and Systems to be Grounded.** AC circuits and systems shall be grounded as provided for in (a), (b), or (c) below. Other circuits and systems may be grounded.

(a) **Alternating-Current Circuits of Less than 50 Volts.** AC circuits of less than 50 volts shall be grounded under any of the following conditions:

(1) Where supplied by transformers if the transformer supply system exceeds 150 volts to ground.

(2) Where supplied by transformers if the transformer supply system is ungrounded.

(3) Where installed as overhead conductors outside of buildings.

(b) **Alternating-Current Systems of 50 Volts and Over.** AC systems



supplying interior wiring and interior wiring systems shall be grounded under any of the following conditions:

- (1) Where the system can be so grounded that the maximum voltage to ground on the ungrounded conductors does not exceed 150 volts.
- (2) Where the system is nominally rated 480Y/277-volt, 3-phase, 4-wire in which the neutral is used as a circuit conductor.
- (3) Where the system is nominally rated 240/120-volt, 3-phase, 4-wire in which the midpoint of one phase is used as a circuit conductor.
- (4) Where a service conductor is uninsulated in accordance with Section 230-4.

*Exception: Electric systems used exclusively to supply industrial electric furnaces for melting, refining, tempering, and the like need not be grounded.*

The proper use of suitable ground detectors on ungrounded systems can provide additional protection.

**(c) Separately Derived Systems.** An interior wiring system whose power is derived from generator, transformer, or converter windings that have no direct electrical connection to supply conductors originating in another supply system, if required to be grounded as in (a) or (b) above, shall be grounded as specified in Section 250-26.

**250-7. Circuits Not to be Grounded.** The following circuits shall not be grounded.

(1) Circuits for electric cranes operating over combustible fibers in Class III locations, as provided in Section 503-13.

(2) Circuits as provided in Article 517.

### C. Location of Grounding Connections

**250-21. Current Over Grounding Conductors.** The grounding of wiring systems, circuits, arresters, cable armor, conduit, or other metal raceways as a protective measure shall be so arranged that there will be no objectionable passage of current over the grounding conductors. The temporary currents set up under accidental conditions, while the grounding conductors are performing their intended protective functions, are not to be considered as objectionable. Where an objectionable flow of current occurs over a grounding conductor, due to the use of multiple grounds, (1) one or more of such grounds shall be abandoned, or (2) their location shall be changed, or (3) the continuity of the conductor between the grounding connections shall be suitably interrupted, or (4) other means satisfactory to the authority having jurisdiction shall be taken to limit the current.

**250-22. Grounding Connection for Direct-Current Systems.** Direct-current systems which are to be grounded shall have the grounding connection made at one or more supply stations but not at individual services nor elsewhere on interior wiring.

**250-23. Grounding Connections for Alternating-Current Systems.** (a) Secondary AC systems to be grounded shall have a grounding electrode conductor connected to a grounding electrode at each service. Such

supply systems that originate outside the building shall have at least one additional grounding connection made to a grounding electrode on the secondary side of the transformer supplying the system, either at the transformer or elsewhere. The grounding electrode conductor shall be connected to the AC system on the supply side of the service disconnecting means, preferably within the enclosure for the service disconnecting means. Grounding connections shall not be made on the load side of the service disconnecting means.

*Exception No. 1: A grounding conductor shall be connected to each separately derived system as provided in Section 250-26.*

*Exception No. 2: A grounding conductor connection shall be made at each separate building where required by Section 250-24.*

*Exception No. 3: For ranges, counter-mounted cooking units, wall-mounted ovens, and clothes dryers as permitted by Section 250-61.*

The grounding electrode conductor of a service of large capacity shall be connected within the service equipment enclosure.

**(b) Grounded Conductor Brought to Service Equipment.** Where the secondary system is grounded at any point, the grounded conductor shall be run to each service. This conductor shall be not smaller than the required grounding electrode conductor specified in Table 250-94(a) and, in addition, for service phase conductors larger than 1100 MCM, the grounded conductor shall be not smaller than 12½ percent of the area of the largest phase conductor.

*Exception: The grounded conductor need not be larger than the largest ungrounded service conductor.*

**250-24. Two or More Buildings Supplied From Single Service Equipment.** Where two or more buildings are supplied from a single service equipment, a grounding electrode at each building shall be connected to the AC system grounded conductor on the supply side of the building disconnecting means of a grounded system or connected to the metal enclosure of the building disconnecting means of an ungrounded system.

*Exception: A grounding electrode at a separate building supplied by a feeder or branch circuit is not required where either of the following conditions are met:*

*a. Only one branch circuit is supplied, there is no noncurrent-carrying equipment in the building that requires grounding, and no livestock is housed in the building; or*

*b. An equipment grounding conductor is run with the circuit conductors for grounding any noncurrent-carrying equipment, water piping, or building metal frames in the separate building and no livestock is housed in the building. If the separate building has an approved grounding electrode and/or interior metallic piping system, the equipment grounding conductor shall be bonded to the electrode and/or piping system.*

**250-25. Conductor to be Grounded.** For alternating-current interior wiring systems the conductor to be grounded shall be as follows:

**(a) Single-phase, 2-wire:** the identified conductor;

(b) Single-phase, 3-wire: the identified neutral conductor;

(c) Multiphase systems having one wire common to all phases: the identified common conductor;

(d) Multiphase systems having one phase grounded: the identified conductor;

(e) Multiphase systems in which one phase is used as in (b): the identified neutral conductor.

See Article 200.

The identified conductor is commonly known as "the white wire."

**250-26. Grounding Separately Derived Alternating-Current Systems.** A separately derived AC system that is required to be grounded by Section 250-5 shall be grounded in the following manner:

(a) A bonding jumper, sized in accordance with Section 250-79(c) for the derived phase conductors, shall be used to connect the system noncurrent-carrying equipment enclosures to the system circuit conductor that is to be grounded. This connection shall be made on the supply side of the separately derived system and ahead of any system disconnecting means or overcurrent device.

(b) A grounding conductor, sized in accordance with Section 250-94(a) for the derived phase conductors, shall be used to connect the circuit conductor of the system that is to be grounded to the grounding electrode as specified in (c) below. This connection shall be made on the supply side of the separately derived system and ahead of any system disconnecting means or overcurrent device.

(c) The grounding electrode shall be as near as practicable to and preferably in the same area as the grounding conductor connection to the system. The grounding electrode shall be: (1) The nearest available effectively grounded structural metal member of the structure; or (2) The nearest available effectively grounded metal water pipe; or (3) Other electrodes as specified in Sections 250-82 and 250-83 where electrodes specified by (1) or (2) above are not available.

(d) In all other respects, grounding methods shall comply with requirements prescribed in other parts of this Code.

#### D. Enclosure Grounding

**250-32. Service Conductor Enclosures.** Service raceways, service cable sheaths or armoring, when of metal, shall be grounded.

**250-33. Other Conductor Enclosures.** Metal enclosures for other than service conductors shall be grounded.

*Exception No. 1: Metal enclosures for conductors added to existing installations of open wire, knob and tube work and nonmetallic-sheathed cable in runs of less than 25 feet which are free from probable contact with ground, grounded metal, metal lath or other conductive material and which are guarded against contact by persons need not be grounded.*

*Exception No. 2: Metallic enclosures used to protect approved cable assemblies from physical damage need not be grounded.*

### E. Equipment Grounding

**250-42. Fixed Equipment, General.** Exposed noncurrent-carrying metal parts of fixed equipment that are likely to become energized under abnormal conditions shall be grounded under any of the following conditions:

(a) Where within 8 feet vertically or 5 feet horizontally of ground or grounded metal objects and subject to contact by persons.

(b) Where located in a wet or damp location and not isolated.

(c) Where in electrical contact with metal.

(d) Where in a hazardous location as covered by Articles 500 through 517.

(e) Where supplied by a metal-clad, metal-sheathed, or metal-race-way wiring method.

*Exception: As permitted by Section 250-33 for short sections of race-way.*

(f) Where equipment operates with any terminal in excess of 150 volts to ground.

*Exception No. 1: Enclosures for switches or circuit breakers used for other than service equipment and accessible to qualified persons only.*

*Exception No. 2: Metal frames of electrically heated devices, exempted by special permission, in which case the frames shall be permanently and effectively insulated from ground.*

*Exception No. 3: Transformer cases mounted on wooden poles at a height exceeding 8 feet above ground or grade level.*

**250-43. Fixed Equipment—Specific.** Exposed, noncurrent-carrying metal parts of the following kinds of equipment, regardless of voltage, shall be grounded:

(a) Frames of motors as specified in Section 430-142;

(b) Controller cases for motors, except lined covers of snap switches;

(c) Electric equipment of elevators and cranes;

(d) Electric equipment in garages, theaters and motion picture studios, except pendant lampholders on circuits of not more than 150 volts to ground;

(e) Motion-picture projection equipment;

(f) Electric signs and associated equipment, unless these are inaccessible to unauthorized persons and are also insulated from ground and from other conductive objects;

(g) Generator and motor frames in an electrically operated organ, unless the generator is effectively insulated both from ground and from the motor driving it;

(h) Switchboard frames and structures supporting switching equipment, except that frames of direct-current, single-polarity switchboards need not be grounded where effectively insulated;

(i) Equipment supplied by Class 1 and Class 2 remote control and signaling circuits where Part B of this Article requires those circuits to be grounded.

**250-44. Nonelectrical Equipment.** The following metal parts shall be grounded:

(a) Frames and tracks of electrically operated cranes;

(b) The metal frame of a nonelectrically driven elevator car to which electric conductors are attached;

(c) Hand-operated metal shifting ropes or cables of electric elevators;

(d) Metal enclosures such as partitions, grill work, etc., around equipment carrying voltages in excess of 750 volts between conductors, unless in substations or vaults under the sole control of the supply company.

(e) Mobile homes and recreational vehicles as required in Articles 550 and 551.

Where extensive metal in or on buildings may become energized and is subject to personal contact, adequate bonding and grounding will provide additional safety.

**250-45. Equipment Connected by Cord and Plug.** Under any of the following conditions, exposed noncurrent-carrying metal parts of cord- and plug-connected equipment, which are liable to become energized, shall be grounded:

(a) In hazardous locations (see Articles 500 through 517);

(b) When operated at more than 150 volts to ground, except:

(1) Motors, where guarded;

(2) Metal frames of electrically heated appliances exempted by Section 422-16.

(c) In residential occupancies, (1) refrigerators, freezers, air conditioners, and (2) clothes-washing, clothes-drying and dish-washing machines, sump pumps and (3) portable, hand-held, motor-operated tools and appliances of the following types: drills, hedge clippers, lawn mowers, wet scrubbers, sanders and saws.

*Exception: Portable tools and appliances protected by an approved system of double insulation, or its equivalent, need not be grounded. Where such an approved system is employed the equipment shall be distinctively marked.*

Portable tools or appliances not provided with special insulating or grounding protection are not intended to be used in damp, wet or conductive locations.

(d) In other than residential occupancies, (1) refrigerators, freezers, air conditioners, and (2) clothes-washing, clothes-drying and dish-washing machines, sump pumps and (3) portable, hand-held, motor-operated tools and appliances of the following types: drills, hedge clippers, lawn mowers, wet scrubbers, sanders and saws, and (4) cord- and plug-connected appliances used in damp or wet locations, or by persons standing on the ground or on metal floors or working inside of metal tanks or boilers, and (5) portable tools which are likely to be used in wet and conductive locations.

(250-45(d) continued)

*Exception No. 1: Portable tools which are likely to be used in wet and conductive locations need not be grounded where supplied through an insulating transformer with ungrounded secondary of not over 50 volts.*

*Exception No. 2: Portable tools and appliances protected by an approved system of double insulation, or its equivalent, need not be grounded. Where such an approved system is employed, the equipment shall be distinctively marked. Where conditions of maintenance and supervision assure that proper grounding of tools or appliances will be maintained (as, for example, on some factory production lines) it is recommended that grounded-type tools and appliances be used.*

It is recommended that the frames of all portable motors which operate at more than 50 volts to ground be grounded.

**250-46. Spacing from Lightning Rods.** Metal raceways, enclosures, frames, and other noncurrent-carrying metal parts of electric equipment shall be kept at least 6 feet away from lightning rod conductors, or they shall be bonded to the lightning rod conductors.

See Sections 250-86 and 800-31(b)(5). For further information see the Lightning Protection Code (NFPA No. 78 — 1968, ANSI C5.1 — 1969) which contains detailed information on grounding lightning protection systems.

## F. Methods of Grounding

**250-50. Equipment Grounding Connections.** The grounding connection for metal noncurrent-carrying equipment shall be made on the supply side of the service disconnecting means or as outlined in Section 250-5(c) if for a separately derived system.

**(a) For Grounded System.** The connection shall be made by bonding the equipment grounding conductor to the grounded circuit conductor and the grounding electrode conductor.

**(b) For Ungrounded System.** The connection shall be made by bonding the equipment grounding conductor to the grounding electrode conductor.

*Exception: For branch-circuit extensions only in existing installations which do not have a grounding conductor in the branch circuit, the grounding conductor of a grounding-type receptacle outlet may be grounded to a grounded cold water pipe near the equipment.*

**250-51. Effective Grounding.** The path to ground from circuits, equipment, and conductor enclosures shall (1) be permanent and continuous and (2) shall have ample carrying capacity to conduct safely any currents liable to be imposed on it, and (3) shall have impedance sufficiently low to limit the potential above ground and to facilitate the operation of the overcurrent devices in the circuit.

**250-52. Location of System Ground Connection.** The grounding electrode conductor may be connected to the grounded conductor of the wiring system at any convenient point on the premises on the supply side of the service disconnecting means.

High capacity services shall have the grounding conductor connected to the grounded circuit conductor within the service entrance equipment enclosure.

**250-53. Grounding Path to Grounding Electrode.**

(a) **Grounding Electrode Conductor.** A grounding electrode conductor shall be used to connect the equipment grounding conductors, the service-equipment enclosures and, when the system is grounded, the grounded conductor to the grounding electrode.

(b) **Main Bonding Jumper.** For a grounded system, an unspliced main bonding jumper shall be used to connect the equipment grounding conductor and the service-equipment enclosure to the grounded conductor of the system.

A main bonding jumper may be a wire, bus, screw, or similar suitable conductor.

**250-54. Common Grounding Electrode.** Where the alternating-current system is connected to a grounding electrode in or at a building as specified in Sections 250-23 and 250-24, the same electrode shall be used to ground conductor enclosures and equipment in or on that building.

Two or more electrodes that are effectively bonded together are to be treated as a single electrode in this sense.

**250-55. Underground Service Cable.** Where served from a continuous underground metal-sheathed cable system, the sheath or armor of underground service cable metallically connected to the underground system, or underground service conduit containing a metal-sheathed cable bonded to the underground system, need not be grounded at the building and may be insulated from the interior conduit or piping.

**250-56. Short Sections of Raceway.** Isolated sections of metal raceway or cable armor, where required to be grounded, shall preferably be grounded by connecting to other grounded raceway or armor, but may be grounded in accordance with Section 250-57.

**250-57. Fixed Equipment.**

(a) Metal boxes, cabinets and fittings, or noncurrent-carrying metal parts of other fixed equipment may be grounded by the use of any of the conductors specified in Section 250-91(b).

(b) They may also be grounded in one of the following ways:

(1) By a grounding conductor run with circuit conductors; this conductor may be uninsulated, but where it is provided with an individual covering, the covering shall be finished a continuous green color or a continuous green color with one or more yellow stripes.

(2) By a grounding conductor in the supply cord, when cord connected as permitted in Section 400-3;

(3) By special permission, other means for grounding fixed equipment may be used.

**250-58. Equipment on Structural Metal.**

(a) Electric equipment secured to and in contact with the grounded structural metal frame of a building, shall be deemed to be grounded.

(b) Metal car frames supported by metal hoisting cables attached to or running over sheaves or drums of elevator machines shall be deemed

(250-58(b) continued)

to be grounded where the machine is grounded in accordance with this Code.

**250-59. Portable and/or Cord- and Plug-Connected Equipment.** The noncurrent carrying metal parts of cord- and plug-connected equipment required to be grounded may be grounded in any one of the following ways:

(a) By means of the metal enclosure of the conductors feeding such equipment, provided an approved grounding-type attachment plug is used, one fixed contacting member being for the purpose of grounding the metal enclosure, and provided, further, that the metal enclosure of the conductors is attached to the attachment plug and to the equipment by connectors approved for the purpose;

*Exception: The grounding contacting member of grounding-type attachment plugs on the power supply cord of portable hand-held, hand-guided or hand-supported tools or appliances may be of the movable self-restoring type.*

Attachment plug caps are not intended to be used as terminations for metal-clad cable or flexible metal conduit.

(b) By means of a grounding conductor run with the power supply conductors in a cable assembly or flexible cord that is properly terminated in an approved grounding-type attachment plug having a fixed grounding contacting member. The grounding conductor in a cable assembly may be uninsulated; but where an individual covering is provided for such conductors it shall be finished a continuous green color or a continuous green color with one or more yellow stripes.

*Exception: The grounding contacting member of grounding-type attachment plugs on the power supply cord of portable hand-held, hand-guided or hand-supported tools or appliances may be of the movable self-restoring type.*

(c) A separate flexible wire or strap, insulated or bare, protected as well as practicable against physical damage may be used only by special permission except where a part of an approved portable equipment.

**250-60. Frames of Electric Ranges and Electric Clothes Dryers.** Frames of electric ranges and electric clothes dryers shall be grounded by any of the means provided for in Sections 250-57 and 250-59; or, where served by a 120/240-volt, single-phase, 3-wire circuit or a 120/208-volt circuit derived from a 3-phase, 4-wire supply, they may be grounded by connection to the grounded circuit conductors, provided the grounded circuit conductors are not smaller than No. 10 AWG. Where service-entrance cable having an uninsulated neutral conductor is used, the branch circuit shall originate at the service-entrance equipment. The frames of wall-mounted ovens and counter-mounted cooking units shall be grounded and may be grounded in the same manner as electric ranges. Grounding contacts of receptacles furnished as a part of equipment grounded to the neutral circuit conductor shall be bonded to the equipment which is so grounded.

All branch circuits supplying equipment which is grounded to the grounded circuit conductor shall originate at the service equipment.



**250-61. Use of Grounded Circuit Conductor for Grounding Equipment.**

(a) **Supply-Side Equipment.** A grounded circuit conductor may be used to ground noncurrent-carrying equipment on the supply side of the service disconnecting means, such as meter enclosures, service raceways, etc., and on the supply side of the main disconnecting means of separate buildings and of separately derived systems as provided in Sections 250-24 and 250-26 respectively.

(b) **Load-Side Equipment.** A grounded circuit conductor shall not be used for grounding noncurrent-carrying equipment on the load side of the service disconnecting means or on the load side of a separately derived system disconnecting means or the overcurrent devices for a separately derived system not having a main disconnecting means.

*Exception No. 1: The frames of ranges, wall-mounted ovens, counter-mounted cooking units, and clothes dryers under the conditions specified by Section 250-60.*

*Exception No. 2: As permitted in Section 250-24 for separate buildings.*

*Exception No. 3: By special permission as provided in Section 250-57(b)(3).*

**250-62. Multiple Circuit Connections.** When an installation of fixed or portable equipment is supplied by separate connection to more than one circuit or grounded interior wiring system, a means for grounding shall be provided for each such connection as described in Sections 250-57 and 250-59.

### **G. Bonding**

**250-70. General.** Bonding shall be provided where necessary to assure electrical continuity and the capacity to conduct safely any fault current likely to be imposed.

**250-71. Bonding at Service Equipment.** The electrical continuity of the grounding circuit for the following metal equipment and enclosures shall be assured by one of the means given in Section 250-72.

(a) The service raceways or service cable armor or sheath;

*Exception: Where exempted by Sections 230-63(b) and 250-55.*

(b) All service equipment enclosures containing service-entrance conductors, including meter fittings, boxes or the like, interposed in the service raceway or armor;

(c) Any conduit or armor which forms part of the grounding conductor to the service raceway.

**250-72. Continuity at Service Equipment.** Electrical continuity at service equipment shall be assured by one of the following means:

(a) Bonding equipment to the grounded service conductor in a manner provided in Section 250-113.

(b) Threaded couplings and threaded bosses on enclosures with joints shall be made up wrenchtight where rigid conduit is involved.

(c) Threadless couplings made up tight for rigid metal conduit and electrical metallic tubing.

(d) Bonding jumpers meeting the other requirements of this article. Bonding jumpers shall be used around concentric or eccentric knock-outs which are punched or otherwise formed so as to impair the electrical connection to ground.

(e) Other devices (not locknuts and bushings) approved for the purpose.

**250-73. Metal Armor or Tape of Service Cable.** With service cable having an uninsulated grounded service conductor in continuous electrical contact with its metallic armor or tape, the metal covering is considered to be adequately grounded.

**250-74. Bonding at Grounding-Type Receptacles.** Grounding continuity between a grounded outlet box and the grounding circuit of the receptacle shall be established by means of a bonding jumper between the outlet box and the receptacle grounding terminal.

*Exception No. 1: When the box is surface-mounted, direct metal-to-metal contact between the device yoke and the box may be used to establish the grounding circuit.*

*Exception No. 2: Contact devices or yokes designed and approved for the purpose may be used in conjunction with the supporting screws to establish the grounding circuit between the device yoke and flush-type boxes installed in walls.*

**250-75. Bonding Other Enclosures.** Metal raceways, cable armor, cable sheath, enclosures, frames, fittings, and other metal noncurrent-carrying parts that are to serve as grounding conductors shall be effectively bonded where necessary to assure electrical continuity and the capacity to conduct safely any fault current likely to be imposed on them. Any nonconductive paint, enamel, or similar coating shall be removed at threads, contact points, and contact surfaces or be connected by means of fittings so designed as to make such removal unnecessary.

**250-76. Voltages Exceeding 250 Volts.** The electrical continuity of metal raceway or metal-sheathed cable which contains any conductor other than service-entrance conductors of more than 250 volts to ground shall be assured by one of the methods specified in Sections 250-72(b), (c), (d), and (e), or by one of the following methods:

(a) Threadless fittings, made up tight, with conduit or metal-clad cable;

(b) Two locknuts, one inside and one outside of boxes and cabinets.

**250-77. Loosely Jointed Metal Raceways.** Expansion joints and telescoping sections of raceways shall be made electrically continuous by bonding jumpers or other approved means.

**250-78. Hazardous Locations.** In hazardous locations, regardless of the voltage involved, the electrical continuity of metallic raceway, boxes and the like, shall be assured by one of the methods specified in Sections 250-72(b), (c), (d), and (e).

**250-79. Main and Equipment Bonding Jumpers.**

(a) **Material.** Main and equipment bonding jumpers shall be of copper or other corrosion-resistant material.

(b) **Attachment.** Main and equipment bonding jumpers shall be attached in the manner specified by the applicable provisions of Section 250-113 for circuits and equipment and by Section 250-115 for grounding electrodes.

(c) **Size — Equipment Bonding Jumper on Supply Side of Service and Main Bonding Jumper.** The bonding jumper shall not be smaller than the sizes given in Table 250-94(a) for grounding electrode conductors. Where the service-entrance phase conductors are larger than the sizes given in Table 250-94(a), the bonding jumper shall have an area not less than 12½ percent of the area of the largest phase conductor. Where the service-entrance conductors are paralleled in two or more raceways, the size of the bonding jumper for each raceway shall be based on the size of service conductors in each raceway.

(d) **Size — Equipment Bonding Jumper on Load Side of Service.** The equipment bonding jumper on the load side of the service overcurrent devices shall not be smaller than the sizes listed by Table 250-95 for equipment grounding conductors.

**250-80. Bonding of Piping Systems.** All interior metallic water and gas piping which may become energized shall be bonded together and made electrically continuous. A bond having a size in conformance with Table 250-95 shall be made between the bonded piping system(s) and the grounding electrode conductor at the service disconnecting means.

**H. Grounding Electrodes**

**250-81. Water Pipe Electrode.** Where available on the premises, a metal underground water pipe shall always be used as the grounding electrode, regardless of its length and whether supplied by a community or a local underground water piping system or by a well on the premises. Where the buried portion of the water pipe (including any metal well casing effectively bonded to the pipe) is less than 10 feet long or where the water pipe is or is likely to be isolated by insulated sections or joints so that the effectively grounded portion is less than 10 feet long, it shall be supplemented by the use of an additional electrode of a type specified by Sections 250-82 or 250-83. The interior metal cold water piping system shall always be bonded to the service-equipment enclosure, the grounded conductor at the service, the grounding electrode conductor where of sufficient size, or to the one or more grounding electrodes used.

Expanding use of nonmetallic piping for water systems and insulating couplings on metal water systems makes it more important that water piping within a building be adequately grounded without depending on connections to an outside piping system. The interior piping system should be electrically continuous. Bonding to sewer piping and metal air ducts within the premises will provide additional safety.

**250-82. Other Available Electrodes.** Where a water system as described in Section 250-81 is not available, the grounding connection may be made to any of the following:

(a) The metal frame of the building, where effectively grounded.

(b) Underground gas service piping shall not be used as a grounding electrode.

(c) Other local metallic underground systems, such as piping, tanks, and the like.

(d) The concrete-encased steel reinforcing bar or rod systems of underground footings or foundations, where the total rod length, diameter and depth below earth surface are not less than 50 ft.,  $\frac{3}{8}$  inches and  $2\frac{1}{2}$  feet respectively. The required length may be made up of one or more rods.

Connections to the encased rods or bars shall employ metal-fusing methods for any connections to be encased.

**250-83. Made Electrodes.** Where electrodes described in Sections 250-81 and 250-82 are not available, the grounding electrode shall consist of a driven pipe, driven rod, buried plate or other device approved for the purpose and conforming to the following requirements:

(a) **Concrete-Encased Electrodes.** Not less than 20 feet of bare copper conductor not smaller than No. 4 encased by at least 2 inches of concrete and located within and near the bottom of a concrete foundation footing that is in direct contact with the earth.

(b) **Plate Electrodes.** Each plate electrode shall present not less than 2 square feet of surface to exterior soil. Electrodes of iron, or steel plates shall be at least  $\frac{1}{4}$  inch in thickness. Electrodes of nonferrous metal shall be at least 0.06 inch in thickness.

(c) **Pipe Electrodes.** Electrodes of pipe or conduit shall be not smaller than of the  $\frac{3}{4}$ -inch trade size and, where of iron or steel, shall have the outer surface galvanized or otherwise metal-coated for corrosion protection.

(d) **Rod Electrodes.** Electrodes of rods of steel or iron shall be at least  $\frac{5}{8}$  inch in diameter. Approved rods of nonferrous materials or their approved equivalent used for electrodes shall be not less than  $\frac{1}{2}$  inch in diameter.

(e) **Installation.** Electrodes should, as far as practicable, be imbedded below permanent moisture level. Except where rock bottom is encountered, pipes or rods shall be driven to a depth of at least 8 feet regardless of size or number of electrodes used. Pipes or rods when less than standard commercial length shall preferably be of one piece. Such pipes or rods shall have clean metal surfaces and shall not be covered with paint, enamel or other poorly conducting materials. Where rock bottom is encountered at a depth of less than 4 feet, electrodes shall be buried in a horizontal trench, and where pipes or rods are used as the electrode they shall comply with Sections 250-83(b) and (c) and shall not be less than 8 feet in length. Each electrode shall be separated at least 6 feet from any other electrode, including those used for signal circuits, radio, lightning rods, or any other purpose.

**250-84. Resistance.** Made electrodes shall, where practicable, have a resistance to ground not to exceed 25 ohms. Where the resistance is not as low as 25 ohms, two or more electrodes connected in parallel shall be used.

Continuous metallic underground water piping system in general have a resistance to ground of less than 3 ohms. Metal frames of buildings and local metallic underground piping systems, metal well casings, and the like, have, in general, a resistance substantially below 25 ohms. It is recommended that in locations where it is necessary to use made electrodes for grounding interior wiring systems, additional grounds, such as connections to a system ground conductor be placed on the distribution circuit. It is also recommended that single electrode grounds when installed, and periodically afterwards, be tested for resistance.

**250-86. Use of Lightning Rods.** Lightning rod conductors and driven pipes, rods or other made electrodes used for grounding lightning rods, shall not be used in lieu of the made grounding electrodes required by this Article for grounding wiring systems and equipment. The foregoing provision shall not be taken to forbid the bonding together of the several made electrodes that are respectively provided for electric wiring systems and equipment, for communication systems, and for lightning protection. See Section 800-31(b)(5).

All separate electrodes shall be bonded together to limit potential differences between them and between their associated wiring systems.

## J. Grounding Conductors

**250-91. Material.** The material for the grounding conductors shall be as follows:

**(a) Grounding Electrode Conductor.** The grounding electrode conductor shall be of copper, aluminum or other corrosion-resistant material. The material selected shall be resistant to any corrosive condition existing at the installation or shall be suitably protected against corrosion. Where not of copper, its electrical resistance per linear foot shall not exceed that for copper of the size required by Table 250-94(a) or Table 250-94(b). The conductor may be solid or stranded, insulated, covered, or bare and shall be installed in one continuous length without a splice or joint.

*Exception No. 1: A bus-bar may be spliced.*

*Exception No. 2: For a grounding electrode conductor of an ungrounded system only, rigid metal conduit, pipe, and electrical metallic tubing, including such conduit, pipe, and tubing with threaded or threadless joints, may be used and sized in accordance with Table 250-94(b).*

**(b) Types of Equipment Grounding Conductors.** The equipment grounding conductor run with or enclosing the circuit conductors shall be one or more or a combination of the following: (1) A copper or other corrosion-resistant conductor. This conductor may be solid or stranded; insulated, covered, or bare; and in the form of a wire or a bus-bar of any shape; (2) Rigid metal conduit; (3) Electrical metallic tubing; (4) Flexible metal conduit approved for the purpose and in-

(250-91(b) continued)

stalled with fittings approved for the purpose; (5) Armor of Type AC metal-clad cable; (6) The sheath of Type MI cable; (7) The sheath of Type ALS cable; (8) Other raceways specifically approved for grounding purposes.

*Exception No. 1: Flexible metal conduit may be used for grounding provided all the following conditions are met:*

- a. The length does not exceed 6 feet.*
- b. The circuit conductors contained therein are protected by over-current devices rated at 20 amperes or less.*
- c. The conduit is terminated in fittings approved for the purpose.*

*Exception No. 2: Liquidtight flexible metal conduit may be used for grounding in the 1¼ inches and smaller trade sizes if the length is 6 feet or less and it is terminated in fittings approved for the purpose.*

**250-92. Installation.** Grounding conductors shall be installed as follows:

**(a) Grounding Electrode Conductor.** A grounding electrode conductor or its enclosure shall be securely fastened to the surface on which it is carried. A No. 4 or larger conductor shall be protected if exposed to severe physical damage. A No. 6 grounding conductor that is free from exposure to physical damage may be run along the surface of the building construction without metal covering or protection where it is rigidly stapled to the construction; otherwise, it shall be in conduit, electrical metallic tubing, or cable armor. Grounding conductors smaller than No. 6 shall be in conduit, electrical metallic tubing, or cable armor. Metallic enclosures for grounding conductors shall be electrically continuous from the point of attachment to cabinets or equipment to the grounding electrode, and shall be securely fastened to the ground clamp or fitting. Metallic enclosures that are not physically continuous from cabinet or equipment to the grounding electrode may be made electrically continuous by bonding each end to the grounding conductor. Where rigid metal conduit or steel pipe is used as protection for a grounding conductor, the installation shall comply with the requirements of Article 346; where electrical metallic tubing is used, the installation shall comply with the requirements of Article 348. Aluminum or copper-clad aluminum grounding conductors shall not be used where in direct contact with masonry or the earth or where subject to corrosive conditions. Where used outside, aluminum or copper-clad aluminum grounding conductors shall not be installed within 18 inches of the earth. Magnetic metal enclosures, such as steel pipe or armor may not be used where protection from physical damage can be otherwise obtained, such as by size of the conductor itself or by non-metallic enclosures.

**(b) Equipment Grounding Conductor.** An equipment grounding conductor shall be installed as follows:

(1) Where it consists of a raceway, cable armor, or cable sheath or where it is a wire within a raceway or cable, it shall be installed in accordance with the applicable provisions in this Code using fittings for joints and terminations approved for use with the type raceway or cable used. All connections, joints, and fittings shall be made tight using suitable tools.

(2) Where it is a separate grounding conductor as provided in Section 210-7 or by special permission as provided by Section 250-57(b) (3), it shall be installed in accordance with Section 250-92(a) in regard to restrictions for aluminum and also in regard to protection from physical damage.

*Exception: Sizes smaller than No. 6 need not be enclosed in a race-way or armor where run in the hollow spaces of a wall or partition or where otherwise installed so as not to be subject to physical damage.*

**250-93. Direct-Current Systems.** The size of the grounding conductor for a direct-current supply system or generator shall be not less than that of the largest conductor supplied by the system, except that where the grounded circuit conductor is a neutral derived from a balancer winding or a balancer set protected in accordance with requirements of Section 445-4(d), the size of the grounding conductor shall not be less than that of the neutral conductor. The grounding conductor shall in no case be smaller than No. 8 copper.

**250-94. Alternating-Current Systems.**

(a) **Grounding Electrode Conductor for Grounded Systems.** Where the wiring system is grounded, the size of the grounding electrode conductor for an alternating-current system shall not be less than is given in Table 250-94(a), except that where connected to made electrodes (as in Section 250-83), that portion of the grounding electrode conductor which is the sole connection between the grounding electrode

**Table 250-94(a)**

**Grounding Electrode Conductor for Grounded Systems**

Size of Largest Service-Entrance Conductor or Equivalent for Parallel Conductors		Size of Grounding Electrode Conductor	
Copper	Aluminum or Copper-Clad Aluminum	Copper	*Aluminum or Copper-Clad Aluminum
2 or smaller	0 or smaller	8	6
1 or 0	2/0 or 3/0	6	4
2/0 or 3/0	4/0 or 250 MCM	4	2
Over 3/0 thru 350 MCM	Over 250 MCM thru 500 MCM	2	0
Over 350 MCM thru 600 MCM	Over 500 MCM thru 900 MCM	0	3/0
Over 600 MCM thru 1100 MCM	Over 900 MCM thru 1750 MCM	2/0	4/0
Over 1100 MCM	Over 1750 MCM	3/0	250 MCM

Where there are no service-entrance conductors, the grounding electrode conductor size shall be determined by the equivalent size of the largest service-entrance conductor required for the load to be served.

\* See installation restrictions in Section 250-92(a).

See Section 250-23(b).

and the grounded system conductor need not be larger than No. 6 copper or its equivalent in ampacity.

**(b) Grounding Electrode Conductor for Ungrounded Systems.** Where the wiring system is ungrounded, the size of a grounding electrode conductor for a service raceway, for the metal sheath or armor of a service cable, and for service equipment shall not be less than is given in Table 250-94(b), except that where connected to made electrodes (as in Section 250-83) that portion of the grounding electrode conductor which is the sole connection between the grounding electrode and the service equipment need not be larger than No. 6 copper wire or its equivalent in ampacity.

**Table 250-94(b)**  
**Grounding Electrode Conductor for Ungrounded Systems**

Size of Largest Service-Entrance Conductor or Equivalent for Parallel Conductors		Size of Grounding Electrode Conductor			
Copper	Aluminum or Copper-Clad Aluminum	Copper	*Aluminum or Copper-Clad Aluminum	Conduit or Pipe	Electrical Metallic Tubing
2 or smaller	0 or smaller	8	6	1/2	1/2
1 or 0	2/0 or 3/0	6	4	1/2	1
2/0 or 3/0	4/0 or 250 MCM	4	2	3/4	1 1/4
Over 3/0 thru 350 MCM	Over 250 MCM thru 500 MCM	2	0	3/4	1 1/4
Over 350 MCM thru 600 MCM	Over 500 MCM thru 900 MCM	0	3/0	1	2
Over 600 MCM thru 1100 MCM	Over 900 MCM thru 1750 MCM	2/0	4/0	1	2
Over 1100 MCM	Over 1750 MCM	3/0	250 MCM	1	2

Where there are no service-entrance conductors the grounding electrode conductor size shall be determined by the equivalent size of the largest service-entrance conductor required for the load to be served.

\* See installation restrictions in Section 250-92(a).

**250-95. Size of Equipment Grounding Conductors.** The size of copper, aluminum, or copper-clad aluminum equipment grounding conductors shall be not less than given in Table 250-95. For permissible use of the enclosing raceway see Sections 250-57(a) and 250-91(b).

When conductors are run in parallel in multiple raceways, as permitted in Section 310-10, the metallic equipment grounding conductor, when used, also shall be run in parallel. Each parallel equipment grounding conductor shall be sized on the basis of the ampere rating of



the overcurrent protective device protecting the circuit conductors in the raceway as per Table 250-95.

*Exception No. 1: An equipment grounding conductor not smaller than No. 18 copper and not smaller than the circuit conductors if an integral part of an approved flexible cord assembly, may be used to ground cord-connected equipment where the equipment is protected by overcurrent devices not exceeding 20-ampere rating.*

*Exception No. 2: The equipment grounding conductor need not be larger than the circuit conductors supplying the equipment.*

**Table 250-95. Size of Equipment Grounding Conductors for Grounding Interior Raceway and Equipment**

Rating or Setting of Automatic Overcurrent Device in Circuit Ahead of Equipment, Conduit, etc., Not Exceeding (Amperes)	Size	
	Copper Wire No.	Aluminum or Copper-Clad Aluminum Wire No.*
15	14	12
20	12	10
30	10	8
40	10	8
60	10	8
100	8	6
200	6	4
400	3	1
600	1	2/0
800	0	3/0
1000	2/0	4/0
1200	3/0	250 MCM
1600	4/0	350 "
2000	250 MCM	400 "
2500	350 "	500 "
3000	400 "	600 "
4000	500 "	800 "
5000	700 "	1000 "
6000	800 "	1200 "

\* See installation restrictions in Section 250-92(a).

**250-97. Outline Lighting.** Isolated noncurrent-carrying metal parts of outline lighting systems may be bonded together by a No. 14 conductor protected from physical damage, where a conductor complying with Section 250-95 is used to ground the group.

**250-98. Grounding Conductor in Common Raceway.** A grounding conductor may be installed in the same raceway with other conductors of the system to which it is connected.

**250-99. Continuity.** No automatic cutout or switch shall be placed in the grounding conductor of an interior wiring system unless the opening of the cutout or switch disconnects all sources of energy.

### **K. Grounding Conductor Connections**

**250-111. To Raceway or Cable Armor.** The point of connection of the grounding conductor to interior metal raceways, cable armor and the like shall be as near as practicable to the source of supply and shall be so chosen that no raceway or cable armor is grounded through a run of smaller size than is called for in Section 250-95.

**250-112. To Grounding Electrode.** The grounding connection of a grounding conductor to a grounding electrode shall be made at a point and in a manner that will assure a permanent and effective ground. Where necessary to assure this for a metal piping system used as a grounding electrode, effective bonding shall be provided around insulated joints and sections and around any equipment that is likely to be disconnected for repairs or replacement.

**250-113. Attachment to Circuits and Equipment.** The grounding conductor, bond, or bonding jumper shall be attached to circuits, conduits, cabinets, equipment, and the like, which are to be grounded, by means of suitable lugs, pressure connectors, clamps, or other approved means, except that connections which depend upon solder shall not be used.

**250-114. Continuity and Attachment of Branch-Circuit Equipment Grounding Conductors to Boxes.** Where more than one equipment grounding conductor of a branch circuit enters a box, all such conductors shall be in good electrical contact with each other and the arrangement shall be such that the disconnection or removal of a receptacle, fixture, or other device fed from the box will not interfere with or interrupt the grounding continuity.

**(a) Metallic Boxes.** A connection shall be made between the one or more equipment grounding conductors and a metallic box by means of a grounding screw which shall be used for no other purpose, or an approved grounding device.

**(b) Nonmetallic Boxes.** One or more equipment grounding conductors brought into a nonmetallic outlet box shall be so arranged that a connection can be made to any fitting or device in that box which requires grounding.

**250-115. Attachment to Electrodes.** The grounding conductor shall be attached to the grounding electrode by means of (1) an approved bolted clamp of cast bronze or brass or of plain or malleable cast iron, or (2) a pipe fitting, plug, or other approved device, screwed into the pipe or into the fitting, or (3) other equally substantial approved means. The grounding conductor shall be attached to the grounding fitting by means of suitable lugs, pressure connectors, clamps, or other approved means, except that connections which depend upon solder shall not be used. Not more than one conductor shall be connected to the grounding electrode by a single clamp or fitting, unless the clamp or fitting is of a type approved for such use.

**250-116. Ground Clamps.** For the grounding conductor of a wiring system the sheet-metal-strap type of ground clamp is not considered adequate unless the strap is attached to a rigid metal base which, when installed, is seated on the water pipe, or other electrode and the strap is of such material and dimensions that it is not liable to stretch during or after installation.

Ground clamps for use on copper water tubing and copper, brass, or lead pipe should preferably be of copper, and those for use on galvanized or iron pipe should preferably be of galvanized iron and so designed as to avoid physical damage to pipe. Ground clamps used with aluminum or copper-clad aluminum grounding conductors should be approved for the purpose.

**250-117. Protection of Attachment.** Ground clamps or other fittings, unless approved for general use without protection, shall be protected from ordinary physical damage (1) by being placed where they are not liable to be damaged or (2) by being enclosed in metal, wood, or equivalent protective covering.

**250-118. Clean Surfaces.** Where a nonconductive protective coating, such as paint or enamel, is used on the equipment, conduit, couplings or fittings, such coating shall be removed from threads and other contact surfaces in order to insure a good electrical connection.

#### **L. Instrument Transformers, Relays, etc.**

**250-121. Instrument Transformer Circuits.** The secondary circuits of current and potential instrument transformers shall be grounded where the primary windings are connected to circuits of 300 volts or more to ground, and where on switchboards, shall be grounded irrespective of voltage, except that such circuits need not be grounded where the primary windings are connected to circuits of 750 volts or less and no live parts or wiring are exposed or accessible to other than qualified persons.

**250-122. Instrument Transformer Cases.** Cases or frames of instrument transformers shall be grounded where accessible to other than qualified persons, except that cases or frames of current transformers, the primaries of which are not over 150 volts to ground and which are used exclusively to supply current to meters, need not be grounded.

**250-123. Cases of Instruments, Meters and Relays—Operating Voltage 750 or Less.** Instruments, meters and relays which operate with windings or working parts at 750 volts or less shall be grounded as follows:

(a) **Not on Switchboards.** Instruments, meters, and relays not located on switchboards, which operate with windings or working parts at 300 volts or more to ground, and accessible to other than qualified persons, shall have the cases and other exposed metal parts grounded;

(b) **On Dead-Front Switchboards.** Instruments, meters and relays (whether operated from current and potential transformers, or connected directly in the circuit) on switchboards having no live parts on the front of the panels shall have the cases grounded;

(c) **On Live-Front Switchboards.** Instruments, meters and relays (whether operated from current and potential transformers, or con-

(250-123(c) continued)

nected directly in the circuit) on switchboards having exposed live parts on the front of panels shall not have their cases grounded. Mats of insulating rubber or other suitable floor insulation, shall be provided for the operator where the voltage to ground exceeds 150.

**250-124. Cases of Instruments, Meters and Relays—Operating Voltage Over 750.** Where instruments, meters and relays have current-carrying parts over 750 volts to ground, they shall be isolated by elevation or protected by suitable barriers, grounded metal or insulating covers or guards. Their cases shall not be grounded, except as follows:

(a) In electrostatic ground detectors the internal ground segments of the instrument are connected to the instrument case and grounded; the ground detector shall be isolated by elevation.

**250-125. Instrument Grounding Conductor.** The grounding conductor for secondary circuits of instrument transformers and for instrument cases shall not be smaller than No. 12 where of copper, or where of other metal shall have equal conductance. Cases of instrument transformers, instruments, meters and relays which are mounted directly on grounded metal surfaces of enclosures or grounded metal switchboard panels shall be considered to be grounded and no additional grounding conductor will be required.

### M. Lightning Arresters

**250-131. Services of 750 Volts or Less.** Where a lightning arrester is installed on a service of 750 volts or less, the connecting conductors shall be as short and straight as practicable and of copper not smaller than No. 14 or of equivalent corrosion-resistant material. Bends, especially sharp bends, shall be avoided where practicable. The arrester grounding conductor shall be connected to one of the following:

- (a) The grounded service conductor.
- (b) The grounding electrode conductor.
- (c) The grounding electrode for the service.

**250-132. On Primary Circuits.** The grounding conductor of a lightning arrester protecting a transformer which supplies a secondary distribution system may be interconnected as follows:

(a) **Metallic Interconnection.** A metallic interconnection may be made to the secondary neutral provided that, in addition to the direct grounding connection at the arrester:

(1) The grounded conductor of the secondary has elsewhere a grounding connection to a continuous metallic underground water piping system. However, in urban water-pipe areas where there are at least 4 water-pipe connections on the neutral and not less than 4 such connections in each mile of neutral, the metallic interconnection may be made to the secondary neutral with omission of the direct grounding connection at the arrester.

(2) The grounded conductor of the secondary system is part of a multigrounded neutral system, of which the primary neutral has at least 4 ground connections in each mile of line in addition to a ground at each service.

**(b) Through Spark Gap.** Where the secondary is not grounded as in Section 250-132(a), but is otherwise grounded as in Sections 250-82 and 250-83, such interconnection, where made, shall be through a spark gap having a 60-hertz breakdown voltage of at least twice the primary circuit voltage but not necessarily more than 10 kV, and there shall be at least one other ground on the grounded conductor of the secondary not less than 20 feet distant from the lightning arrester grounding electrode.

**(c) By Special Permission.** Except as above provided, interconnection of the arrester ground and the secondary neutral may be made only by special permission.

## ARTICLE 280 — LIGHTNING ARRESTERS

### A. Industrial Stations

**280-1. Where Required.** Lightning arresters shall be provided in industrial stations in locations where thunderstorms are frequent and adequate protection against lightning is not otherwise provided.

For lightning arresters in hazardous locations, see Articles 500 through 517.

**280-2. Number Required.** A lightning arrester shall be connected to each ungrounded overhead conductor entering or leaving the station, except that where there is more than one circuit, a single set of arresters may be installed on the station bus where means are provided to protect circuits that may remain disconnected from the bus.

**280-3. Where Connected.** The arrester shall be connected on the line side of all connected station apparatus.

### B. Other Occupancies

**280-11. Utilization Equipment.** Lightning arresters installed for the protection of utilization equipment may be installed either inside or outside the building or enclosure containing the equipment to be protected. Arresters, unless isolated by elevation or made otherwise inaccessible to unqualified persons, shall be enclosed, and where the operating voltage of the circuit exceeds 750 volts between conductors they shall be inaccessible to unqualified persons.

Secondary lightning protection devices may reduce damage to wiring and equipment caused by lightning disturbances. (See Section 502-3.)

### C. General

**280-21. Location—Indoors.** Arresters installed indoors shall be located well away from other equipment, passageways and combustible parts of buildings, and where containing oil shall be separated from other equipment by walls meeting the requirements of Section 450-42.

**280-22. Location—Outdoors.** Where arresters containing oil are located outdoors, provision shall be made to drain away any accumulation of oil.

Oil may be drained away by ditches and drains or the oil may be absorbed and danger of spreading removed by paving the yard with cinders or other absorbent material to a depth of several inches.

**280-23. Connectors—Size and Material.** The connections between the arrester and the line wire or bus, and between arrester and ground shall be of copper wire or cable or the equivalent, and, except as provided on secondary services in Section 250-131, shall not be smaller than No. 6, and shall be made as short and as straight as practicable, avoiding as far as possible all bends and turns, especially sharp bends.

**280-24. Insulation.** Lightning-protection accessories such as gap electrodes, and choke coils where used, shall have an insulation from ground or from other conductors at least equal to the insulation required at other points of the circuit.

**280-25. Switch for Isolating Arrester.** Where isolating switches or disconnecting devices are used, they shall withstand, in full open position, a voltage test between live parts 10 percent in excess of the maximum voltage test they will withstand to ground.

**280-26. Grounding.** Lightning arresters shall be grounded in the manner prescribed in Article 250, except that grounding conductors shall not be run in metallic enclosures unless bonded to both ends of such enclosures.

## **Chapter 3. Wiring Methods and Materials**

### **ARTICLE 300 — WIRING METHODS — GENERAL REQUIREMENTS**

#### **300-1. Scope.**

(a) The provisions of this Article shall apply to all wiring installations, except for remote-control, including low-voltage relay switching, low-energy power and signal systems as provided in Article 725, and communication systems as provided in Article 800.

(b) The provisions of this Article are not intended to apply to the conductors which form an integral part of equipment, such as motors, motor controllers and the like.

**300-2. Voltage Limitations.** Wiring methods specified in Chapter 3 may be used for voltages not exceeding 600, unless specifically limited in some Article of Chapter 3. They may be used for voltages over 600 where specifically permitted elsewhere in this code.

#### **300-3. Conductors of Different Systems.**

(a) Conductors of light and power systems of 600 volts or less may occupy the same enclosure, without regard to whether the individual circuits are alternating-current or direct-current, only where all conductors are insulated for the maximum voltage of any conductor within the enclosure.

(b) Conductors of light and power systems of over 600 volts shall not occupy the same enclosure with conductors of light and power systems of 600 volts or less.

(c) Secondary wiring to electric-discharge lamps of 1,000 volts or less, insulated for the secondary voltage involved, may occupy the same fixture enclosure as the branch-circuit conductors.

(d) Primary leads of electric-discharge lamp ballasts, insulated for the primary voltage of the ballast, when contained within the individual wiring enclosure may occupy the same fixture enclosure as the branch-circuit conductors.

(e) Excitation, control, relay and ammeter conductors used in connection with any individual motor or starter may occupy the same enclosure as the motor-circuit conductors.

(f) Conductors of signal or radio systems shall not occupy the same enclosure with conductors of light or power systems except as permitted for elevators in Section 620-36; for sound recording in Section 640-6; for remote-control, low-energy power and signal circuits in Sections 725-16 and 725-42; and communication system in Sections 800-3 and 800-21.

**300-4. Protection Against Physical Damage.** Where subject to physical damage, conductors shall be adequately protected.

**300-5. Protection Against Corrosion.** Metal raceways, cable armor, boxes, cable sheathing, cabinets, metallic elbows, couplings, fittings, supports and support hardware shall be of materials suitable for the environment in which they are to be installed.

(a) Ferrous raceways, cable armor, boxes, cable sheathing, cabinets, metallic elbows, couplings, fittings, supports and support hardware shall be suitably protected against corrosion inside and outside (except threads at joints) by a coating of approved corrosion-resistant material such as zinc, cadmium, or enamel. Where protected from corrosion solely by enamel, they shall not be used out of doors or in wet locations as described in (c) below. When boxes or cabinets have an approved system of organic coatings and are marked "Raintight" or "Outdoor Type" they may be used out of doors.

(b) Unless made of materials judged suitable for the condition, or unless corrosion protection approved for the condition is provided, ferrous or nonferrous metallic raceways, cable armor, boxes, cable sheathing, cabinets, elbows, couplings, fittings, supports and support hardware shall not be installed in concrete or in direct contact with the earth, or in areas subject to severe corrosive influences.

(c) In portions of dairies, laundries, canneries, and other indoor wet locations, and in locations where walls are frequently washed or where there are surfaces of absorbent materials, such as damp paper or wood, the entire wiring system, including all boxes, fittings, conduits and cable used therewith, shall be mounted so that there is at least 1/4-inch air space between it and the wall or supporting surface.

In general, areas where acids and alkali chemicals are handled and stored may present such corrosive conditions, particularly when wet or damp. Severe corrosive conditions may also be present in portions of meat-packing plants, tanneries, glue houses, some stables; installations immediately adjacent to a seashore, swimming pool areas; areas where chemical de-icers are used; and storage cellars or rooms for hides, casings, fertilizer, salt and bulk chemicals.

**300-6. Raceways Exposed to Different Temperatures.**

(a) **Sealing.** Where portions of an interior raceway system are exposed to widely different temperatures, as in refrigerating or cold-storage plants, provision shall be made to prevent circulation of air from a warmer to a colder section through the raceway.

(b) **Expansion Joints.** Expansion joints for runs of raceway shall be provided where required to compensate for thermal expansion and contraction.

**300-7. Underground Runs.** Conductors run underground shall comply with the provisions of Section 230-32 as far as mechanical protection is concerned.

Underground cable run under a building shall be in a raceway that is extended beyond the outside wall of the building.

**300-8. Through Studs, Joists and Rafters.**

(a) Where exposed or concealed wiring conductors in insulating tubes or cables are installed through bored holes in studs, joists or similar



wood members, holes shall be bored at the approximate centers of wood members, or at least 2 inches from the nearest edge where practical.

(b) Where there is no objection because of weakening the building structure, metal-clad or nonmetallic-sheathed cable, aluminum-sheathed cable and mineral-insulated metal-sheathed cable may be laid in notches in the studding or joists when the cable at those points is protected against the driving of nails into it by having the notch covered with a steel plate at least 1/16 inch in thickness before building finish is applied.

**300-9. Grounding Metal Enclosures.** Metal raceways, boxes, cabinets, cable armor and fittings shall be grounded if and as prescribed in Article 250.

**300-10. Electrical Continuity of Metal Raceways and Enclosures.** Metal raceways, cable armor, and other metal enclosures for conductors, shall be metallically joined together into a continuous electrical conductor, and shall be so connected to all boxes, fittings and cabinets as to provide effective electrical continuity. Raceways and cable assemblies shall be mechanically secured to boxes, fittings, cabinets and other enclosures, except as provided for nonmetallic boxes in Section 370-7.

**300-11. Secured in Place.** Raceways, cable assemblies, boxes, cabinets and fittings shall be securely fastened in place, unless otherwise provided for specific purposes elsewhere in this Code.

See Article 318 for Continuous Rigid Cable Supports.

**300-12. Mechanical Continuity — Raceways and Cables.** Raceways and cable assemblies shall be continuous from outlet to outlet and from fitting to fitting.

**300-13. Mechanical and Electrical Continuity — Conductors.** Conductors shall be continuous between outlets, devices, etc., and, except as permitted for auxiliary gutters in Section 374-8, for wireways in Section 362-6, and Section 300-15(a), there shall be no splice or tap within a raceway itself.

In multiwire circuits the continuity of an identified grounded conductor shall not be dependent upon device connections, such as lamp-holders, receptacles, etc., where the removal of such devices would interrupt the continuity.

**300-14. Free Length of Conductors at Outlets and Switch Points.** At least 6 inches of free conductor shall be left at each outlet and switch point for the making up of joints or the connection of fixtures or devices, except where conductors are intended to loop without joints through lampholders, receptacles and similar devices.

**300-15. Boxes or Fittings Where Required.**

(a) **Box or Fitting.** A box or fitting shall be installed at each conductor splice connection point, outlet, switch point, junction point or pull point for the connection of conduit, electrical metallic tubing, surface raceways or other raceways.

*Exception No. 1: A box or fitting is not required for a conductor splice connection in surface raceways, wireways, header ducts, multi-*

*outlet assemblies and auxiliary gutters having a removable cover which is accessible after installation.*

*Exception No. 2: As permitted in Section 410-26.*

**(b) Box Only.** A box shall be installed at each conductor splice connection point, outlet, switch point, junction point, or pull point for the connection of metal-clad cable, mineral-insulated metal-sheathed cable, aluminum-sheathed cable, nonmetallic-sheathed cable, or other cables and at each outlet and switch point for concealed knob-and-tube wiring.

*Exception No. 1: As permitted by Section 336-11 for insulated outlet devices supplied by nonmetallic-sheathed cable.*

*Exception No. 2: As permitted by Section 410-60 for rosettes.*

*Exception No. 3: Where accessible fittings approved for the purpose are used for straight-through splices in mineral-insulated metal-sheathed cable.*

### **300-16. Raceway or Cable to Open or Concealed Wiring.**

**(a)** A box or terminal fitting having a separately bushed hole for each conductor shall be used wherever a change is made from conduit, electrical metallic tubing, nonmetallic-sheathed cable, metal-clad cable, aluminum-sheathed cable, or mineral-insulated metal-sheathed cable and surface raceway wiring to open wiring or to concealed knob-and-tube work. A fitting used for this purpose shall contain no taps or splices and shall not be used at fixture outlets.

**(b)** A bushing may be used in lieu of a box or terminal fitting at the end of a conduit or electrical metallic tubing where the raceway terminates behind an open (unenclosed) switchboard or at an unenclosed control and similar equipment. The bushing shall be of the insulating type for other than lead-sheathed conductors.

**300-17. Number of Conductors in Raceway.** In general the percentage of the total interior cross-sectional area of a raceway occupied by conductors shall not be more than will permit a ready installation or withdrawal of the conductors and dissipation of the heat generated without injury to the insulation of the conductors. See the following Sections of this Code: conduit, Section 346-6; electrical metallic tubing, 348-6; flexible metal conduit, 350-3; surface raceways, 352-4 and 352-25; underfloor raceways, 354-5; cellular metal floor raceways, 356-5; structural raceways, 357-6; cellular concrete floor raceways, 358-9; wireways, 362-5; auxiliary gutters, 374-5; fixture wire, 402-7; theaters, 520-5; signs, 600-21(d); elevators, 620-33; and sound recording, 640-3 and 640-4; and remote-control, low-energy power, low-voltage power and signal circuits, Article 725.

### **300-18. Inserting Conductors in Raceways.**

**(a)** Raceways shall first be installed as a complete raceway system without conductors, except those raceways exposed and having a removable cover or capping.

**(b)** As far as possible, conductors shall not be inserted until the interior of the building has been physically protected from the weather, and all mechanical work on the building which is likely to injure the conductors has been completed.

(c) Pull wires, if to be used, shall not be installed until the raceway system is in place.

(d) Cleaning agents or materials used as lubricants that might have a deleterious effect on conductor coverings shall not be used.

### 300-19. Supporting Conductors in Vertical Raceways.

(a) **Spacing Intervals — Maximum.** Conductors in vertical raceways shall be supported. One cable support shall be provided at the top of the vertical raceway or as close to the top as practical, plus a support for each additional interval of spacing as specified in Table 300-19(a).

*Exception: If the total vertical riser is less than 25 percent of the spacing specified in Table 300-19(a), no cable support shall be required.*

**Table 300-19(a). Spacings for Conductor Supports**

				Conductors	
				Aluminum	Copper
No. 18	to No. 8	.....	Not Greater than	100 feet	100 feet
No. 6	to No. 0	.....	" " "	200 feet	100 feet
No. 00	to No. 0000	.....	" " "	180 feet	80 feet
211,601 CM	to 350,000 CM	....	" " "	135 feet	60 feet
350,001 CM	to 500,000 CM	....	" " "	120 feet	50 feet
500,001 CM	to 750,000 CM	....	" " "	95 feet	40 feet
	Above 750,000 CM	....	" " "	85 feet	35 feet

(b) One of the following methods of support, or a method of equal effectiveness is recommended:

(1) By clamping devices constructed of or employing insulating wedges inserted in the ends of the conduits. With cables having varnished-cambric or thermoplastic insulation it may also be necessary to clamp the conductor.

(2) By inserting boxes at the required intervals in which insulating supports are installed and secured in a satisfactory manner to withstand the weight of the conductors attached thereto, the boxes being provided with covers.

(3) In junction boxes, by deflecting the cables not less than 90 degrees and carrying them horizontally to a distance not less than twice the diameter of the cable, the cables being carried on two or more insulating supports, and additionally secured thereto by tie wires if desired. When this method is used cables shall be supported at intervals not greater than 20 percent of those mentioned in the preceding tabulation.

**300-20. Induced Currents in Metal Enclosures.** When conductors carrying alternating current are installed in metal enclosures they shall be so arranged as to avoid heating the surrounding metal by induction. To accomplish this all phase conductors and, where used, the neutral and all equipment grounding conductors shall be grouped together, except as permitted in Section 250-50(b), Exception.

When a single conductor of a circuit passes through metal with magnetic properties the inductive effect shall be minimized by:

(1) Cutting slots in the metal between the individual holes through which the individual conductors pass, or

(2) Passing all the conductors in the circuit through an insulating wall sufficiently large for all of the conductors of the circuit.

*Exception: In the case of circuits supplying vacuum or electric-discharge lighting systems or signs, or X-ray apparatus, the currents carried by the conductors are so small that the inductive heating effect may be ignored where these conductors are placed in metal enclosures or pass through metal.*

Aluminum, being a nonmagnetic metal, there will be no heating due to eddy currents; however, induced currents will be present. These are not considered of sufficient magnitude to require grouping of conductors or special treatment in passing conductors through aluminum wall sections.

**300-21. Prevention of Fire Spread.** Electrical installations shall be so made that:

(1) The fire-protective rating of fire walls and fire-resistant or fire-stopped walls, partitions, ceilings, and floors will be substantially equivalent to its original rating.

(2) The possible spread of fire through hollow spaces, vertical shafts, and ventilating or air-handling ducts will be reduced to a minimum.

**300-22. Wiring in Ducts, Plenums, and Other Air Handling Spaces.**

(a) **Ducts for Dust, Loose Stock or Vapor Removal.** No wiring systems of any type shall be installed in ducts used to transport dust, loose stock, flammable vapors, nor shall any wiring system of any type be installed in any duct, or shaft containing only such ducts, used for vapor removal or ventilation of commercial type cooking equipment.

(b) **Ducts or Plenums Used for Environmental Air.** Wiring systems of mineral-insulated metal-sheathed cable, aluminum-sheathed cable, electrical metallic tubing, or rigid metal conduit may be installed in ducts or plenum chambers used to transport environmental air. Flexible metal conduit may be used, in lengths not to exceed 4 feet, to connect physically adjustable equipment and devices permitted to be in these ducts and plenum chambers. The connectors used with flexible metal conduit shall effectively close any openings in the connection. Equipment and devices may only be installed within such ducts or plenum chambers if necessary for their direct action upon, or sensing of, the contained air. Where equipment or devices are installed and illumination is necessary to facilitate maintenance and repair, enclosed gasketed-type fixtures may be installed.

(c) **Hollow Spaces Used as Ducts or Plenums for Environmental Air.** Hollow spaces which are used as ducts or plenum chambers for environmental air, other than those described in paragraph (b) above, may contain mineral-insulated metal-sheathed cable, aluminum-sheathed cable, electrical metallic tubing, rigid metal conduit, flexible metal conduit, or metal-clad cables, and other electrical equipment that is permitted within the concealed spaces of such structures, provided that the wiring materials, including fixtures, are suitable for the expected ambient temperature to which they will be subjected.

*Exception No. 1: The above provisions shall not apply to integral fan systems specifically approved for the purpose.*

*Exception No. 2: This section does not include habitable rooms or areas of buildings, the prime purpose of which is not air handling.*

NFPA Standard for the Installation of Air Conditioning and Ventilating Systems, No. 90A-1971, sets forth requirements of building used for ducts and plenums.

(d) The wiring systems used for data processing systems and located within air handling areas created by raised floors shall conform to Article 645.

## ARTICLE 305 — TEMPORARY WIRING

**305-1. Scope.** The provisions of this Article are applicable to temporary electrical power and lighting wiring methods which may be of a class less than would be required for a permanent installation. Except as specifically modified in this Article, all other requirements of this Code for permanent wiring shall apply to temporary wiring installations.

(a) Temporary electrical power and lighting installations may be used during the period of construction, remodeling, or demolition of buildings, structures, equipment, or similar activities.

(b) Temporary electrical power and lighting installations may be used for a period not to exceed 90 days for Christmas decorative lighting, carnivals, and similar purposes, and for experimental or development work.

### 305-2. General.

(a) **Services.** Services shall be installed in conformance with Article 230.

(b) **Feeders.** Feeders shall be protected as provided in Article 240. They shall originate in an approved distribution center. The conductors may be contained within multi-conductor cord or cable assemblies or where not subject to mechanical injury, they may be run as open conductors on insulators not more than 10 feet apart.

(c) **Branch Circuits.** All branch circuits shall originate in an approved distribution cabinet or panelboard. Conductors may be contained within multi-conductor cord or cable assemblies or as open wiring. All conductors shall be protected by overcurrent devices at their rated ampacity. When run as open conductors they shall be fastened at ceiling height every 10 feet. No conductor shall be laid on the floor. Each branch circuit which supplies receptacles or fixed equipment shall contain a separate equipment grounding conductor when run as open wiring.

(d) **Receptacles.** All receptacles shall be of the grounding-type. Unless installed in a complete metallic raceway all branch circuits shall contain a separate equipment grounding conductor and all receptacles shall be electrically connected to the grounding conductor.

See Section 210-7 for receptacles installed on construction sites.

(e) **Earth Returns.** No bare conductors nor earth returns shall be used for the wiring of any temporary circuit.

(f) **Disconnecting Means.** Suitable disconnecting switches or plug connectors shall be installed to permit the disconnection of all ungrounded conductors of each temporary circuit.

**305-3. Grounding.** All grounding shall conform with Article 250.

## ARTICLE 310 — CONDUCTORS FOR GENERAL WIRING

### 310-1. General.

(a) The purpose of this Article is to assure that conductors have mechanical strength, insulation, and ampacity adequate for the particular conditions under which they are to be used.

(b) Conductors shall be insulated, except when covered or bare conductors are specifically permitted in this Code.

(c) The provisions of this Article are not intended to apply to conductors which form an integral part of equipment such as motors, motor controllers, and the like, or which are provided for elsewhere in this Code.

### 310-2. Application and Construction.

(a) **Conductor Application.** Conductor insulations as specified in the following Table 310-2(a) may be installed for any of the wiring methods recognized in this Chapter, except as otherwise provided for in the Table or in Section 310-3, or as otherwise specified in this Code. They are suitable for 600 volts unless otherwise specified.

(b) **Conductor Construction.** Insulated conductors for use at 600 volts or less shall conform to the provisions of Table 310-2(b).

(c) **Identified Conductors.** Insulated conductors of No. 6 or smaller, intended for use as identified conductors of circuits shall have an outer identification of a white or natural gray color. Multiple-conductor flat cable No. 4 AWG or larger may employ an external ridge on the identified conductor.

*Exception No. 1: Multiple-conductor varnished-cloth-insulated cables.*

*Exception No. 2: Fixture wires as outlined below.*

*Exception No. 3: Mineral-insulated metal-sheathed cable.*

*Exception No. 4: A conductor identified as required by Section 210-5.*

For fixture wires the identification shall be as above, or by means of (1) stripes, or (2) by the means described in Sections 400-13 (a), (b), (c), (d) and (e).

For aerial cable the identification shall be as above, or by means of a ridge so located on the exterior of the cable as to identify it.

Wires having their outer covering finished to show a white or natural gray color but having colored tracer threads in the braid, identifying the source of manufacture, are considered as meeting the provisions of this Section.

(310-2 continued on page 107)

Table 310-2(a). Conductor Application

Trade Name	Type Letter	Max. Operating Temp.	Application Provisions
Rubber-Covered Fixture Wire Solid or 7-Strand	*RF-1	60°C 140°F	Fixture wiring. Limited to 300 volts.
	*RF-2	60°C 140°F	Fixture wiring, and as permitted in Section 725-14.
Rubbered-Covered Fixture Wire Flexible Stranding	*FF-1	60°C 140°F	Fixture wiring. Limited to 300 volts.
	*FF-2	60°C 140°F	Fixture wiring, and as permitted in Section 725-14.
Heat-Resistant Rubber-Covered Fixture Wire Solid or 7-Strand	*RFH-1	75°C 167°F	Fixture wiring. Limited to 300 volts.
	*RFH-2	75°C 167°F	Fixture wiring, and as permitted in Section 725-14.
Heat-Resistant Rubber-Covered Fixture Wire Flexible Stranding	*FFH-1	75°C 167°F	Fixture wiring. Limited to 300 volts.
	*FFH-2	75°C 167°F	Fixture wiring, and as permitted in Section 725-14.
Thermoplastic-Covered Fixture Wire—Solid or Stranded	*TF	60°C 140°F	Fixture wiring, and as permitted in Section 725-14.
Thermoplastic-Covered Fixture Wire—Flexible Stranding	*TFF	60°C 140°F	Fixture wiring, and as permitted in Section 725-14.
Heat Resistant, Thermoplastic—Covered Fixture Wire—Solid or Stranded	*TFN	90°C	Fixture wiring, and as permitted in Section 725-14.
Heat Resistant Thermoplastic—Covered Fixture Wire—Flexible Stranding	*TFFN	90°C	Fixture wiring, and as permitted in Section 725-14.
Cotton-Covered, Heat-Resistant, Fixture Wire	*CF	90°C 194°F	Fixture wiring. Limited to 300 volts.

\* Fixture wires are not intended for installation as branch-circuit conductors except as permitted in Section 725-14.

**Table 310-2(a)—Continued**

Trade Name	Type Letter	Max. Operating Temp.	Application Provisions
Asbestos-Covered Heat-Resistant, Fixture Wire	*AF	150°C 302°F	Fixture wiring. Limited to 300 volts. and Indoor Dry Location.
Fluorinated Ethylene Propylene Fixture Wire Solid or 7 Strand	*PF *PGF	200°C 392°F	Fixture Wiring and as permitted in Section 725-14.
Fluorinated Ethylene Propylene Fixture Wire	*PFF *PGFF	150°C 302°F	Fixture Wiring and as permitted in Section 725-14.
Extruded Polytetrafluoroethylene (PTFE) Solid or 7-Strand	*PTF	250°C 482°F	Fixture wire, and as permitted in Section 725-14. (Nickel or nickel-coated copper)
Extruded Polytetrafluoroethylene (PTFE) Flexible Stranding (#26-#36 AWG)	*PTFF	150°C 302°F	Fixture wire, and as permitted in Section 725-14. (Silver or nickel-coated copper)
Silicone Rubber Insulated Fixture Wire	*SF-1	200°C 392°F	Fixture wiring. Limited to 300 volts.
Solid or 7 Strand	*SF-2	200°C 392°F	Fixture wiring and as permitted in Section 725-14.
Silicone Rubber Insulated Fixture Wire	*SFF-1	150°C 302°F	Fixture wiring. Limited to 300 volts.
Flexible Stranding	*SFF-2	150°C 302°F	Fixture wiring and as permitted in Section 725-14.
Heat-Resistant Rubber	RH	75°C 167°F	Dry locations.
Heat-Resistant Rubber	RHH	90°C 194°F	Dry locations.

\* Fixture wires are not intended for installation as branch-circuit conductors except as permitted in Section 725-14.



Table 310-2(a)—Continued

Trade Name	Type Letter	Max. Operating Temp.	Application Provisions
Moisture and Heat-Resistant Rubber	RHW	75°C 167°F	Dry and wet locations. For over 2,000 volts, insulation shall be ozone-resistant.
Heat-Resistant Latex Rubber	RUH	75°C	Dry locations.
Moisture Resistant Latex Rubber	RUW	60°C 140°F	Dry and wet locations.
Thermoplastic	T	60°C 140°F	Dry locations.
Moisture-Resistant Thermoplastic	TW	60°C 140°F	Dry and wet locations.
Heat-Resistant Thermoplastic	THHN	90°C 194°F	Dry locations.
Moisture and Heat-Resistant Thermoplastic	THW	75°C 167°F  90°C 194°F	Dry and wet locations.  Special applications <i>within</i> electric discharge lighting equipment. Limited to 1000 open-circuit volts or less. (Size 14-8 only as permitted in Section 410-26.)
Moisture and Heat-Resistant Thermoplastic	THWN	75°C 167°F	Dry and wet locations.
Moisture and Heat-Resistant Cross-Linked Synthetic Polymer	XHHW	90°C 194°F  75°C 167°F	Dry locations.  Wet locations.
Moisture-, Heat- and Oil-Resistant Thermoplastic	MTW	60°C 140°F  90°C 194°F	Machine Tool Wiring in wet locations as permitted in NFPA Standard No. 79 (See Article 670).  Machine Tool Wiring in dry locations as permitted in NFPA Standard No. 79 (See Article 670).
Thermoplastic and Asbestos	TA	90°C 194°F	Switchboard wiring only.

Table 310-2(a)—Continued

Trade Name	Type Letter	Max. Operating Temp.	Application Provisions
Thermoplastic and Fibrous Outer Braid	TBS	90°C 194°F	Switchboard wiring only.
Synthetic Heat-Resistant	SIS	90°C 194°F	Switchboard wiring only.
Mineral Insulation (Metal Sheathed)	MI	85°C 185°F  250°C 482°F	Dry and wet locations.  For special application.
Extruded Polytetrafluoroethylene	TFE	250°C 482°F	Dry locations only. Only for leads within apparatus or within raceways connected to apparatus, or as open wiring. (Nickel or nickel-coated copper only.)
Silicone-Asbestos	SA	90°C 194°F  125°C 257°F	Dry locations.  For special application.
Fluorinated Ethylene Propylene	FEP or FEPB	90°C 194°F 200°C 392°F	Dry locations.  Dry locations—special applications.
Varnished Cambric	V	85°C 185°F	Dry locations only. Smaller than No. 6 by special permission.
Asbestos and Varnished Cambric	AVA	110°C 230°F	Dry locations only.
Asbestos and Varnished Cambric	AVL	110°C 230°F	Dry and wet locations.
Asbestos and Varnished Cambric	AVB	90°C 194°F	Dry locations only.
Asbestos	A	200°C 392°F	Dry locations only. Only for leads within apparatus or within raceways connected to apparatus. Limited to 300 volts.

**Table 310-2(a)—Continued**

<b>Trade Name</b>	<b>Type Letter</b>	<b>Max. Operating Temp.</b>	<b>Application Provisions</b>
Asbestos	AA	200°C 392°F	Dry locations only. Only for leads within apparatus or within raceways connected to apparatus or as open wiring. Limited to 300 volts.
Asbestos	AI	125°C 257°F	Dry locations only. Only for leads within apparatus or within raceways connected to apparatus. Limited to 300 volts.
Asbestos	AIA	125°C 257°F	Dry locations only. Only for leads within apparatus or within raceways connected to apparatus or as open wiring.
Paper		85°C 185°F	For underground service conductors, or by special permission.

**Table 310-2(b). Conductor Insulations**

Trade Name	Type Letter	Insulation	Thickness of Insulation	Outer Covering
Heat-Resistant	RH RHH	Heat-Resistant Rubber	**14-12 ..... 30 Mils 10 ..... 45 Mils 8-2 ..... 60 Mils 1-4/0 ..... 80 Mils 213-500 ..... 95 Mils 501-1000 ..... 110 Mils 1001-2000 ..... 125 Mils	*Moisture-resistant, flame-retardant, non-metallic covering
Moisture and Heat-Resistant	RHW	Moisture and Heat Resistant Rubber	14-10 ..... 45 Mils 8-2 ..... 60 Mils 1-4/0 ..... 80 Mils 213-500 ..... 95 Mils 501-1000 ..... 110 Mils 1001-2000 ..... 125 Mils	*Moisture-resistant, flame-retardant, non-metallic covering
Heat-Resistant Latex Rubber	RUH	90% Unmilled, Grainless Rubber	14-10 ..... 18 Mils 8-2 ..... 25 Mils	Moisture-resistant, flame-retardant, non-metallic covering
Moisture-Resistant Latex Rubber	RUW	90% Unmilled, Grainless Rubber	14-10 ..... 18 Mils 8-2 ..... 25 Mils	Moisture-resistant, flame-retardant, non-metallic covering
Thermo-plastic	T	Flame-Retardant, Thermo-plastic Compound	14-10 ..... 30 Mils 8 ..... 45 Mils 6-2 ..... 60 Mils 1-4/0 ..... 80 Mils 213-500 ..... 95 Mils 501-1000 ..... 110 Mils 1001-2000 ..... 125 Mils	None
Moisture-Resistant Thermo-plastic	TW	Flame-Retardant, Moisture-Resistant Thermo-plastic	14-10 ..... 30 Mils 8 ..... 45 Mils 6-2 ..... 60 Mils 1-4/0 ..... 80 Mils 213-500 ..... 95 Mils 501-1000 ..... 110 Mils 1001-2000 ..... 125 Mils	None

\* Outer covering is not required over rubber insulations which have been specifically approved for the purpose.

\*\* For 14-12 sizes RHH shall be 45 mils thickness insulation.

For insulated aluminum and copper-clad aluminum conductors, the minimum size is No. 12 AWG. See Tables 310-14 and 310-15.

Table 310-2(b)—Continued

Trade Name	Type Letter	Insulation	Thickness of Insulation		Outer Covering
Heat-Resistant Thermo-plastic	THHN	Flame-Retardant Heat Resistant Thermo-plastic	14-12 ..... 15 Mils 10 ..... 20 Mils 8-6 ..... 30 Mils 4-2 ..... 40 Mils 1-4/0 ..... 50 Mils 250-500 MCM ..... 60 Mils 501-1000 MCM ..... 70 Mils		Nylon Jacket
Moisture and Heat-Resistant Thermo-plastic	THW	Flame-Retardant, Moisture and Heat-Resistant Thermo-plastic	14-10 ..... 45 Mils 8-2 ..... 60 Mils 1-4/0 ..... 80 Mils 213-500 ..... 95 Mils 501-1000 ..... 110 Mils 1001-2000 ..... 125 Mils		None
Moisture and Heat-Resistant Thermo-plastic	THWN	Flame-Retardant, Moisture and Heat-Resistant Thermo-plastic	14-12 ..... 15 Mils 10 ..... 20 Mils 8-6 ..... 30 Mils 4-2 ..... 40 Mils 1-4/0 ..... 50 Mils 250-500 MCM ..... 60 Mils 501-1000 MCM ..... 70 Mils		Nylon Jacket
Moisture and Heat-Resistant Cross-Linked Synthetic Polymer	XHHW	Flame-Retardant Cross-Linked Synthetic Polymer	14-10 ..... 30 Mils 8-2 ..... 45 Mils 1-4/0 ..... 55 Mils 213-500 ..... 65 Mils 501-1000 ..... 80 Mils 1001-2000 ..... 95 Mils		None
Moisture-, Heat- and Oil-Resistant Thermo-plastic	MTW	Flame-Retardant, Moisture-, Heat- and Oil-Resistant Thermo-plastic	<div>(A) (B)</div> 22-12 ..... 30 Mils 15 Mils 10 ..... 30 Mils 20 Mils 8 ..... 45 Mils 30 Mils 6 ..... 60 Mils 30 Mils 4-2 ..... 60 Mils 40 Mils 1-4/0 ..... 80 Mils 50 Mils 213-500MCM 95 Mils 60 Mils 501-1000MCM 110 Mils 70 Mils		(A) None (B) Nylon jacket
Extruded Polytetra-fluoroethylene	TFE	Extruded Polytetra-fluoro-ethylene	14-10 ..... 20 Mils 8-2 ..... 30 Mils 1-4/0 ..... 45 Mils		None
Thermo-plastic and Asbestos	TA	Thermo-plastic and Asbestos	Th'pl'. Asb. 14-8 ..... 20 Mils 20 Mils 6-2 ..... 30 Mils 25 Mils 1-4/0 ..... 40 Mils 30 Mils		Flame-retardant, nonmetallic covering

For insulated aluminum and copper-clad aluminum conductors, the minimum size is No. 12 AWG. See Tables 310-14 and 310-15.

Table 310-2(b)—Continued

Trade Name	Type Letter	Insulation	Thickness of Insulation	Outer Covering
Thermo-plastic and Fibrous Braid	TBS	Thermo-plastic	14-10 ..... 30 Mils 8 ..... 45 Mils 6-2 ..... 60 Mils 1-4/0 ..... 80 Mils	Flame-retardant, nonmetallic covering
Synthetic Heat-Resistant	SIS	Heat-Resistant Rubber	14-10 ..... 30 Mils 8 ..... 45 Mils 6-2 ..... 60 Mils 1-4/0 ..... 80 Mils	None
Mineral-Insulated Metal-Sheathed	MI	Magnesium Oxide	16-4 ..... 50 Mils 3-250 MCM ..... 55 Mils	Copper
Silicone-Asbestos	SA	Silicone Rubber	14-10 ..... 45 Mils 8-2 ..... 60 Mils 1-4/0 ..... 80 Mils 213-500 ..... 95 Mils 501-1000 ..... 110 Mils 1001-2000 ..... 125 Mils	Asbestos or glass
Fluorinated Ethylene Propylene	FEP	Fluorinated Ethylene Propylene	14-10 ..... 20 Mils 8-2 ..... 30 Mils	None
	FEPB	Fluorinated Ethylene Propylene	14-8 ..... 14 Mils 6-2 ..... 14 Mils	Glass braid Asbestos braid
Varnished Cambric	V	Varnished Cambric	14-8 ..... 45 Mils 6-2 ..... 60 Mils 1-4/0 ..... 80 Mils 213-500 ..... 95 Mils 500-1000 ..... 110 Mils 1001-2000 ..... 125 Mils	Nonmetallic covering or lead-sheath
Asbestos and Varnished Cambric	AVA and AVL	Impregnated Asbestos and Varnished Cambric	(Dimen. in Mils) 1st 2nd Asb. VC Asb. Asb. 14-8 (solid only) .. — 30 20 25 14-8 ..... 10 30 15 25 6-2 ..... 15 30 20 25 1-4/0 .... 20 30 30 30 213-500 .. 25 40 40 40 501-1000 . 30 40 40 40 1001-2000 30 50 50 50	AVA-asbestos braid or glass AVL-lead sheath

For insulated aluminum and copper-clad aluminum conductors, the minimum size is No. 12 AWG. See Tables 310-14 and 310-15.

Table 310-2(b)—Continued

Trade Name	Type Letter	Insulation	Thickness of Insulation				Outer Covering		
Asbestos and Varnished Cambric	AVB	Impregnated Asbestos and Varnished Cambric	Mils				Flame-retardant, cotton braid (switchboard wiring)		
			VC		Asb.				
			18-8	.....	30	20			
			6-2	.....	40	30			
			1-4/0	.....	40	40	Flame-retardant, cotton braid		
			Mils						
			Asb.		VC			2nd Asb.	
			14-8	.....	10	30		15	
			6-2	.....	15	30		20	
			1-4/0	.....	20	30		30	
213-500	...	25	40	40					
501-1000	..	30	40	40					
1001-2000	..	30	50	50					
Asbestos	A	Asbestos	14	.....	30	Mils	Without asbestos braid		
12-8	.....	40	Mils						
Asbestos	AA	Asbestos	14	.....	30	Mils	With asbestos braid or glass		
12-8	.....	30	Mils						
6-2	.....	40	Mils						
1-4/0	.....	60	Mils						
Asbestos	AI	Impregnated Asbestos	14	.....	30	Mils	Without asbestos braid		
12-8	.....	40	Mils						
Asbestos	AIA	Impregnated Asbestos	Sol.		Str.		With asbestos braid or glass		
			14	.....	30	Mils		30	Mils
			12-8	.....	30	Mils		40	Mils
			6-2	.....	40	Mils		60	Mils
			1-4/0	.....	60	Mils		75	Mils
			213-500	.....	90	Mils			
			501-1000	.....	105	Mils			
Paper		Paper					Lead sheath		

The nonmetallic covering over individual rubber-covered conductors of aluminum-sheathed cable and of lead-sheathed or multiple-conductor cable is not required to be flame retardant. For metal-clad cable, see Section 334-4. For nonmetallic-sheathed cable, see Section 336-2. For Type UF cable, see Section 339-1. For aluminum-sheathed cable, see Section 331-9.

For insulated aluminum and copper-clad aluminum conductors, the minimum size is No. 12 AWG. See Tables 310-14 and 310-15.

(310-2 continued from page 98)

**(d) Unidentified Conductors.** Single conductors, intended for use as unidentified conductors, and conductors other than the identified conductor in multi-conductor cables, shall be finished to show a color or combination of colors other than, and contrasting with, white or natural

gray. The colors contrasting with white or natural gray, may be provided by means of an approved stripe or stripes on black conductors. For identification requirements for conductors larger than No. 6 see Section 200-6(b).

**(e) Insulation Thickness—Over 600 Volts.** The thickness of insulation for conductors for use at over 600 volts shall conform to Tables 310-2(e)(1) thru (e)(4):

**310-3. Insulating Materials.** The rubber insulations include those made from natural and synthetic rubber, neoprene and other vulcanizable materials.

Thermoplastic insulation may stiffen at temperatures colder than minus 10°C (plus 14°F) requiring care to be exercised during installation at such temperatures. Thermoplastic insulation may also be deformed at normal temperatures where subjected to pressure, requiring care to be exercised during installation and at points of support.

**310-4. Temperature Limitations.** No conductor shall be used under such conditions that its temperature, even when carrying current, will exceed the temperature specified in Table 310-2(a) for the type of insulation involved.

**310-5 Wet Locations.** Insulated conductors used underground, in concrete slabs or other masonry in direct contact with earth, in wet locations, or where condensation or accumulation of moisture within the raceway is likely to occur, shall be moisture- and heat-resistant, rubber-covered (Type RHW); moisture-resistant latex rubber (Type RUW); moisture-resistant, thermoplastic-covered (Type TW); moisture- and heat-resistant, thermoplastic-covered (Type THW); moisture- and heat-resistant thermoplastic (Type THWN); moisture- and heat-resistant cross-linked synthetic polymer (Type XHHW); lead-covered; aluminum-sheathed cable (Type ALS); mineral-insulated metal-sheathed; or of a type approved for the purpose.

Such conductors are not suitable for direct burial in the earth unless of a type specifically approved for the purpose.

**310-6. Buried Conductors.** Cables of one or more conductors for direct burial in the earth shall be of a type approved for the purpose and use, such as Types USE and UF. Where single conductor cables are installed, all conductors of each service, feeder, sub-feeder or branch circuit, including the neutral conductor, shall be run continuously in the same trench or raceway. Supplementary mechanical protection, such as a covering board, concrete pad, raceway, etc., may be required by the authority having jurisdiction. See Section 339-3(c).

**310-7. Corrosive Conditions.** Conductors exposed to oils, greases, vapors, gases, fumes, liquids or other substances having a deleterious effect upon the conductor or insulation shall be of a type approved for the purpose.

**310-8. Minimum Size of Conductors.** Conductors, whether solid or stranded, shall not be smaller than No. 14, except for printing press control circuits; as provided for flexible cords in Section 400-7; for fixture wire in Section 410-18; for fractional horsepower motors in Sec-

*(Continued on page 111)*



**Table 310-2(e) (1)**  
**Thickness of Insulation for**  
**Rubber-Covered Wire and Cable, in Mils**

Conductor Size AWG-MCM	RHW, RHH, 2000 Volts Unshielded		RHW, RHH, 5000 Volts† Unshielded* or Shielded	
	A	B	A	B
14-10**	80	60	Not Permitted	
8	80	70	155	90
6-2	95	70	155	90
1-2/0	110	90	155	90
3/0-4/0	110	90	155	90
213-500	125	105	170	90
501-1000	140	120	170	90

Column A insulations are limited to natural, SBR and butyl rubbers.

Column B insulations are those specifically approved for the purpose such as cross-linked polyethylene and ethylene-propylene rubber.

\* Limited to multi-conductor cables with common overall covering, such as a jacket, sheath, or armor.

\*\* No. 12 AWG is the minimum conductor size for aluminum.

† Shall be of approved ozone-resistant type for operation at voltages over 2000.

**Table 310-2(e) (2)**  
**Thickness of Varnished-Cambric Insulation for**  
**Single-Conductor Cable, in Mils**

Conductor Size AWG or MCM	For Voltages Not Exceeding				
	1000	2000	3000	4000	5000
14	60	..	..	..	..
12	60	80	..	..	..
10	60	80	95	..	..
8-2	60	80	95	110	140
1-4/0	80	95	95	110	140
213-500	95	95	110	125	155
501-1000	110	110	110	125	155
1001-2000	125	125	125	140	155

**Table 310-2(e) (3)**

**Thickness of Varnished-Cambric Insulation for Multiple-Conductor Cable, in Mils**

Conductor Size AWG or MCM	For Voltages Not Exceeding									
	1000		2000		3000		4000		5000	
	C	B	C	B	C	B	C	B	C	B
14	60	0	..	..	..	..	..	..	..	..
12	60	0	80	0	..	..	..	..	..	..
10	60	0	80	0	80	30	..	..	..	..
8-2	60	0	80	0	80	30	95	45	95	60
1-4/0	80	0	95	0	95	30	95	45	95	60
213-500	95	0	95	0	95	30	95	45	110	60
501-1000	95	30	95	30	95	45	95	60	110	60
1001-2000	110	30	110	30	110	45	110	60	110	80

The thickness given in columns headed "C" are for the insulation on the individual conductors. Those given in the columns headed "B" are for the thickness of the over-all belt of insulation.

**Table 310-2(e) (4)**

**Thickness of Asbestos and Varnished-Cambric Insulation for Single-Conductor Cable, Types AVA, AVB and AVL, in Mils**

Conductor AWG or MCM	1st Wall Asbestos	Varnished Cambric					Asbestos 2nd Wall
	For Voltages Not Exceeding						
	1000-5000	1000	2000	3000	4000	5000	1000-5000
14-2	15	45	60	80	100	120	25
1-4/0	20	45	60	80	100	120	30
213-500	25	45	60	80	100	120	40
501-1000	30	45	60	80	100	120	40
1001-2000	30	55	75	95	115	140	50

(Continued from page 108)

tion 430-22; for cranes and hoists in Section 610-14; for elevator control and signal circuits in Section 620-12; and for remote-control, low energy power, low-voltage power and signal circuits in Section 725-13.

**310-9. Stranded Conductors.** Except when used as bus-bars or in mineral-insulated metal-sheathed cable, conductors No. 6 and larger, installed in raceways, shall be stranded. This requirement shall be changed to No. 8 and larger effective January 1, 1973.

**310-10. Conductors in Parallel.** Aluminum, copper-clad aluminum, or copper conductors of size 1/0 and larger, comprising each phase or neutral, may be connected in parallel (electrically joined at both ends to form a single conductor) only if all of the following conditions are met: All of the parallel conductors shall be of the same length, of the same conductor material, circular-mil area, same insulation type and terminated in the same manner. Where run in separate raceways or cables, the raceways or cables shall have the same physical characteristics.

When metallic equipment grounding conductors are used with conductors in parallel, they shall comply with the requirements of this Section except that they shall be sized as per Section 250-95.

When conductors are used in parallel, space in enclosures should be given consideration.

**310-11. Ampacity Reduction Factors.** Where more than 3 conductors are installed in a raceway or assembled into one or more cables the ampacity of each conductor shall be reduced in accordance with Note 8 to Tables 310-12 through 310-15.

**310-12. Marking.**

(a) **Required Information.** All conductors and cables shall be marked to indicate the following information using the applicable method described in Section 310-12(b).

(1) The maximum working voltage for which the conductor was tested or approved.

(2) The proper type letter or letters for the type of wire or cable as specified elsewhere in this Article, in Tables 310-2(a) and 310-2(b) and in Articles 336, 337, 338, and 339.

(3) The manufacturer's name, trademark or other distinctive marking by which the organization responsible for the product may be readily identified.

(4) The AWG size or circular-mil area.

**(b) Method of Marking**

(1) **Surface Marking.** The following conductors and cables shall be durably marked on the surface at intervals not exceeding 24 inches:

- a. Single- and multi-conductor rubber- and thermoplastic-insulated wire.
- b. Nonmetallic-sheathed cable.
- c. Service-entrance cable.

(310-12(b-1) continued)

- d. Underground feeder and branch-circuit cable.
- e. Thermoplastic-insulated fixture wire.

**(2) Marker Tape.** Metallic-covered and multi-conductor cables shall employ a marker tape located within the cable and running for its complete length.

*Exception: Mineral-insulated metal-sheathed cable.*

Included in the group of metal-covered cables are: aluminum-sheathed cable, Type ALS (Article 331); metal-clad cable (Article 334) and lead-sheathed cable.

**(3) Tag Marking.** The following conductors and cables shall be marked by means of a printed tag attached to the coil, reel or carton:

- a. Mineral-insulated, metal-sheathed cable.
- b. Fixture wire other than thermoplastic.
- c. Flexible cords.
- d. Switchboard wires.
- e. Metallic-covered single-conductor cables.
- f. Conductors having outer surface of asbestos.

**(c) Suffixes to Designate Number of Conductors.** A type letter or letters used alone shall indicate a single insulated conductor. The following letter suffixes shall indicate the following:

- D — for two insulated conductors laid parallel within an outer nonmetallic covering.
- M — for an assembly of two or more insulated conductors twisted spirally within an outer nonmetallic covering.

**Notes To Tables 310-12 through 310-15.**

**Ampacity.** The maximum, continuous, ampacities of copper conductors are given in Tables 310-12 and 310-13. The ampacities of aluminum and copper-clad aluminum conductors are given in Tables 310-14 and 310-15.

**1. Explanation of Tables.** For explanation of Type Letters, and for recognized size of conductors for the various conductor insulations, see Sections 310-2 and 310-3. For installation requirements, see Section 310-1 through 310-7, and the various Articles of this Code. For flexible cords see Tables 400-9(b) and 400-11.

**2. Application of Tables.** For open wiring on insulators and for concealed knob-and-tube work, the allowable ampacities of Tables 310-13 and 310-15 shall be used. For all other recognized wiring methods, the allowable ampacities of Tables 310-12 and 310-14 shall be used, unless otherwise provided in this Code.

**3. Aluminum and Copper-Clad Aluminum Conductors.** For aluminum and copper-clad aluminum conductors the allowable ampacities shall be in accordance with Tables 310-14 and 310-15.

**4. Bare Conductors.** Where bare conductors are used with insulated conductors, their allowable ampacities shall be limited to that permitted for the insulated conductors of the same size.

**5. Mineral-Insulated, Metal-Sheathed Cable.** The temperature limitation on which the ampacities of mineral-insulated, metal-sheathed cable are based, is determined by the insulating materials used in the end seal. Termination fittings incorporating unimpregnated, organic, insulating materials are limited to 85°C. operation.

**6. Ultimate Insulation Temperature.** In no case shall conductors be associated together in such a way with respect to the kind of circuit, the wiring method employed, or the number of conductors, that the limiting temperature of the conductors will be exceeded.

**7. Use of Conductors With Higher**

**Operating Temperatures.** Where the room temperature is within 10 degrees C of the maximum allowable operating temperature of the insulation, it is desirable to use an insulation with a higher maximum allowable operating temperature; although insulation can be used in a room temperature approaching its maximum allowable operating temperature limit if the current is reduced in accordance with the Correction Factors for different room temperatures as shown in the Correction Factor Table, Note 13.

**8. More Than 3 Conductors in a Raceway or Cable.** Tables 310-12 and 310-14 give the allowable ampacities for not more than 3 conductors in a raceway or cable. Where the number of conductors in a raceway or cable exceeds 3, the allowable ampacity of each conductor shall be reduced as shown in the following Table:

Number of Conductors	Percent of Values in Tables 310-12 and 310-14
4 to 6	80
7 to 24	70
25 to 42	60
43 and above	50

*Exception No. 1: When conductors of different systems, as provided in Section 300-3, are installed in a common raceway the derating factors shown above apply to the number of power and lighting (Articles 210, 215, 220 and 230) conductors only.*

Where the number of conductors in a raceway or cable exceeds three, or where single conductors or multi-conductor cables are stacked or bundled without maintaining spacing as required in Article 318 and are not installed in raceways, the individual ampacity of each conductor shall be reduced as shown in the above table.

*Exception No. 2: The derating factors of Sections 210-23(b) and 220-2 (second paragraph) do not*

approximately the same current as the other conductors and shall be counted in determining ampacities as provided in Note 8.

Where the major portion of the load consists of electric-discharge lighting there may be harmonic currents present in the neutral conductor which may be equal to the phase currents, thus the neutral could be considered to be a current-carrying conductor.

**11. Voltage Drop.** The allowable ampacities in Tables 310-12 through 310-15 are based on temperature alone and do not take voltage drop into consideration.

**12. Aluminum-Sheathed Cable.** The ampacities of Type ALS cable are determined by the temperature limitation of the insulated conductors incorporated within the cable. Hence the ampacities of aluminum-sheathed cable may be determined from the columns in Tables 310-12 and 310-14 applicable to the type of insulated conductors employed within the cable.

(b) In a 3-wire circuit consisting of two phase wires and the neutral of a 4-wire, 3-phase WYE connected system, a common conductor carries

**Ambient Temps. Over 30°C. 86°F.**

[illegible]

**Table 310-12. Allowable Ampacities of Insulated Copper Conductors**

Not More than Three Conductors in Raceway or Cable or  
Direct Burial (Based on Ambient Temperature of 30° C. 86°F.)

Size	Temperature Rating of Conductor. See Table 310-2(a)							
AWG MCM	60° C (140° F)	75° C (167° F)	85° C (185° F)	90° C (194° F)	110° C (230° F)	125° C (257° F)	200° C (392° F)	250° C (482° F)
	TYPES RUW (14-2), T, TW	TYPES RH, RHW, RUH (14-2), THW, THWN, XHHW	TYPES V, MI	TYPES TA, TBS, SA, AVB, SIS, FEP, FEPB, RHH, THHN, XHHW**	TYPES AVA, AVL	TYPES AI (14-8), AIA	TYPES A (14-8), AA, FEP*, FEPB*	TYPE TFE (Nickel or nickel-coated copper only)
14	15	15	25	25†	30	30	30	40
12	20	20	30	30†	35	40	40	55
10	30	30	40	40†	45	50	55	75
8	40	45	50	50	60	65	70	95
6	55	65	70	70	80	85	95	120
***4	70	85	90	90	105	115	120	145
***3	80	100	105	105	120	130	145	170
***2	95	115	120	120	135	145	165	195
***1	110	130	140	140	160	170	190	220
***0	125	150	155	155	190	200	225	250
***00	145	175	185	185	215	230	250	280
000	165	200	210	210	245	265	285	315
0000	195	230	235	235	275	310	340	370
250	215	255	270	270	315	335	....	....
300	240	285	300	300	345	380	....	....
350	260	310	325	325	390	420	....	....
400	280	335	360	360	420	450	....	....
500	320	380	405	405	470	500	....	....
600	355	420	455	455	525	545	....	....
700	385	460	490	490	560	600	....	....
750	400	475	500	500	580	620	....	....
800	410	490	515	515	600	640	....	....
900	435	520	555	555	....	....	....	....
1000	455	545	585	585	680	730	....	....
1250	495	590	645	645	....	....	....	....
1500	520	625	700	700	785	....	....	....
1750	545	650	735	735	....	....	....	....
2000	560	665	775	775	840	....	....	....

\* Special use only. See Table 310-2(a).

\*\* For dry locations only. See Table 310-2(a).

These ampacities relate only to conductors described in Table 310-2(a).

\*\*\* For 3-wire, single-phase residential services, the allowable ampacity of RH, RHH, RHW, THW and XHHW copper conductors shall be for sizes No. 4-100 Amp., No. 3-110 Amp., No. 2-125 Amp., No. 1-150 Amp., No. 1/0-175 Amp., and No. 2/0-200 Amp.

† The ampacities for Types FEP, FEPB, RHH, THHN, and XHHW conductors for sizes AWG 14, 12 and 10 shall be the same as designated for 75°C conductors in this Table.

For ambient temperatures over 30°C, see Correction Factors, Note 13.

**Table 310-13. Allowable Ampacities of Insulated Copper Conductors**

Single Conductor in Free Air  
(Based on Ambient Temperature of 30°C. 86°F.)

Size	Temperature Rating of Conductor. See Table 310-2(a)								
AWG MCM	60°C (140°F)	75°C (167°F)	85°C (185°F)	90°C (194°F)	110°C (230°F)	125°C (257°F)	200°C (392°F)	250°C (482°F)	
	TYPES RUW (14-2), T, TW	TYPES RH, RHW, RUH (14-2), THW, THWN XHHW	TYPES V, MI	TYPES TA, TBS, SA, AVB, SIS, FEP, FEPB, RHH, THHN, XHHW**	TYPES AVA, AVL	TYPES AI (14-8), AIA	TYPES A (14-8), AA, FEP* FEPB*	TYPE TFE (Nickel or nickel- coated copper only)	Bare and Covered Conduc- tors
14	20	20	30	30†	40	40	45	60	30
12	25	25	40	40†	50	50	55	80	40
10	40	40	55	55†	65	70	75	110	55
8	55	65	70	70	85	90	100	115	70
6	80	95	100	100	120	125	135	210	100
4	105	125	135	135	160	170	180	285	130
3	120	145	155	155	180	195	210	335	150
2	140	170	180	180	210	225	240	390	175
1	165	195	210	210	245	265	280	450	205
0	195	230	245	245	285	305	325	545	235
00	225	265	285	285	330	355	370	605	275
000	260	310	330	330	385	410	430	725	320
0000	300	360	385	385	445	475	510	850	370
250	340	405	425	425	495	530	....	....	410
300	375	445	480	480	555	590	....	....	460
350	420	505	530	530	610	655	....	....	510
400	455	545	575	575	665	710	....	....	555
500	515	620	660	660	765	815	....	....	630
600	575	690	740	740	855	910	....	....	710
700	630	755	815	815	940	1005	....	....	780
750	655	785	845	845	980	1045	....	....	810
800	680	815	880	880	1020	1085	....	....	845
900	730	870	940	940	....	....	....	....	905
1000	780	935	1000	1000	1165	1240	....	....	965
1250	890	1065	1130	1130	....	....	....	....	....
1500	980	1175	1260	1260	1450	....	....	....	1215
1750	1070	1280	1370	1370	....	....	....	....	....
2000	1155	1385	1470	1470	1715	....	....	....	1405

\* Special use only. See Table 310-2(a).

\*\* For dry locations only. See Table 310-2(a).

These ampacities relate only to conductors described in Table 310-2(a).

† The ampacities for Types FEP, FEPB, RHH, THHN, and XHHW conductors for sizes AWG 14, 12 and 10 shall be the same as designated for 75°C conductors in this Table.

For ambient temperatures over 30°C, see Correction Factors, Note 13.



**Table 310-14. Allowable Ampacities of Insulated Aluminum and Copper-Clad Aluminum Conductors**

Not More than Three Conductors in Raceway or Cable or  
Direct Burial (Based on Ambient Temperature of 30°C. 86°F.)

Size	Temperature Rating of Conductor. See Table 310-2(a)						
AWG MCM	60°C (140°F)	75°C (167°F)	85°C (185°F)	90°C (194°F)	110°C (230°F)	125°C (257°F)	200°C (392°F)
	TYPES RUW (12-2), T, TW	TYPES RH, RHW, RUH (12-2), THW, THWN XHHW	TYPES V, MI	TYPES TA, TBS, SA, AVB, SIS, RHH, THHN XHHW**	TYPES AVA, AVL	TYPES AI (12-8), AIA	TYPES A (12-8), AA
12	15	15	25	25 †	25	30	30
10	25	25	30	30 †	35	40	45
8	30	40	40	40	45	50	55
6	40	50	55	55	60	65	75
4	55	65	70	70	80	90	95
3	65	75	80	80	95	100	115
*2	75	90	95	95	105	115	130
*1	85	100	110	110	125	135	150
*0	100	120	125	125	150	160	180
*00	115	135	145	145	170	180	200
*000	130	155	165	165	195	210	225
*0000	155	180	185	185	215	245	270
250	170	205	215	215	250	270	....
300	190	230	240	240	275	305	....
350	210	250	260	260	310	335	....
400	225	270	290	290	335	360	....
500	260	310	330	330	380	405	....
600	285	340	370	370	425	440	....
700	310	375	395	395	455	485	....
750	320	385	405	405	470	500	....
800	330	395	415	415	485	520	....
900	355	425	455	455	....	....	....
1000	375	445	480	480	560	600	....
1250	405	485	530	530	....	....	....
1500	435	520	580	580	650	....	....
1750	455	545	615	615	....	....	....
2000	470	560	650	650	705	....	....

These ampacities relate only to conductors described in Table 310-2(a).

\* For 3-wire, single-phase residential services, the allowable ampacity of RH, RHH, RHW, THW, and XHHW conductors shall be for sizes No. 2-100 Amp., No. 1-110 Amp., No. 1/0-125 Amp., No. 2/0-150 Amp., No. 3/0-175 Amp. and No. 4/0-200 Amp.

\*\* For dry locations only. See Table 310-2(a).

† The ampacities for Type RHH, THHN, and XHHW conductors for sizes AWG 12 and 10 shall be the same as designated for 75°C conductors in this Table.

For ambient temperatures over 30°C, see Correction Factors, Note 13.

**Table 310-15. Allowable Ampacities of Insulated Aluminum and Copper-Clad Aluminum Conductors**

Single Conductor in Free Air  
(Based on Ambient Temperature of 30°C, 86°F.)

Size	Temperature Rating of Conductor. See Table 310-2(a)							
AWG MCM	60°C (140°F)	75°C (167°F)	85°C (185°F)	90°C (194°F)	110°C (230°F)	125°C (257°F)	200°C (392°F)	
	TYPES RUW (12-2), T, TW	TYPES RH, RHW, RUH (12-2), THW XHHW	TYPES V, MI	TYPES TA, TBS, SA, AVB, SIS, RHH, THHN, XHHW*	TYPES AVA, AVL	TYPES AI (12-8), AIA	TYPES A (12-8), AA	Bare and Covered Conduc- tors
12	20	20	30	30 †	40	40	45	30
10	30	30	45	45 †	50	55	60	45
8	45	55	55	55	65	70	80	55
6	60	75	80	80	95	100	105	80
4	80	100	105	105	125	135	140	100
3	95	115	120	120	140	150	165	115
2	110	135	140	140	165	175	185	135
1	130	155	165	165	190	205	220	160
0	150	180	190	190	220	240	255	185
00	175	210	220	220	255	275	290	215
000	200	240	255	255	300	320	335	250
0000	230	280	300	300	345	370	400	290
250	265	315	330	330	385	415	....	320
300	290	350	375	375	435	460	....	360
350	330	395	415	415	475	510	....	400
400	355	425	450	450	520	555	....	435
500	405	485	515	515	595	635	....	490
600	455	545	585	585	675	720	....	560
700	500	595	645	645	745	795	....	615
750	515	620	670	670	775	825	....	640
800	535	645	695	695	805	855	....	670
900	580	700	750	750	....	....	....	725
1000	625	750	800	800	930	990	....	770
1250	710	855	905	905	....	....	....	....
1500	795	950	1020	1020	1175	....	....	985
1750	875	1050	1125	1125	....	....	....	....
2000	960	1150	1220	1220	1425	....	....	1165

These ampacities relate only to conductors described in Table 310-2(a).

\* For dry locations only. See Table 310-2(a).

† The ampacities for Types RHH, THHN, and XHHW conductors for sizes AWG 12 and 10 shall be the same as designated for 75°C conductors in this Table.

For ambient temperatures over 30°C, see Correction Factors, Note 13.

**310-20. Simplified Wiring Table.** The simplified wiring table, Table 310-21, may be used for the selection of feeder and branch-circuit conductor sizes and insulation types only under the conditions stated in this Section. The simplified wiring table shall be used only when a demand factor of 80 percent or less exists.

**(a) Application of Table 310-21.**

(1) Determine load amperes, either continuous or noncontinuous. [Section 310-20(b).]

(2) Select conductor sizes from Table 310-21.

(3) Determine ambient temperature. Use 30°C (86°F) except where higher ambients may be expected as covered in Section 310-20(c).

(4) Select wire insulation type from Table 310-20(c) and Section 310-2(a).

**(b) Loads.**

(1) **Continuous.** Continuous loads are expected to continue for 3 hours or longer [see Section 210-23(b).]

(2) **Noncontinuous.** Loads are noncontinuous where 67 percent or less of the load is expected to be continuous.

**Table 310-20(c). Typical Ambient Temperatures**

Location	Temperature	Minimum Rating of Required Conductor Insulation
Well ventilated, normally heated buildings	30°C (86°F)	* (See note below)
Buildings with such major heat sources as power stations or in- dustrial processes	50°C (113°F)	75°C (167°F)
Poorly ventilated spaces such as attics	45°C (113°F)	75°C (167°F)
Furnaces and boiler rooms (min.)	40°C (104°F)	75°C (167°F)
(max.)	60°C (140°F)	90°C (194°F)
Outdoors in shade in air	40°C (104°F)	75°C (167°F)
In thermal insula- tion	45°C (113°F)	75°C (167°F)
Direct solar exposure	45°C (113°F)	75°C (167°F)
Places above 60°C (140°F)		110°C (230°F)

\* Note: 60°C for up to and including No. 8 AWG copper and up to and including No. 6 AWG aluminum or copper-clad aluminum. 75°C for over No. 8 AWG copper and No. 6 AWG aluminum or copper-clad aluminum.

**(c) Ambient Temperature.** Ambient temperature is the temperature of the medium, such as air, water or earth, into which the heat of the conductor is dissipated. Ambient temperatures vary and values typical of the installation condition shall be used for determining the type of conductor insulation when applying the Simplified Wiring Table. See Table 310-20(c).

**(d) Conductors in Air.** For ampacities of single conductors in air, use Tables 310-13 and 310-15.

**310-21. Conductor Ampacity.** In Table 310-21 the values of amperes apply to actual diversified continuous or noncontinuous connected loads. This Table shall not be used to determine conductor ampacity; use Tables 310-12 to 310-15 for this purpose.

**Table 310-21. Simplified Wiring Table (See Section 310-20 for use)  
Conductor Size\*—6 or Fewer Conductors in Raceway or Cable**

Am- peres	Copper				Aluminum and Copper-Clad Aluminum			
	Non-Cont.		Continuous		Non-Cont.		Continuous	
	AWG	MCM	AWG	MCM	AWG	MCM	AWG	MCM
15	14		14		12		12	
20	12		12		10		10	
25	10		10		8		8	
30	10		10		8		8	
35	8		8		6		6	
40	8		8		6		6	
45	6		6		4		4	
50	6		6		4		4	
60	4		4		4		4	
70	4		4		3		3	
80	3		3		3		2	
90	3		2		2		1	
100	2		1		1		0	
110	1		0		0		2/0	
125	1		0		2/0		3/0	
150	0		2/0		3/0		4/0	
175	2/0		3/0		4/0			250
200	3/0		4/0			250		300
225	4/0			250		300		350
250		250		300		350		400
300		350		400		400		750
350		400		500		500		1000
400		500		750		750		
450		750		1000		1000		
500		750				1000		
600		1000						

\* Neutral conductors shall be treated in accordance with Note 10 — Neutral Conductors of Notes to Tables 310-12 through 310-15.

**ARTICLE 318 — CONTINUOUS RIGID CABLE SUPPORTS**

**318-1. Definition.** A continuous rigid cable support is a unit or an assembly of units or sections, and associated fittings, made of metal or other noncombustible materials forming a continuous rigid structure used to support cables. Continuous rigid cable supports include ladders, troughs, channels, and other similar structures.

It is not the intent of this Article to require that cables be supported by continuous rigid cable supports or to recognize the use of conductors described in Article 310 in continuous rigid cable supports for general wiring.

**318-2. Use.**

(a) Continuous rigid cable supports may be used as the mechanical support for only the following wiring methods under the conditions detailed in the Article for each wiring method: (1) Mineral-insulated metal-sheathed cables, (Article 330), (2) Aluminum-sheathed cable, (Article 331), (3) Metal-clad cable, (Article 334), (4) Nonmetallic-sheathed cable, (Article 336), (5) Multiple-conductor service-entrance cables, (Article 338), (6) Multiple-conductor underground feeder and branch-circuit cable, (Article 339), (7) Any approved conduit or raceway with its contained conductors, (8) Shielded nonmetallic-sheathed cable (Type SNM) for hazardous locations (Article 337).

(b) Continuous rigid cable supports may be used as the mechanical support for factory-assembled, multiconductor control, signal, and power cables, which are specifically approved for installation in continuous rigid cable supports, in fire-resistive or noncombustible construction, but shall not be used (1) in hoistways, (2) where the cables supported are subject to severe physical damage, (3) in areas having readily combustible contents as determined by the authority enforcing this Code. Continuous rigid cable supports may be used to support cables in hazardous locations when the cables are specifically approved for such use. See Sections 501-4, 502-4, and 503-3.

**318-3. Construction.** Continuous rigid cable supports shall be approved for the purpose and shall comply with the following:

(1) Shall have suitable strength and rigidity to provide adequate support for all contained wiring.

(2) Shall not present sharp edges, burrs or projections injurious to the insulation or jackets of the wiring.

(3) If made of metal, shall be adequately protected against corrosion or shall be made of corrosion-resistant material.

(4) Shall have side rails or equivalent structural members.

(5) Shall include fittings for changes in direction and elevation of runs.

**318-4. Installation.**

(a) Continuous rigid cable supports shall be installed as a complete support system.

(318-4 continued)

(b) Each run of continuous rigid cable support shall be complete before the installation of cables.

(c) Continuous rigid cable supports shall be mechanically connected to any enclosure or raceway into which the cables contained in the continuous rigid cable support extend or terminate.

(d) In portions of runs where additional physical protection is required, noncombustible covers or enclosures providing the required protection shall be used.

(e) Installations involving different electrical systems shall comply with Section 300-3 and, where separation is required, the separation shall be a solid noncombustible partition or compartment. Where cables, as permitted by Section 318-2(b), are installed in the same continuous rigid cable support as the cables permitted by Section 318-2(a), the requirements of this section shall apply.

(f) When continuous rigid cable supports are installed in tiers, the minimum vertical clearance between tiers shall be 12 inches.

(g) Continuous rigid cable supports may extend transversely through partitions or walls, other than fire walls, provided the section of the support within the wall is continuous and unventilated. See Section 300-21.

*Exception: Where an opening in a partition or wall provides 2 inches minimum clearance above and on both sides, the continuous rigid cable support may be of a ventilated type.*

(h) Continuous rigid cable supports may extend vertically through dry floors and platforms provided the continuous rigid cable support is totally enclosed where it passes through the floor or platform opening and for a distance of 6 feet above the floor or platform to provide protection from physical injury. See Section 300-21.

(i) Continuous rigid cable supports may extend vertically through floors and platforms in wet locations where: (1) there are curbs or other suitable means to prevent water flow through the floor or platform opening and (2) the continuous rigid cable support is totally enclosed where it passes through the floor or platform opening and for a distance of 6 feet above the floor or platform to provide protection from physical injury. See Section 300-21.

(j) Cable splices and cable taps shall be made only in junction boxes or fittings approved for the purpose.

(k) In other than horizontal runs, and where side rails do not provide adequate containment of the cables, they shall be fastened securely to transverse members of the continuous rigid cable support.

(l) Where continuous rigid cable supports are located adjacent to one another an adequate working space of 24 inches minimum should be maintained on one side of each continuous rigid cable support, or where grouped in rows adjacent to each other a minimum working space of 32 inches should be maintained over each continuous rigid cable support.

(m) Except as provided in Section 318-4(g), a minimum vertical clearance of 6 inches should be maintained from the top of the continuous rigid cable support to all ceilings, beams, and other obstructions.

**318-5. Grounding.** All metal sections of continuous rigid cable supports and fittings shall be bonded and effectively grounded to provide a continuous circuit for fault current. A continuous rigid cable support system shall not be used either as a grounded circuit conductor or as an equipment grounding conductor. See Section 250-33.

**318-6. Ampacity.** The ampacities of cables installed in continuous rigid cable supports shall be as follows:

(a) Where cables containing not more than 3 current-carrying conductors are installed in ventilated continuous rigid cable supports and spacing is maintained at from one-quarter to one cable diameter, the factors of Table 318-6(a) shall be applied to the ampacities of the cables used.

(b) The ampacities of cables shall be in accordance with the requirements of Note 8 of Notes to Tables 310-12 through 310-15 where (1) cables are not spaced, (2) spacing is maintained between cables of more than 3 current-carrying conductors, or (3) unventilated continuous rigid cable supports are used.

**Table 318-6 (a)**  
**Factors for Cables with Maintained Spacing**

Number of Cables	Horizontally					
	1	2	3	4	5	6
<b>Vertically</b>						
1	1.00	0.93	0.87	0.84	0.83	0.82
2	0.89	0.83	0.79	0.76	0.75	0.74
3	0.80	0.76	0.72	0.70	0.69	0.68
4	0.77	0.72	0.68	0.67	0.66	0.65
5	0.75	0.70	0.66	0.65	0.64	0.63
6	0.74	0.69	0.64	0.63	0.62	0.61

## ARTICLE 320 — OPEN WIRING ON INSULATORS

**320-1. Definition.** Open wiring is a wiring method using cleats, knobs, tubes and flexible tubing for the protection and support of insulated conductors run in or on buildings, and not concealed by the building structure.

### 320-2. Use.

(a) Open wiring on insulators may be used for exposed work, either inside or outside building; in dry or wet locations; where subject to corrosive vapors such as covered by Article 480; for services as covered by Article 230, provided the requirements of this Article are satisfied.

(b) Open wiring on insulators shall not be used (1) in commercial garages, (2) in theaters and assembly halls, (3) in motion-picture studios, (4) in hoistways, and (5) in hazardous locations, except in storage compartments of Class III locations as provided in Section 503-3(b).

**320-3. Other Articles.** In addition to the provisions of this Article, open wiring shall conform to the other applicable provisions of this Code. See especially Articles 300 and 730.

**320-4. Conductors.** The type of conductors shall conform to Article 310. Only single conductors shall be used.

(a) The allowable ampacities of insulated conductors as shown in Article 310 shall apply to open wiring on insulators.

**320-5. Supports.**

(a) Conductors shall not be in contact with any object other than their insulating supports. They shall be rigidly supported on noncombustible, nonabsorptive insulating material as follows:

(1) Under ordinary circumstances, supports for wiring over flat surfaces shall be not more than  $4\frac{1}{2}$  feet apart. Where the conductors are likely to be disturbed, the distance between supports shall be shortened sufficiently to provide adequate support for conductors;

(2) Conductors shall be supported within 6 inches of a tap;

(3) Conductors shall not be dead ended at a rosette, lampholder, or receptacle unless the last support is within 12 inches of the device.

(b) The following exceptions to the provisions of Section 320-5(a) may be permitted:

*Exception No. 1: For use of nonmetallic flexible tubing, see Section 320-7.*

*Exception No. 2: Conductors of No. 8 or larger installed in the open across open spaces where not likely to be disturbed, may be supported at distances not greater than 15 feet provided that approved noncombustible, nonabsorptive insulating separators assuring not less than  $2\frac{1}{2}$ -inch separation between conductors, are installed at intervals of not over  $4\frac{1}{2}$  feet.*

*Exception No. 3: In buildings of mill construction where not likely to be disturbed, feeders in the open, not smaller than No. 8, may be separated about 6 inches and installed direct from timber to timber, being supported from each timber only.*

(c) When nails are used to mount knobs they shall not be smaller than 10 penny. When screws are used to mount knobs, or when nails or screws are used to mount cleats, they shall be of a length sufficient to penetrate the wood to a depth equal to at least one-half the height of the knob and fully the thickness of the cleat. Cushion washers shall be used with nails.

**320-6. Conductor Separation.** Open conductors shall be separated as follows:

(a) For voltage not exceeding 300 volts between conductors,  $2\frac{1}{2}$  inches from each other and shall be separated from the surface wired over at least  $\frac{1}{2}$  inch in dry locations.



(b) For voltages of 301 to 600 volts between conductors, 4 inches from each other and shall be separated from surface wired over at least one inch.

(c) In damp or wet locations, a separation of at least one inch from the surface wired over shall be maintained for all voltages.

**320-7. Flexible Nonmetallic Tubing.** In dry locations, when not exposed to severe physical damage, conductors may be separately encased in flexible tubing. Tubing shall be in continuous length not exceeding 15 feet, and secured to the surface wired over by straps spaced not exceeding  $4\frac{1}{2}$  feet apart.

**320-8. Tie Wires.** No. 8 or larger conductors supported on solid knobs shall be securely tied thereto. Tie wires shall have a covering equivalent to conductors which they confine.

**320-9. Passing Through Walls and Floors.** Open conductors shall be separated from contact with walls, floors, timbers or partitions through which they pass by tubes or bushings of noncombustible, nonabsorptive insulating material. Where the bushing is shorter than the hole, a waterproof sleeve of noninductive material shall be inserted in the hole and an insulating bushing slipped into the sleeve at either end in such a manner as to keep the conductors absolutely out of contact with the sleeve. Each conductor must be carried through a separate tube or sleeve.

**320-10. Separation from Metal Work.** Open conductors shall be separated at least 2 inches from metallic conduit, piping, or other conducting material, and from any exposed lighting, power or signal conductor, or shall be separated therefrom by a continuous and firmly fixed nonconductor additional to the insulation of the conductor. Where any insulating tube is used, it shall be secured at the ends. Deviation from this requirement may, when necessary, be allowed by the authority enforcing this Code.

**320-11. Separation from Piping in Damp Locations.** Open conductors located close to water pipes or tanks, or in other damp locations, shall be so placed that an air space will be permanently maintained between them and pipes which they cross. Where practicable, conductors shall be installed over, rather than under, pipes upon which moisture is likely to gather or which may leak.

**320-12. Protection from Physical Damage.** Where open conductors cross ceiling joists and wall studs, and are exposed to physical damage, they shall be protected by one of the following methods. Conductors within 7 feet from the floor shall be considered exposed to physical damage.

(a) By guard strips not less than  $\frac{7}{8}$  inch in thickness and at least as high as the insulating supports, placed on each side of and close to the wiring.

(b) By a substantial running board at least  $\frac{1}{2}$  inch thick back of the conductors with side protections. Running boards shall extend at least one inch outside the conductors, but not more than 2 inches and the protecting sides shall be at least 2 inches high and at least  $\frac{7}{8}$  inch thick.

(c) By boxing made as above and furnished with cover kept at least one inch away from the conductors within. Where protecting vertical conductors on side walls the boxing shall be closed at the top and the holes through which the conductors pass shall be bushed.

(d) By rigid metal conduit or electrical metallic tubing, in which case the rules of Articles 346 or 348 shall apply; or by metal piping, in which case the conductors shall be encased in continuous lengths of approved flexible tubing. The conductors passing through metal enclosures shall be so grouped that current in both directions is approximately equal.

**320-13. In Accessible Attics.** Conductors in unfinished attics or roof spaces shall be installed in accordance with the provisions of Section 324-8.

**320-14. Entering Spaces Subject to Dampness, Wetness or Corrosive Vapors.** Conductors entering or leaving locations subject to dampness, wetness or corrosive vapors shall have drip loops formed on them and shall then pass upward and inward from the outside of buildings, or from the damp, wet, or corrosive location, through noncombustible, nonabsorptive insulating tubes. See also Sections 230-49 and 730-21.

**320-15. Switches.**

(a) Surface-type snap switches shall be mounted in accordance with the provisions of Section 380-10. Metal boxes are not required. See Section 380-3.

(b) Other types of switches shall be installed in accordance with the provisions of Section 380-3.

## ARTICLE 324 — CONCEALED KNOB-AND-TUBE WORK

**324-1. Definition.** Concealed knob-and-tube wiring is a wiring method using knobs, tubes and flexible nonmetallic tubing for the protection and support of insulated conductors concealed in hollow spaces of walls and ceilings of buildings.

**324-2. Use.** Concealed knob-and-tube work may be used in the hollow spaces of walls and ceilings. It shall not be used (1) in commercial garages, (2) in theaters and assembly halls, except as provided in Section 520-4, (3) in motion-picture studios, nor (4) in hazardous locations.

**324-3. Other Articles.** In addition to the provisions of this Article, concealed knob-and-tube wiring shall conform to the other applicable provisions of this Code. See especially Article 300.

**324-4. Conductors.** Only single conductors shall be used. The ampacity and type of conductor shall conform to Article 310.

**324-5. Supports.** Conductors shall be supported at intervals not exceeding 4½ feet by knobs or tubes of noncombustible, nonabsorptive,

insulating material. There shall be a knob within 6 inches of each side of each tap or splice. Tie wires shall comply with Section 320-8. Where such support is impracticable and the conductors are in a dry location, they may be fished when separately enclosed in flexible nonmetallic tubing extending in continuous lengths from one support to the next or to a box, or from one box to another.

#### **324-6. Conductor Separation.**

(a) Conductors shall be separated at least 3 inches and maintained at least one inch from the surface wired over.

(b) At distributing centers, meters, outlets, switches or other places where space is limited and the 3-inch separation cannot be maintained, each conductor shall be encased in a continuous length of flexible tubing.

(c) Where practicable, conductors shall be run singly on separate joists, rafters or studding.

**324-7. Separation from Other Objects and Protection.** Conductors shall be separated from other conductors and objects as follows:

(a) The provisions as to rigid supporting and clearance from foreign wires and other objects, as specified for open wiring in Sections 320-9, 320-10, 320-11, and 320-15, shall be complied with.

(b) Conductors passing through wood cross members in plastered partitions shall be protected by an additional noncombustible, nonabsorptive insulating tube extending at least 3 inches above the member.

**324-8. In Unfinished Attics and Roof Spaces.** Conductors in unfinished attics or roof spaces shall comply with the following:

(a) Conductors in unfinished attics and roof spaces shall be run through or on the sides of joists, studs and rafters, except in attics and roof spaces having head room at all points of less than 3 feet in buildings completed before the wiring is installed.

(b) Where conductors in accessible unfinished attics or roof spaces reached by stairway or permanent ladder are run through bored holes in floor joists or through bored holes in studs or rafters within 7 feet of the floor or floor joists, such conductors shall be protected by substantial running boards extending at least one inch on each side of the conductors and securely fastened in place.

(c) Where carried along the sides of rafters, studs or floor joists, neither running boards nor guard strips will be required.

**324-9. Boxes of Insulating Material.** Nonmetallic outlet boxes may be used as provided in Sections 370-3 and 370-7.

**324-10. Switches.** See Sections 380-3 and 380-10.

**324-11. Splices.** Splices shall be made only where close to knobs or tubes using solder or specially approved splicing devices. In line or strain splices shall not be used.

## ARTICLE 330 — MINERAL-INSULATED METAL-SHEATHED CABLE

### Type MI

#### A. General

**330-1. Definition and Construction.** For the purpose of this Article, mineral-insulated metal-sheathed Type MI cable is a cable in which one or more electrical conductors are insulated with a highly compressed refractory mineral insulation and enclosed in a liquidtight and gastight metallic tube sheathing. It shall be used with approved fittings for terminating and connecting to boxes, outlets and other equipment.

**330-2. Use.** Mineral-insulated metal-sheathed cable may be used for services, feeders and branch circuits in both exposed and concealed work, in dry or wet locations; in Class I, Class II, and Class III hazardous locations as noted in the appropriate Articles; for underplaster extensions as provided in Article 344; and embedded in plaster finish on brick or other masonry. It may be used where exposed to weather or continuous moisture, for underground runs and embedded in masonry, concrete or fill, in buildings in course of construction or where exposed to oil, gasoline, or other conditions not having a deteriorating effect on the metal sheath. The sheath of mineral-insulated metal-sheathed cable exposed to destructive corrosive conditions, such as some types of cinder fill, shall be protected by materials suitable for those conditions.

**330-3. Other Articles.** In addition to the provisions of this Article, the installation of mineral-insulated metal-sheathed cable shall comply with the other applicable provisions of this Code. See especially Article 300.

#### B. Installation

**330-4. Supports.** Mineral-insulated metal-sheathed cable shall be securely supported by approved staples, straps, hangers or similar fittings, so designed and installed as not to injure the cable. Cable shall be secured at intervals not exceeding 6 feet except where cable is fished.

**330-5. Through Studs, Joists and Rafters.** See Section 300-8.

**330-6. Wet Locations.** See Section 300-5.

**330-7. Bends.** All bends shall be so made that the cable will not be damaged and the radius of the curve of the inner edge of any bend shall be not less than 5 times the diameter of the cable.

**330-8. Terminating Seal.** At all points where mineral-insulated metal-sheathed cable terminates an approved seal shall be provided immediately after stripping to prevent entrance of moisture into the mineral insulation. The conductors extending beyond the sheath shall be insulated with an approved insulating material.

**330-9. Fittings.** When Type MI cable is connected to boxes or equipment, the fittings shall be approved for the conditions of service. When single-conductor Type MI cables enter metal boxes through separate openings, refer to Section 300-20.

**330-10. Insulation Resistance.** The completed wiring system shall be tested for insulation resistance in accordance with Section 110-20.

### **C. Construction Specifications**

**330-11. General.** Type MI Cable for 600 volts shall conform to the following:

(a) **Conductors.** The conductors are solid copper and have cross-sectional areas corresponding to the standard American Wire Gage sizes.

(b) **Insulation.** The insulation is a highly compressed refractory mineral which provides proper spacing for the conductors.

(c) **Outer Sheath.** The outer sheath shall be of a continuous copper construction to provide mechanical protection and a moisture seal, and an adequate path for grounding purposes.

## **ARTICLE 331 — ALUMINUM-SHEATHED CABLE**

### **Type ALS**

#### **A. General**

**331-1. Definition and Construction.** Aluminum-sheathed Type ALS cable is a factory-assembled cable consisting of one or more insulated conductors enclosed in an impervious, continuous, closely fitting tube of aluminum. It shall be used with approved fittings for terminating and connecting to boxes, outlets and other equipment.

**331-2. Use.** Aluminum-sheathed cable may be used in both exposed and concealed work, in dry or wet locations. The sheath of aluminum-sheathed cable exposed to destructive corrosive conditions such as environments containing strong chlorides or caustic alkalis, or where vapors of chlorine or hydrochloric acid are present or where the cable is installed underground, shall be protected by materials suitable for those conditions. See Section 300-5.

Aluminum-sheathed cable and fittings shall not be embedded or buried directly in concrete or used in areas subject to severe corrosive influences unless suitable supplemental corrosion protection is provided.

See Section 310-6.

**331-3. Other Articles.** In addition to the provisions of this Article, the installation of aluminum-sheathed cable shall comply with the other applicable provisions of this Code. See especially Article 300.

#### **B. Installations**

**331-4. Supports.** Aluminum-sheathed cable shall be securely supported by staples, straps, hangers, or similar fittings so designed and installed as not to injure the cable. Cable shall be secured at intervals not exceeding 6 feet except where the cable is fished.

**331-5. Through Studs, Joists and Rafters.** See Section 300-8.

**331-6. Wet locations.** See Section 300-5.

**331-7. Bends.** All bends shall be so made that the cable will not be damaged and the radius of the curve on the inner edge of any bend shall be not less than:

(a) Ten times the external diameter of the sheath for cable not more than  $\frac{3}{4}$  inch in external diameter.

(b) Twelve times the external diameter of the sheath for cable more than  $\frac{3}{4}$  inch but not more than  $1\frac{1}{2}$  inches in external diameter; and

(c) Fifteen times the external diameter of the sheath for cable more than  $1\frac{1}{2}$  inches in external diameter.

**331-8. Fittings.** When aluminum-sheathed cable is connected to boxes or equipment, the fittings shall be approved for the conditions of service. When single-conductor aluminum-sheathed cables enter metal boxes through separate openings refer to Section 300-20.

### C. Construction

**331-9. General.** Type ALS cable shall conform to the following:

(a) **Conductors.** The conductors shall be copper, copper-clad aluminum, or electrical conductor grade aluminum, solid or stranded.

(b) **Insulation.** The insulation shall be a type listed in Table 310-2(b).

(c) **Insulation Covering.** The covering over the insulation shall be the same as permitted for lead-sheathed cable or multiple-conductor cable.

(d) **Outer Sheath.** The outer sheath shall be of a continuous, closely fitting tube of aluminum to provide mechanical protection, a moisture seal and an adequate path for equipment grounding purposes and shall conform with provisions of Section 331-2. The sheath shall not be used as a current-carrying conductor.

## ARTICLE 334 — METAL-CLAD CABLE

### Type MC and AC Series

**334-1. Definition.** A metal-clad cable is a fabricated assembly of insulated conductors in a flexible metallic enclosure. See Section 334-4.

**334-2. Voltage.** See Section 300-2. For systems in excess of 600 volts see Article 710.

**334-3. Marking.** The provisions of Section 310-12 shall apply, except that Type AC cable shall have ready identification of the maker by distinctive external markers in the cable sheath throughout its entire length.

**334-4. Construction.** Metal-clad cable shall be an approved cable of Type MC or AC Series, with acceptable metal covering. The insulated conductors shall conform with Section 334-5.

(a) **Type MC.** Type MC cables are power cables limited in size, for the voltages of this article, to conductors of No. 4 AWG and larger for copper and No. 2 AWG and larger for aluminum and copper-clad aluminum. The metal enclosures shall be either a covering of interlocking metal tape, or an impervious, close fitting, corrugated tube. Supplemental protection of an outer covering of corrosion-resistant material shall be required where such protection is needed. See Section 300-5. The cables shall provide adequate path for grounding purposes.

(b) **Type AC.** Type AC cables are branch-circuit and feeder cables with armor of flexible metal tape. Cables of the AC type, except ACL, shall have an internal bonding strip of copper or aluminum, in intimate contact with the armor for its entire length.

**334-5. Conductors.** Conductors for metal-clad cable shall conform with the following:

(a) **Type MC.** For cables of Type MC, insulated conductors shall be of a type listed in Table 310-2(b) for rubber, thermoplastic, varnished cloth, asbestos-varnished cloth, or of a type especially approved for the purpose.

(b) **Type AC.** For cables of Type AC, insulated conductors shall be of a type listed in Table 310-2(b). In addition, the conductors shall have an over-all moisture-resistant and fire-retardant fibrous covering; for Type ACT, a moisture-resistant fibrous covering is required only on the individual conductors.

**334-6. Use.** Except where otherwise specified elsewhere in this Code, and where not subject to physical damage, metal-clad cable may be installed for branch circuits and feeders in both exposed and concealed work as follows:

(a) **Type MC.** This type of power cable may be used in partially protected areas, such as in continuous rigid cable supports and the like, in dry locations and when any of the following conditions are met it may be used in wet locations:

(1) The metallic covering is impervious to moisture.

(2) A lead sheath or moisture impervious jacket is provided under the metal covering.

(3) The insulated conductors under the metallic covering are approved for use in wet locations.

See Section 300-5.

(b) **Type AC.** Metal-clad cable of the AC type may be used in dry locations; for underplaster extensions as provided in Article 344; and embedded in plaster finish on brick or other masonry, except in damp or wet locations. This cable may be run or fished in the air voids of masonry block or tile walls; where such walls are exposed or subject to excessive moisture or dampness or are below grade line, Type ACL cable shall be used. This cable shall contain lead-covered conductors (Type ACL), if used where exposed to the weather or to continuous

(334-6(b) continued)

moisture, for underground runs in duct or raceway and embedded in masonry, concrete or fill in buildings in course of construction, or where exposed to oil, or other conditions having a deteriorating effect on the insulation. Type AC metal-clad cable shall not be used where prohibited elsewhere in this Code, including (1) in theaters and assembly halls, except as provided in Section 520-4; (2) in motion-picture studios; (3) in any hazardous locations; (4) where exposed to corrosive fumes or vapors; (5) on cranes or hoists, except as provided in Section 610-11 Exception No. 3; (6) in storage battery rooms; (7) in hoistways or on elevators, except as provided in Section 620-21; or (8) commercial garages where prohibited in Article 511. Type ACL cable shall not be used for direct burial in the earth.

**334-7. Other Articles.** In addition to the provisions of this Article, metal-clad cable shall conform to other applicable provisions of this Code. See especially Article 300.

**334-8. Supports.** Metal-clad cable shall be secured by approved staples, straps, hangers or similar fittings so designed and installed as not to injure the cable.

(a) Type MC cable shall be secured at intervals not exceeding 6 feet, and within 2 feet from every box or fitting, except where cable is fished. Cable may be installed on metal racks, trays, troughs, or continuous rigid cable supports grounded as required by Article 250. The cables shall be separated from each other by a distance of not less than one-quarter of a cable diameter. There shall be no more than one layer of cables on a rack or other support member; each cable so installed shall be supported at intervals not exceeding 6 feet and within 2 feet from every box or fitting, and each cable shall be attached to the support at intervals of not more than 10 feet horizontally and 2 feet vertically.

(b) Type AC cable shall be secured at intervals of not exceeding 4½ feet and within 12 inches from every outlet box or fitting, except where cable is fished and except lengths of not over 24 inches at terminals where flexibility is necessary.

**334-9. Bends.** All bends shall be so made that the cable will not be injured, and the radius of the curve of the inner edge of any bend shall not be less than 7 times the diameter of Type MC cable nor 5 times the diameter of Type AC cable.

**334-10. Boxes and Fittings.**

(a) At all points where Type MC metal-clad cable terminates, suitable fittings designed for use with the particular wiring cable and the conditions of service, shall be used.

(b) At all points where the armor of AC cable terminates, a fitting shall be provided to protect wires from abrasion, unless the design of the outlet boxes or fittings is such as to afford equivalent protection, and in addition, an approved insulating bushing or its equivalent approved protection shall be provided between the conductors and the armor. The connector or clamp by which the metal-clad cable is fastened to boxes or cabinets shall be of such design that the insulating bushing or its equivalent will be visible for inspection. This bushing is



not required with lead-covered cables which shall be so installed that the lead sheath will be visible for inspection. Where change is made from metal-clad cable to other cable or raceway wiring methods, a box shall be installed at junction point as required in Section 300-15.

**334-11. Through Studs, Joists and Rafters.** See Section 300-8.

**334-12. Exposed Work.** Exposed runs of cable shall closely follow the surface of the building finish or of running boards, except:

(a) Lengths of not more than 24 inches at terminals where flexibility is necessary.

(b) Where suitably supported in accordance with Section 334-8(a).

(c) On the underside of floor joists in basements where supported at each joist and so located as not to be subject to physical damage.

**334-13. In Accessible Attics.** Type AC cables in accessible attics or roof spaces shall be installed as follows:

(a) Where run across the top of floor joists, or within 7 feet of floor or floor joists across the face of rafters or studding, in attics and roof spaces which are accessible, the cable shall be protected by substantial guard strips which are at least as high as the cable. Where this space is not accessible by permanent stairs or ladders, protection will only be required within 6 feet of the nearest edge of scuttle hole or attic entrance.

(b) Where cable is carried along the sides of rafters, studs or floor joists, neither guard strips nor running boards shall be required.

## ARTICLE 336 — NONMETALLIC-SHEATHED CABLE

### Types NM and NMC

**336-1. Definition.** A nonmetallic-sheathed cable is an assembly of 2 or more insulated conductors having an outer sheath of moisture-resistant, flame-retardant, nonmetallic material.

**336-2. Construction.** Nonmetallic-sheathed cable shall be an approved Type NM or NMC in sizes No. 14 through 2 AWG with copper conductors and in sizes No. 12 through 2 with aluminum and copper-clad aluminum conductors. In addition to the insulated conductors, the cable may have an approved size of uninsulated or bare conductor for grounding purposes only.

(a) **Type NM.** The conductors shall comply with the requirements for the type of conductor used. Over-all fibrous coverings shall have a flame-retardant and moisture-resistant finish.

(b) **Type NMC.** The cable shall be of a type approved for the purpose. The over-all covering shall be flame-retardant, moisture-resistant, fungus-resistant and corrosion-resistant.

(c) **Marking.** In addition to the provisions of Section 310-12, the cable shall have a distinctive marking on the exterior for its entire length specifying cable type.

**336-3. Use.** Nonmetallic sheathed cable may be installed for both exposed and concealed work as follows:

(a) **Type NM.** This type of nonmetallic sheathed cable may be installed for both exposed and concealed work in normally dry locations. It may be installed or fished in air voids in masonry block or tile walls where such walls are not exposed or subject to excessive moisture or dampness. Type NM cable shall not be installed where exposed to corrosive fumes or vapors; nor shall it be imbedded in masonry, concrete, fill or plaster; nor run in shallow chase in masonry or concrete and covered with plaster or similar finish.

(b) **Moisture and Corrosion-Resistant Type NMC.** This type of non-metallic sheathed cable may be installed for both exposed and concealed work in dry, moist, damp or corrosive locations, and in outside and inside walls of masonry block or tile. Where embedded in plaster or run in a shallow chase in masonry walls and covered with plaster within 2 inches of the finished surface, it shall be protected against damage from nails by a cover of corrosion-resistant coated steel at least 1/16 inch in thickness and 3/4 inch wide in the chase or under the final surface finish.

(c) **Uses Not Permissible for Either Type NM or NMC Nonmetallic-Sheathed Cable.** These types shall not be used as: (1) service-entrance cable, (2) in commercial garages, (3) in theaters and assembly halls, except as provided in Section 520-4, (4) in motion-picture studios, (5) in storage battery rooms, (6) in hoistways, (7) in any hazardous location, (8) embedded in poured cement, concrete or aggregate.

**336-4. Other Articles.** In addition to the provisions of this Article, installations of nonmetallic-sheathed cable shall conform to the other applicable provisions of this Code. See especially Article 300.

**336-5. Supports.** Nonmetallic-sheathed cable shall be secured by approved staples, straps, or similar fittings, so designed and installed as not to injure the cable. Cable shall be secured in place at intervals not exceeding 4½ feet and within 12 inches from every cabinet, box or fitting, except that in concealed work in finished buildings or finished panels for prefabricated buildings where such supporting is impracticable, the cable may be fished between points of access.

**336-6. Exposed Work — General.** In exposed work, except as provided in Sections 336-8 and 336-9, the cable shall be installed as follows:

(a) The cable shall closely follow the surface of the building finish or of running boards.

(b) It shall be protected from physical damage where necessary, by conduit, pipe, guard strips or other means. Where passing through a floor the cable shall be enclosed in rigid metal conduit or metal pipe extending at least 6 inches above the floor.

**336-7. Through Studs, Joists and Rafters.** See Section 300-8.

**336-8. In Unfinished Basements.** Where the cable is run at angles with joists in unfinished basements, assemblies not smaller than two No. 6 or three No. 8 conductors may be secured directly to the lower edges of the joists; smaller assemblies shall either be run through bored holes

in the joists or on running boards. Where run parallel to joists, cable of any size shall be secured to the sides or face of the joists.

**336-9. In Accessible Attics.** Cable in accessible attics or roof spaces shall also conform with Section 334-13.

**336-10. Bends.** Bends in cable shall be so made, and other handling shall be such, that the protective coverings of the cable will not be injured, and no bend shall have a radius less than 5 times the diameter of the cable.

**336-11. Devices of Insulating Material.** Switch, outlet, and tap devices of insulating material may be used without boxes in exposed cable wiring, and for concealed work for rewiring in existing buildings where the cable is concealed and fished. Openings in such devices shall form a close fit around the outer covering of the cable and the device shall fully enclose that part of the cable from which any part of the covering has been removed.

Where connections to conductors are by binding-screw terminals, there shall be available as many terminals as conductors, unless cables are clamped within the structure and terminals are of a type approved for multiple conductors.

**336-12. Boxes of Insulating Material.** Nonmetallic outlet boxes approved for the purpose may be used as provided in Section 370-3.

## ARTICLE 337 — SHIELDED NONMETALLIC-SHEATHED CABLE

### Type SNM

**337-1. Scope.** This Article covers a wiring method of shielded non-metallic-sheathed cable and fittings and defines installation and construction specifications.

**337-2. Definitions.** Type SNM, shielded nonmetallic-sheathed cable, is a factory assembly of two or more insulated conductors in an extruded core of moisture-resistant, flame-resistant nonmetallic material, covered with an overlapping spiral metal tape and wire shield and jacketed with an extruded moisture, flame, oil, corrosion, fungus and sunlight-resistant nonmetallic material.

**337-3. Other Articles.** In addition to the provisions of this Article, installation of Type SNM cable shall conform to other applicable provisions, such as Articles 300 and 318 of the Code.

**337-4. Uses Permitted.** Type SNM cable may be used only as follows:

(1) Where operating temperatures do not exceed the rating marked on the cable.

(2) In continuous rigid cable supports or in raceways.

(3) In hazardous locations where permitted in Articles 500 through 516.

**337-5. Bends.** Bends in Type SNM cable shall be so made as not to damage the cable or its covering. The radius of the inner edge shall not be less than 5 times the cable diameter.

**337-6. Handling.** Type SNM cable shall be handled in such a manner as not to damage the cable or its covering.

**337-7. Fittings.** Fittings for connecting Type SNM cable to enclosures or equipment shall be approved for the purpose and for the conditions of use.

**337-8. Construction.** The conductors of Type SNM cable shall be Type THHN or THWN in sizes No. 14 through No. 2 copper and No. 12 through No. 2 in aluminum and copper-clad aluminum. Conductor sizes may be mixed in individual cables. The flat overlapping metal tapes shall be spiraled with a long lay. The shield wires shall have a total cross-sectional area as required by Article 250 and not less than the largest circuit conductor in the cable.

The outer jacket shall be water, oil, flame, corrosion, fungus, and sunlight resistant suitable for installation in continuous rigid cable supports.

**337-9. Marking.** Type SNM cable shall have a distinctive marking on its exterior surface for its entire length indicating its type and maximum operating temperature. It shall comply with the general marking requirements of Section 310-12.

The conductors shall each be numbered for identification from each other by durable marking on two sides 180° apart every 6 inches of length, with alternate legends inverted to facilitate reading from both sides.

## ARTICLE 338 — SERVICE-ENTRANCE CABLE

### Types SE and USE

**338-1. Definition.** Service-entrance cable is a conductor assembly provided with a suitable over-all covering, primarily used for services and of the following types. When consisting of two or more conductors, one may be without individual insulation.

(a) Type SE, having a flame-retardant, moisture-resistant covering, but not required to have inherent protection against mechanical abuse.

(b) Type USE, recognized for underground use, having a moisture-resistant covering, but not required to have a flame-retardant covering or inherent protection against mechanical abuse. Single-conductor cables having rubber insulation specifically approved for the purpose do not require an outer covering.

**338-2. Use as Service-Entrance Conductors.** Service-entrance cable used as service-entrance conductors shall be installed as required by Article 230.

**338-3. Use as Branch Circuit or Feeders.**

(a) Type SE, service-entrance cables may be used in interior wiring systems where all of the *circuit* conductors of the cable are of the rubber-covered or thermoplastic type.

(b) Type SE, service-entrance cables without individual insulation on the grounded circuit conductor shall not be used as a branch circuit or as a feeder within a building, except a cable which has a final nonmetallic outer covering and when supplied by alternating current at not exceeding 150 volts to ground, may be used: (1) As a branch circuit to supply only a range, wall-mounted oven, counter-mounted cooking unit, or clothes dryer as covered in Section 250-60, or (2) as a feeder to supply only other buildings on the same premises. It shall not be used as a feeder terminating within the same building in which it originates.

The above provisions do not intend to deny the use of service-entrance cable for interior use when the fully insulated conductors are used for circuit wiring and the uninsulated conductor is used for equipment grounding purposes.

(c) Type SE, service-entrance cable used to supply appliances shall not be subject to conductor temperatures in excess of the temperature specified for the type of insulation involved.

**338-4. Installation Methods.**

(a) In addition to the provisions of this Article, Type SE service-entrance cable used for interior wiring shall comply with the applicable provisions of Article 300.

(b) Unarmored cable shall be installed in accordance with the applicable provisions of Article 336.

(c) Cables through studs, joists and rafters shall be installed as required in Section 300-8.

**338-5. Marking.** Service-entrance cable shall conform with the marking required in Section 310-12. Cable with the neutral conductor smaller than the ungrounded conductors shall be so marked.

## ARTICLE 339 — UNDERGROUND FEEDER AND BRANCH-CIRCUIT CABLE

### Type UF

**339-1. Description and Marking.**

(a) **Description.** Underground feeder and branch-circuit cable shall be an approved Type UF cable in sizes No. 14 to No. 4/0 AWG, inclusive. The conductors shall be Types TW, RHW, or other conductors approved for the purpose. In addition to the insulated conductors, the cable may have an approved size of uninsulated or bare conductor for grounding purposes only. The over-all covering shall be flame-retardant, moisture-resistant, fungus-resistant and corrosive-resistant, and suitable for direct burial in the earth.

(b) **Marking.** In addition to the provisions of Section 310-12, the cable shall have a distinctive marking on the exterior for its entire length specifying cable type.

**339-2. Other Articles.** In addition to the provisions of this Article, installations of underground feeder and branch-circuit cable (Type UF) shall comply with other applicable provisions of this Code. See especially Article 300, and Section 310-2(b).

**339-3. Use.**

(a) Underground feeder and branch-circuit cable may be used underground, including direct burial in the earth, as feeder or branch-circuit cable when provided with overcurrent protection of the rated ampacity as required in Section 339-4.

(b) Where single-conductor cables are installed, all cables of the feeder circuit, sub-feeder circuit, or branch circuit, including the neutral conductor, if any, shall be run together in the same trench or raceway.

(c) A minimum depth of 18 inches shall be maintained for conductors and cables buried directly in the earth. This depth may be reduced to 12 inches provided supplemental protective covering such as a 2 inch concrete pad, metal raceway, pipe or other suitable protection is used.

(d) Type UF cable may be used for interior wiring in wet, dry, or corrosive locations under the recognized wiring methods of this Code, and when installed as nonmetallic-sheathed cable it shall conform with the installation provisions of Article 336 and shall be of the multiple-conductor type, except where recognized under the provisions of Section 424-43. Type UF cable supported by continuous rigid cable supports shall be of the multiple-conductor type.

(e) This type of cable shall not be used: (1) as service-entrance cables; (2) in commercial garages; (3) in theaters or assembly halls, except as provided in Section 520-4; (4) in motion-picture studios; (5) in storage battery rooms; (6) in hoistways; (7) in any hazardous location; (8) embedded in poured cement, concrete or aggregate, except where recognized in Article 424; (9) when exposed to direct rays of the sun, unless approved for the purpose.

**339-4. Overcurrent Protection.** Overcurrent protection shall be provided in accordance with provisions of Section 240-5.

**339-5. Rated Ampacity.** The ampacities of conductors in Type UF cable shall be according to Tables 310-12 and 310-14.

## ARTICLE 342 — NONMETALLIC EXTENSIONS

**342-1. Description.** Nonmetallic extensions are an assembly of two insulated conductors within a nonmetallic jacket or an extruded thermoplastic covering. The classification includes both surface extensions, intended for mounting directly on the surface of walls or ceilings, and aerial cable, containing a supporting messenger cable as an integral part of the cable assembly.

**342-2. Other Articles.** In addition to the provisions of this Article, nonmetallic extensions shall conform to other applicable provisions of this Code.

**342-3. Use Permitted.** Nonmetallic extensions may be used only where all of the following conditions are met:

(a) The extension is from an existing outlet on a 15- or 20-ampere branch circuit in conformity with the requirements of Article 210.

(b) The extension is run exposed and in a dry location.

(c) For nonmetallic surface extensions, the building is occupied for residential or office purposes.

(d) For aerial cable, the building is occupied for industrial purposes, and the nature of the occupancy requires a highly flexible means for connecting equipment.

**342-4. Use Prohibited.** Nonmetallic extensions shall not be installed:

(a) As aerial cable to substitute for one of the general wiring methods specified by this Code.

(b) In unfinished basements, attics, or roof spaces.

(c) Where voltage between conductors exceeds 150 volts for non-metallic surface extension and 300 volts for aerial cable.

(d) Where subject to corrosive vapors.

(e) Where run through a floor or partition, or outside the room in which it originates.

**342-5. Splices and Taps.** Extensions shall consist of a continuous unbroken length of the assembly, without splices, and without exposed conductors between fittings. Taps may be made where approved fittings completely covering the tap connections are used. Aerial cable and its tap connectors shall be provided with an approved means for polarization. Receptacle-type tap connectors shall be of the locking-type.

**342-6. Fittings.** Each run shall terminate in a fitting which covers the end of the assembly. All fittings and devices shall be of a type approved for the purpose.

**342-7. Installation.** Nonmetallic extensions shall be installed in conformity with the following requirements:

**(a) Nonmetallic Surface Extensions.**

(1) One or more extensions may be run in any direction from an existing outlet, but not on the floor or within 2 inches from the floor.

(2) Nonmetallic surface extensions shall be secured in place by approved means at intervals not exceeding 8 inches, except that where connection to the supplying outlet is made by means of an attachment plug the first fastening may be placed 12 inches or less from the plug. There shall be at least one fastening between each two adjacent outlets supplied. An extension shall be attached only to woodwork or plaster finish, and shall not be in contact with any metal work or other conductive material except with metal plates on receptacles.

(342-7(a) continued)

(3) A bend which reduces the normal spacing between the conductors shall be covered with a cap to protect the assembly from physical damage.

**(b) Aerial Cable.**

(1) Aerial cable shall be supported by its messenger cable, securely attached at each end with approved clamps and turnbuckles. Intermediate supports shall be provided at not more than 20-foot intervals. Cable tension shall be adjusted to eliminate excessive sag. The cable shall have a clearance of not less than 2 inches from steel structural members or other conductive material.

(2) Aerial cable shall have a clearance of not less than 10 feet above floor areas accessible to pedestrian traffic, and not less than 14 feet above floor areas accessible to vehicular traffic.

(3) Cable suspended over work benches, not accessible to pedestrian traffic, shall have a clearance of not less than 8 feet above the floor.

(4) Aerial cable may serve to support lighting fixtures when the total load on the supporting messenger cable does not exceed that for which the assembly is intended.

(5) The supporting messenger cable, when conforming to the applicable provisions of Article 250 and when properly identified as a grounding conductor, may be used for the grounding of equipment. The messenger cable shall not be used as a branch-circuit conductor.

## ARTICLE 344 — UNDERPLASTER EXTENSIONS

**344-1. Use.** An underplaster extension installed as permitted by this Article, may be used only for extending an existing branch circuit in a building of fire-resistive construction.

**344-2. Materials.** Such extensions shall be run in rigid or flexible conduit, Type AC metal-clad cable, electrical metallic tubing, Type MI cable or metal raceways approved for the purpose. Standard sizes of conduit, cable, tubing and raceways shall be used except that for a single conductor only conduit or tubing having not less than 5/16 inch inside diameter, single-conductor Type AC metal-clad cable or single conductor Type MI cable may be used.

**344-3. Box and Fittings.** See Article 370.

**344-4. Installation.** An underplaster extension shall be laid on the face of masonry or other material and buried in the plaster finish of ceilings or walls. The methods of installation of the raceway or cable for such extension shall be as specified elsewhere in this Code for the particular type of material used.

**344-5. Extension to Another Floor.** No such extension shall extend beyond the floor on which it originates unless installed in a standard size of rigid metal conduit, electrical metallic tubing, Type AC metal-clad cable, or MI cable.



**ARTICLE 346 — RIGID METAL CONDUIT**

Note: Where conduit is threaded in the field, it is assumed that a standard conduit cutting die providing  $\frac{3}{4}$ -inch taper per foot will be employed.

**346-1. Use.** Rigid metal conduit may be used under all atmospheric conditions and occupancies, except that ferrous raceways and fittings protected from corrosion solely by enamel may be used only indoors and in occupancies not subject to severe corrosive influences. Where practicable dissimilar metals in contact anywhere in the system shall be avoided to eliminate the possibility of galvanic action.

Unless made of a material judged suitable for the condition, or unless corrosion protection approved for the condition is provided, ferrous or nonferrous metallic conduit, elbows, couplings, and fittings shall not be installed in concrete or in direct contact with the earth, or in areas subject to severe corrosive influences.

**346-2. Other Articles.** Installations of rigid metal conduit shall comply with the provisions of the applicable Sections of Article 300.

**A. Installation**

**346-3. Cinder Fill.** Conduit, unless of corrosion-resistant material suitable for the purpose shall not be used in or under cinder fill where subject to permanent moisture unless protected on all sides by a layer of noncinder concrete at least 2 inches thick or unless the conduit is at least 18 inches under the fill.

**346-4. Wet Locations.** All supports, bolts, straps, screws, etc., shall be of corrosion-resistant materials or protected against corrosion by approved corrosion-resistant materials.

See Section 300-5.

**346-5. Minimum Size.** No conduit smaller than  $\frac{1}{2}$  inch, electrical trade size, shall be used, except as provided for underplaster extensions in Article 344, and for enclosing the leads of motors as permitted in Section 430-145(b).

**346-6. Number of Conductors in Conduit.** The number of conductors permitted in a single conduit shall be in accordance with the percentage fill specified in Table 1, Chapter 9.

**346-7. Reaming.** All cut ends of conduits shall be reamed to remove rough edges.

**346-8. Bushings.** Where a conduit enters a box or other fitting, a bushing shall be provided to protect the wire from abrasion unless the design of the box or fitting is such as to afford equivalent protection. See Section 373-6(b) for the protection of conductors at bushings.

**346-9. Couplings and Connectors.**

(a) Threadless couplings and connectors used with conduit shall be made tight. Where buried in masonry or concrete, they shall be of the concrete-tight type, or where installed in wet locations, shall be of the raintight type.

(b) Running threads shall not be used on conduit for connection at couplings.

**346-10. Bends — How Made.** Bends of rigid conduit shall be so made that the conduit will not be injured, and that the internal diameter of the conduit will not be effectively reduced. The radius of the curve of the inner edge of any field bend shall not be less than shown in Table 346-10(a).

*Exception: For field bends for conductors without lead sheath and made with a single operation (one shot) bending machine designed for the purpose, the minimum radius may be in accordance with Table 346-10(b).*

**Table 346-10(a)**  
**Radius of Conduit Bends (Inches)**

Size of Conduit (In.)	Conductors Without Lead Sheath (In.)	Conductors With Lead Sheath (In.)
½	4	6
¾	5	8
1	6	11
1¼	8	14
1½	10	16
2	12	21
2½	15	25
3	18	31
3½	21	36
4	24	40
4½	27	45
5	30	50
6	36	61

**Table 346-10(b)**  
**Radius of Conduit Bends (Inches)**

Size of Conduit (In.)	Radius to Center of Conduit (In.)
½	4
¾	4½
1	5¾
1¼	7¼
1½	8¼
2	9½
2½	10½
3	13
3½	15
4	16
4½	20
5	24
6	30

**346-11. Bends — Number in One Run.** A run of conduit between outlet and outlet, between fitting and fitting, or between outlet and fitting shall not contain more than the equivalent of 4 quarter bends (360 degrees, total), including those bends located immediately at the outlet or fitting.

**346-12. Supports.** Rigid metal conduit shall be installed as a complete system as provided in Article 300 and shall be securely fastened in place. Conduit shall be firmly fastened within 3 feet of each outlet box, junction box, cabinet, or fitting. Conduit shall be supported at least every 10 feet except that straight runs of rigid conduit made up with approved threaded couplings may be secured in accordance with Table 346-12, provided such fastening prevents transmission of stresses to terminus when conduit is deflected between supports.

**Table 346-12. Supports for Rigid Metal Conduit**

Conduit Size (Inches)	Maximum distance between rigid metal conduit supports (Feet)
$\frac{1}{2}$ – $\frac{3}{4}$	10
1	12
$1\frac{1}{4}$ – $1\frac{1}{2}$	14
2– $2\frac{1}{2}$	16
3 and larger	20

**346-13. Boxes and Fittings.** See Article 370.

#### **B. Construction Specifications**

**346-14. General.** Rigid metal conduit shall conform to the following:

(a) Rigid conduit as shipped shall be in standard lengths of 10 feet including coupling, one coupling to be furnished with each length. Each length shall be reamed and threaded on each end. For specific applications or uses, lengths shorter or longer than 10 feet, with or without couplings, may be shipped.

(b) Nonferrous conduit of corrosion-resistant material shall have suitable markings.

(c) Each length shall be clearly and durably identified in every 10 feet as required in the first sentence of Section 110-21.

## **ARTICLE 347 — RIGID NONMETALLIC CONDUIT**

**347-1. Description.** The provisions of this Article shall apply to a type of conduit and fittings of suitable nonmetallic material which is resistant to moisture and chemical atmospheres. For use aboveground, it shall also be flame retardant, resistant to impact and crushing, shall resist distortion due to heat under conditions likely to be encountered in

service and shall be resistant to low temperature and sunlight effects. For use underground, the material shall be acceptably resistant to moisture and corrosive agents and shall be of sufficient strength to withstand abuse, such as by impact and crushing, in handling and during installation. Where intended for direct burial, without encasement in concrete, the material shall also be capable of withstanding continued loading which is likely to be encountered after installation.

Materials which have been recognized as having suitable physical characteristics when properly formed and treated include fiber, asbestos cement, soapstone, rigid polyvinyl chloride and high-density polyethylene for underground use and rigid polyvinyl chloride for use aboveground.

**347-2. Use Permitted.** Rigid nonmetallic conduit and fittings approved for the purpose may be used under the following conditions and where the potential is 600 volts or less except as noted in Section 347-3.

(a) Direct earth burial not less than 18 inches below the surface. If less than 18 inches it shall be encased in not less than 2 inches of concrete.

(b) In walls, floors and ceilings.

(c) In locations subject to severe corrosive influences as set forth in Section 300-5 and where subject to chemicals for which the materials are specifically approved.

(d) Cinder fill.

(e) Wet Locations. In portions of dairies, laundries, canneries or other wet locations and in locations where walls are frequently washed, the entire conduit system including boxes and fittings used therewith shall be so installed and equipped as to prevent water from entering the conduit. All supports, bolts, straps, screws, etc., shall be of corrosion-resistant materials or protected against corrosion by approved corrosion-resistant materials.

(f) In dry and damp locations not prohibited by Section 347-3.

**347-3. Use Prohibited.** Rigid nonmetallic conduit shall not be used:

(a) In hazardous locations except as covered in Sections 514-8 and 515-5.

(b) For the support of fixtures or other equipment.

(c) Where subject to physical damage unless approved for the purpose.

(d) Where subject to ambient temperatures exceeding those for which the conduit had been approved.

(e) For conductors whose insulation temperature limitations would exceed those for which the conduit had been approved.

(f) For potentials exceeding 600 volts unless encased in not less than 2 inches of concrete.

**347-4. Other Articles.** Installation of rigid nonmetallic conduit shall comply with provisions of the applicable Sections of Article 300.

### A. Installations

**347-5. Trimming.** All cut ends shall be trimmed inside and outside to remove rough edges.

**347-6. Joints.** All joints between lengths of conduit, and between conduit and couplings, fittings and boxes shall be made by a method specifically approved for the purpose.

**347-8. Supports.** Rigid nonmetallic conduit shall be adequately supported as required in Table 347-8. In addition, there shall be a support within 4 feet of each box, cabinet, or other conduit termination.

**Table 347-8. Support of Rigid Nonmetallic Conduit**

Conduit Size (Inches)	Maximum Spacing between Supports (Feet)	
	Conductors Rated 60°C and Below	Conductors Rated More Than 60°C
1/2-3/4	4	2
1-2	5	2 1/2
2 1/2-3	6	3
3 1/2-5	7	3 1/2
6	8	4

**347-9. Expansion Joints.** Expansion joints for rigid nonmetallic conduit shall be provided where required to compensate for thermal expansion and contraction.

**347-10. Minimum Size.** No conduit smaller than 1/2-inch electrical trade size shall be used.

**347-11. Number of Conductors.** The number of conductors permitted in a single conduit shall be in accordance with the percentage fill specified in Table 1, Chapter 9.

**347-12. Bushings.** Where a conduit enters a box or other fitting, a bushing or adapter shall be provided to protect the wire from abrasion unless the design of the box or fitting is such as to provide equivalent protection. See Section 373-6(b) for the protection of conductors at bushings.

**347-13. Bends, How Made.** Bends of rigid nonmetallic conduit shall be so made that the conduit will not be injured and that the internal diameter of the conduit will not be effectively reduced. Field bends shall be made only with bending equipment specifically intended for the purpose, and the radius of the curve of the inner edge of such bends shall be not less than shown in Table 346-10(a).

**347-14. Bends, Number in One Run.** A run of conduit between outlet and outlet, between fitting and fitting or between outlet and fitting shall not contain more than the equivalent of 4 quarter bends (360°) total including those bends located immediately at the outlet or fitting.

**347-15. Boxes and Fittings.** See Article 370.

### **B. Construction Specifications**

**347-16. General.** Rigid nonmetallic conduit shall conform to the following:

(a) Rigid nonmetallic polyvinyl chloride conduit as shipped shall be in standard lengths of 10 feet including couplings, one coupling to be furnished with each length. For specific applications or uses, lengths shorter or longer than 10 feet with or without couplings may be shipped.

(b) High-density polyethylene conduit as shipped shall be in standard lengths of 10 feet. One threaded coupling shall be furnished with each threaded length of high-density polyethylene conduit. For specific applications or uses, lengths shorter or longer than 10 feet with or without couplings may be shipped.

(c) Each length of nonmetallic conduit shall be clearly and durably marked at least every 10 feet as required in the first sentence of Section 110-21. The type of material shall also be included in the marking unless it is visually identifiable.

For conduit recognized for use aboveground these markings shall be permanent. For conduit limited to underground use only, these markings shall be sufficiently durable to remain legible until the material is installed.

## **ARTICLE 348 — ELECTRICAL METALLIC TUBING**

**348-1. Use.** Electrical metallic tubing may be used for both exposed and concealed work. Electrical metallic tubing protected from corrosion solely by enamel shall not be used. Electrical metallic tubing shall not be used: (1) where during installation or afterward, it will be subject to severe physical damage; (2) in cinder concrete or fill where subject to permanent moisture unless protected on all sides by a layer of noncinder concrete at least 2 inches thick or unless the tubing is at least 18 inches under the fill. Where practicable, the use of dissimilar metals throughout the system shall be avoided to eliminate the possibility of galvanic action.

Unless made of a material judged suitable for the condition, or unless corrosion protection approved for the condition is provided, ferrous or nonferrous electrical metallic tubing, elbows, couplings and fittings shall not be installed in concrete or in direct contact with the earth, or in areas subject to severe corrosive influences.

**348-2. Other Articles.** Installations of electrical metallic tubing shall comply with the provisions of the applicable sections of Article 300.

### **A. Installation**

**348-4. Wet Locations.** All supports, bolts, straps, screws, etc. shall be of corrosion-resistant materials or protected against corrosion by approved corrosion-resistant materials. See Section 300-5.

**348-5. Minimum and Maximum Sizes.** No tubing smaller than ½-inch, electrical trade size, shall be used except as provided for underplaster extensions in Article 344 and for enclosing the leads of motors as permitted in Section 430-145(b). The maximum size of tubing shall be the 4-inch electrical trade size.

**348-6. Number of Conductors in Tubing.** One tubing shall not contain more conductors than as provided in Section 346-6.

**348-7. Threads.** Tubing shall not be coupled together nor connected to boxes, fittings, or cabinets by means of threads in the wall of the tubing, except by fittings approved for the purpose. Threads shall not be of the standard pipe-thread dimensions.

**348-8. Couplings and Connectors.** Threadless couplings and connectors used with tubing shall be made up tight. Where buried in masonry or concrete, they shall be concrete-tight type, or where installed in wet locations, shall be of the raintight-type.

**348-9. Bends — How Made.** Bends in the tubing shall be so made that the tubing will not be injured and that the internal diameter of the tubing will not be effectively reduced. The radius of the curve of the inner edge of any field bend shall not be less than shown in Table 346-10(a).

*Exception: For field bends made with a bending machine designed for the purpose, the minimum radius may be in accordance with the dimensions of Table 346-10(b).*

**348-10. Bends — Number in One Run.** A run of electrical metallic tubing between outlet and outlet, between fitting and fitting, or between outlet and fitting, shall not contain more than the equivalent of 4 quarter bends (360 degrees, total), including those bends located immediately at the outlet or fitting.

**348-11. Reaming.** All cut ends of electrical metallic tubing shall be reamed to remove rough edges.

**348-12. Supports.** Electrical metallic tubing shall be installed as a complete system as provided in Article 300 and shall be securely fastened in place at least every 10 feet and within 3 feet of each outlet box, junction box, cabinet, or fitting.

**348-13. Boxes and Fittings.** See Article 370.

## **B. Construction Specifications**

**348-14. General.** Electrical metallic tubing shall conform to the following:

(a) **Cross Section.** The tubing, and elbows and bends for use with the tubing, shall have a circular cross section.

(b) **Finish.** Tubing shall have such a finish or treatment of outer surfaces as will provide an approved durable means of readily distinguishing it, after installation, from rigid conduit.

(c) **Connectors.** Where the tubing is coupled together by threads, the connector shall be so designed as to prevent bending of the tubing at any part of the thread.

## ARTICLE 350 — FLEXIBLE METAL CONDUIT

**350-1. Other Articles.** Installations of flexible metal conduit shall comply with the appropriate (or applicable) provisions of Articles 300, 334, and 346.

**350-2. Use.** Flexible metal conduit shall not be used (1) in wet locations, unless conductors are of the lead-covered type or of other type specially approved for the conditions; (2) in hoistways, except as provided in Section 620-21; (3) in storage-battery rooms; (4) in any hazardous location except as permitted in Sections 501-4(b), 502-4 and 503-3; nor (5) where rubber-covered conductors are exposed to oil, gasoline, or other materials having a deteriorating effect on rubber.

**350-3. Minimum Size.** No flexible metal conduit less than ½-inch electrical trade size shall be used except (1) as permitted for under-plaster extensions by Section 344-2; (2) as permitted for motors by Section 430-145(b); and (3) flexible metal conduit of ¾-inch nominal trade size may be used in lengths not in excess of 72 inches as a part of an approved assembly or for lighting fixtures.

**Table 350-3. Maximum Number of Insulated Conductors in ¾ In. Flexible Metal Conduit.\***

**Col. A = With fitting inside conduit.**

**Col. B = With fitting outside conduit.**

Size AWG	Types RF-2, RFH-2, SF-2		Types TF, T, XHHW, AF, TW, RUH, RUW		Types TFN, THHN, THWN		Types FEP, FEPB, PF, PGF	
	A	B	A	B	A	B	A	B
18	..	3	3	7	4	8	5	8
16	..	2	2	4	3	7	4	8
14	..	..	..	4	3	7	3	7
12	..	..	..	3	..	4	..	4
10	..	..	..	..	..	2	..	3

\* In addition one uninsulated grounding conductor of the same AWG size may be installed.

**350-4. Supports.** When flexible metal conduit is installed, it shall be secured by approved means at intervals not exceeding 4½ feet and within 12 inches on each side of every outlet box or fitting.

*Exception No. 1: Where flexible metal conduit is fished.*

*Exception No. 2: Lengths of not more than 3 feet at terminals where flexibility is necessary.*

*Exception No. 3: Lengths of not more than 6 feet from a fixture terminal connection for tap connections to lighting fixtures as required in Section 410-65(b) (2).*



**350-5. Grounding.** Flexible metal conduit may be used as a grounding means where both the conduit and the fittings are approved for the purpose.

*Exception: Flexible metal conduit may be used for grounding if the length is 6 feet or less, it is terminated in fittings approved for the purpose, and the circuit conductors contained therein are protected by overcurrent devices rated at 20 amperes or less.*

## ARTICLE 351 — LIQUIDTIGHT FLEXIBLE METAL CONDUIT

**351-1. Scope.** The provisions of this Article shall apply to a type of flexible metal conduit having an outer liquidtight nonmetallic sunlight-resistant jacket.

**351-2. Use.**

(a) Liquidtight flexible metal conduit may be used in exposed or concealed locations:

(1) Where conditions of installation, operation or maintenance require flexibility or protection from liquids, vapors or solids.

(2) As permitted by Sections 501-4(b), 502-4 and 503-3, and in other hazardous locations where specifically approved.

(b) Liquidtight flexible metal conduit shall not be used:

(1) Where subject to physical damage.

(2) Where any combination of ambient and/or conductor temperature will produce an operating temperature in excess of that for which the material is approved.

**351-3. Size.** The sizes of liquidtight flexible metal conduit shall be electrical trade sizes  $\frac{1}{2}$  to 4 inch inclusive.

*Exception:  $\frac{3}{8}$ -inch size may be used as permitted in Section 350-3.*

**351-4. Number of Conductors.**

(a) The number of conductors permitted in a single conduit shall be in accordance with the percentage of fill specified in Table 1, Chapter 9.

(b) See Table 350-3 for maximum number of conductors in  $\frac{3}{8}$ -inch liquidtight flexible metal conduit.

**351-5. Fittings.** Liquidtight flexible metal conduit shall be used only with terminal fittings approved for the purpose.

**351-6. Supports.** Where liquidtight flexible metal conduit is installed as a fixed raceway, it shall be secured by approved means at intervals not exceeding  $4\frac{1}{2}$  feet and within 12 inches on each side of every outlet box or fitting except where the conduit is fished.

**351-7. Grounding.**

(a) Liquidtight flexible metal conduit may be used for grounding in the 1¼ inch and smaller trade sizes if the length is 6 feet or less and it is terminated in fittings approved for the purpose.

(b) Liquidtight flexible metal conduit may be used as a grounding means where both the conduit and fittings are approved for the purpose.

**ARTICLE 352 — SURFACE RACEWAYS****Metal Raceways**

**352-1. Use.** Surface metal raceways may be installed in dry locations. They shall not be used (1) where subject to severe physical damage unless approved for the purpose; (2) where the voltage is 300 volts or more between conductors unless the metal has a thickness of not less than .040 inch; (3) where subject to corrosive vapors; (4) in hoistways; nor (5) in any hazardous location; (6) concealed except as follows:

*Exception No. 1: Surface metal raceways approved for the purpose may be used for underplaster extensions.*

*Exception No. 2: Where accessible, surface metal raceways may be used in nonair-handling plenum chamber areas.*

See definition of "Exposed — (As applied to wiring methods)" in Article 100.

**352-2. Other Articles.** Installations of surface metal raceways shall comply with the applicable provisions of Article 300.

**A. Installation**

**352-3. Size of Conductors.** No conductor larger than that for which the raceway is designed shall be installed in surface metal raceway.

**352-4. Number of Conductors in Raceways.** The number of conductors installed in any raceway shall be no greater than the number for which the raceway is designed.

**352-5. Extension Through Walls and Floors.** Except in multioutlet assemblies, raceways may be extended through dry walls, dry partitions and dry floors, if in unbroken lengths where passing through.

**352-6. Combination Raceways.** Where combination metal raceways are used both for signal and for lighting and power circuits, the different systems shall be run in separate compartments, identified by sharply contrasting colors of the interior finish, and the same relative position of compartments shall be maintained throughout the premises.

**352-7. Splices and Taps.** Splices and taps shall be made only in junction boxes except that they may be made in surface metal raceway having a removable cover which is accessible after installation. The conductors, including splices and taps, shall not fill the raceway to more than 75 percent of its area at that point. All splices and taps shall be made by approved methods.

### B. Construction Specifications

**352-8. General.** Surface metal raceways shall be of such construction as will distinguish them from other raceways. Surface metal raceways and their elbows, couplings, and similar fittings shall be so designed that the sections can be electrically and mechanically coupled together, while protecting the wires from abrasion. Holes for screws or bolts inside the raceway shall be so designed that when screws or bolts are in place their heads will be flush with the metal surface.

### Nonmetallic Raceways

**352-21. Description.** The provisions of the following Sections of this Article shall apply to a type of surface nonmetallic raceway and fittings of suitable nonmetallic material which is resistant to moisture and chemical atmospheres. It shall also be flame-retardant, resistant to impact and crushing, shall resist distortion due to heat under conditions likely to be encountered in service and shall be resistant to low-temperature effects.

**352-22. Use.** Surface nonmetallic raceways may be installed in dry locations. They shall not be used (1) where concealed; (2) where subject to severe physical damage unless approved for the purpose; (3) where the voltage is 300 volts or more between conductors; (4) in hoistways; (5) in any hazardous location; (6) where subject to ambient temperatures exceeding 50°C; nor (7) for conductors whose insulation temperature exceeds 75°C.

**352-23. Other Articles.** Installations of surface nonmetallic raceways shall comply with the applicable provisions of Article 300.

### A. Installation

**352-24. Size of Conductors.** No conductor larger than that for which the raceway is designed shall be installed in surface nonmetallic raceway.

**352-25. Number of Conductors in Raceways.** The number of conductors installed in any raceway shall be no greater than the number for which the raceway is designed.

**352-26. Combination Raceways.** Where combination nonmetallic raceways are used both for signal and for lighting and power circuits, the different systems shall be run in separate compartments, identified by printed legend or by sharply contrasting colors of the interior finish, and the same relative position of compartments shall be maintained throughout the premises.

### B. Construction Specifications

**352-27. General.** Surface nonmetallic raceways shall be of such construction as will distinguish them from other raceways. Surface nonmetallic raceways and their elbows, couplings, and similar fittings shall be so designed that the sections can be mechanically coupled together, while protecting the wires from abrasion. Holes for screws or bolts inside the raceway shall be so designed that when screws or bolts are in place their heads will be flush with the nonmetallic surface.

## ARTICLE 353 — MULTIOUTLET ASSEMBLY

**353-1. Other Articles.** Installations of multioutlet assembly shall comply with applicable provisions of Article 300. See definition in Article 100.

**353-2. Use.** Multioutlet assembly may be installed in dry locations. It shall not be installed (1) where concealed, except that the back and sides of metal multioutlet assembly may be surrounded by the building finish and nonmetallic multioutlet assembly may be recessed in the baseboard; (2) where subject to severe physical damage unless approved for the purpose; (3) where the voltage is 300 volts or more between conductors unless assembly is of metal having a thickness of not less than .040 inch; (4) where subject to corrosive vapors; (5) in hoistways; nor (6) in any hazardous locations.

**353-3. Metal Multioutlet Assembly Through Dry Partitions.** Metal multioutlet assembly may be extended through (not run within) dry partitions, providing arrangements are made for removing the cap or cover on all exposed portions and no outlet is located within the partitions.

## ARTICLE 354 — UNDERFLOOR RACEWAYS

**354-1. Other Articles.** Installations of underfloor raceways shall comply with the applicable provisions of Article 300.

**354-2. Use.** Underfloor raceways may be installed beneath the surface of concrete or other flooring material, or in office occupancies, where laid flush with the concrete floor and covered with linoleum or equivalent floor covering. Underfloor raceways shall not be installed (1) where subject to corrosive vapors nor (2) in any hazardous location. Unless made of a material judged suitable for the condition, or unless corrosion protection approved for the condition is provided, ferrous or non-ferrous metallic underfloor raceways, junction boxes, and fittings shall not be installed in concrete; or in areas subject to severe corrosive influences.

**354-3. Covering.** Raceway coverings shall conform to the following:

(a) **Raceways Not Over 4 Inches Wide.** Half-round raceways not over 4 inches in width, and, except as permitted in (c) flat-top raceways not over 4 inches in width, shall have not less than  $\frac{3}{4}$  inch of concrete or wood above the raceway.

(b) **Raceways Over 4 Inches Wide but Not Over 8 Inches Wide.** Flat top raceways over 4 but not over 8 inches wide with a minimum of one inch spacing between raceways shall be covered with concrete to a depth of not less than one inch. Raceways spaced less than one inch apart shall be covered with concrete to a depth of  $1\frac{1}{2}$  inches.

(c) **Raceways Flush With Concrete.** Approved flush raceways with removable covers may be laid flush with the floor surface. Such approved

raceways shall be so designed that the cover plates will provide adequate mechanical protection and rigidity equivalent to junction box covers.

**354-4. Size of Conductors.** No conductor larger than that for which the raceway is designed shall be installed in underfloor raceways.

**354-5. Number of Conductors in Raceway.** The combined cross-sectional area of all conductors shall not exceed 40 percent of the interior area of the raceway; except that where the raceway contains only Type AC metal-clad cable or nonmetallic-sheathed cable, these requirements shall not apply.

**354-6. Splices and Taps.** Splices and taps shall be made only in junction boxes.

For the purposes of this Section, so-called loop wiring (continuous, unbroken conductor connecting the individual outlets) is not considered to be a splice or tap.

**354-7. Discontinued Outlets.** When an outlet is abandoned, discontinued, or removed, the sections of circuit conductors supplying the outlet shall be removed from the raceway. No splices or reinsulated conductors such as would be the case with abandoned outlets on loop wiring, shall be allowed in raceways.

**354-8. Laid in Straight Lines.** Underfloor raceways shall be laid so that a straight line from the center of one junction box to the center of the next junction box will coincide with the center line of the raceway system. Raceways shall be firmly held in place to prevent disturbing this alignment during construction.

**354-9. Markers at Ends.** At every end of line of raceway, and at other locations where the location of the raceway is not apparent, a suitable number of markers shall be installed extending through the floor for future location of inserts and for system identification.

**354-10. Dead Ends.** Dead ends of raceways shall be closed.

**354-11. Low Points.** Where practicable, raceways and their fittings shall be so arranged as to avoid low points that may form traps for water.

**354-12. Fittings at Angles.** Where raceways are run at other than right angles, special fittings shall be provided.

**354-13. Junction Boxes.** Junction boxes shall be leveled to the floor grade and sealed against the entrance of water. Junction boxes used with metal raceways shall be metal and shall be electrically continuous with the raceways.

**354-14. Inserts.** Inserts shall be leveled to the floor grade and sealed against the entrance of water. Inserts used with metal raceways shall be metal and shall be electrically continuous with the raceway. Inserts set in or on fiber raceways before the floor is laid shall be mechanically secured to the raceway. Inserts set in fiber raceways after the floor is laid shall be screwed into the raceway. In cutting through the raceway wall and setting inserts, chips and other dirt shall not be allowed to

fall into the raceway, and tools shall be used which are so designed as to prevent the tool from entering the raceway and injuring conductors that may be in place.

**354-15. Connections to Cabinets and Wall Outlets.** Connections between raceways and distribution centers and wall outlets shall be made by means of rigid or flexible metal conduit or by means of fittings approved for the purpose.

## ARTICLE 356 — CELLULAR METAL FLOOR RACEWAYS

**356-1. Definitions.** For the purposes of this Article, a “cellular metal floor raceway” shall be defined as the hollow spaces of cellular metal floors, together with suitable fittings, which may be approved as enclosures for electrical conductors; a “cell” shall be defined as a single, enclosed tubular space in a cellular metal floor member, the axis of the cell being parallel to the axis of the metal floor member; a “header” shall be defined as a transverse raceway for electrical conductors, providing access to predetermined cells of a cellular metal floor, thereby permitting the installation of electrical conductors from a distribution center to the cells.

**356-2. Use.** Conductors shall not be installed in cellular metal floor raceways (1) where subject to corrosive vapor; (2) in any hazardous location; nor (3) in commercial garages, except for supplying ceiling outlets or extensions to the area below the floor but not above. No electric conductors shall be installed in any cell or header which contains a pipe for steam, water, air, gas, drainage, or other service than electrical.

**356-3. Other Articles.** Installations of conductors in the raceways of cellular metal floor shall comply with the applicable provisions of Article 300.

### A. Installation

**356-4. Size of Conductors.** No conductor larger than No. 0 shall be installed, except by special permission.

**356-5. Number of Conductors in Raceway.** The total cross-sectional area of all conductors in a header or in an individual cell shall not exceed 40 percent of the cross-sectional area of the header or cell in which they are located; except that where the raceway contains only Type AC metal-clad cable or nonmetallic-sheathed cable, these requirements shall not apply.

**356-6. Splices and Taps.** Splices and taps shall be made only in header access units or junction boxes.

For the purposes of this Section so-called loop wiring (continuous unbroken conductor connecting the individual outlets) is not considered to be a splice or tap.

**356-7. Discontinued Outlets.** When an outlet is abandoned, discontinued, or removed, the sections of circuit conductors supplying the outlet shall be removed from the raceway. No splices or reinsulated conductors, such as would be the case with abandoned outlets on loop wiring, shall be allowed in raceways.

**356-8. Markers.** A suitable number of markers shall be installed extending through the floor for the future locating of cells and for system identification.

**356-9. Junction Boxes.** Junction boxes shall be levelled to the floor grade and sealed against the entrance of water. Junction boxes used with these raceways shall be of metal and shall be electrically continuous with the raceway.

**356-10. Inserts.** Inserts shall be levelled to the floor grade and sealed against the entrance of water. Inserts shall be of metal and shall be electrically continuous with the raceway. In cutting through the cell wall and setting inserts, chips and other dirt shall not be allowed to fall into the raceway, and tools shall be used which are designed to prevent the tool from entering the cell and injuring the conductors.

**356-11. Connection to Cabinets and Extensions from Cells.** Connections to cabinets and extensions from cells to outlets shall be made by means of rigid or flexible conduit or by means of fittings approved for the purpose.

### **B. Construction Specifications**

**356-12. General.** Cellular metal floor raceways shall be so constructed that adequate electrical and mechanical continuity of the complete system will be secured. They shall provide a complete enclosure for the conductors. The interior surfaces shall be free from burrs and sharp edges, and surfaces over which conductors are drawn shall be smooth. Suitable bushings or fittings having smooth rounded edges shall be provided where conductors pass.

## **ARTICLE 357 — STRUCTURAL RACEWAYS**

**357-1. Definitions.** Structural raceways are formed steel members approved for the installation of electrical wires or cables within them.

(a) Vertical members used for studs or columns shall be tubes or channels.

(b) Horizontal headers used as beams or top plates shall be provided with suitable covers, end closers, and fittings.

**357-2. Use.** Structural raceways used to enclose electrical conductors shall be used only in single-family dwellings.

**357-3. Other Articles.** Installation of conductors in structural raceways shall comply with the applicable provisions of Article 300.

### A. Installation

**357-4. Openings in Vertical Members.** Vertical members may have openings provided in them for the purpose of installing wiring devices. Vertical members may be concealed. Openings in vertical members shall provide access to wiring. The size of such openings shall comply with the provisions of Section 300-15 and Article 370. Wiring devices may be installed in openings in vertical members without the use of individual boxes, provided that the back and sides of each device are surrounded by terminal barriers.

**357-5. Horizontal Headers.** Horizontal headers shall be securely fastened to vertical members.

**357-6. Number of Conductors in Raceway.** Structural raceways shall not contain more than 20 current-carrying conductors at any cross-section, and the total cross-sectional areas of all contained conductors shall not exceed 20 percent of the interior cross-section.

**357-7. Splices and Taps.** Splices and taps shall be made only in horizontal headers, or junction boxes. The conductors including splices and taps shall not fill the structural raceway to more than 75 percent of its area at that point. All splices and taps shall be made and insulated by approved methods.

**357-8. Size of Conductors.** No conductor larger than No. 6 AWG shall be installed in vertical or horizontal members.

**357-9. Accessibility.** The covers of the horizontal members shall be accessible after installation and shall not be obstructed by the wall finish.

**357-10. Fittings.** Fittings shall be designed and installed to prevent physical damage to electrical conductors. Fittings shall be free from burrs and sharp edges.

**357-11. Extensions from Vertical Structural Members.** Extensions from vertical structural members shall be made with rigid or flexible metal conduit, electrical metallic tubing, surface metal raceway or metal-clad cable.

**357-12. Dead Ends.** Dead ends of structural raceways shall be closed.

**357-13. Installation of Electrical Devices.** The installation of switches, receptacles, and outlets shall be in accordance with the requirements of Articles 380 and 410, except as otherwise permitted in this Article.

**357-14. Grounding.** All elements of structural raceway systems shall be bonded and effectively grounded.

### B. Construction Specifications

**357-15. Marking.** Structural raceways and fittings shall be marked with the manufacturer's name, trademark, or identification symbol.

**357-16. General.** All metal components shall be properly coated to prevent corrosion. The interior shall be free from sharp edges and burrs. The structural raceway systems shall be constructed to provide electrical and mechanical continuity of the complete system. They shall provide a complete enclosure for the conductors. Enclosures shall be approved for the purpose.



## ARTICLE 358 — CELLULAR CONCRETE FLOOR RACEWAYS

**358-1. Scope.** Approved precast cellular concrete floor raceways shall comply with the applicable requirements of Article 300, and shall also comply with the provisions of Sections 358-2 to 358-11 inclusive. For the purpose of this Article, "precast cellular concrete floor raceways" shall be defined as the hollow spaces in floors constructed of precast cellular concrete slabs, together with suitable metal fittings designed to provide access to the floor cells in an approved manner. A "cell" shall be defined as a single, enclosed tubular space in a floor made of precast cellular concrete slabs, the direction of the cell being parallel to the direction of the floor member. "Header ducts" shall be defined as transverse metal raceways for electrical conductors, furnishing access to predetermined cells of a precast cellular concrete floor, thus providing for the installation of electrical conductors from a distribution center to the floor cells.

**358-2. Use.** Conductors shall not be installed in precast cellular concrete floor raceways (1) where subject to corrosive vapor; (2) in hazardous locations; nor (3) in commercial garages, except for supplying ceiling outlets or extensions to the area below the floor but not above. No electrical conductors shall be installed in any cell or header which contains a pipe for steam, water, air, gas, drainage, or any service other than electrical.

**358-3. Header Duct.** The header duct shall be installed in a straight line, at right angles to the cells. The header duct shall be mechanically secured to the top of the precast cellular concrete floor. The end joints shall be closed by metallic closure fittings and sealed against the penetration of water. The header duct shall be electrically continuous throughout its entire length and shall be electrically bonded to the enclosure of the distribution center.

**358-4. Connection to Cabinets and Other Enclosures.** Connection from header duct to cabinets and other enclosures shall be made by means of metallic duct and fittings approved for the purpose.

**358-5. Junction Boxes.** Junction boxes shall be levelled to the floor grade and sealed against the entrance of water. Junction boxes shall be of metal and shall be mechanically and electrically continuous with the header ducts.

**358-6. Markers.** Each hidden access point between a header and a cell intended for future use shall be provided with a marker extending through the floor covering. A suitable number of markers shall be installed, extending through the floor covering, to locate the cells and to provide system identification.

**358-7. Inserts.** Inserts shall be levelled to the floor grade and sealed against the entrance of water. Inserts shall be of metal and shall be fitted with receptacles of the grounded type. A ground conductor shall connect the insert receptacles to a positive ground connection provided on the header duct. In cutting through the cell wall for setting inserts or

other purposes (such as providing access openings between header duct and cells) chips and other dirt shall not be allowed to fall into the raceway, and the tool used shall be so designed as to prevent the tool from entering the cell and injuring the conductors.

**358-8. Size of Conductors.** No conductor larger than No. 0 shall be installed, except by special permission.

**358-9. Number of Conductors.** The total cross-sectional area of all conductors in a header or in an individual cell shall not exceed 40 percent of the cross-sectional area of the header or cell in which they are located; except that where the raceway contains only Type AC metal-clad cable or nonmetallic-sheathed cable, these requirements shall not apply.

**358-10. Splices and Taps.** Splices and taps shall be made only in header duct access units or junction boxes.

**358-11. Discontinued Outlets.** When an outlet is discontinued, the conductors supplying the outlet shall be removed from the header and cell.

## ARTICLE 362 — WIREWAYS

**362-1. Definition.** Wireways are sheet-metal troughs with hinged or removable covers for housing and protecting electrical wires and cable and in which conductors are laid in place after the wireway has been installed as a complete system.

**362-2. Use.** Wireways may be installed only for exposed work. Wireways intended for outdoor use shall be of approved raintight construction. Wireways shall not be installed: (1) where subject to severe physical damage or corrosive vapor; nor (2) in any hazardous location except Class II, Division 2. See Section 502-4(b).

**362-3. Other Articles.** Installations of wireways shall comply with the applicable provisions of Article 300.

**362-4. Size of Conductors.** No conductor larger than that for which the wireway is designed shall be installed in any wireway.

**362-5. Number of Conductors.** Wireways shall not contain more than 30 current-carrying conductors at any cross section. The sum of the cross-sectional areas of all contained conductors at any cross section of a wireway shall not exceed 20 percent of the interior cross-sectional area of the wireway.

*Exception No. 1: See Section 620-32.*

The correction factors specified in Note 8 to Tables 310-12 through 310-15 are not applicable to the foregoing.

*Exception No. 2: Conductors for signal circuits or controller conductors between a motor and its starter and used only for starting duty shall not be considered as current-carrying conductors.*

*Exception No. 3: When the correction factors specified in Note 8 of Tables 310-12 through 310-15 are applied, no limit on the number of*

*current-carrying conductors is needed, but the sum of the cross-sectional areas of all contained conductors at any cross section of the wireway shall not exceed 20 percent of the interior cross-sectional area of the wireway.*

*Exception No. 4: See Section 520-5.*

**362-6. Splices and Taps.** Splices and taps, made and insulated by approved methods, may be located within the wireway provided they are accessible. The conductors, including splices and taps, shall not fill the wireway to more than 75 percent of its area at that point.

**362-7. Supports.** Wireways shall be securely supported at intervals not exceeding 5 feet, unless specially approved for supports at greater intervals, but in no case shall the distance between supports exceed 10 feet.

*Exception: Vertical runs of wireways shall be securely supported at intervals not exceeding 15 feet and shall have not more than one joint between supports. Adjoining wireway sections shall be securely fastened together to provide a rigid joint.*

**362-8. Extension Through Walls.** Wireways may extend transversely through walls if in unbroken lengths where passing through.

**362-9. Dead Ends.** Dead ends of wireways shall be closed.

**362-10. Extensions From Wireways.** Extensions from wireways shall be made with rigid or flexible metal conduit, electrical metallic tubing, surface metal raceway or metal-clad cable.

**362-11. Marking.** Wireways shall be marked so that their manufacturer's name or trademark will be visible after installation.

## ARTICLE 363 — FLAT CABLE ASSEMBLIES

### Type FC

**363-1. Scope.** This Article covers a field-installed wiring method using Type FC, flat cable assembly, in an approved surface metal raceway.

**363-2. Definition.** Type FC, a flat cable assembly, is an assembly of parallel conductors formed integrally with an insulating material web specifically designed for field installation in surface metal raceway approved for the purpose.

**363-3. Other Articles.** In addition to the provisions of this Article, installation of Type FC cable shall conform with the applicable provisions of Articles 210, 220, 250, 300, 310 and 352.

**363-4. Uses Permitted.** Flat cable assemblies may be used only as branch circuits to supply suitable tap devices for lighting, small appliances or small power loads. Flat cable assemblies shall be installed for exposed work only. Flat cable assemblies shall be installed in locations where they will not be subjected to severe physical damage.

**363-5. Uses Not Permitted.** Flat cable assemblies shall not be installed: (1) where subject to corrosive vapors unless specifically approved for the purpose; (2) in hoistways; (3) in any hazardous location; or (4) outdoors or in wet or damp locations unless specifically approved for the purpose.

**363-6. Installation.** Flat cable assemblies shall be installed in the field only in surface metal raceways approved for the purpose. The surface metal raceway systems shall be installed as complete systems before the flat cable assemblies are pulled into the raceways.

**363-7. Number Of Conductors.** The flat cable assemblies may consist of either 3 or 4 conductors.

**363-8. Size of Conductors.** Flat cable assemblies shall have conductors of No. 10 AWG special stranded copper wires.

**363-9. Conductor Insulation.** The entire flat cable assembly shall be formed to provide a suitable insulation covering all of the conductors and using one of the materials recognized in Table 310-2(a) for general branch-circuit wiring.

**363-10. Splices.** Splices shall be made in approved junction boxes using approved terminal blocks.

**363-11. Taps.** Taps shall be made only between any phase conductor and the neutral by means of devices and fittings approved for the purpose. Tap devices shall be rated at not less than 15 amperes or more than 300 volts, and they shall be color-coded in accordance with the requirements of Section 363-21.

**363-12. Dead Ends.** Each flat cable assembly dead end shall be terminated in an end-cap device approved for the purpose.

The dead-end fitting for the enclosing surface metal raceway shall be approved for the purpose.

**363-13. Fixture Hangers.** Fixture hangers installed with the flat cable assemblies shall be approved for the purpose.

**363-14. Fittings.** Fittings to be installed with flat cable assemblies shall be designed and installed to prevent physical damage to the cable assemblies.

**363-15. Extensions.** All extensions from flat cable assemblies shall be made from the terminal blocks enclosed within the junction boxes, installed at either end of the flat cable assembly runs.

All extensions shall be made with wiring methods approved for the purpose.

**363-16. Supports.** The flat cable assemblies shall be supported by means of their special design features, within the surface metal raceways with which they are specifically approved to be used.

The surface metal raceways shall be supported as required for the specific raceway to be installed.

**363-17. Rating.** The rating of the branch circuit shall not exceed 30 amperes.

**363-18. Marking.** In addition to the provisions of Section 310-12, Type FC cable shall have the temperature rating durably marked on the surface at intervals not exceeding 24 inches.

**363-19. Protective Covers.** When a flat cable assembly is installed less than 8 feet from the floor it shall be protected by a metal cover approved for the purpose.

**363-20. Identification.** The neutral conductor shall be identified throughout its length by means of a distinctive and durable white or natural gray marking.

**363-21. Terminal Block Identification.** Terminal blocks approved for the purpose shall have distinctive and durable markings for color or word coding. The neutral section shall have a white marking or other suitable designation. The next adjacent section of the terminal block shall have a black marking or other suitable designation. The next section shall have a red marking or other suitable designation. The final or outer section, opposite the neutral section of the terminal block, shall have a blue marking or other suitable designation.

## ARTICLE 364 — BUSWAYS

**364-1. Other Articles.** Installations of busways shall comply with the applicable provisions of Article 300.

**364-2. Use.** Busways may be installed only for exposed work. Busways shall not be installed (1) where subject to severe physical damage or corrosive vapors; (2) in hoistways; (3) in any hazardous location; nor (4) outdoors or in wet or damp locations unless specially approved for the purpose.

Busways may be used for service-entrance conductors. See Section 230-44.

It is recommended that where secondary systems are operated ungrounded, a combination ground detector and potentializer plug be used as an auxiliary fitting for busway systems to establish a definite potential difference between the bus-bars and the grounded casing of the busways. This will serve to drain off any static or other charge from the entire busway system including its connected apparatus, supply and branch-circuit conductors.

**364-3. Support.** Busways shall be securely supported at intervals not exceeding 5 feet, unless specially approved for supports at greater intervals, but in no case shall the distance between supports exceed 10 feet. Where a busway is installed in a vertical position, the supports for the bus-bars shall be designed for vertical installation.

**364-4. Through Walls and Floors.** Busways may extend transversely through dry walls if in unbroken lengths where passing through. Busways may extend vertically through dry floors when totally enclosed (unventilated) where passing through and for a minimum distance of 6 feet above the floor to provide adequate protection from physical damage.

**364-5. Dead Ends.** A dead end of a busway shall be closed.

**364-7. Branches from Busways.** Branches from busways shall be made with busways or with rigid or flexible metal conduit, electrical metallic

tubing, surface metal raceway, metal-clad cable or with suitable cord assemblies approved for hard usage for portable equipment or for the connection of stationary equipment to facilitate their interchange.

**364-8. Overcurrent Protection.** Overcurrent protection shall be provided in accordance with Sections 364-9 through 364-13.

**364-9. Rating of Overcurrent Protection — Feeders and Sub-Feeders.** Where the allowable current rating of the busway does not correspond to a standard rating of the overcurrent device, the next higher rating may be used.

**364-10. Reduction in Size of Busway.** Overcurrent protection may be omitted at points where busways are reduced in size, provided that the smaller busway does not extend more than 50 feet and has a current rating at least equal to one-third the rating or setting of the overcurrent device next back on the line, and provided further that such busway is free from contact with combustible material.

**364-11. Branch Circuits.** Where a busway is used as a feeder, devices or plug-in connections for tapping off branch circuits from the busway shall contain the overcurrent devices required for the protection of the branch circuits.

*Exception No. 1: For overcurrent protection of taps, see Section 240-15.*

*Exception No. 2: For fixed or semi-fixed lighting fixtures, the branch-circuit overcurrent device may be part of the fixture cord plug on cord-connected fixtures.*

*Exception No. 3: Where fixtures without cords are plugged directly into the busway, the overcurrent device may be mounted on the fixture.*

**364-12. Rating of Overcurrent Protection — Branch Circuits.** A busway may be used as a branch circuit of any one of the types described in Article 210. When so used, the rating or setting of the overcurrent device protecting the busway shall determine the ampere rating of the branch circuit, and the circuit shall in all respects conform with the requirements of Article 210 that apply to branch circuits of that rating.

**364-13. Length of Busways Used as Branch Circuits.** Busways which are used as branch circuits and which are so designed that loads can be connected at any point shall be limited to such lengths as will provide that in normal use the circuits will not be overloaded.

In general, the length of such run in feet should not exceed 3 times the ampere rating of the branch circuit.

**364-14. Marking.** Busways shall be marked with the voltage and current rating for which they are designed, and with the manufacturer's name or trademark in such manner as to be visible after installation.

## ARTICLE 365 — CABLEBUS

**365-1. Definition.** Cablebus is an approved assembly of insulated conductors mounted in spaced relationship in a ventilated metal protective supporting structure including fittings and conductor terminations. Cablebus may be used at any voltage or current for which the spaced conductors are rated.

Cablebus is ordinarily assembled at the point of installation, from components furnished or specified by the manufacturer.

**365-2. Use.** Cablebus shall be installed only for exposed work. Cablebus installed outdoors or in corrosive, wet or damp locations shall be approved for the purpose. Cablebus shall not be installed in hoistways or in hazardous locations unless specifically approved for such use. Cablebus may be used for branch circuits, feeders and services.

Approved cablebus framework where adequately bonded may be used as the equipment grounding conductor for branch circuits and feeders.

### 365-3. Conductors.

(a) **Types of Conductors.** The current-carrying conductors in cablebus shall have an insulation rating of 75°C or better of an approved type and suitable for the application in accordance with Articles 310 and 710.

(b) **Ampacity of Conductors.** The ampacity of conductors in cablebus shall be in accordance with Tables 310-13 and 310-15.

(c) **Size and Number of Conductors.** The size and number of conductors shall be that for which the cablebus is designed, and in no case smaller than 1/0 AWG.

(d) **Conductor Supports.** The insulated conductors shall be supported on blocks or other mounting means designed for the purpose.

The individual conductors in a cablebus shall be supported at intervals not greater than 3 feet for horizontal runs and 1½ feet for vertical runs. Vertical and horizontal spacing between supported conductors shall be not less than one conductor diameter at the points of support.

**365-5. Overcurrent Protection.** When the allowable current rating of the cablebus conductors does not correspond to a standard rating of the overcurrent device, the next higher rated overcurrent device may be used.

### 365-6. Support.

(a) Cablebus shall be securely supported at intervals not exceeding 12 feet.

(b) Cablebus may extend transversely through partitions or walls, other than fire walls, provided the section within the wall is continuous, protected against physical damage and unventilated.

(c) Except where fire stops are required, cablebus may extend vertically through dry floors and platforms, provided the cablebus is totally enclosed at the point where it passes through the floor or platform and for a distance of 6 feet above the floor or platform.

(d) Except where fire stops are required, cablebus may extend vertically through floors and platforms in wet locations where (1) there are curbs or other suitable means to prevent waterflow through the floor or platform opening and (2) where the cablebus is totally enclosed at the point where it passes through the floor or platform and for a distance of 6 feet above the floor or platform.

#### **365-7 Fittings.**

(a) Cablebus system shall provide approved fittings for:

(1) Changes in horizontal or vertical direction of the run.

(2) Dead ends.

(3) Terminations in or on connected apparatus or equipment or the enclosures for such equipment.

(4) Additional physical protection where required such as guards for severe mechanical exposure.

**365-8. Conductor Terminations.** Approved terminating means shall be used for connections to cablebus conductors.

**365-9. Grounding.** Sections of cablebus shall be electrically bonded either by inherent design of the mechanical joints or by applied bonding means. See Section 250-75.

A cablebus installation shall be grounded in accordance with the requirements of Sections 250-32 and 250-33.

**365-10. Marking.** Each section of cablebus shall be marked with the manufacturer's name or trade designation and the maximum diameter, number, voltage rating and ampacity of the conductors to be installed. Markings shall be so located as to be visible after installation.

## **ARTICLE 370 — OUTLET, SWITCH AND JUNCTION BOXES, AND FITTINGS**

### **A. Scope and General**

**370-1. Scope.** The provisions of this Article shall apply to the installation of outlet, switch and junction boxes, and fittings as required by Section 300-15. Installations in hazardous locations shall conform to Articles 500 through 517.

The provisions contained in this Article for boxes shall also apply to those conduit fittings with covers which serve to enclose the conductors in that conduit system.

**370-2. Round Boxes.** Round boxes shall not be used where conduits or connectors requiring the use of locknuts or bushings are to be connected to the side of the box.

**370-3. Nonmetallic Boxes.** Nonmetallic boxes approved for the purpose may be used only with open wiring on insulators, concealed knob-and-tube work, nonmetallic-sheathed cable, and with approved non-metallic conduit.



**370-4. Metallic Boxes.** Where used with knob-and-tube work or non-metallic-sheathed cable, and mounted on metal or metal lath ceilings or walls, such boxes shall be insulated from their supports and from the metal or metal lath, or shall be grounded.

#### **B. Installation**

**370-5. Damp or Wet Locations.** In damp or wet locations, boxes and fittings shall be so placed or equipped as to prevent moisture or water from entering and accumulating within the box or fitting. Boxes and fittings installed in wet locations shall be weatherproof. For boxes in floors, see Section 370-17.

It is recommended that approved boxes of nonconductive material be used with nonmetallic-sheathed cable or approved nonmetallic conduit when such cable or conduit is used in locations where there is likely to be occasional moisture present such as in dairy barns.

**370-6. Number of Conductors in a Box.** Boxes shall be of sufficient size to provide free space for all conductors enclosed in the box.

The provisions of this Section shall not apply to terminal housings supplied with motors. See Section 430-12.

Sections 370-6(a) and (b) do not apply to conductors used for re-wiring existing raceways as referred to in Table 1, Chapter 9.

(a) The maximum number of conductors, not counting fixture wires, permitted in outlet and junction boxes shall be as in Tables 370-6(a) (1) and (a) (2) with the exceptions noted.

Tables 370-6(a) (1) and (a) (2) apply where no fittings or devices such as fixture studs, cable clamps, hickey, switches or receptacles, are contained in the box and where no grounding conductors are part of the wiring within the box. Where one or more fixture studs, cable clamps or hickey are contained in the box, the number of conductors shall be one less than shown in the Tables; an additional deduction of one conductor shall be made for each strap containing one or more devices; and a further deduction of one conductor shall be made for one or more grounding conductors entering the box. A conductor running through the box is counted as one conductor, and each conductor originating outside of the box and terminating inside the box is counted as one conductor. Conductors, no part of which leaves the box, are not to be counted. The volume of a wiring enclosure (box) shall be the total of the volume of the assembled sections.

(b) For combinations or conductor sizes not shown in Tables 370-6(a) (1) and (a) (2), Table 370-6(b) shall apply.

(c) Boxes, other than those described in Tables 370-6(a) (1) and 370-6(a) (2), shall be durably and legibly marked by the manufacturer with their cubic-inch content. All boxes shall be durably and legibly marked with the manufacturer's name or trademark.

**370-7. Conductors Entering Boxes or Fittings.** Conductors entering boxes or fittings shall be protected from abrasion, and shall conform to the following:

(a) **Openings to Be Closed.** Openings through which conductors enter shall be adequately closed.

**Table 370-6(a)(1). Deep Boxes**

Box Dimensions, Inches Trade Size	Cubic Inch Cap.	Maximum Number of Conductors			
		No. 14	No. 12	No. 10	No. 8
3¼ x 1½ Octagonal .....	10.9	5	4	4	3
3½ x 1½ " .....	11.9	5	5	4	3
4 x 1½ " .....	17.1	8	7	6	5
4 x 2½ " .....	23.6	11	10	9	7
4 x 1½ Square .....	22.6	11	10	9	7
4 x 2½ " .....	31.9	15	14	12	10
4 11/16 x 1½ Square .....	32.2	16	14	12	10
4 11/16 x 2½ " .....	46.4	23	20	18	15
3 x 2 x 1½ Device .....	7.9	3	3	3	2
3 x 2 x 2 " .....	10.7	5	4	4	3
3 x 2 x 2¼ " .....	11.3	5	5	4	3
3 x 2 x 2½ " .....	13	6	5	5	4
3 x 2 x 2¾ " .....	14.6	7	6	5	4
3 x 2 x 3½ " .....	18.3	9	8	7	6
4 x 2½ x 1½ " .....	11.1	5	4	4	3
4 x 2½ x 1¾ " .....	13.9	6	6	5	4
4 x 2½ x 2½ " .....	15.6	7	6	6	5

See Section 370-18 where boxes are used as pull and junction boxes.

**Table 370-6(a)(2). Shallow Boxes**

Box Dimensions, Inches Trade Size	Maximum Number of Conductors		
	No. 14	No. 12	No. 10
3¼ .....	4	4	3
4 .....	6	6	4
1½ x 4 Square .....	9	7	6
4 11/16 .....	8	6	6

Any box less than 1½-inch deep is considered to be a shallow box.

**Table 370-6(b). Volume Required Per Conductor**

Size of Conductor	Free Space Within Box for Each Conductor
No. 14 .....	2. cubic inches
No. 12 .....	2.25 cubic inches
No. 10 .....	2.5 cubic inches
No. 8 .....	3. cubic inches
No. 6 .....	5. cubic inches

(370-7 continued)

**(b) Metal Boxes and Fittings.** Where metal outlet boxes or fittings are installed with open wiring or concealed knob-and-tube work, conductors shall enter through insulating bushings or, in dry places, through flexible tubing extending from the last insulating support and firmly secured to the box or fitting. Where raceway or cable is installed with metal outlet boxes or fittings, the raceway or cable shall be secured to such boxes and fittings.

**(c) Nonmetallic Boxes.** Where nonmetallic boxes are used with open wiring or concealed knob-and-tube work, the conductors shall enter through individual holes. Where flexible tubing is used to encase the conductor, the tubing shall extend from the last insulating support and may be run into the box or terminate at the wall of the box. If non-metallic-sheathed cable is used, the cable assembly shall enter the box through a knockout opening. Clamping of individual conductors or cables to the box is not required where supported within 8 inches of the box. Where nonmetallic conduit is installed with nonmetallic boxes or fittings, the conduit shall be secured to such boxes and fittings in an approved manner.

**370-8. Unused Openings.** Unused openings in boxes and fittings shall be effectively closed to afford protection substantially equivalent to that of the wall of the box or fitting. Metal plugs or plates used with non-metallic boxes or fittings shall be recessed at least  $\frac{1}{4}$  inch from the outer surface.

**370-9. Boxes Enclosing Flush Devices.** Boxes used to enclose flush devices shall be of such design that the devices will be completely enclosed on back and sides, and that substantial support for the devices will be provided. Screws for supporting the box shall not be used in attachment of the device contained therein.

**370-10. In Wall or Ceiling.** In walls or ceilings of concrete, tile or other noncombustible material, boxes and fittings shall be so installed that the front edge of the box or fitting will not set back of the finished surface more than  $\frac{1}{4}$  inch. In walls and ceilings constructed of wood or other combustible material, outlet boxes and fittings shall be flush with the finished surface or project therefrom.

**370-11. Repairing Plaster.** Except on walls or ceilings of concrete, tile or other noncombustible material, a plaster surface which is broken or incomplete shall be repaired so that there will be no gaps or open spaces at the edge of the box or fitting.

**370-12. Exposed Extensions.** In making an exposed extension from an existing outlet of concealed wiring, a box, extension ring or blank cover shall be mounted over the original box and electrically and mechanically secured to it. The extension shall then be connected to this box in the manner prescribed for the method of wiring employed in making the extension.

**370-13. Supports.** Boxes shall be securely and rigidly fastened to the surface upon which they are mounted, or securely and rigidly embedded in concrete or masonry. Except as otherwise provided in this Section, boxes shall be supported from a structural member of the building either directly or by using a substantial and approved metallic or wooden

brace. If of wood the brace shall not be less than nominal one-inch thickness. If of metal it shall be corrosion-resistant and shall be not less than No. 24 MSG.

Where mounted in new walls in which no structural members are provided or in existing walls in previously occupied buildings, boxes not over 100 cubic inches in size, specifically approved for the purpose, shall be affixed with approved anchors or clamps so as to provide a rigid and secure installation.

Threaded boxes or fittings not over 100 cubic inches in size, which do not contain devices or support fixtures may be considered adequately supported if two or more conduits are threaded into the box wrench-tight and are supported within 3 feet of the box on two or more sides as is required by this Section.

Threaded boxes or fittings, not over 100 cubic inches in size, may be considered to be adequately supported if two or more conduits are threaded into the box wrenchtight and are supported as required by this Section within 18 inches of the box.

**370-14. Depth of Outlet Boxes for Concealed Work.** Outlet boxes for concealed work shall have an internal depth of at least 1½ inches, except that where the installation of such a box will result in injury to the building structure or is impracticable, a box not less than ½ inch internal depth may be installed.

**370-15. Covers and Canopies.** In completed installations each outlet box shall be provided with a cover unless a fixture canopy is used.

(a) Nonmetallic covers and plates or metallic covers and plates may be used with nonmetallic outlet boxes. When metallic covers or plates are used, they shall comply with the grounding requirements of Section 250-42.

See Section 410-95.

(b) Where a fixture canopy or pan is used, any combustible wall or ceiling finish exposed between the edge of the canopy or pan and the outlet box shall be covered with noncombustible material.

(c) Covers of outlet boxes having holes through which flexible cord pendants pass, shall be provided with bushings designed for the purpose or shall have smooth, well-rounded surfaces on which the cords may bear. So-called hard-rubber or composition bushings shall not be used.

**370-16. Fastened to Gas Pipes.** Outlet boxes used where gas outlets are present shall be so fastened to the gas pipes as to be mechanically secure.

**370-17. Outlet Boxes.**

(a) **Boxes at Lighting Fixture Outlets.** Boxes used at lighting fixture outlets shall be designed for the purpose. At every outlet used exclusively for lighting, the box shall be so designed or installed that a lighting fixture may be attached.

(b) **Floor Boxes.** Floor boxes especially approved for the purpose shall be used for receptacles located in the floor.

*Exception: The standard approved type of flush receptacle box may be used where receptacles are located in elevated floors of show windows or other locations when the authority enforcing this Code judges them to be free from physical damage, moisture and dirt.*

**370-18. Pull and Junction Boxes.** Pull and junction boxes shall conform to the following:

**(a) Minimum Size.** For raceways of one-inch trade size and larger, containing conductors of No. 6 or larger, and for cables\* containing conductors of No. 6 or larger, the minimum dimensions of a pull or junction box installed in a raceway or cable run shall conform to the following:

**(1) Straight Pulls.** In straight pulls the length of the box shall be not less than 8 times the trade diameter of the largest raceway.

**(2) Angle or U Pulls.** Where angle or U pulls are made, the distance between each raceway entry inside the box and the opposite wall of the box shall not be less than 6 times the trade diameter of the largest raceway. This distance shall be increased for additional entries by the amount of the sum of the diameters of all other raceway entries on the same wall of the box. The distance between raceway entries enclosing the same conductor shall not be less than 6 times the trade diameter of the larger raceway.

**(3) Boxes of lesser dimensions than those required in sub-sections (1) and (2) of this Section may be used for installations of combinations of conductors which are less than the maximum conduit fill (of conduits being used) permitted by Table 1, Chapter 9, provided the box has been approved for and is permanently marked with the maximum number of conductors and the maximum AWG size permitted.**

*Exception: Terminal housings supplied with motors which shall comply with the provisions of Section 430-12.*

**(b) Conductors in Pull or Junction Boxes.** In pull boxes or junction boxes having any dimension over 6 feet, all conductors shall be cabled or racked up in an approved manner.

See Section 373-6(b) for insulation of conductors at bushings.

**(c) Covers.** All pull boxes, junction boxes and fittings shall be provided with covers approved for the purpose. Where metallic covers are used, they shall comply with the grounding requirements of Section 250-42.

**370-19. Junction, Pull and Outlet Boxes to Be Accessible.** Junction, pull and outlet boxes shall be so installed that the wiring contained in them may be rendered accessible without removing any part of the building, sidewalks or paving.

---

\* When transposing cable size into raceway size in (1) and (2) above, the minimum trade size raceway required for the number and size of conductors in the cable shall be used.

### C. Construction Specifications

**370-20. Metallic Outlet, Switch and Junction Boxes and Fittings.** Outlet, switch and junction boxes and fittings, when of metal, shall conform to the following:

(a) **Corrosion-Resistant.** Metallic boxes and fittings, unless of corrosion-resistant metal, shall be well galvanized, enameled, or otherwise properly coated, inside and out, to prevent corrosion.

See Section 300-5 for limitation in the use of boxes and fittings protected from corrosion solely by enamel.

It is recommended that the protective coating be of conductive material, such as cadmium, tin or zinc, in order to secure better electrical contact.

(b) **Thickness of Metal.** Sheet metal boxes and fittings not over 100 cubic inches in size shall be made from metal not less than No. 14 MSG. Cast-metal boxes shall have a wall thickness not less than  $\frac{1}{8}$  inch, except that boxes of malleable iron shall have a wall thickness of not less than  $\frac{3}{32}$  inch.

(c) **Boxes Over 100 Cubic Inches.** Boxes of over 100 cubic inches in size shall be composed of metal and shall conform to the requirements for cabinets and cutout boxes, except that the covers may consist of single flat sheets secured to the box proper by screws, or bolts instead of hinges. Boxes having covers of this form are for use only for enclosing joints in conductors or to facilitate the drawing in of wires and cables. They are not intended to enclose switches, cutouts or other control devices.

**370-21. Covers.** Metal covers shall be of a thickness not less than that specified for the walls of the box or fitting of the same material and with which they are designed to be used, or shall be lined with firmly attached insulating material not less than  $\frac{1}{32}$  inch in thickness. Covers of porcelain or other approved insulating material may be used when of such form and thickness as to afford the requisite protection and strength.

**370-22. Bushings.** Covers of outlet boxes and outlet fittings having holes through which flexible cord pendants may pass, shall be provided with approved bushings or shall have smooth, well-rounded surfaces, upon which the cord may bear. Where conductors other than flexible cord may pass through a metal cover, there shall be provided a separate hole for each wire, said hole being equipped with a bushing of suitable insulating material.

**370-23. Nonmetallic Boxes.** Provisions for supports, or other mounting means, for nonmetallic boxes, shall be outside of the box, or the box shall be so constructed as to prevent contact between the conductors in the box and the supporting screws.

## ARTICLE 373 — CABINETS AND CUTOOT BOXES

**373-1. Scope.** The provisions of this Article shall apply to the installation of cabinets and cutout boxes. Installations in hazardous locations shall conform to the provisions of Articles 500 through 517.

### A. Installation

**373-2. Damp or Wet Locations.** In damp or wet locations, cabinets and cutout boxes of the surface type shall be so placed or equipped as to prevent moisture or water from entering and accumulating within the cabinet or cutout box, and shall be mounted so there is at least  $\frac{1}{4}$ -inch air space between the enclosure and the wall or other supporting surface. Cabinets or cutout boxes installed in wet locations shall be weatherproof.

It is recommended that boxes of nonconductive material be used with nonmetallic-sheathed cable when such cable is used in locations where there is likely to be moisture present.

**373-3. Position in Wall.** In walls of concrete, tile, or other noncombustible material, cabinets shall be so installed that the front edge of the cabinet will not set back of the finished surface more than  $\frac{1}{4}$  inch. In walls constructed of wood or other combustible material, cabinets shall be flush with the finished surface or project therefrom.

**373-4. Unused Openings.** Unused openings in cabinet or cutout boxes shall be effectively closed to afford protection substantially equivalent to that of the wall of the cabinet or cutout box. Where metal plugs or plates are used with nonmetallic cabinets or cutout boxes, they shall be recessed at least  $\frac{1}{4}$  inch from the outer surface.

**373-5. Conductors Entering Cabinets or Cutout Boxes.** Conductors entering cabinets or cutout boxes shall be protected from abrasion and shall conform to the following:

(a) **Openings to Be Closed.** Openings through which conductors enter shall be adequately closed.

(b) **Metal Cabinets and Cutout Boxes.** Where metal cabinets or cutout boxes are installed with open wiring or concealed knob-and-tube work, conductors shall enter through insulating bushings or, in dry places, through flexible tubing extending from the last insulating support and firmly secured to the cabinet or cutout box.

**373-6. Deflection of Conductors.** Conductors at terminals or conductors entering or leaving cabinets or cutout boxes and the like shall conform to the following:

(a) **Width of Wiring Gutters.** Conductors shall not be deflected within a cabinet or cutout box unless a gutter having a width in accordance with Table 373-6(a) is provided. Conductors in multiple in accordance with Section 310-10 are judged on the basis of the number of conductors in multiple.

(1) **Wire Bending Space at Terminals.** Conductors shall not be deflected at a terminal unless bending space in accordance with Table 373-6(a) is provided.

**Table 373-6(a) — Minimum Wire Bending Space at Terminals and Minimum Width of Wiring Gutters in Inches**

AWG or Circular-Mil Size of Wire	Wires per Terminal				
	1	2	3	4	5
14-8	Not Specified	—	—	—	—
6	1½	—	—	—	—
4-3	2	—	—	—	—
2	2½	—	—	—	—
1	3	—	—	—	—
0-00	3½	5	7	—	—
000-0000	4	6	8	—	—
250 MCM	4½	6	8	10	—
300-350 MCM	5	8	10	12	—
400-500 MCM	6	8	10	12	14
600-700 MCM	8	10	12	14	16
750-900 MCM	8	12	14	16	18
1,000-1,250 MCM	10	—	—	—	—
1,500-2,000 MCM	12	—	—	—	—

Bending space at terminals shall be measured in a straight line from the end of the lug or wire connector (in the direction that the wire leaves the terminal) to the wall or barrier.

**(b) Insulation at Bushings.** Where ungrounded conductors of No. 4 or larger enter a raceway in a cabinet, pull box, junction box, or auxiliary gutter, the conductors shall be protected by a substantial bushing providing a smoothly rounded insulating surface, unless the conductors are separated from the raceway fitting by substantial insulating material securely fastened in place. Where conduit bushings are constructed wholly of insulating material, a locknut shall be installed both inside and outside the enclosure to which the conduit is attached.

**373-7. Space in Enclosures.** Cabinets and cutout boxes shall conform to the following:

**(a) To Accommodate Conductors.** Cabinets and cutout boxes shall be selected which have sufficient space to accommodate all conductors installed in them without crowding.

**373-8. Enclosures for Switches or Overcurrent Devices.** Enclosures for switches or overcurrent devices shall not be used as junction boxes, auxiliary gutters or raceways for conductors feeding through or tapping off to other switches or overcurrent devices, unless adequate space is provided so that the conductors do not fill the wiring space at any cross section to more than 40 percent of the cross-sectional area of the space, and so that the conductors, splices and taps do not fill the wiring space at any cross section to more than 75 percent of the cross-sectional area of the space.

**373-9. Side or Back Wiring Spaces or Gutters.** Cabinets and cutout boxes shall be provided with back wiring spaces, gutters, or wiring compartments as required by Section 373-11(c) and (d).



**B. Construction Specifications**

**373-10. Material.** Cabinets and cutout boxes shall conform to the following:

(a) **Metal Cabinets and Boxes.** Metal cabinets and cutout boxes shall be well galvanized, plated with cadmium or other approved metallic finish, enameled, or otherwise properly coated, inside and out, to prevent corrosion.

It is recommended that the protective coating be of conductive material, such as cadmium, tin or zinc, in order to secure better electrical contact.

(b) **Strength.** The design and construction of cabinets and cutout boxes shall be such as to secure ample strength and rigidity. If constructed of sheet steel, the metal shall be of not less than No. 16 MSG.

(c) **Composition Cabinets.** Composition cabinets shall be submitted for approval prior to installation.

**373-11. Spacing.** The spacing within cabinets and cutout boxes shall conform to the following:

(a) **General.** The spacing within cabinets and cutout boxes shall be sufficient to provide ample room for the distribution of wires and cables placed in them, and for a separation between metal parts of devices and apparatus mounted within them as follows:

(1) **Base.** There shall be an air space of at least 1/16 inch, except at points of support, between the base of the device and the wall of any metal cabinet or cutout box in which the device is mounted.

(2) **Doors.** There shall be an air space of at least one inch between any live metal part (including live metal parts of enclosed fuses) and the door, unless the door is lined with an approved insulating material or is of a thickness of metal not less than No. 12 MSG when the air space shall be not less than 1/2 inch.

(3) **Doors and Walls — Link Fuses.** There shall be a space of at least 2 inches between open-link fuses and metal-lined walls or metal, metal-lined or glass-paneled doors.

(4) **Live Parts.** Except as noted above, there shall be an air space of at least 1/2 inch between the walls, back, gutter partition, if of metal, or door of any cabinet or cutout box and the nearest exposed current-carrying part of devices mounted within the cabinet where the potentials do not exceed 250 volts. This spacing shall be increased to at least one inch where the potentials exceed 250 volts.

(b) **Switch Clearance.** Cabinets and cutout boxes shall be deep enough to allow the closing of the doors when 30-ampere branch-circuit panelboard switches are in any position, or when combination cutout switches are in any position, or when other single-throw switches are opened as far as their construction will permit.

(c) **Wiring Space.** Cabinets and cutout boxes which contain devices or apparatus connected within the cabinet or box to more than 8 conductors, including those of branch circuits, meter loops, sub-feeder circuits, power circuits and similar circuits, but not including the supply

(373-11(c) continued)

circuit or a continuation thereof, shall have back-wiring spaces or one or more side-wiring spaces, side gutters or wiring compartments.

**(d) Wiring Space — Enclosure.** Side-wiring spaces, side gutters or side-wiring compartments of cabinets and cutout boxes shall be rendered tight enclosures by means of covers, barriers or partitions extending from the bases of the devices, contained in the cabinet, to the door, frame, or sides of the cabinet; provided, however, that where the enclosure contains only those conductors which are led from the cabinet at points directly opposite their terminal connections to devices within the cabinet, such covers, barriers or partitions may be omitted. Partially enclosed back-wiring spaces shall be provided with covers to complete enclosure. Wiring spaces that are required by Section 373-11(c) and which are exposed when doors are open, shall be provided with covers to complete the enclosure. Where adequate space is provided for feed-through conductors and for splices as is required in Section 373-8, additional barriers are not required.

## ARTICLE 374 — AUXILIARY GUTTERS

**374-1. Purpose.** Auxiliary gutters, used to supplement wiring spaces at meter centers, distribution centers, switchboards and similar points of wiring systems, may enclose conductors or bus-bars, but shall not be used to enclose switches, overcurrent devices, appliances or other similar equipment.

**374-2. Extension Beyond Equipment.** An auxiliary gutter shall not extend a greater distance than 30 feet beyond the equipment which it supplements except in elevator work. Any extension beyond this distance shall comply with the provisions for wireways in Article 362 or with the provisions for busways in Article 364.

**374-3. Supports.** Gutters shall be supported throughout their entire length at intervals not exceeding 5 feet.

**374-4. Covers.** Covers shall be securely fastened to the gutter.

**374-5. Number of Conductors.** Auxiliary gutters shall not contain more than 30 current-carrying conductors at any cross section. The sum of the cross-sectional areas of all contained conductors at any cross section of an auxiliary gutter shall not exceed 20 percent of the interior cross-sectional area of the auxiliary gutter.

*Exception No. 1: See Section 620-35 for elevators.*

*Exception No. 2: Conductors for signal circuits or controller conductors between a motor and its starter and used only for starting duty shall not be considered as current-carrying conductors.*

*Exception No. 3: When the correction factors specified in Note 8 to Tables 310-12 thru 310-15 are applied, no limit on the number of current-carrying conductors is needed, but the sum of the cross-sectional*

*tional area of all contained conductors at any cross section of the auxiliary gutter shall not exceed 20 percent of the interior cross-sectional area of the auxiliary gutter.*

**374-6. Ampacity of Conductors.** The ampacities of insulated copper and aluminum conductors are given in Tables 310-12 and 310-14 respectively. When the number of current-carrying conductors contained in the auxiliary gutter is 30 or less, the correction factors specified in Note 8 of these Tables shall not apply. The current carried continuously in bare copper bars in auxiliary gutters shall not exceed 1000 amperes per square inch of cross section of the conductor. For aluminum bars the current carried continuously shall not exceed 700 amperes per square inch of cross section of the conductor.

**374-7. Clearance of Bare Live Parts.** Bare conductors shall be securely and rigidly supported so that the minimum clearance between bare current-carrying metal parts of opposite polarities mounted on the same surface shall be not less than 2 inches, nor less than one inch for parts that are held free in the air. A clearance not less than one inch shall be secured between bare current-carrying metal parts and any metal surface. Adequate provisions shall be made for the expansion and contraction of bus-bars.

**374-8. Splices and Taps.** Splices and taps shall conform to the following:

(a) Splices or taps, made and insulated by approved methods, may be located within gutters when they are accessible by means of removable covers or doors. The conductors, including splices and taps, shall not fill the gutter to more than 75 percent of its area.

(b) Taps from bare conductors shall leave the gutter opposite their terminal connections and conductors shall not be brought in contact with uninsulated current-carrying parts of opposite polarity.

(c) All taps shall be suitably identified at the gutter as to the circuit or equipment which they supply.

(d) Tap connections from conductors in auxiliary gutters shall be provided with overcurrent protection in conformity with the provisions of Section 240-15.

**374-9. Construction and Installation.** Auxiliary gutters shall be constructed in accordance with the following:

(a) Gutters shall be so constructed and installed that adequate electrical and mechanical continuity of the complete system will be secured.

(b) Gutters shall be of substantial construction and shall provide a complete enclosure for the contained conductors. All surfaces, both interior and exterior, shall be suitably protected from corrosion. Corner joints shall be made tight and where the assembly is held together by rivets or bolts, these shall be spaced not more than 12 inches apart.

(c) Suitable bushings, shields or fittings having smooth rounded edges shall be provided where conductors pass between gutters, through partitions, around bends, between gutters and cabinets or junction boxes

and at other locations where necessary to prevent abrasion of the insulation of the conductors.

(d) Gutters shall be constructed of sheet metal of thicknesses not less than in the following table:

Table 374-9(d)

Maximum Width of the Widest Surface of Gutters  
Thickness (Manufacturers Standard Gage)

Up to and including 6 inches .....	No. 16
Over 6 in. and not over 18 in. ....	No. 14
Over 18 in. and not over 30 in. ....	No. 12
Over 30 inches .....	No. 10

(e) Where insulated conductors are deflected within the auxiliary gutter, either at the ends or where conduits, fittings or other raceways enter or leave the gutter, or where the direction of the gutter is deflected greater than 30 degrees, dimensions corresponding to Section 373-6 shall apply.

(f) Auxiliary gutters intended for outdoor use shall be of approved raintight construction.

ARTICLE 380 — SWITCHES

A. Installation

**380-1. Grounded Conductors.** No switch or circuit breaker shall disconnect the grounded conductor of a circuit unless the switch or circuit breaker simultaneously disconnects the ungrounded conductor or conductors, or unless the switch or circuit breaker is so arranged that the grounded conductor cannot be disconnected until the ungrounded conductor or conductors have first been disconnected.

**380-2. Three-Way and Four-Way Switches.** Three-way and four-way switches shall be so wired that all switching is done only in the ungrounded circuit conductor. Wiring between switches and outlets shall, where in metal enclosures, be run with both polarities in the same enclosure.

**380-3. Enclosures.** Switches and circuit breakers shall be of the externally operable type enclosed in metal boxes or cabinets, except pendant- and surface-type snap switches and knife switches mounted on an open-face switchboard or panelboard.

**380-4. Wet Locations.** A switch or circuit breaker in a wet location or outside of a building shall be enclosed in a weatherproof enclosure or cabinet installed to conform to Section 373-2.

**380-5. Time Switches, Flashers, and Similar Devices.** Time switches, flashers, and similar devices need not be of the externally operable type. They shall be enclosed in metal boxes or cabinets except:

*Exception No. 1: Where mounted on switchboards or control panels.*

*Exception No. 2: Where enclosed in approved individual housings.*

**380-6. Position of Knife Switches.** Single-throw knife switches shall be so placed that gravity will not tend to close them. Double-throw knife switches may be mounted so that the throw will be either vertical or horizontal as preferred, but where the throw be vertical a locking device shall be provided which will insure the blades remaining in the open position when so set.

**380-7. Connection of Knife Switches.** Knife switches, unless of the double-throw type, shall be so connected that the blades are dead when the switch is in the open position.

**380-8. Accessibility and Grouping.** Switches and circuit breakers, so far as practicable, shall be readily accessible and shall be grouped.

Snap switches shall not be grouped or ganged in outlet boxes unless they can be so arranged that the voltage between adjacent switches does not exceed 300, or unless they are installed in boxes equipped with permanently installed barriers between adjacent switches.

**380-9. Faceplates for Flush-Mounted Snap Switches.** Flush snap switches, that are mounted in ungrounded metal boxes and located within reach of conducting floors or other conducting surfaces, shall be provided with faceplates of nonconducting, noncombustible material. Metallic faceplates shall be of ferrous metal not less than 0.030 inch in thickness or of nonferrous metal not less than 0.040 inch in thickness. Faceplates of insulating material shall be noncombustible and not less than 0.10 inch in thickness but may be less than 0.10 inch in thickness if formed or reinforced to provide adequate mechanical strength.

**380-10. Mounting of Snap Switches.**

(a) **Surface-Type.** Snap switches used with open wiring on insulators shall be mounted on sub-bases of insulating material which will separate the conductors at least  $\frac{1}{2}$  inch from the surface wired over.

(b) **Box Mounted.** Flush-type snap switches mounted in boxes which are set back of the wall surface as permitted in Section 370-10 shall be installed so that the extension plaster ears are seated against the surface of the wall. Flush-type snap switches mounted in boxes which are flush with the wall surface or project therefrom shall be so installed that the mounting yoke or strap of the switch is seated against the box.

**380-11. Circuit Breakers as Switches.** A circuit breaker operable directly by applying the hand to a lever or handle may serve as a switch provided it has the number of poles required for such switch.

**380-12. Grounding of Enclosures.** Enclosures for switches or circuit breakers on circuits of over 150 volts to ground shall be grounded in the manner specified in Article 250, except where accessible to qualified operators only.

**380-13. Knife Switches.**

(a) Knife switches rated for more than 1200 amperes at 250 volts or less, and for more than 600 amperes at 251 to 600 volts, shall be used only as isolating switches and shall not be opened under load.

(b) To interrupt currents greater than 1200 amperes at 250 volts or less, or 600 amperes at 251 to 600 volts, a circuit breaker or a switch of special design approved for such purpose shall be used.

(c) Knife switches of lower rating may be used as general-use switches and may be opened under load.

(d) Motor-circuit switches (see Definition in Article 100) may be of the knife-switch type.

**380-14. Rating and Use of Snap Switches.** Snap switches shall be used within their ratings and as follows:

(a) **AC General-Use Snap Switch.** A form of general-use snap switch suitable only for use on alternating-current circuits for controlling the following:

(1) Resistive and inductive loads, including electric-discharge lamps, not exceeding the ampere rating of the switch at the voltage applied.

(2) Tungsten-filament lamp loads not exceeding the ampere rating of the switch at 120 volts.

(3) Motor loads not exceeding 80 percent of the ampere rating of the switch at its rated voltage.

(b) **AC-DC General-Use Snap Switch.** A form of general-use snap switch suitable for use on either AC or DC circuits for controlling the following:

(1) Resistive loads not exceeding the ampere rating of the switch at the voltage applied.

(2) Inductive loads not exceeding 50 percent of the ampere rating of the switch at the applied voltage. Switches rated in horsepower are suitable for controlling motor loads within their rating at voltage applied.

(3) Tungsten-filament lamp loads not exceeding the ampere rating of the switch at the applied voltage, when "T" rated.

For switches on signs and outline lighting, see Section 600-2.

For switches controlling motors, see Sections 430-83, 430-109 and 430-110.

## **B. Construction Specifications**

**380-15. Marking.** Switches shall be marked with the current and voltage and, if horsepower rated, the maximum rating for which they are designed.

**380-16. 600-Volt Knife Switches.** Auxiliary contacts of a renewable or quick-break type or the equivalent, shall be provided on all 600-volt knife switches designed for use in breaking currents over 200 amperes.

It is recommended that such auxiliary contacts be provided on all direct-current switches rated at over 250 volts.

**380-17. Fused Switches.** A fused switch shall not have fuses in parallel.

## ARTICLE 384 — SWITCHBOARDS AND PANELBOARDS

**384-1. Scope.** The requirements of this Article shall apply to all switchboards, panelboards, and distribution boards installed for the control of light and power circuits.

*Exception No. 1: Switchboards in utility-company-operated central stations or substations, which directly control energy derived from generators or transforming devices.*

*Exception No. 2: Switchboards or portions thereof used exclusively to control signal circuits operated by batteries.*

The requirements of this Article shall apply to battery-charging panels where current is taken from light or power circuits.

**384-2. Application of Other Articles.** Switches, circuit breakers and overcurrent devices used on switchboards, panelboards and distribution boards, the boards and their enclosures, shall conform to the requirements of Articles 240, 250, 370, 380 and other Articles which apply. Switchboards and panelboards in hazardous locations shall conform to the requirements of Articles 500 through 517.

### **384-3. Support and Arrangement of Bus-bars and Conductors.**

(a) Conductors and bus-bars on a switchboard, panelboard or control board shall be so located as to be free from physical damage and shall be held firmly in place.

(b) The arrangement of bus-bars and conductors shall be such as to avoid overheating due to inductive effects.

(c) Each switchboard, switchboard section or panelboard, if used as service equipment, shall be provided with an equipment grounding means placed within the service disconnect section for connecting the grounded circuit conductor on its supply side to the switchboard or panelboard frame. The equipment grounding means shall not be smaller than called for in Table 250-95 nor smaller than No. 8 AWG copper conductor or approved equivalent.

(d) Load terminals in switchboards and panelboards shall be so located that it will be unnecessary to reach across or beyond a line bus in order to make load connections.

### **A. Switchboards**

**384-4. Location of Switchboards.** Switchboards which have any exposed live parts shall be located in permanently dry locations and then only where under competent supervision and accessible only to qualified persons.

**384-5. Wet Locations.** Where a switchboard is in a wet location or outside of a building, it shall be enclosed in a weatherproof enclosure or cabinet installed to conform to Section 373-2.

**384-6. Location Relative to Easily Ignitable Material.** Switchboards shall be so placed as to reduce to a minimum the probability of communicating fire to adjacent easily ignitable material.

**384-7. Clearance from Ceiling.** Switchboards shall not be built up to a nonfireproof ceiling, a space of 3 feet being left between the ceiling and the board, unless an adequate fireproof shield is provided between the board and the ceiling.

**384-8. Clearances Around Switchboards.** Clearances around switchboards shall conform to the provisions for working space about electrical equipment as specified in Section 110-16 of this Code.

**384-9. Conductor Covering.** Insulated conductors where closely grouped, as on the rear of switchboards, shall each have a flame-retardant outer covering. The conductor covering shall be stripped back a sufficient distance from the terminals so as to not make contact with them. Insulated conductors used for instrument and control wiring on the back of switchboards shall be flame-retardant, either inherently or by means of an outer covering, such as one of the following types: RH, RHH, RHW, V, ALS, AVA, AVB, SIS, T, TA, TBS, TW, THHN, THWN, THW, MI, XHHW, or other types specifically approved for the purpose.

**384-11. Grounding Switchboard Frames.** Switchboard frames and structures supporting switching equipment shall be grounded, except that frames of direct-current single-polarity switchboards need not be grounded if effectively insulated.

**384-12. Grounding of Instruments, Relays, Meters and Instrument Transformers on Switchboards.** Instruments, relays, meters and instrument transformers located on switchboards shall be grounded as specified in Sections 250-121 through 250-125.

## **B. Panelboards**

**384-13. General.** All panelboards shall have a rating not less than the minimum feeder capacity required for the load as computed from Article 220. Panelboards shall be durably marked by the manufacturer with the voltage and the current rating and the number of phases for which they are designed and with the manufacturer's name or trade-mark in such a manner as to be visible after installation, without disturbing the interior parts or wiring.

**384-14. Lighting and Appliance Branch-Circuit Panelboard.** For the purposes of this Article, a lighting and appliance branch-circuit panelboard is one having more than 10 percent of its overcurrent devices rated 30 amperes or less, for which neutral connections are provided.

**384-15. Number of Overcurrent Devices on One Panelboard.** Not more than 42 overcurrent devices (other than those provided for in the mains) of a lighting and appliance branch-circuit panelboard shall be installed in any one cabinet or cutout box.

A lighting and appliance branch-circuit panelboard shall be provided with physical means to prevent the installation of more overcurrent devices than that number for which the panelboard was designed, rated and approved.



For the purposes of this Article a 2-pole circuit breaker shall be considered two overcurrent devices; a 3-pole breaker shall be considered three overcurrent devices.

#### **384-16. Overcurrent Protection.**

(a) Each lighting and appliance branch-circuit panelboard shall be individually protected on the supply side by not more than two main circuit breakers or two sets of fuses having a combined rating not greater than that of the panelboard.

*Exception No. 1: Individual protection for a lighting and appliance panelboard is not required when the panelboard feeder has overcurrent protection not greater than that of the panelboard.*

*Exception No. 2: Individual protection for lighting and appliance branch-circuit panelboards is not required where such panelboards are used as service equipment in supplying an individual residential occupancy and where any bus supplying 15- or 20-ampere circuits is protected on the supply side by an overcurrent device.*

(b) Panelboards equipped with snap switches rated at 30 amperes or less, shall have overcurrent protection not in excess of 200 amperes.

(c) The total load on any overcurrent device located in a panelboard shall not exceed 80 percent of its rating where in normal operation the load will continue for 3 hours or more.

*Exception: Where the assembly including the overcurrent device is approved for continuous duty at 100 percent of its rating.*

**384-17. Panelboards in Damp or Wet Locations.** Panelboards in damp or wet locations shall be installed in conformity to Section 373-2.

**384-18. Enclosure.** Panelboards shall be mounted in cabinets or cut-out boxes.

**384-19. Relative Arrangement of Switches and Fuses.** Panelboards having switches on the load side of any type of fuses shall not be installed except for use as service equipment as provided in Section 230-94.

### **C. Construction Specifications**

**384-20. Panels.** The panels of switchboards shall be made of moisture-resistant, noncombustible material.

**384-21. Bus-bars.** Bus-bars may be of bare metal provided they are rigidly mounted.

**384-22. Protection of Instrument Circuits.** Instruments, pilot lights, potential transformers, and other switchboard devices with potential coils, except where the operation of the overcurrent device might introduce a hazard in the operation of devices, shall be supplied by a circuit that is protected by standard overcurrent devices of a rating not greater than 15 amperes, except that for ratings of 2 amperes or less special types of enclosed fuses may be used.

**384-23. Component Parts.** Switches, fuses, and fuseholders used on panelboards shall conform to the requirements of Articles 240 and 380 so far as they apply.

**384-24. Knife Switches.** Knife switches shall be so arranged that the blades, when exposed during operation, will be dead when the switches are open.

**384-25. Color Coding.** On switchboards or panelboards that are provided with color markings to indicate the main bus-bars to which branch-circuit bus-bars are connected, the colors shall conform to the color coding of Section 210-5.

**384-26. Spacings.** Except at switches and circuit breakers, the distance between bare metal parts, bus-bars, etc., shall be not less than specified in the following Table:

**Table 384-26. Spacings Between Bare Metal Parts**

	Opposite Polarity When Mounted on the Same Surface	Opposite Polarity When Held Free in Air	*Live Parts to Ground
Not over 125 volts .....	¾ inch	½ inch	½ inch
Not over 250 volts .....	1¼ inch	¾ inch	½ inch
Not over 600 volts .....	2 inches	1 inch	1 inch

\* For spacing between live parts and doors of cabinets, see Section 373-11(a) (1), (2), (3) and (4).

It should be noted that the above distances are the minimum allowable, and it is recommended that greater distances be provided wherever the conditions will permit.

At switches, enclosed fuses, etc., parts of the same polarity may be placed as close together as convenience in handling will allow, unless close proximity causes excessive heating.

**384-27. Grounding of Panelboards.** Panelboard cabinets shall be grounded in the manner specified in Article 250 or Section 384-3(c). An approved terminal bar for equipment grounding conductors shall be provided and secured inside of the cabinet for the attachment of all the feeder and branch-circuit equipment grounding conductors, when the panelboard is used with nonmetallic raceway, cable wiring or where separate grounding conductors are provided. The terminal bar shall be bonded to the cabinet or panelboard frame and shall not be connected to the neutral bar except at service equipment as permitted in Section 250-52.

---

ARTICLE 390 - PREFABRICATED BUILDINGS AND  
PREFABRICATED BUILDING INTERIORS

**390-1. Scope.** The intent and purpose of the following Sections is to define approved methods for the wiring of prefabricated building sections, panels, or units designed for later erection or assembly as integral parts of buildings whether wired in the process of manufacture or at the site of erection or assembly.

**390-2. Wiring Methods.** Only wiring methods recognized in this Code shall be used.

Prefabricated building interiors having electrical systems specifically designed and listed for exclusive use as component parts of the prefabricated building interior shall be considered as complying with the wiring methods of this Code.

**390-3. Code Provisions to Apply.** The provisions of this Code shall apply for the type of wiring method used and the type of construction employed.

## Chapter 4. Equipment for General Use

### ARTICLE 400 — FLEXIBLE CORDS AND CABLES

#### A. General and Types

**400-1. General.** Flexible cords and cables and their associated fitting shall be suitable for the conditions of use and location.

**400-2. Types.** Cords of the several types shall conform to the descriptions of Table 400-11. Types of flexible cords other than those listed in Table 400-11 and other uses for types listed in the Table, shall be the subject of special investigations and shall not be used before being approved.

#### B. Use and Installation

##### 400-3. Use.

(a) Flexible cord may be used only for (1) pendants; (2) wiring of fixtures; (3) connection of portable lamps or appliances; (4) elevator cables; (5) wiring of cranes and hoists; (6) connection of stationary equipment to facilitate their frequent interchange; or (7) prevention of the transmission of noise or vibration; or (8) facilitating the removal or disconnection of fixed or stationary appliances for maintenance or repair.

(b) Where used as permitted in sub-sections (a)(3), (a)(6), and (a)(8) of this Section, each flexible cord shall be equipped with an attachment plug and shall be energized from an approved receptacle outlet.

**400-4. Prohibited Uses.** Except where installed in accordance with Article 645, flexible cord shall not be used (1) as a substitute for the fixed wiring of a structure; (2) where run through holes in walls, ceilings, or floors; (3) where run through doorways, windows, or similar openings; (4) where attached to building surfaces; or (5) where concealed behind building walls, ceilings, or floors.

**400-5. Splices.** Flexible cord shall be used only in continuous lengths without splice or tap.

**400-6. Cords in Show Windows and Show Cases.** Flexible cord used in show windows and show cases shall be of Types S, SO, SJ, SJO, ST, STO, SJT, SJTO and AFS, except for the wiring of chain-supported fixtures, and for supplying current to portable lamps and other merchandise for exhibition purposes.

**400-7. Minimum Size.** The individual conductors of a flexible cord or cable shall be not smaller than the sizes shown in Table 400-11.

**400-8. Insulation—Over 300 Volts.** Where the voltage between any two conductors exceeds 300, but does not exceed 600, flexible cord of No. 10 and smaller shall have rubber or thermoplastic insulation on the

*(Continued on page 186)*

**Table 400-9(b). Ampacity of Flexible Cord**

Table 400-9(b) gives the allowable ampacity for not more than 3 current-carrying conductors in a cord. If the number of current-carrying conductors in a cord is from 4 to 6, the allowable ampacity of each conductor shall be reduced to 80 percent of the values for not more than 3 current-carrying conductors in the Table. A conductor used for equipment grounding and a neutral conductor which carries only the unbalanced current from other conductors, as in the case of normally balanced circuits of 3 or more conductors, are not considered to be current-carrying conductors. Where a single conductor is used for both equipment grounding and to carry unbalanced current from other conductors, it shall not be considered to be a current-carrying conductor. (See Section 250-60.)

(Based on Ambient Temperature of 30°C (86°F). See Section 400-9 and Table 400-11)

Size  AWG	Rubber Types TP, TS	Rubber Types PO, C, PD, E, EO, EN, S, SO, SRD, SJ, SJO, SV, SVO, SP		Types AFS, AFSJ, HC, HPD, HSJ, HSJO, HS, HSO, HPN SVHT	Types AVPO AVPD	Cotton Types CFPD*
	Thermo- plastic Types TPT, TST	Thermo- plastic Types ET, ETT, ETLB, ETP, ST, STO, SRDT, SJT, SJTO, SVT SVTO, SPT				Asbestos Types AFC* AFPD*
27**	0.5	A†	B†			
18	..	7	10	10	17	6
17	..			12	..	..
16	..	10	13	15	22	8
15	..		..	17		
14	..	15	18	20	28	17
12	..	20	25	30	36	23
10	..	25	30	35	47	28
8	..	35	40	..	..	..
6	..	45	55	..	..	..
4	..	60	70	..	..	..
2	..	80	95	..	..	..

\* These types are used almost exclusively in fixtures where they are exposed to high temperatures and ampere ratings are assigned accordingly.

\*\* Tinsel Cord.

† The ampacities under sub-heading A are applicable to 3-conductor cords and other multi-conductor cords connected to utilization equipment so that only 3 conductors are current carrying. The ampacities under sub-heading B are applicable to 2-conductor cords and other multi-conductor cords connected to utilization equipment so that only 2 conductors are current carrying.

NOTE 1. Ultimate Insulation Temperature. In no case shall conductors be associated together in such way with respect to the kind of circuit, the wiring method employed, or the number of conductors, that the limiting temperature of the conductors will be exceeded.

NOTE 2. SVHT made only in No. 18 and 17 AWG sizes.

*(Continued from page 184)*

- individual conductors at least 45 mils in thickness, unless Type S, SO, ST or STO cord is used.

#### **400-9. Overcurrent Protection and Ampacities of Flexible Cords.**

- Flexible cords not smaller than No. 18, and tinsel cords, or cords having equivalent characteristics, of smaller size approved for use with specific appliances, shall be considered as protected against overcurrent by the overcurrent devices described in Section 240-5. Cords shall be not smaller than required in Table 400-9(b) for rated current of the connected equipment.

**400-10. Pull at Joints and Terminals.** Flexible cords shall be so connected to devices and to fittings that tension will not be transmitted to joints or terminal screws. This shall be accomplished by a knot in the cord, winding with tape, by a special fitting designed for that purpose, or by other approved means which will prevent a pull on the cord from being directly transmitted to joints or terminal screws.

---

#### **Notes to Table 400-11**

1. Except for Types PO-1, PO-2, PO, SP-1, SP-2, SPT-1, SPT-2, TP, TPT, and AVPO, individual conductors are twisted together.

2. Type PO-1 is for use only with portable lamps, portable radio receiving appliances, portable clocks and similar appliances which are not liable to be moved frequently and where appearance is a consideration.

3. Types TP, TPT, TS, and TST are suitable for use in lengths not exceeding 8 feet when attached directly, or by means of a special type of plug, to a portable appliance rated at 50 watts or less and of such nature that extreme flexibility of the cord is essential.

4. Rubber-filled or varnished cambric tapes may be substituted for the inner braids.

5. Types S, SO, ST, and STO are suitable for use on theater stages, in garages and elsewhere, where flexible cords are permitted by this Code.

6. Traveling cables for operating, control and signal circuits may have one or more nonmetallic fillers or may have a supporting filler of stranded steel wires having its own protective braid or cover. Cables exceeding 100 feet between supports shall have steel supporting fillers, except in locations subject to excessive moisture or corrosive vapors or

gases. Where steel supporting fillers are used, they shall run straight through the center of the cable assembly and shall not be cabled with the copper strands of any conductor.

Types E, EO, EN, ET, ETP, ETLB, and ETT cables may incorporate in the construction No. 20 gauge conductors formed as a pair, and covered with suitable shielding for telephone and other audio or higher frequency communication circuits. The insulation of the conductors may be rubber or thermoplastic of thickness specified for the other conductors of the particular type of cable. The shield shall have its own protective covering. This component may be incorporated in any layer of the cable assembly, and shall not run straight through the center.

7. A third conductor in these cables is for grounding purposes only.

8. The individual conductors of all cords except those of heat-resistant cords (Types AFC, AFPD, AFS, AFSJ, AVPO, AVPD and CFPD) shall have a rubber or thermoplastic insulation, except that the grounding conductor where used, shall be in accordance with Section 400-14(b). A rubber compound shall be vulcanized except for heater cords (Types HC, HPD and HSJ).

**Table 400-11. Flexible Cord**  
(See Section 400-2)

Trade Name	Type Letter	Size AWG	No. of Conductors	Insulation	Braid on Each Conductor	Outer Covering	Use	
Parallel Tinsel Cord	TP See Note 3	27	2	Rubber	None	Rubber	Attached to an Appliance	Damp Places
	TPT See Note 3	27	2	Thermoplastic	None	Thermoplastic	Attached to an Appliance	Damp Places
Jacketed Tinsel Cord	TS See Note 3	27	2 or 3	Rubber	None	Rubber	Attached to an Appliance	Damp Places
	TST See Note 3	27	2 or 3	Thermoplastic	None	Thermoplastic	Attached to an Appliance	Damp Places
Asbestos-Covered Heat-Resistant Cord	AFC	18-10	2 or 3	Impregnated Asbestos	Cotton or Rayon	None	Pendant	Dry Places
			2		None	Cotton, Rayon or Saturated Asbestos		
	AFPD		2 or 3					
Cotton-Covered Heat-Resistant Cord		18-10	2 or 3	Impregnated Cotton	Cotton or Rayon	None	Pendant	Dry Places
			2		None	Cotton or Rayon		
	CFPD		2 or 3					

See Notes 1 through 8 preceding table.

Table 400-11 continued

Trade Name	Type Letter	Size AWG	No. of Conductors	Insulation	Braid on Each Conductor	Outer Covering	Use		
							See Note 2	Dry Places	Not Hard Usage
Parallel Cord	PO-1	18	2	Rubber	Cotton	Cotton or Rayon	Pendant or Portable	Dry Places	Not Hard Usage
	PO-2	18-16							
	PO	18-10							
All Rubber Parallel Cord	SP-1	18	2	Rubber	None	Rubber	Pendant or Portable	Damp Places	Not Hard Usage
	SP-2 See Note 7	18-16	2 or 3						
	SP-3 See Note 7	18-12					Refrigerators or Room Air Conditioners	Damp Places	Not Hard Usage
All Plastic Parallel Cord	SPT-1	18	2	Thermoplastic	None	Thermoplastic	Pendant or Portable	Damp Places	Not Hard Usage
	SPT-2 See Note 7	18-16	2 or 3						
	SPT-3 See Note 7	18-10					Refrigerators or Room Air Conditioners	Damp Places	Not Hard Usage

See Notes 1 through 8 preceding table.



Table 400-11 continued

Lamp Cord	C	18-10	2 or more	Rubber	Cotton	None	Pendant or Port.	Dry Places	Not Hard Usage
Twisted Portable Cord	PD	18-10	2 or more	Rubber	Cotton	Cotton or Rayon	Pendant or Port.	Dry Places	Not Hard Usage
Vacuum Cleaner Cord	SV, SVO	18	2	Rubber	None	Rubber	Pendant or Portable	Damp Places	Not Hard Usage
	SVT,	18-17		Thermopl <sup>1</sup>		Thermoplastic			
	SVTO See Note 7	18							
Heat Resistant V.C. Cord	SVHT	18-17	2	Thermopl <sup>1</sup>	None	Thermoplastic	Pendant or Portable	Damp Places	Not Hard Usage
Junior Hard Service Cord	SJ	18-16	2, 3, or 4	Rubber	None	Rubber	Pendant or Portable	Damp Places	Hard Usage
	SJO					Oil Resistant Compound			
	SJT SJTO			Thermopl <sup>1</sup> or Rubber		Thermoplastic			
Hard Service Cord	S See Note 5	18-2	2 or more	Rubber	None	Rubber	Pendant or Portable	Damp Places	Extra Hard Usage
	SO					Oil Resist. Compound			
	ST					Thermoplastic			
	STO					Oil Resistant Thermoplastic			

See Notes 1 through 8 preceding table.

Table 400-11 continued

Trade Name	Type Letter	Size AWG	No. of Conductors	Insulation	Braid on Each Conductor	Outer Covering	Use		
Rubber-Jacketed Heat-Resistant Cord	AFSJ	18-16	2 or 3	Impregnated Asbestos	None	Rubber	Portable	Damp Places	Portable Heaters
	AFS	18-16-14							
Heater Cord	HC	18-12	2, 3 or 4	Rubber or thermoplastic & Asbestos	Cotton	None	Portable	Dry Places	Portable Heaters
				Rubber or thermoplastic with Asbestos or All Neoprene					
	HPD	18-12	2, 3 or 4		None	Cotton or Rayon	Portable		
Rubber Jacketed Heater Cord	HSJ	18-16	2, 3 or 4	Rubber or thermoplastic with Asbestos or All Neoprene	None	Cotton and Rubber	Portable	Damp Places	Portable Heaters
Jacketed Heater Cord	HSJO	18-16	2, 3 or 4	Rubber with Asbestos or All Neoprene	None	Cotton and Oil Resistant Compound	Portable	Damp Places	Portable Heaters
	HS	14-12				Cotton and Rubber or Neoprene			
	HSO	14-12				Cotton and Oil Resistant Compound			

See Notes 1 through 8 preceding table.

Table 400-11 continued

Parallel Heater Cord	HPN See Note 7	18-12	2 or 3	Thermosetting	None	Thermosetting	Portable	Damp Places	Not Hard Usage
Heat & Moisture-Resistant Cord	AVPO	18-10	2	Asbestos & Var. Cam.	None	Asbestos, Flame-Ret. Moisture Resistant	Pendant or Portable	Damp Places	Not Hard Usage
	AVPD		2 or 3						
Range, Dryer Cable	SRD	10-4	3 or 4	Rubber	None	Rubber or Neoprene	Portable	Damp Places	Ranges, Dryers
	SRDT	10-4	3 or 4	Thermoplastic	None	Thermoplastic	Portable	Damp Places	Ranges, Dryers
Data Processing Cable	DP	30 Min.	2 or more	Thermoplastic, Rubber or Cross-linked Synthetic Polymer	None	Thermoplastic Rubber or Cross-linked Synthetic Polymer	Data Processing Systems	Dry Places	Power and Signal Circuits
Elevator Cable	E See Note 6	18-14	2 or more	Rubber	Cotton	Three Cotton, Outer one Flame-Retardant & Moisture-Resist. See Note 4	Elevator Lighting and Control	Non-Hazardous Locations	
	EO See Note 6					One Cotton and a Neoprene Jacket See Note 4	Elevator Lighting and Control	Hazardous Locations	

See Notes 1 through 8 preceding table.

Table 400-11 continued

Trade Name	Type Letter	Size AWG	No. of Conductors	Insulation	Braid on Each Conductor	Outer Covering	Use
Elevator Cable	EN See Note 6	18-14	2 or more	Rubber	Flexible Nylon Jacket	Three Cotton, Outer one Flame-Retardant & Moisture-Resist. See Note 4	Non-Hazardous Locations
						One Cotton and a Neoprene or Thermoplastic Jacket See Note 4	Hazardous Locations
	ET See Note 6			Thermoplastic	Rayon	Three Cotton, Outer one Flame-Retardant & Moisture-Resist. See Note 4	Non-Hazardous Locations
	ETLB See Note 6				None		
	ETP See Note 6			Thermoplastic	Rayon	Thermoplastic	Hazardous Locations
	ETT See Note 6			Thermoplastic	None	One Cotton and a Thermoplastic Jacket	

See Notes 1 through 8 preceding table.

### C. Construction Specifications

**400-12. Labels.** Flexible cords shall be examined and tested at the factory and shall be labeled before shipment.

**400-13. Grounded-Conductor Identification.** One conductor of flexible cords which is intended to be used as a grounded circuit conductor shall have a continuous marker readily distinguishing it from the other conductor or conductors. The identification shall consist of one of the following:

(a) **Colored Braid.** A braid finished to show a white or natural gray color and the braid on the other conductor or conductors finished to show a readily distinguishable solid color or colors.

(b) **Tracer in Braid.** A tracer in a braid of any color contrasting with that of the braid and no tracer in the braid of the other conductor or conductors. No tracer shall be used in the braid of any conductor of a flexible cord which contains a conductor having a braid finished to show white or natural gray, except, in the case of Types C, PD and PO cords having the braids on the individual conductors finished to show white or natural gray. In such Types C, PD and PO cords the identifying marker may consist of the solid white or natural gray finish on one conductor provided there is a colored tracer in the braid of each other conductor.

(c) **Colored Insulation.** A white or natural gray insulation on one conductor and insulation of a readily distinguishable color or colors on the other conductor or conductors for cords having no braids on the individual conductors (except cords which have insulation on the individual conductors integral with the jacket). The insulation may be covered with an outer finish to provide the desired color.

(d) **Colored Separator.** A white or natural gray separator on one conductor and a separator of a readily distinguishable solid color on the other conductor or conductors of cords having insulation on the individual conductors integral with the jacket.

(e) **Tinned Conductors.** One conductor having the individual strands tinned and the other conductor or conductors having the individual strands untinned for cords having insulation on the individual conductors integral with the jacket.

(f) **Surface Marking.** One or more stripes, ridges or grooves so located on the exterior of the cord as to identify one conductor for cords having insulation on the individual conductors integral with the jacket.

**400-14. Grounding-Conductor Identification.** A conductor intended to be used as a grounding conductor shall have a continuous identifying marker readily distinguishing it from the other conductor or conductors. Conductors having a continuous green color or a continuous green color with one or more yellow stripes shall not be used for other than grounding purposes. The identifying marker shall consist of one of the following:

(a) **Colored Braid.** A braid finished to show a continuous green color or a continuous green color with one or more yellow stripes.

(b) **Colored Insulation or Covering.** For cords having no braids on the individual conductors, an insulation of a continuous green color or a continuous green color with one or more yellow stripes.

**400-15. Insulation Thickness.** The nominal thickness of rubber or thermoplastic conductor insulation in Types TS, TST, PO-1, SV, SVT, and SVHT shall be not less than 15 mils. The nominal thickness of rubber insulation in Types HC, HPD, HSJ, and HS shall be not less than 15 mils for the Nos. 18-16 AWG sizes, and not less than 30 mils for the Nos. 14-12 AWG sizes. For heater cord other than Types HC and HPN, the all neoprene insulation shall be 30 mils for No. 18 and No. 16 AWG sizes and 45 mils for No. 14 and No. 12 AWG sizes. The nominal thickness of the thermoplastic insulation in Type ET and ETP elevator cable shall be not less than 20 mils for the No. 18 and No. 16 AWG size and not less than 30 mils for the No. 14 AWG size. The nominal thickness of the rubber insulation in Types E, EO, and EN elevator cables shall be not less than 20 mils for the No. 18 and 16 AWG sizes and not less than 30 mils for the No. 14 AWG size for ratings not exceeding 300 volts. The nominal thickness of latex-rubber insulation, when employed, in Types SJ, SJO, S and SO shall be not less than 15 mils for the Nos. 18-16 AWG sizes and not less than 18 mils for the No. 14 AWG and larger sizes. The nominal thickness of conductor insulation in Types PO, SP-2, SPT-2, HPN, SRD, and SRDT shall be not less than 45 mils. The nominal thickness of thermoplastic insulation in Type SPT-3 shall be not less than 60 mils for sizes 18-16 and 80 mils for No. 14, 95 mils for No. 12 and 110 mils for No. 10 AWG. The nominal thickness of the thermoplastic insulation on the individual conductors in Type DP cable shall be not less than 8 mils for sizes Nos. 30-27 AWG, not less than 12 mils for sizes Nos. 26-23 AWG, not less than 16 mils for sizes Nos. 22-20 AWG, when the voltage impressed is less than 50; when the voltage is more than 50 but less than 300, the nominal thickness of the thermoplastic insulation on the individual conductors shall be not less than 20 mils for sizes 30-16 AWG, not less than 30 mils for sizes Nos. 14-10 AWG and not less than 60 mils for sizes Nos. 8-2 AWG. For other types, the minimum nominal thickness of rubber or thermoplastic conductor insulation shall be as follows: size AWG 27, and 18 to 16 — 30 mils; 14 to 10 — 45 mils; 8 to 2 — 60 mils.

**400-16. Attached to Receptacle Plugs.** Where a flexible cord is provided with a grounding conductor and equipped with an attachment plug, the plug shall comply with Sections 250-59(a) and (b).

## ARTICLE 402 — FIXTURE WIRES

**402-1. Use.** Fixture wires are designed for installation in lighting fixtures and in similar equipment where enclosed or protected and not subject to bending or twisting in use. Also, they are used for connecting lighting fixtures to the conductors of the circuit that supplies the fixtures.

For application in lighting fixtures, see Article 410.

Fixture wires are not intended for installation as branch-circuit conductors, except as permitted in Section 725.

**402-2. Minimum Size.** Fixture wires shall not be smaller than No. 18.

**402-3. Insulation.**

(a) The rubber insulations include those made from natural and synthetic rubber, neoprene and other vulcanized materials.

Thermoplastic insulation may stiffen at temperatures below minus 10°C (14°F) and care should be used in its installation at such temperatures. It may be deformed when subject to pressure; care should be taken in its installation, as for example, at bushings, or points of support. See Section 373-6(b).

(b) No conductor shall be used under such conditions that its temperature, even when carrying current, will exceed the temperature specified in Table 310-2(a) for the type of insulation involved.

**Table 402-4. Allowable Ampacity of Fixture Wire**  
(Based on Ambient Temperature of 30°C., 86°F.)

Size AWG	Fixture Wire	
	Rubber Types RF-1, RF-2, FF-1, FF-2, RFH-1, RFH-2, FFH-1, FFH-2	Thermoplastic Types TF, TFF, TFN, TFFN
		Cotton Type CF*
		Asbestos Type AF*
		Silicone Rubber Types SF-1*, SF-2*, SFF-1*, SFF-2*
		Fluorinated Ethylene Propylene Types PF*, PGF*, PFF*, PGFF* Extruded Polytetra- fluoroethylene Types PTF*, PTFF*
18	5	6
16	7	8
14	..	17

\* These types are used almost exclusively in fixtures where they are exposed to high temperatures and ampere ratings are assigned accordingly.

Ultimate Insulation Temperature. In no case shall conductors be associated together in such a way with respect to the kind of circuit, the wiring method employed, or the number of conductors, that the limiting temperature of the conductors will be exceeded.

**402-5. Overcurrent Protection.**

See Section 240-5(a), Exception No. 2.

Table 402-6. Fixture Wire

Trade Name	Type Letter	Insulation	Thickness of Insulation	Outer Covering
Rubber-Covered Fixture Wire Solid or 7-Strand	RF-1	Code Rubber	18 ..... 15 Mils	Nonmetallic Covering
	RF-2	Code Rubber	18-16 ..... 30 Mils	Nonmetallic Covering
		Latex Rubber	18-16 ..... 18 Mils	
Rubber-Covered Fixture Wire Flexible Stranding	FF-1	Code Rubber	18 ..... 15 Mils	Nonmetallic Covering
	FF-2	Code Rubber	18-16 ..... 30 Mils	Nonmetallic Covering
		Latex Rubber	18-16 ..... 18 Mils	
Heat Resistant Rubber-Covered Fixture Wire Solid or 7-Strand	RFH-1	Heat-Resistant Rubber	18 ..... 15 Mils	Nonmetallic Covering
	RFH-2	Heat-Resistant Rubber	18-16 ..... 30 Mils	Nonmetallic Covering
		Heat-Resistant Latex Rubber	18-16 ..... 18 Mils	
Heat Resistant Rubber-Covered Fixture Wire Flexible Stranding	FFH-1	Heat-Resistant Rubber	18 ..... 15 Mils	Nonmetallic Covering
	FFH-2	Heat-Resistant Rubber	18-16 ..... 30 Mils	Nonmetallic Covering
		Heat-Resistant Latex Rubber	18-16 ..... 18 Mils	
Thermoplastic-Covered Fixture Wire—Solid or Stranded	TF	Thermoplastic	18-16 ..... 30 Mils	None
Thermoplastic-Covered Fixture Wire—Flexible Stranding	TFF	Thermoplastic	18-16 ..... 30 Mils	None
Heat Resistant Thermoplastic-Covered Fixture Wire—Solid or Stranded	TFN	Thermoplastic	18-16 ..... 15 Mils	Nylon Jacketed



Table 402-6 (Continued)

Trade Name	Type Letter	Insulation	Thickness of Insulation	Outer Covering
Heat Resistant Thermoplastic-Covered Fixture Wire—Flexible Stranded	TFFN	Thermoplastic	18-16 ..... 15 Mils	Nylon Jacketed
Cotton-Covered, Heat-Resistant, Fixture Wire	CF	Impregnated	18-14 ..... 30 Mils	None
Asbestos-Covered, Heat-Resistant, Fixture Wire	AF	Cotton Impregnated Asbestos	18-14 ..... 30 Mils	None
Silicone Insulated Fixture Wire Solid or 7-Strand	SF-1	Silicone Rubber	18 ..... 15 Mils	Nonmetallic Covering
	SF-2	Silicone Rubber	18-14 ..... 30 Mils	Nonmetallic Covering
Silicone Insulated Fixture Wire Flexible Stranding	SFF-1	Silicone Rubber	18 ..... 15 Mils	Nonmetallic Covering
	SFF-2	Silicone Rubber	18-14 ..... 30 Mils	Nonmetallic Covering
Fluorinated Ethylene Propylene Fixture Wire Solid or 7 Strand	PF	Fluorinated Ethylene Propylene	18-14 ..... 20 Mils	None
	PGF		18-14 ..... 14 Mils	Glass Braid
Fluorinated Ethylene Propylene Fixture Wire Flexible Stranding	PFF	Fluorinated Ethylene Propylene	18-14 ..... 20 Mils	None
	PGFF		18-14 ..... 14 Mils	Glass Braid
Extruded Polytetrafluoroethylene Solid or 7-Strand (Nickel or Nickel Coated Copper)	PTF	Extruded Polytetrafluoroethylene	18-14 ..... 20 Mils	None

**Table 402-6(Continued)**

Trade Name	Type Letter	Insulation	Thickness of Insulation	Outer Covering
Extruded Polytetra-fluoroethylene Flexible Stranding (No. 26-36 AWG) Silver or Nickel Coated Copper)	PTFF	Extruded Polytetra-fluoroethylene	18-14 ..... 20 Mils	None

**402-7. Number of Conductors in Conduit.** The number of fixture wires permitted in a single conduit shall be as given in Table 2 of Chapter 9.

## ARTICLE 410 — LIGHTING FIXTURES, LAMPHOLDERS, LAMPS, RECEPTACLES AND ROSETTES

### A. General

**410-1. Scope.** Lighting fixtures, lampholders, pendants, receptacles, and rosettes, incandescent filament lamps, arc lamps, electric discharge lamps, the wiring and equipment forming part of such lamps, fixtures and lighting installations shall conform to the provisions of this Article, except as otherwise provided in this Code.

**410-2. Application to Other Articles.** Equipment for use in hazardous locations shall conform to Articles 500 through 517.

**410-3. Live Parts.** Fixtures, lampholders, lamps, rosettes and receptacles shall have no live parts normally exposed to contact, except in the case of cleat-type lampholders, receptacles and rosettes which are located at least 8 feet above the floor. Lampholders, receptacles and switches which have exposed accessible terminals shall not be installed in metal fixture canopies or in open bases of portable table or floor lamps.

### B. Provisions for Fixture Locations

**410-4. Fixtures in Damp, Wet or Corrosive Locations.**

(a) Fixtures installed in damp or wet locations shall be approved for such locations and shall be so constructed or installed that water cannot enter or accumulate in wireways, lampholders or other electrical parts. All fixtures installed in wet locations shall be marked, "Suitable for Wet Locations." All fixtures installed in damp locations shall be marked, "Suitable for Wet Locations" or "Suitable for Damp Locations."

Installations underground or in concrete slabs or masonry in direct contact with the earth, and locations subject to saturation with water or other liquids, such as locations exposed to weather and unprotected, vehicle washing areas, and like locations, are considered to be wet locations with respect to the above requirement.

Interior locations protected from weather but subject to moderate degrees of moisture, such as some basements, some barns, some cold storage warehouses and the like, and partially protected locations under canopies, marquees, roofed open porches, and the like, are considered to be damp locations with respect to the above requirement.

(b) Fixtures installed in corrosive locations shall be of a type approved for such locations.

See Section 210-21 (b) for receptacles in fixtures.

(c) Fixtures in nonresidential occupancies shall not be installed in ducts or hoods used for removal of cooking smoke or grease-laden vapors or located in the path of travel of such exhaust products unless specifically approved for such use.

Fixtures in nonresidential occupancies having approved metallic enclosures mounted on the outer surface of the hood and separated from exhaust products by tight fitting glass may be used. Fixtures on hoods in nonresidential occupancies shall not be located in concealed spaces unless part of an approved grease extractor.

**410-5. Fixtures near Combustible Material.** Fixtures shall be so constructed, or installed, or equipped with shades or guards that combustible material will not be subjected to temperatures in excess of 90° C (194° F).

**410-6. Fixtures over Combustible Material.** Lampholders installed over highly combustible material shall be of the unswitched type and unless an individual switch is provided for each fixture, shall be located at least 8 feet above the floor, or shall be otherwise so located or guarded that the lamps cannot be readily removed or damaged.

**410-7. Fixtures in Show Windows.** Externally wired fixtures shall not be used in a show window.

*Exception: Fixtures of the chain-supported type may be externally wired.*

**410-8. Fixtures in Clothes Closets.**

(a) A fixture in a clothes closet shall be installed:

(1) On the wall above the closet door, provided the clearance between the fixture and a storage area where combustible material may be stored within the closet is not less than 18 inches, or

(2) On the ceiling over an area which is unobstructed to the floor, maintaining an 18-inch clearance horizontally between the fixture and a storage area where combustible material may be stored within the closet.

**NOTE:** A flush recessed fixture equipped with a solid lens is considered to be outside the closet area.

(b) Pendants shall not be installed in clothes closets.

**410-9. Space for Cove Lighting.** Coves shall have adequate space and shall be so located that lamps and equipment can be properly installed and maintained.

**C. Provisions at Fixture Outlet Boxes, Canopies and Pans**

**410-10. Space for Conductors.** Canopies and outlet boxes taken together shall provide adequate space so that fixture conductors and their connecting devices may be properly installed.

**410-11. Temperature Limit of Conductors in Outlet Boxes.** Fixtures shall be of such construction or so installed that the conductors in outlet boxes shall not be subjected to temperatures greater than that for which the conductors are approved.

Branch-circuit wiring shall not be passed through an outlet box that is an integral part of an incandescent fixture unless the fixture is approved for the purpose.

**410-12. Outlet Boxes to be Covered.** In a completed installation, each outlet box shall be provided with a cover unless covered by means of a fixture canopy, lampholder, receptacle, rosette, or similar device.

**410-13. Covering of Combustible Material at Outlet Boxes.** Any combustible wall or ceiling finish exposed between the edge of a fixture canopy or pan and an outlet box shall be covered with noncombustible material.

**410-14. Connection of Electric-Discharge Lighting Fixtures.** Electric-discharge lighting fixtures when supported independently of the outlet box shall be connected through metal raceways, metal-clad cable or non-metallic-sheathed cable. Cord-equipped fixtures may be suspended directly below the outlet box, provided that the cord is continuously visible for its entire length outside the fixture and is not subject to strain or physical damage. Such cord-equipped fixtures shall terminate at the outer end of the cord in a grounding-type attachment plug (cap) or busway plug.

Electric-discharge lighting fixtures provided with mogul-base screw-shell lampholders may be connected to branch circuits of 50 amperes or less by cords complying with Exception No. 2 of Section 240-5(a). Receptacles and caps may be of lower ampere rating but not less than 125 percent of the fixture full-load current.

Fixtures may be connected in accordance with Section 364-11.

**D. Fixture Supports**

**410-15. Supports—General.** Fixtures, lampholders, rosettes and receptacles shall be securely supported. A fixture which weighs more than 6 pounds or exceeds 16 inches in any dimension shall not be supported by the screw shell of a lampholder.

**410-16. Means of Support.** Where the outlet box or fitting will provide adequate support, a fixture shall be attached thereto; otherwise a fixture shall be supported as required by Section 370-13. A fixture which weighs more than 50 pounds shall be supported independently of the outlet box.

In suspended ceilings, fixtures containing a ballast that are partially or wholly recessed shall be independently supported directly to the building structure in addition to or in lieu of the ceiling support structure. Such supports shall be of wire, chain or threaded rod having adequate tensile strength to support each fixture and shall be attached to no less than one point at each end of the fixture.

### E. Wiring of Fixtures

**410-17. Fixture Wiring—General.** Wiring on or within fixtures shall be neatly arranged and shall not be exposed to physical damage. Excess wiring shall be avoided. Conductors shall be so arranged that they shall not be subjected to temperatures above those for which they are approved.

**410-18. Conductor Size.** Fixture conductors shall not be smaller than No. 18 AWG.

**410-19. Conductor Insulation.**

(a) Fixtures shall be wired with conductors having insulation suitable for the current, voltage, and temperature to which the conductors will be subjected.

(b) Where fixtures are installed in damp, wet, or corrosive locations, conductors shall be of a type approved for such locations.

(c) For ampacity of fixture wire, see Table 402-4.

(d) For maximum operating temperature and voltage limitation of fixture wires, see Section 310-2.

**410-20. Conductors for Certain Conditions.**

(a) Fixtures provided with mogul-base screw-shell lampholders and operating at not more than 300 volts between conductors shall be wired with Type AF, SF-1, SF-2, SFF-1, SFF-2, PF, PGF, PFF, PGFF, PTF or PTFE fixture wire.

(b) Fixtures provided with other than mogul-base screw-shell lampholders and operating at not more than 300 volts between conductors shall be wired with Type AF, SF-1, SF-2, PF, PGF, PFF, PGFF, PTF or PTFE fixture wire or Type AFC or AFPD flexible cord.

*Exception No. 1: Where temperatures do not exceed 90°C (194°F), Type CF, TFN and TFFN fixture wire or Type CFPD, flexible cord may be used.*

*Exception No. 2: Where temperatures exceed 60°C (140°F) but are not higher than 75°C (167°F) Type RH and RHW rubber-covered wire, Type RFH-1, RFH-2, FFH-1, and FFH-2 fixture wires may be used.*

*Exception No. 3: Where temperatures do not exceed 60°C (140°F), Type T thermoplastic wire, Types TF and TFF fixture wire, and Types RF-1, RF-2, FF-1, FF-2 fixture wires may be used, including use in fixtures of decorative type on which lamps of not over 60-watt rating are used in connection with imitation candles.*

See Table 402-6 and Section 310-2 for fixture wires and conductors; also, Table 400-9(b) for flexible cords.

**410-21. Conductors for Movable Parts.**

(a) Stranded conductor shall be used for wiring on fixture chains and on other movable or flexible parts.

(b) Conductors shall be so arranged that the weight of the fixture or movable parts will not put a tension on the conductors.

**410-22. Pendant Conductors for Incandescent Filament Lamps.**

(a) Pendant lampholders with permanently attached leads, where used in other than festoon wiring, shall be hung from separate stranded rubber-covered conductors which are soldered directly to the circuit conductors but supported independently thereof.

(b) Such pendant conductors shall be not smaller than No. 14 AWG for heavy-duty or medium-base screw-shell lampholders, nor, except for approved Christmas tree and decorative lighting outfits, smaller than No. 18 AWG for intermediate or candelabra-base lampholders.

(c) Pendant conductors longer than 3 feet shall be twisted together where not cabled in an approved assembly.

**410-23. Protection of Conductors and Insulation.**

(a) Conductors shall be secured in a manner that will not tend to cut or abrade the insulation.

(b) Conductor insulation shall be protected from abrasion where it passes through metal.

(c) Individual showcases, other than fixed, may be connected by flexible cord to permanently installed receptacles, and groups of not more than 6 such showcases may be coupled together by flexible cord and separable locking-type connectors with one of the group connected by flexible cord to a permanently installed receptacle.

The installation shall comply with the following requirements:

(1) Flexible cord shall be hard-service type, having conductors not smaller than the branch-circuit conductors, having ampacity at least equal to the branch-circuit overcurrent device, and having an equipment grounding conductor. See Table 250-95.

(2) Receptacles, connectors and caps shall be of an approved grounding type rated 15 or 20 amperes.

(3) Flexible cords shall be secured to the undersides of showcases so that: (a) Wiring will not be exposed to mechanical damage.

(b) Will allow a separation between cases not in excess of 2 inches, nor more than 12 inches between the first case and the supply receptacle.

(c) The free lead at the end of a group of showcases will have a female fitting not extending beyond the case.

(4) Equipment other than showcases shall not be electrically connected to showcases.

(5) Standpipes of floor receptacles shall allow floor-cleaning equipment to be operated without damage to receptacles.

**410-24. Conductor Protection at Lampholders.** Where a metal lampholder is attached to a flexible cord, the inlet shall be equipped with an insulating bushing which, if threaded, shall not be smaller than nominal  $\frac{3}{8}$ -inch pipe size. The cord hole shall be of a size appropriate for the cord and all burrs and fins removed in order to provide a smooth bearing surface for the cord.

Bushings having holes  $9/32$  inch in diameter are suitable for use with plain pendant cord and holes  $13/32$  inch in diameter with reinforced cord.

**410-25. Connections, Splices and Taps.**

(a) Fixtures shall be so installed that the connections between the fixture conductors and the circuit conductors may be inspected without requiring the disconnection of any part of the wiring, unless the fixture is connected by means of a plug and receptacle.

(b) Splices and taps shall not be located within fixture arms or stems.

(c) No unnecessary splices or taps shall be made within or on a fixture.

(d) For approved means of making connections, see Section 110-14.

**410-26. Fixture Raceways.** Fixtures shall not be used as a raceway for circuit conductors unless the fixtures meet the requirements for approved raceways, except that the conductors of the single branch circuit supplying the fixtures may be carried through as follows:

*Exception No. 1: An installation of fixtures approved for end-to-end assembly to form a continuous raceway, or*

*Exception No. 2: Fixtures which are connected together by approved wiring methods.*

Branch-circuit conductors within 3 inches of a ballast within the ballast compartment shall be recognized for use at temperatures not lower than  $90^{\circ}\text{C}$  ( $194^{\circ}\text{F}$ ), such as Types RHH, THHN, FEP, FEPB, SA, XHHW and AVA. See Table 310-2(a) for Type THW.

**410-27. Polarization of Fixtures.** Fixtures shall be so wired that the screw shells of lampholders will be connected to the same fixture or circuit conductor or terminal. For polarity identification of conductors to screw shells of lampholders, see Section 200-8.

**F. Construction of Fixtures**

**410-28. Combustible Shades and Enclosures.** Adequate air space shall be provided between lamps and shades or other enclosures of combustible material.

**410-29. Fixture Rating.**

(a) All fixtures requiring ballasts or transformers shall be plainly marked with their electrical rating and the manufacturer's name, trademark or other suitable means of identification.

(b) The electrical rating shall include the voltage and frequency, and shall indicate the current rating of the unit including the ballast, transformer or autotransformer.

**410-30. Design and Material.** Fixtures shall be constructed of metal, wood, or other approved material and shall be so designed and assembled as to secure requisite mechanical strength and rigidity. Wireways, including the entrances thereto, shall be such that conductors may be drawn in and withdrawn without injury.

**410-31. Nonmetallic Fixtures.** In all fixtures not made entirely of metal, wireways shall be lined with metal or approved noncombustible materials unless approved armored or lead-covered conductors with suitable fittings are used.

**410-32. Mechanical Strength.**

(a) Tubing used for arms and stems where provided with cut threads shall be not less than 0.040 inch in thickness and when provided with rolled (pressed) threads shall be not less than 0.025 inch in thickness. Arms and other parts shall be fastened to prevent turning.

(b) Metal canopies supporting lampholders, shades, etc., exceeding 8 pounds, or incorporating attachment-plug receptacles, shall be not less than 0.020 inch in thickness. Other canopies shall be not less than 0.016 inch when made of steel and not less than 0.020 inch when of other metals.

(c) Pull-type canopy switches shall not be inserted in the rims of metal canopies which are less than 0.025 inch in thickness unless the rims are reinforced by the turning of a bead or the equivalent. Pull-type canopy switches, whether mounted in the rims or elsewhere in sheet metal canopies, shall be located not more than 3½ inches from the center of the canopy. Double set-screws, double canopy rings, a screw ring, or equal method shall be used where the canopy supports a pull-type switch or pendant receptacle.

The above thickness requirements apply to measurements made on finished (formed) canopies.

**410-33. Wiring Space.** Bodies of fixtures, including portable lamps, shall provide ample space for splices and taps and for the installation of devices, if any. Splice compartments shall be of nonabsorptive, noncombustible material.

**410-34. Fixture Studs.** Fixture studs which are not parts of outlet boxes, hickey, tripods, and crowfeet shall be made of steel, malleable iron, or other approved material.

**410-35. Insulating Joints.** Insulating joints shall be composed of materials especially approved for the purpose. Those which are not designed to be mounted with screws or bolts shall have a substantial exterior metal casing, insulated from both screw connections.

**410-36. Portable Lamps.** Portable table and floor lamps and fan motors on ceiling fixtures may be wired with approved rubber-covered conductors, provided the wiring is not located so as to be subject to undue heating from lamps.

**410-37. Portable Handlamps.** Hand lamps of the portable type supplied through flexible cords shall be of the molded composition or other type approved for the purpose. Metal-shell paper-lined lampholders shall not be used. Hand lamps shall be equipped with a handle. Where subject to physical damage or where lamps may come in contact with combustible material, hand lamps shall be equipped with a substantial guard attached to the lampholder or the handle.

For garages, see Section 511-6.



**410-38. Cord Bushings.** A bushing or the equivalent shall be provided where flexible cord enters the base or stem of a portable lamp. The bushing shall be of insulating material unless a jacketed-type of cord is used.

**410-39. Tests.** All wiring shall be free from short circuits and grounds, and shall be tested for these defects prior to being connected to the circuit.

**410-40. Live Parts.** Exposed live parts within porcelain fixtures shall be suitably recessed and so located as to make it improbable that wires will come in contact with them. There shall be a spacing of at least  $\frac{1}{2}$  inch between live parts and the mounting plane of the fixture.

### G. Installation of Lampholders

**410-41. Screw-Shell Type.** Lampholders of the screw-shell type shall be installed for use as lampholders only.

**410-42. Double-Pole Switched Lampholders.** Where used on unidentified 2-wire circuits tapped from the ungrounded conductors of multi-wire circuits, the switching device of lampholders of the switched type shall simultaneously disconnect both conductors of the circuit. See Section 200-5.

**410-43. Lampholders in Damp or Wet Locations.** Lampholders installed in damp or wet locations shall be of the weatherproof type.

### H. Construction of Lampholders

**410-44. Insulation.** The outer metal shell and the cap shall be lined with insulating material which shall prevent the shell and cap from becoming a part of the circuit. The lining shall not extend beyond the metal shell more than  $\frac{1}{8}$  inch, but shall prevent any current-carrying part of the lamp base from being exposed when a lamp is in the lamp-holding device.

**410-45. Lead Wires.** Lead wires, furnished as a part of weatherproof lampholders and intended to be exposed after installation, shall be of approved, stranded, rubber-covered conductors, not less than No. 14 AWG (No. 18 AWG for candelabra sockets), and shall be sealed in place or otherwise made raintight.

**410-46. Switched Lampholders.** Switched lampholders shall be of such construction that the switching mechanism interrupts the electrical connection to the center contact. The switching mechanism may also interrupt the electrical connection to the screw shell when connection to the center contact is simultaneously interrupted.

### J. Lamps

**410-49. Bases, Incandescent Lamps.** An incandescent lamp for general use on lighting branch circuits shall not be equipped with a medium base when rated over 300 watts, nor with a mogul base when rated over 1,500 watts. Above 1,500 watts, special approved bases or other devices shall be used.

**410-50. Enclosures, Mercury-Vapor Lamp Auxiliary Equipment.** Resistors or regulators for mercury-vapor lamps shall be enclosed in non-combustible cases and treated as sources of heat.

**410-51. Arc Lamps.** Arc lamps used in theaters shall conform to Section 520-61, and arc lamps used in projection machines shall conform to Section 540-20. Arc lamps used on constant-current systems shall conform to the general requirements of Article 710.

### **K. Receptacles, Cord Connectors and Attachment Plugs (Caps)**

#### **410-52. Rating and Type.**

(a) Receptacles installed for the attachment of portable cords shall be rated at not less than 15 amperes, 125 volts, or 10 amperes, 250 volts, and shall be of a type not suitable for use as lampholders.

(b) Metallic faceplates shall be of ferrous metal not less than 0.030 inch in thickness or of nonferrous metal not less than 0.040 inch in thickness. Faceplates of insulating material shall be noncombustible and not less than 0.10 inch in thickness but may be less than 0.10 inch in thickness if formed or reinforced to provide adequate mechanical strength.

(c) After installation, receptacle faces shall be flush with or project from faceplates of insulating material. Receptacle faces shall project a minimum of 0.015 inches from metal faceplates after installation. Faceplates shall be installed so as to seat against mounting surfaces. Boxes shall be installed in accordance with Section 370-10.

(d) All 15- and 20-ampere attachment plugs and connectors shall be so constructed that there are no exposed current-carrying parts except the prongs, blades or pins. The cover for wire terminations shall be mechanically secured, or an integral part of the attachment plug or connector.

#### **410-54 Receptacles in Damp or Wet Locations.**

(a) **Damp Locations.** A receptacle outlet installed outdoors in a location protected from the weather or in other damp locations shall have an enclosure for the receptacle which is weatherproof when the receptacle is covered (attachment plug cap not inserted and receptacle covers closed).

An installation suitable where exposed to wet locations is also suitable for damp locations.

A receptacle outlet may be considered to be in a location protected from the weather when located under roofed open porches, canopies, marquees, and the like, so as not to be subjected to a beating rain or water run-off.

(b) **Wet Locations.** A receptacle installed outdoors where exposed to weather or in other wet locations shall be in a weatherproof enclosure, the integrity of which is not affected when the receptacle is in use (attachment plug cap inserted).

*Exception: An enclosure which is weatherproof only when a self-closing receptacle cover is closed may be used for a receptacle installed*

*outdoors where the receptacle is not likely to be used with other than portable tools or other portable equipment not usually left connected to the outlet indefinitely.*

**(c) Flush Mounting With Faceplate.** The enclosure for a receptacle installed in an outlet box flush-mounted on a wall surface may be weatherproof when a faceplate assembly for use in weatherproof installation is used and the connection between the plate and wall surface has been made watertight.

**(d) Installation Height.** A receptacle outlet installed outdoors shall be located above the ground or floor such that water accumulation is not likely to touch the outlet cover or plate.

**410-55. Grounding-Type Receptacles, Adapters, Cord Connectors and Attachment Plugs.**

**(a)** Receptacles, cord connectors and attachment plugs of the grounding type shall be provided with one fixed grounding member in addition to the circuit members.

*Exception: The grounding contacting member of grounding-type attachment plugs on the power supply cords of portable hand-held, hand-guided or hand-supported tools or appliances may be of the movable self-restoring type on circuits operating at not to exceed 150 volts between any two conductors nor 150 volts between any conductor and ground.*

**(b)** Grounding-type receptacles, adapters, cord connectors and attachment plugs shall have a means for connection of a grounding conductor to the grounding member. A terminal for connection to the grounding member shall be designated by:

**(1)** A hexagonal headed or shaped terminal screw or nut, not readily removable, and green colored; or

**(2)** A pressure wire connector which has a green-colored body (a wire barrel); or

**(3)** A similar green-colored connection device in the case of adapters. The grounding terminal of a grounding adapter shall be a green-colored rigid ear, lug, or similar device. The grounding connection shall be so designed that it cannot make contact with current-carrying parts of the receptacle, adapter, or attachment plug. The adapter shall be polarized.

**(4)** If the terminal for the equipment grounding conductor is not visible, the conductor entrance hole shall be marked with the word "Green" or otherwise identified a distinctive green color.

**(c)** In no case shall a grounding terminal or grounding-type device be used for purposes other than grounding.

**(d)** Grounding-type attachment plugs and mating cord connectors and receptacles shall be so designed that the grounding connection is made before the current-carrying connections. Grounding-type devices shall be designed so grounding members of attachment plugs cannot be brought into contact with current-carrying parts of receptacles or cord connectors.

**L. Rosettes****410-57. Approved Types.**

(a) Fusible rosettes shall not be installed.

(b) Separable rosettes which make possible a change in polarity shall not be used.

**410-58. Rosettes in Damp or Wet Locations.** Rosettes installed in damp or wet locations shall be of the weatherproof type.

**410-59. Rating.** Rosettes shall be rated at 660 watts, 250 volts, with a maximum current rating of 6 amperes.

**410-60. Rosettes for Exposed Wiring.** When designed for use with exposed wiring, rosettes shall be provided with bases which shall have at least two holes for supporting screws, shall be high enough to keep the wires and terminals at least  $\frac{1}{2}$  inch from the surface wired over, and shall have a porcelain lug under each terminal to prevent the rosette being placed over projections which would reduce the separation to less than  $\frac{1}{2}$  inch.

**410-61. Rosettes for Use with Boxes or Raceways.** When designed for use with conduit boxes or wire raceways, rosette bases shall be high enough to keep wires and terminals at least  $\frac{3}{8}$  inch from the surface wired over.

**M. Special Provisions for Flush and Recessed Fixtures**

**410-62. Approved Type.** Fixtures which are installed in recessed cavities in walls or ceilings shall be of an approved type and shall conform to Sections 410-63 through 410-70.

**410-63. Temperature.**

(a) Fixtures shall be so constructed or installed that adjacent combustible material will not be subjected to temperatures in excess of  $90^{\circ}\text{C}$  ( $194^{\circ}\text{F}$ ).

(b) Where a fixture is recessed in fire-resistant material in a building of fire-resistant construction, a temperature higher than  $90^{\circ}\text{C}$  ( $194^{\circ}\text{F}$ ), but not higher than  $150^{\circ}\text{C}$  ( $302^{\circ}\text{F}$ ) is acceptable if the fixture is plainly marked that it is approved for that service.

**410-64. Clearance.** Recessed portions of enclosures, other than at points of support, shall be spaced at least  $\frac{1}{2}$  inch from combustible material and thermal insulation.

**410-65. Wiring.**

(a) Conductors having insulation suitable for the temperature encountered shall be used.

(b) Fixtures having branch-circuit terminal connections which operate at temperatures higher than  $60^{\circ}\text{C}$  ( $140^{\circ}\text{F}$ ) shall have circuit conductors as described in Sections 410-65(b)(1) and (b)(2):

(1) Branch-circuit conductors having an insulation suitable for the temperature encountered may be run directly to the fixture.

(2) Tap connection conductors having an insulation suitable for

the temperature encountered shall be run from the fixture terminal connection to an outlet box placed at least one foot from the fixture. Such a tap shall be in a suitable metal raceway which shall extend for at least 4 feet but not more than 6 feet.

#### **N. Construction, Flush and Recessed Fixtures**

**410-66. Temperature.** Fixtures shall be so constructed that adjacent combustible material will not be subject to temperatures in excess of 90° C (194° F).

**410-67. Enclosure.** Sheet metal enclosures shall be protected against corrosion and shall not be less than No. 22 MSG.

*Exception: Where a wireway cover is within the No. 22 MSG enclosure, it may be of No. 24 MSG metal.*

**410-68. Lamp Wattage Marking.** Incandescent lamp fixtures shall be marked to indicate the maximum allowable wattage of lamps. The markings shall be permanently installed, in letters at least ¼ inch high, and located where visible during relamping.

**410-69. Solder Prohibited.** No solder shall be used in the construction of the fixture box.

**410-70. Lampholders.** Lampholders of the screw-shell type shall be of porcelain unless specially approved for the purpose. Cements, where used, shall be of the high-heat type.

#### **P. Special Provisions for Electric-Discharge Lighting Systems of 1,000 Volts or Less**

##### **410-71. General.**

(a) Equipment for use with electric-discharge lighting systems and designed for an open-circuit voltage of 1,000 volts or less shall be of a type approved for such service.

(b) The terminals of an electric-discharge lamp shall be considered as alive where any lamp terminal is connected to a potential of more than 300 volts.

(c) Transformers of the oil-filled type shall not be used.

(d) In addition to complying with the general requirements for lighting fixtures, such equipment shall conform to Part P of this Article.

(e) Integral ballast protection shall be provided for fluorescent fixtures installed indoors.

*Exception: Fluorescent fixtures when they employ simple reactance ballasts.*

**410-72. Direct-Current Equipment.** Fixtures installed on direct-current circuits shall be equipped with auxiliary equipment and resistors especially designed and approved for direct-current operation and the fixtures shall be so marked.

##### **410-73. Voltages—Dwelling Occupancies.**

(a) Equipment having an open-circuit voltage of more than 1,000 volts shall not be installed in dwelling occupancies.

(b) Equipment having an open-circuit voltage of more than 300 volts shall not be installed in dwelling occupancies unless such equipment is so designed that there shall be no exposed live parts when lamps are being inserted, are in place, or are being removed.

#### **410-74. Fixture Mounting.**

(a) **Exposed Ballasts.** Fixtures having exposed ballasts or transformers shall be so installed that such ballasts or transformers shall not be in contact with combustible material.

(b) **Combustible Low-Density Cellulose Fiberboard.** Where a fixture containing a ballast is to be installed on combustible low-density cellulose fiberboard it shall, where surface mounted:

(1) Be approved for this condition, or

(2) Be spaced not less than 1½ inches from the surface of the fiberboard.

(3) Where such fixtures are partially or wholly recessed, the provisions of Sections 410-62 through 410-70 shall apply.

Combustible low-density cellulose fiberboard is considered to include sheets, panels and tiles which have a density of 20 pounds per cubic foot or less, and which are formed of bonded plant fiber material; but does not include solid or laminated wood, nor fiberboard which has a density in excess of 20 pounds per cubic foot or is an approved material which has been integrally treated with fire-retarding chemicals to the degree that the flame spread in any plane of the material will not exceed 25 as determined by the Method of NFPA No. 255-1969, ASTM Designation-1961 E-84 or U.L. No. 723-1968.

#### **410-75. Auxiliary Equipment Not Integral with Fixture.**

(a) Auxiliary equipment, including reactors, capacitors, resistors, and similar equipment, where not installed as part of a lighting fixture assembly shall be enclosed in accessible, permanently installed metal cabinets.

(b) Where display cases are not permanently installed, no portion of a secondary circuit may be included in more than a single case.

(c) Ballasts approved for separate mounting and for direct connection to an approved wiring system need not be separately enclosed.

**410-76. Autotransformers.** An autotransformer which is used as part of a ballast for supplying lighting units and which raises the voltage to more than 300 volts shall be supplied only by a grounded system.

**410-77. Switches.** Snap switches shall conform to Section 380-14.

### **Q. Special Provisions for Electric-Discharge Lighting Systems of More Than 1,000 Volts**

#### **410-78. General.**

(a) Equipment for use with electric-discharge lighting systems and designed for an open-circuit voltage of more than 1,000 volts shall be of a type approved for such service.

(b) The terminal of an electric-discharge lamp shall be considered as

alive when any lamp terminal is connected to a potential of more than 300 volts.

(c) In addition to complying with the general requirements for lighting fixtures, such equipment shall conform to Sections 410-78 through 410-90.

For signs and outline lighting, see Article 600.

#### **410-79. Control.**

(a) Fixtures or lamp installations shall be controlled either singly or in groups by an externally operable switch or circuit breaker which shall open all ungrounded primary conductors.

(b) The switch or circuit breaker shall be located within sight of the fixtures or lamps, or it may be located elsewhere if it is provided with means for locking in the open position.

**410-80. Lamp Terminals and Lampholders.** Parts which must be removed for lamp replacement shall be hinged or fastened by an approved means. Lamps or lampholders or both shall be so designed that there shall be no exposed live parts when lamps are being inserted or are being removed.

**410-81. Transformer Ratings.** Transformers and ballasts shall have a secondary open-circuit voltage of not more than 15,000 volts with an allowance on test of 1,000 volts additional. The secondary-current rating shall be not more than 120 milliamperes when the open-circuit voltage is more than 7,500 volts, and not more than 240 milliamperes when the open-circuit voltage is 7,500 volts or less.

**410-82. Transformer Type.** Transformers shall be of an approved enclosed type. Transformers of other than the askarel-insulated or dry-type shall not be used.

#### **410-83. Transformer Secondary Connections.**

(a) The high-voltage windings of transformers shall not be connected in series or in parallel, except that for two transformers, each having one end of its high-voltage winding grounded and connected to the enclosure, the high-voltage windings may be connected in series to form the equivalent of a mid-point grounded transformer.

(b) The grounded ends shall be connected by an insulated conductor not smaller than No. 14 AWG.

#### **410-84. Transformer Locations.**

(a) Transformers shall be accessible after installation.

(b) The transformers should be installed as near to the lamps as practicable to keep the secondary conductors as short as possible.

(c) Transformers shall be so located that adjacent combustible materials will not be subjected to temperatures in excess of 90° C (194° F).

**410-85. Transformer Loading.** The lamps connected to any transformer shall be of such length and characteristics as not to cause a condition of continuous overvoltage on the transformer.

**410-86. Wiring Method. Secondary Conductors.** Approved gas-tube sign cable suitable for the voltage of the circuit shall be used. For installation of conductors, see Section 600-31.

**410-87. Lamp Supports.** Lamps shall be adequately supported as required in Section 600-33.

**410-88. Exposure to Damage.** Lamps shall not be located where normally exposed to physical damage.

**410-89. Marking.** Each fixture or each secondary circuit of tubing having an open-circuit voltage of more than 1,000 volts shall have a clearly legible marking in letters not less than ¼-inch high reading "Caution . . . . . volts." The voltage indicated shall be the rated open-circuit voltage.

**410-90. Switches.** Snap switches shall conform to Section 380-14.

### R. Grounding

**410-91. General.** Fixtures and lighting equipment shall be grounded as provided in Sections 410-92 through 410-96.

**410-92. Metallic Wiring Systems.** Metal fixtures directly wired, or attached to outlets wired with grounded metal raceways or grounded Type MI, AC, or ALS cable shall be grounded.

**410-93. Nonmetallic Wiring Systems.** Metal fixtures installed on outlets wired with knob-and-tube work, nonmetallic raceways, or non-metallic-sheathed cable, on circuits operating at 150 volts or less to ground, shall be grounded.

*Exception: Fixtures and their outlet boxes mounted on electrically nonconducting ceilings or walls need not be grounded where located not less than 8 feet vertically or 5 feet horizontally from grounded surfaces. (See Section 410-95).*

Fixtures made of insulating materials, and lampholders with shells of insulating material, are recommended for use with wiring systems that do not afford a ready means for grounding the exposed noncurrent-carrying parts of fixtures and lampholders.

**410-94. Equipment of More Than 150 Volts to Ground.**

(a) Metal fixtures, transformers and transformer enclosures on circuits operating at more than 150 volts to ground shall be grounded.

(b) Other exposed metal parts shall be grounded unless they are insulated from ground and other conducting surfaces and are inaccessible to unqualified persons, except that lamp tie wires, mounting screws, clips and decorative bands on glass lamps spaced not less than 1½ inches from lamp terminals need not be grounded.

**410-95. Equipment Near Grounded Surfaces.**

(a) Ungrounded metal lighting fixtures, lampholders and faceplates shall not be installed in contact with conducting surfaces nor within 8 feet vertically or 5 feet horizontally of laundry tubs, bath tubs, shower baths, plumbing fixtures, steam pipes or other grounded metal work or grounded surfaces.



(b) Metal pull chains used at these locations shall be provided with insulating links.

**410-96. Methods of Grounding.** Equipment shall be considered as grounded where mechanically connected in a permanent and effective manner to metal raceway, the armor of Types AC, MI and ALS metal-clad cable, the grounding conductor in nonmetallic-sheathed cable, or to a separate grounding conductor sized in accordance with Table 250-95, provided that the raceway, armor, or grounding conductor is grounded in a manner specified in Article 250.

## ARTICLE 422—APPLIANCES

### A. General

**422-1. Scope.** This Article shall apply to electric appliances used in any occupancy.

**422-2. Live Parts.** Appliances shall have no live parts normally exposed to contact, except for toasters, grills or other appliances in which the current-carrying parts at high temperatures are necessarily exposed.

**422-3. Other Articles.** All requirements of this Code shall apply when applicable. Appliances for use in hazardous locations shall be installed to conform to Articles 500 through 517.

The requirements of Article 430 apply to the installation of motor-operated appliances except as specifically amended in this Article.

### B. Branch-Circuit Requirements

**422-5. Branch-Circuit Sizing.** The provisions of this Section specify sizes of conductors capable of carrying appliance current without overheating under the conditions specified (see Article 210). They are not intended to apply to conductors which form an integral part of the appliance.

(a) The rating of an individual branch circuit shall not be less than the marked rating of the appliance or the marked rating of an appliance having combined loads (see Section 422-32).

*Exception No. 1: For household cooking appliances, see Table 220-5.*

*Exception No. 2: For motor-operated appliances not having a marked rating the branch-circuit size shall be in accordance with Part B of Article 430.*

*Exception No. 3: Except as noted in Section 210-23(b), Exception No. 1, an appliance, other than a motor-operated appliance, which is continuously loaded, the branch-circuit rating shall not be less than 125 percent of the marked rating.*

(b) For branch circuits supplying appliance and other loads, the rating shall be determined in accordance with Section 210-24.

**422-6. Branch-Circuit Overcurrent Protection.** Branch circuits shall be protected in accordance with Section 240-5.

When there is a protective device rating marked on an appliance, the branch-circuit overcurrent device rating shall not exceed the protective device rating marked on the appliance.

### **C. Installation of Appliances**

**422-7. General.** All appliances shall be installed in an approved manner.

**422-8. Flexible Cords.** Flexible cords used to connect appliances shall comply with the following:

(a) **Heater Cords Required.** All smoothing irons and portable electrically heated appliances rated at more than 50 watts and which produce temperatures in excess of 121°C (250°F) on surfaces with which the cord is liable to be in contact shall be provided with one of the types of approved heater cords listed in Table 400-11.

(b) **Other Heating Appliances.** All other portable electrically heated appliances shall be connected with one of the approved types of cord listed in Table 400-11, selected in accordance with the usage specified in that Table.

(c) **Other Appliances.** Flexible cord may be used for: (1) connection of portable appliances; (2) connection of stationary appliances to facilitate their frequent interchange or prevention of the transmission of noise or vibration; or (3) facilitating the removal or disconnection of fixed appliances for maintenance or repair.

**422-9. Portable Immersion Heaters.** Electric heaters of the portable immersion type shall be so constructed and installed that current-carrying parts are effectively insulated from electrical contact with the substance in which immersed. The authority having jurisdiction may make exception of special applications of apparatus where suitable precautionary measures are followed.

**422-10. Protection of Combustible Material.** Each electrically heated appliance that is obviously intended by size, weight and service to be located in a fixed position shall be so placed as to provide ample protection between the appliance and adjacent combustible material.

**422-11. Stands for Portable Appliances.** Each smoothing iron and other portable electrically heated appliance which is intended to be applied to combustible material shall be equipped with an approved stand, which may be a separate piece of equipment or may be a part of the appliance.

**422-12. Signals for Heated Appliances.** In other than residence occupancies, each electrically heated appliance, or group of electrically heated appliances, intended to be applied to combustible material, shall be installed in connection with a signal unless the appliance is provided with an integral temperature-limiting device.

**422-13. Flatirons.** Electrically heated smoothing irons intended for use in residences shall be equipped with approved temperature-limiting means.

**422-14. Water Heaters — Storage and Instantaneous Types.** Each storage- or instantaneous-type water heater shall be equipped with temperature-limiting means in addition to the control thermostat to disconnect all ungrounded conductors, and such means shall be: (1) installed to sense maximum water temperature; (2) trip-free, manually reset, or it shall use a replacement element. Such water heaters shall be marked to require the installation of a temperature and pressure relief valve. See ANSI Standard Z-21.22-1971.

*Exception: Each water heater with supply water temperature of 180°F or above and capacity of 60 kW or above, and water heaters with a capacity of one gallon or less, approved for the purpose.*

**422-15. Infrared Lamp Industrial Heating Appliances.**

(a) Infrared heating lamps rated at 300 watts or less may be used with lampholders of the medium-base, unswitched porcelain type, or other types approved for the purpose.

(b) Screw-shell lampholders shall not be used with infrared lamps over 300 watts rating unless the lampholders are especially approved for the purpose.

(c) Lampholders may be connected to any of the branch circuits of Article 210 and, in industrial occupancies, may be operated in series on circuits of more than 150 volts to ground provided the voltage rating of the lampholders is not less than the circuit voltage.

Each section panel or strip carrying a number of infrared lampholders (including the internal wiring of such section, panel or strip) is considered an appliance. The terminal connection block of each such assembly is deemed an individual outlet.

**422-16. Grounding.** Metal frames of portable, stationary and fixed electrically heated appliances, operating on circuits above 150 volts to ground, shall be grounded in the manner specified in Article 250; provided, however, that where this is impracticable, grounding may be omitted by special permission, in which case the frames shall be permanently and effectively insulated from the ground.

Refrigerators, freezers and air conditioners shall comply with the requirements of Sections 250-42, 250-43 and 250-45.

It is recommended that the frames be grounded in all cases. For methods of grounding frames of electric ranges and clothes dryers, see Sections 250-57 and 250-60.

**422-17. Wall-Mounted Ovens and Counter-Mounted Cooking Units.**

(a) Wall-mounted ovens and counter-mounted cooking units complete with provisions for mounting and for making electrical connections shall be considered as fixed appliances.

(b) A separable connector or a plug and receptacle combination in the supply line to an oven or cooking unit used only for ease in servicing or for installation shall:

(1) Not be installed as the disconnecting means required by Section 422-20;

(2) Be approved for the temperature of the space in which it is located.

**422-18. Other Installation Methods.** Appliances employing methods of installation other than covered by this Article may be used only by special permission.

#### **D. Control and Protection of Appliances**

**422-20. Disconnecting Means.** Means shall be provided to disconnect each appliance from all ungrounded conductors as required by the following Sections of Part D. Where an appliance is supplied by more than one source the disconnecting means shall be grouped and identified.

**422-21. Disconnection of Fixed Appliances.**

(a) For fixed appliances rated at not over 300 volt amperes or  $\frac{1}{8}$  hp. the branch-circuit overcurrent device may serve as the disconnecting means.

(b) For fixed appliances of greater rating the branch-circuit switch or circuit breaker may, where readily accessible to the user of the appliance, serve as the disconnecting means.

**422-22. Disconnection of Portable Appliances.**

(a) For portable appliances a separable connector or an attachment plug and receptacle may serve as the disconnecting means.

(b) The rating of a receptacle or of a separable connector shall not be less than the rating of any appliance connected thereto, except that demand factors authorized elsewhere in this Code may be applied.

(c) Attachment plugs and connectors shall conform to the following:

(1) **Live Parts.** They shall be so constructed and installed as to guard against inadvertent contact with live parts.

(2) **Interrupting Capacity.** They shall be capable of interrupting their rated current without hazard to the operator.

(3) **Interchangeability.** They shall be so designed that they will not fit into receptacles of lesser rating.

**422-23. Disconnection of Stationary Appliances.**

(a) For stationary appliances rated at not over 300 volt amperes or  $\frac{1}{8}$  horsepower, the branch-circuit overcurrent device may serve as the disconnecting means.

(b) For stationary appliances of greater rating the branch-circuit switch or circuit breaker may, where readily accessible to the user of the appliance, serve as the disconnecting means.

(c) For cord-connected appliances such as free-standing household-type ranges and clothes dryers, a separable connector or an attachment plug and receptacle may serve as the disconnecting means. Attachment plugs and connectors shall conform to Section 422-22(c).

For household electric ranges, a plug and receptacle connection at the rear base of a range, if it is accessible from the front by removal of a drawer, is considered as meeting the intent of this rule.

**422-24. Unit Switches as Disconnecting Means.** Unit switches which are a part of an appliance shall not be considered as taking the place of the

disconnecting means required by Part D (Control and Protection of Appliances) of this Article, unless there are other means for disconnection as follows:

**(a) Multi-Family Dwellings.** In multi-family (more than two) dwellings, the disconnecting means shall be within the apartment, or on the same floor as the apartment in which the appliance is installed, and may control lamps and other appliances.

**(b) Two-Family Dwellings.** In two-family dwellings, the disconnecting means may be outside the apartment in which the appliance is installed. This will permit an individual switch for the apartment to be used.

**(c) Single-Family Dwellings.** In single-family dwellings, the service disconnecting means may be used.

**(d) Other Occupancies.** In other occupancies, the branch-circuit switch or circuit breaker, where readily accessible to the user of the appliance, may be used for this purpose.

**422-25. Switch and Circuit Breaker to be Indicating.** Switches and circuit breakers used as disconnecting means shall be of the indicating type.

**422-26. Disconnecting Means for Motor-Driven Appliances.** When a switch or circuit breaker serves as the disconnecting means for a stationary or fixed motor-driven appliance of more than  $\frac{1}{8}$  horsepower, it shall be located within sight of the motor controller and shall comply with Part H of Article 430.

**422-27. Overcurrent Protection.**

**(a)** Appliances shall be considered as protected against overcurrent when supplied by branch circuits as specified in Sections 422-5, 422-6, and (e) below.

*Exception: Motors of motor-operated appliances shall be provided with overload protection in accordance with Part C of Article 430. Sealed (hermetic-type) motor-compressors in air conditioning or refrigerating equipment shall be provided with overload protection in accordance with Part F of Article 440. When appliance overcurrent protective devices separate from the appliance are required, data for selection of these devices shall be marked on the appliance. The minimum marking shall be that specified in Sections 430-7 and 440-3.*

**(b)** A household-type appliance with surface heating elements and which has a maximum demand of more than 60 amperes as calculated in accordance with Table 220-5 shall have its power supply subdivided into two or more circuits, each of which is provided with overcurrent protection rated at not more than 50 amperes.

**(c)** Infrared lamp heating appliances shall have overcurrent protection not exceeding 50 amperes.

**(d)** Open-coil or exposed sheathed-coil types of surface heating elements in commercial-type heating appliances shall be protected by overcurrent protective devices which are rated at not more than 50 amperes.

**(e)** When the branch circuit supplies a single nonmotor-operated appliance, rated at 10 amperes or more, the overcurrent device rating shall not exceed 150 percent of the appliance rating.

### E. Marking of Appliances

#### 422-30. Nameplate.

(a) Each electric appliance shall be provided with a nameplate, giving the identifying name and the rating in volts and amperes, or in volts and watts. When the appliance is to be used on a specific frequency or frequencies, it shall be so marked.

Where motor overload protection external to the appliance is required, the appliance shall be so marked. See Section 422-27(a) Exception.

(b) This marking shall be located so as to be visible or easily accessible after installation. See Section 110-21.

**422-31. Marking of Heating Elements.** All heating elements rated more than one ampere which are replaceable in the field and which are a part of an appliance shall be legibly marked with the ratings in volts and amperes, or in volts and watts.

**422-32. Appliances Consisting of Motors and Other Loads.** Appliances shall be marked in accordance with Section 422-32(a) or (b).

(a) In addition to the marking required in Section 422-30, the marking on an appliance consisting of a motor with other load(s) or motors with or without other load(s) shall specify the minimum circuit size and the maximum rating of the circuit overcurrent protective device.

*Exception No. 1: Portable appliances and other appliances, factory-equipped with cords and caps, complying with Section 422-30.*

*Exception No. 2: An appliance where both the minimum circuit size and maximum rating of the circuit overcurrent protective device are not more than 15 amperes and complies with Section 422-30.*

(b) An alternate marking method may specify the rating of the largest motor in volts and amperes, and the additional load(s) in volts and amperes, or volts and watts in addition to the marking required in Section 422-30.

*Exception No. 1: Portable appliances and other appliances, factory-equipped with cords and caps, complying with Section 422-30.*

*Exception No. 2: The current value of a motor  $\frac{1}{8}$  hp or less, or a nonmotor load one ampere or less may be omitted unless such loads constitute the principal load.*

### F. Provisions for Room Air-conditioning Units

**422-40. General.** The provisions of Sections 422-41 through 44 shall apply to electrically energized room air-conditioning units which control temperature and humidity. For the purpose of these Sections a room air conditioner is an alternating-current, hermetic-type, air-cooled window, console or in-wall air conditioner which is installed in the conditioned room. These Sections cover equipment rated not greater than 250 volts, single phase, and such equipment may be cord- and plug-connected. These Sections also apply to such an air conditioner if it has provisions for heating.

Room air conditioners rated at 3-phase or above 250 volts shall be directly connected to a wiring method recognized in Chapter 3. See Part H of Article 430 for disconnecting means.

**422-41. Grounding.** See Sections 250-42, -43 and -45.

**422-42. Branch-Circuit Requirements.**

(a) The total marked rating of motor-operated air-conditioning equipment shall not exceed 80 percent of the rating of a branch circuit which supplies no other load.

(b) The total marked rating of air-conditioning equipment shall not exceed 50 percent of the rating of a branch circuit where lighting units or other appliances are also supplied.

(c) The nameplate marking of a room air conditioner shall be used in determining the branch-circuit requirements, and each unit shall be considered as a single motor unit unless the nameplate is otherwise marked. When marked to indicate two or more motors, see Article 440.

**422-43. Disconnecting Means.** An attachment plug and receptacle may serve as the disconnecting means for a single-phase room air-conditioning unit, rated 250 volts or less when:

(1) The manual controls on the air-conditioning units are readily accessible and located within 6 feet of the floor; or

(2) An approved manually operable switch is installed in a readily accessible location within sight of the air-conditioning unit.

**422-44. Supply Cords.** Where flexible cords are used to supply air-conditioning equipment the length of such cords shall not exceed: (1) 10 feet for nominal 125-volt rating, and (2) 6 feet for nominal 250-volt rating.

## ARTICLE 424 — FIXED ELECTRIC SPACE HEATING EQUIPMENT

### A. General

**424-1. Scope.** The requirements of this Article shall apply to fixed electrical equipment used for space heating. Equipment shall be of a type approved for the purpose and location where installed. For the purpose of this Article, heating equipment may be heating cable, unit heaters, boilers, central systems, or other approved fixed electric space heating equipment. This Article does not cover process heating and room air conditioning.

**424-2. Other Articles.** All requirements of this Code shall apply where applicable. Fixed electric space heating equipment for use in hazardous locations shall be installed to conform with Articles 500 through 517. Fixed electric space heating equipment incorporating a sealed (hermetic-type) motor-compressor shall also comply with Article 440.

**424-3. (a) Branch-Circuit Requirements.** Individual branch circuits may supply any size fixed electric space heating equipment.

Branch circuits supplying two or more outlets for fixed electric space heating equipment shall be rated 15, 20, or 30 amperes.

(424-3(a) continued)

*Exception: In other than residential occupancies fixed infrared heating equipment may be supplied from branch circuits rated not more than 50 amperes as provided in Section 424-22.*

**(b) Branch-Circuit Sizing.** The size of branch-circuit conductors and overcurrent protective devices supplying fixed electric space heating equipment consisting of resistance elements with or without a motor shall be calculated on the basis of 125 percent of the total load of the motors and the heaters. A contactor, thermostat, relay or similar device, approved for continuous operation at 100 percent of its rating, may supply its full rated load. See Section 210-23(b), Exception Nos. 1 and 2.

The size of the branch-circuit conductors and overcurrent protective devices supplying fixed electric space heating equipment consisting of mechanical refrigeration with or without resistance units shall be calculated as provided for in Sections 440-34 and 440-35.

The provisions of this Section are not intended to apply to conductors, which form an integral part of approved fixed electric space heating equipment.

### B. Installation

- | **424-9. General.** All fixed electric space heating equipment shall be installed in an approved manner.
- | **424-10. Special-Type Heaters.** Fixed electric space heating systems employing methods of installation other than covered by this Article may be used only by special permission.
- | **424-11. Supply Conductors.** Fixed electric space heating equipment requiring supply conductors with over 60°C insulation shall be clearly and permanently marked. This marking shall be plainly visible after installation and may be adjacent to the field-connection box.
- | **424-12. Locations.**
  - | (a) Fixed electric space heating equipment shall not be used where exposed to severe physical damage unless adequately protected.
  - | (b) Heaters and related equipment installed in damp or wet locations shall be approved for such locations and shall be constructed and installed so that water cannot enter or accumulate in wireways, electrical components or duct work. See Section 110-11.
- | **424-13. Spacing from Combustible Materials.** Fixed electric space heating equipment shall be installed to provide the required spacing between the equipment and adjacent combustible material, unless it has been found to be acceptable when installed in direct contact with combustible material.
- | **424-14. Grounding.** All exposed metal parts of fixed electric space heating equipment liable to become energized shall be grounded as required in Article 250.

### C. Control and Protection of Fixed Electric Space Heating Equipment

- | **424-19. Disconnecting Means.** Means shall be provided to disconnect all fixed electric space heating equipment from all ungrounded con-



ductors. Where heating equipment is supplied by more than one source, the disconnecting means shall be grouped and identified.

(a) For fixed electric space heating equipment rated at not over 300 volt-amperes or  $\frac{1}{8}$  horsepower, the branch-circuit overcurrent device may serve as the disconnecting means.

(b) For fixed electric space heating equipment of greater rating, the branch-circuit switch or circuit breaker may, where readily accessible to the user of the equipment, serve as the disconnecting means.

(c) **Motor-Driven Heating Equipment.** A switch or circuit breaker that serves as the disconnecting means for a motor-driven heater having a motor more than  $\frac{1}{8}$  horsepower shall be located within sight of the motor controller.

(d) **Unit Switches as Disconnecting Means.** Unit switches with a marked "off" position, which are part of a fixed heater, that disconnect all ungrounded conductors may be used as the disconnecting means required by this Article when other means for disconnection are provided in the following types of occupancies:

(1) **Multi-Family Dwellings.** In multi-family (more than two) dwellings, the other disconnecting means shall be within the apartment, or on the same floor as the apartment in which the fixed heater is installed, and may also control lamps and appliances.

(2) **Two-Family Dwellings.** In two-family dwellings, the other disconnecting means may be located either inside or outside of the apartment in which the fixed heater is installed.

(3) **Single-Family Dwellings.** In single-family dwellings, the service disconnecting means may be the other disconnecting means.

(4) **Other Occupancies.** In other occupancies, the branch-circuit switch or circuit breaker, where readily accessible to the user of the fixed heater, may be used for the other disconnecting means.

#### **424-20. Controllers and Disconnecting Means.**

(a) Thermostats and thermostatically controlled switching devices which indicate an off position and which interrupt line current shall open all ungrounded conductors when the control device is in this off position.

(b) Thermostats and thermostatically controlled switching devices which do not have an off position are not required to open all ungrounded conductors.

(c) Remote-control thermostats do not need to meet the requirements of paragraphs (a) and (b) above. These devices shall not serve as the disconnecting means.

(d) Switching devices consisting of combined thermostats and manually controlled switches which serve both as controllers and disconnecting means shall:

(1) Open all ungrounded conductors when manually placed in the off position.

(2) Be so designed that the circuit cannot be energized automatically after the device has been manually placed in the off position.

**424-21. Switch and Circuit Breaker to be Indicating.** Switches and circuit breakers used as disconnecting means shall be of the indicating type.

**424-22. Overcurrent Protection.**

(a) Electric space heating equipment, other than such motor-operated equipment as required by Article 430 to have additional overcurrent protection, shall be considered as protected against overcurrent when supplied by one of the circuits of Article 210 and in accordance with the requirements therein specified.

(b) Infrared electric space heating equipment shall have overcurrent protection not exceeding 50 amperes.

(c) Electric space heating equipment employing resistance-type heating elements rated more than 48 amperes shall have the heating elements subdivided. Each subdivided load shall not exceed 48 amperes and shall be protected at not more than 60 amperes.

*Exception: Water heating boilers, steam boilers and heat transfer fluid heating boilers employing resistance-type immersion electric heating elements contained in an ASME rated and stamped vessel may be subdivided into circuits not exceeding 120 amperes and protected at not more than 150 amperes.*

These overcurrent protective devices shall be: (1) factory-installed within or on the heater enclosure or provided as a separate assembly by the heater manufacturer, and (2) accessible, but need not be readily accessible, and (3) suitable for branch-circuit protection.

The main conductors supplying these overcurrent protective devices shall be considered branch-circuit conductors.

**D. Marking of Heating Equipment**

**424-28. Nameplate.** (a) Each unit of fixed electric space heating equipment shall be provided with a nameplate giving the identifying name and the normal rating in volts and amperes, or in volts and watts.

Electric space heating equipment intended for use on alternating current only or direct current only shall be marked to so indicate. The marking of equipment consisting of motors over  $\frac{1}{8}$  horsepower and other loads shall specify the rating of the motor in volts, amperes, and frequency, and the heating load in volts and watts or amperes.

(b) This nameplate shall be located so as to be visible or easily accessible after installation.

**424-29. Marking of Heating Elements.** All heating elements which are replaceable in the field, and are a part of an electric heater shall be legibly marked with the ratings in volts and amperes, or in volts and watts.

**E. Electric Space Heating Cables and Panels**

**424-34. Heating Cable Construction.** Heating cable shall be furnished complete with factory-assembled nonheating leads at least 7 feet in length.

**424-35. Marking of Heating Cables and Panels.** Each unit shall be marked with the identifying name or identification symbol, catalog number, ratings in volts and watts or amperes.

(a) **Heating Cables.** Each unit length of heating cable shall have a permanent legible marking on each nonheating lead located within 3 inches of the terminal end. The lead wire shall have the following color identification: 120-volt nominal, yellow; 208-volt nominal, blue; 240-volt nominal, red; and 277-volt nominal, brown.

(b) **Heating Panels.** Permanent marking in a location that is readily visible prior to building finishing shall be provided.

**424-36. Clearances of Wiring in Ceilings.**

(a) Wiring located above heated ceilings shall be spaced not less than 2 inches above the heated ceiling and shall be considered as operating at an ambient of 50°C. The ampacities of conductors shall be computed on the basis of the correction factors given in Note 13 to Tables 310-12 through 310-15.

*Exception: Wiring located above heated ceilings and over thermal insulation having a minimum thickness of 2 inches requires no correction for temperature.*

**424-37. Clearances of Branch-Circuit Wiring in Walls.**

(a) Where located in exterior walls, wiring shall be located outside the thermal insulation.

(b) Where located in interior walls or partitions, wiring shall be considered as operating at an ambient of 40°C (104°F); and the ampacities of conductors shall be computed on the basis of the correction factors given in Note 13 to Tables 310-12 through 310-15.

**424-38. Area Restrictions.**

(a) Heating cables and panels shall not extend beyond the room or area in which they originate.

(b) Cables and panels shall not be installed in closets, over walls or partitions that extend to the ceiling, or over cabinets whose clearance from the ceiling is less than the minimum horizontal dimension of the cabinet to the nearest cabinet edge that is open to the room or area.

*Exception: Isolated single runs of cable may pass over partitions where they are embedded.*

(c) This provision shall not prevent the use of cable or panels in closet ceilings as low temperature heat sources to control relative humidity, provided they are used only in those portions of the ceiling which are unobstructed to the floor by shelves, or other permanent fixtures.

**424-39. Clearance from Other Objects and Openings.** Panel and cables shall be separated at least 8 inches from the edge of outlet boxes and junction boxes that are to be used for mounting surface lighting fixtures. Two inches shall be provided from recessed fixtures and their trims, ventilating openings and other such openings in room surfaces. Sufficient area shall be provided to assure that no heating cable or panel will be covered by other surface mounted lighting units.

**424-40. Splices.** Embedded cables may be spliced only where necessary and only by approved means, and in no case shall the length of the heating cable be altered.

**424-41. Installation of Heating Cables on Dry Board, in Plaster and on Concrete Ceilings.**

(a) Cables shall not be installed in walls.

*Exception: Isolated single runs of cable may run down a vertical surface to reach a dropped ceiling.*

(b) Adjacent runs of cable not exceeding  $2\frac{3}{4}$  watts per foot shall be installed not less than  $1\frac{1}{2}$  inches on centers.

(c) Heating cables may be applied only to gypsum board, plaster lath or other fire-resistant material. With metal lath or other electrical conducting surface, a coat of plaster shall be applied to completely separate the metal lath or conducting surface from the cable. (See also Section 424-41(f).)

(d) All the heating cables, the splice between the heating cable and nonheating leads, and 3-inch minimum of the nonheating lead at the splice shall be embedded in plaster or dry board in the same manner as the heating cable.

(e) The entire ceiling surface shall have a finish of thermally non-insulating sand plaster having a nominal thickness of  $\frac{1}{2}$  inch, or other specially approved noninsulating material applied according to specified thickness and directions.

(f) Cables shall be secured at intervals not exceeding 16 inches by means of approved stapling, tape, plaster, nonmetallic spreaders or other approved means. Staples or metal fasteners which straddle the cable shall not be used with metal lath or other electrical conducting surface.

(g) In dry board installations, the entire ceiling below the heating cable shall be covered with gypsum board not exceeding  $\frac{1}{2}$ -inch thickness. The void between the upper layer of gypsum board, plaster lath or other fire-resistant material and the surface layer of gypsum board shall be completely filled with thermally conducting nonshrinking plaster or other approved material of equivalent thermal conductivity.

(h) Cables shall be kept free from contact with metal or other electrical conducting surfaces.

(i) In dry-board applications, cable shall be installed parallel to the joist, leaving a clear space centered under the joist of  $2\frac{1}{2}$  inches (width) between centers of adjacent runs of cable. Crossing of joist by cable shall be kept to a minimum and should be at the ends of the room. Surface layer of gypsum board shall be mounted so that the nails or other fastenings do not pierce the heating cable.

**424-42. Finished Ceilings.** Finished ceilings may be covered with paint, wallpaper or other approved surface finishes.

**424-43. Installation of Nonheating Leads of Cables and Panels.**

(a) Nonheating leads of cables and panels shall be installed in accordance with approved wiring methods from the junction box to a

location within the ceiling. Such installations may be single conductors in approved raceways, single- or multi-conductor Type UF, Type NMC, Type MI, or other approved conductors.

(b) Not less than 6 inches of nonheating leads shall be free within the junction box. The marking of the leads shall be visible in the junction box.

(c) Excess leads shall not be cut but shall be secured to the underside of the ceiling and embedded in plaster or other approved material, leaving only a length sufficient to reach the junction box with not less than 6 inches of free lead within the box.

#### **424-44. Installation of Panels or Cables in Concrete or Poured Masonry Floors.**

(a) Panels or heating units shall not exceed 33 watts per square foot of heated area or 16½ watts per linear foot of cable.

(b) The spacing between adjacent runs of cable shall not be less than one inch on centers.

(c) Cables shall be secured in place by nonmetallic frames or spreaders or other approved means while the concrete or other finish is applied.

Cables, units, and panels shall not be installed where they bridge expansion joints unless protected from expansion and contraction.

(d) Spacings shall be maintained between the heating cable and metal embedded in the floor.

*Exception: Grounded metal-clad cable may be in contact with metal embedded in the floor.*

(e) Leads shall be protected where they leave the floor by rigid metal conduit, electrical metallic tubing, or by other approved means.

(f) Bushings or approved fittings shall be used where the leads emerge within the floor slab.

#### **424-45. Tests During and After Installation.**

(a) Embedded cable installations shall be made with due care to prevent damage to the cable assembly and shall be inspected and approved before cables are covered or concealed.

(b) Cables should be tested for insulation resistance after plastering the ceiling or the pouring of floors.

**424-46. Panels — General.** Sections 424-46 through 424-48 cover only heating panels of less than 25 watts per square foot assembled together in the field to form a heating installation in one room or area using approved methods of interconnection. Such an installation shall be connected by a recognized wiring method.

**424-47. Panels to be Complete Units.** Panels shall be installed as complete units unless approved for field cutting in a recognized manner.

**424-48. Installation.** Panels shall be installed in an approved manner. Nails, staples, or other electrically conducting fasteners shall not be used where they penetrate current-carrying parts.

*Exception: Insulated fasteners may be used with systems for which they are recognized.*

#### F. Duct Heaters

**424-57. General.** The provisions in Part F shall apply to any heater mounted in the air stream of a forced-air system where the air moving unit is not provided as an integral part of the equipment.

**424-58. Approval.** Heaters installed in an air duct shall be approved for the purpose and installed in the approved manner.

**424-59. Air Flow.** Means shall be provided to assure uniform and adequate air flow over the face of the heater.

Heaters installed near (within 4 feet) a fan outlet, elbows, baffle plates or other obstruction in duct work may require turning vanes, pressure plates or other devices on the inlet side of the duct heater to assure an even distribution of air over the face of the heater.

**424-60. Elevated Inlet Temperature.** Duct heaters intended for use with elevated inlet air temperature (such as heat pumps) shall be approved for the purpose and so marked.

**424-61. Installation of Duct Heaters with Heat Pumps and Air Conditioners.** Heat pumps and air conditioners having duct heaters closer than 4 feet to the heat pump or air conditioner shall be approved for such installation and so marked.

**424-62. Condensation.** Duct heaters used with air conditioners or other air-cooling equipment which may result in condensation of moisture shall be approved for use with air conditioners.

**424-63. Fan Circuit Interlock.** Means shall be provided to insure that the fan circuit is energized when the first heater circuit is energized.

This does not prohibit time- or temperature-controlled delay in energizing the fan motor.

**424-64. Limit Controls.** Each duct heater shall be provided with an integral approved automatic reset temperature limiting control or controllers to de-energize the circuit or circuits.

In addition, an integral independent supplementary control or controllers shall be provided in each duct heater which will disconnect a sufficient number of conductors to interrupt current flow. This device shall be manually resettable or replaceable.

**424-65. Location of Disconnecting Means.** Duct heater controller equipment shall be accessible with the disconnecting means installed at or within sight of the controller.

**424-66. Installation.** See NFPA Pamphlets Nos. 90A — 1971 and 90B — 1971.

## ARTICLE 426 — FIXED OUTDOOR ELECTRIC DE-ICING AND SNOW MELTING EQUIPMENT

### A. General

**426-1. Scope.** The requirements of this Article shall apply to electrically energized heating units, panels, and cables where embedded in driveways, walks, steps, and other areas.

**426-2. Application of Other Articles.** All requirements of this Code shall apply where applicable.

**426-3. Branch-Circuit Requirements.** Fixed outdoor electric de-icing and snow melting equipment shall be: (1) considered as a continuous load for sizing branch circuits, and (2) installed according to Section 210-24.

### B. Installation

**426-9. General.** Equipment for use with fixed outdoor electric de-icing and snow melting systems shall be of a type approved for such service and for the location where installed.

**426-10. Use.**

(a) De-icing and snow melting equipment shall be installed only in the specific materials for which they are approved.

(b) De-icing and snow melting units shall be protected from physical damage.

**426-11. Complete Units.**

(a) Units, panels, and cables shall be installed in their complete sizes or lengths as supplied by the manufacturer, except that the nonheating leads may be shortened if the marking specified in Section 426-26 is retained. Units without nameplates shall not be installed.

(b) Units shall be suitable for use with approved wiring systems.

**426-12. Special-Type Equipment.** Fixed outdoor electric de-icing and snow melting equipment employing methods of construction or installation other than that covered by this Article may be used only by special permission.

### C. Control and Protection

**426-20. Disconnecting Means.** All fixed outdoor electric de-icing and snow melting equipment shall be provided with a means for disconnection from all ungrounded conductors. The branch-circuit switch or circuit breaker may, where readily accessible to the user of the equipment, serve as the disconnecting means. Switches used as disconnecting means shall be of the indicating type.

**426-21. Controllers.**

(a) Thermostats and thermostatically controlled switching devices which indicate an off position and which interrupt line current shall

open all ungrounded conductors when the control device is in the off position, and may be used as the disconnecting means.

(b) Thermostats and thermostatically controlled switching devices shall be so designed that the circuit cannot be energized automatically after the device has been manually placed in the off position.

(c) Thermostats and thermostatically controlled switching devices which do not have an off position are not required to open all ungrounded conductors, but shall not be used as the disconnecting means required in Section 426-20.

**426-22. Overcurrent Protection.** Fixed outdoor electric de-icing and snow melting equipment shall be considered as protected against overcurrent when supplied by one of the circuits of Article 210 and in accordance with the requirements therein specified.

**426-23. Nonheating Leads.** Nonheating leads on the cables, panels, or units shall be furnished as part of the factory assembly. The leads shall consist of conductors and wiring approved for general use, or other wiring approved for the purpose.

**426-24. Installation of Heating Cables, Units, or Panels.**

(a) The operating characteristics of embedded assemblies of fixed outdoor electric de-icing and snow melting equipment depend upon the specific materials involved, and, therefore, embedded equipment shall be installed as designed for use in such materials.

(b) Panels or units shall not exceed 120 watts per square foot of heated area.

(c) The spacings between adjacent cable runs is dependent upon the rating of the cable, and shall be not less than one inch on centers.

(d) Units, panels, and cables shall be installed:

(1) On a substantial asphalt or masonry base at least 2 inches thick and have at least 1½ inches of asphalt or masonry applied over the units, panels, or cables, or

(2) They may be installed over other approved bases and embedded within 3½ inches of masonry or asphalt but not less than 1½ inches from the top surface, or

(3) Equipment which has been specially investigated for other forms of installation shall be installed only in the manner for which it has been investigated.

(e) Cables shall be secured in place by frames or spreaders, or other approved means, while the masonry or asphalt finish is applied.

(f) Cables, units, and panels shall not be installed where they bridge expansion joints unless adequately protected from expansion and contraction.

**426-25. Installation of Nonheating Leads.**

(a) Nonheating leads having a grounding sheath or braid may be embedded in masonry or asphalt in the same manner as the heating cable without additional protection.



(b) All but one to 6 inches of nonheating leads of Type TW and other approved types not having a grounding sheath shall be enclosed in conduit, electrical metallic tubing or other raceways within the asphalt or masonry, and the distance from the factory splice to the raceway shall be not less than one inch nor more than 6 inches.

(c) Insulating bushings shall be used in the asphalt or masonry where leads enter conduit, tubing, or raceway.

(d) Leads shall be protected in expansion joints and where they emerge from masonry or asphalt by conduit, electrical metallic tubing, other raceways, or other approved means.

(e) Not less than 6 inches of nonheating leads shall be within the junction box.

**426-26. Marking.** Each heating unit, panel, and cable shall be legibly marked within 3 inches of each end of the nonheating leads with the identification symbol, catalog number, and ratings in volts and watts or amperes.

**426-27. Junction Boxes.** All splices other than factory splices shall be made in properly installed boxes approved for the location.

**426-28. Grounding.**

(a) All exposed metal parts of fixed outdoor electric de-icing and snow melting equipment, raceways, boxes, etc., liable to become energized shall be grounded as required in Article 250.

(b) Grounding means such as copper braid, lead or copper sheath, or other approved means, shall be provided as part of the heating section of the approved cable, panel, or unit.

(c) All noncurrent-carrying parts which are liable to become energized shall be bonded together and positively connected to a continuous (unbroken) No. 14 AWG or larger covered copper wire sized in accordance with Table 250-95 extending to the distribution panelboard. Where the bonding conductor is subject to physical damage, it shall be at least No. 10 AWG copper.

**426-29. Tests.** Embedded heating installations shall be inspected and approved before being covered.


## ARTICLE 430 — MOTORS, MOTOR CIRCUITS AND CONTROLLERS

### A. General

**430-1. (a). Motor Feeder and Branch Circuits.** See Diagram 430-1(a).

(b) **General.** The following general requirements cover provisions for motors, motor circuits, and controllers which do not properly fall into the other parts of this Article. See Article 440 for air-conditioning and refrigerating equipment.

Diagram 430-1(a)



**430-3. Part-Winding Motors.** A part-winding-start induction or synchronous motor is one arranged for starting by first energizing part of its primary (armature) winding and, subsequently, energizing the remainder of this winding in one or more steps. The purpose is to reduce the initial values of the starting current drawn or the starting torque developed by the motor. A standard part-winding-start induction motor is arranged so that one-half of its primary winding can be energized initially and, subsequently, the remaining half can be energized, both halves then carrying the same current. A sealed "hermetic-type" refrigeration compressor motor is not to be considered a standard part-winding-start induction motor.

When separate overcurrent devices are used with a standard part-winding-start induction motor, each half of the motor winding shall be individually protected in accordance with Sections 430-32 and 430-37, except that the trip current shall be one-half that specified.

Each motor-winding connection shall have short-circuit and ground-fault protection rated at not more than one-half that specified by Section 430-52, except that a single device having this half rating may be used for both windings if this will allow the motor to start.

**430-4. In Sight From.** Where in this Article it is specified that some equipment shall be "in sight from" another equipment, it means that the equipment must be visible and not more than 50 feet distant.

**430-5. Other Articles.** Motors and controllers shall also comply with the applicable provisions of the following:

Air-conditioning and Refrigerating Equipment .....	Article 440
Capacitors .....	Section 460-9
Cranes and Hoists .....	Article 610
Elevators, Dumbwaiters, Escalators, and Moving Walks .....	Article 620
Garages, Aircraft Hangars, Gasoline Dispensing and Service Stations, Bulk Storage Plants, Finishing Processes and Flammable Anesthetics ...	Articles 511, 513, 514, 515, 516, and 517-E
Hazardous Locations .....	Articles 500 thru 503
Metalworking Machine Tools .....	Article 670
Motion-picture Projectors .....	Sections 540-12, 540-17
Motion-picture Studios .....	Article 530
Organs .....	Section 650-3
Resistors and Reactors .....	Article 470
Theaters .....	Section 520-48

**430-6. Ampacity Determination.** Ampacities shall be determined as follows:

**(a) General Motor Applications.** Except as noted in Section 430-6(b) whenever the current rating of a motor is used to determine the ampacity of conductors, switches, branch-circuit overcurrent devices, etc., the values given in Tables 430-147, 430-148, 430-149, and 430-150, including notes, shall be used instead of actual current rating marked on the motor nameplate. Separate motor-running overcurrent protection shall be based on the motor nameplate current rating. When a motor is marked in amperes, but not horsepower, the horsepower rating shall be assumed to be that corresponding to the value given in Tables 430-147, 430-148, 430-149, and 430-150 interpolated if necessary.

*Exception: For multispeed motors, see Sections 430-22(a) and 430-52.*

**(b) Torque Motors.** For torque motors the rated current shall be locked-rotor current and this nameplate current shall be used to determine the ampacity of the branch-circuit conductors (see Sections 430-22 and 430-24) and motor operating overcurrent protection. For motor controllers and disconnecting means, see Section 430-83, Exception No. 3 and Section 430-110.

#### **430-7. Marking on Motors and Multimotor Equipment.**

**(a) Usual Motor Applications.** A motor shall be marked with the following information:

- (1)** Maker's name.
- (2)** Rated volts and full-load amperes.
- (3)** Rated frequency and number of phases, if an alternating-current motor.
- (4)** Rated full-load speed.
- (5)** Rated temperature rise or the insulation system class and rated ambient temperature.
- (6)** Time rating.
- (7)** Rated horsepower if  $\frac{1}{8}$  horsepower or more.
- (8)** Code letter if an alternating-current motor rated  $\frac{1}{2}$  horsepower or more (see Section 430-7(b)).
- (9)** Secondary volts and full-load amperes if a wound-rotor induction motor.
- (10)** Winding: straight shunt, stabilized shunt, compound or series, if a direct-current motor.

A multispeed motor, except a shaded-pole or permanent-split capacitor motor, shall be marked with the amperes and horsepower at each speed. A motor provided with a thermal protector complying with Section 430-32(a)(2) or 430-32(c)(2) shall be marked "Thermally Protected." A motor complying with Section 430-32(c)(4) shall be marked "Impedance Protected." The time rating shall be 5, 15, 30, or 60 minutes, or continuous.

*Exception No. 1: On motors of arc welders, the horsepower rating may be omitted.*

*Exception No. 2: On polyphase wound-rotor motors the code letter shall be omitted.*

**(b) Locked-Rotor Indicating Code Letters.** Code letters marked on motor nameplates to show motor input with locked rotor shall be in accordance with Table 430-7(b).

The code letter indicating motor input with locked rotor must be in an individual block on the nameplate, properly designated. This code letter is to be used for determining branch-circuit overcurrent protection by reference to Table 430-152, as provided in Section 430-52.

Table 430-7(b). Locked-Rotor Indicating Code Letters

Code Letter	Kilovolt-Amperes per Horsepower with Locked Rotor		
A .....	0	—	3.14
B .....	3.15	—	3.54
C .....	3.55	—	3.99
D .....	4.0	—	4.49
E .....	4.5	—	4.99
F .....	5.0	—	5.59
G .....	5.6	—	6.29
H .....	6.3	—	7.09
J .....	7.1	—	7.99
K .....	8.0	—	8.99
L .....	9.0	—	9.99
M .....	10.0	—	11.19
N .....	11.2	—	12.49
P .....	12.5	—	13.99
R .....	14.0	—	15.99
S .....	16.0	—	17.99
T .....	18.0	—	19.99
U .....	20.0	—	22.39
V .....	22.4	—	and up

The above table is an adopted standard of the National Electrical Manufacturers Association.

(1) Multispeed motors shall be marked with the code letter designating the locked-rotor kVA per horsepower for the highest speed at which the motor can be started, except constant horsepower motors which shall be marked with the code letter giving the highest locked-rotor kVA per horsepower.

(2) Single-speed motors starting on Y connection and running on delta connections shall be marked with a code letter corresponding to the locked-rotor kVA per horsepower for the Y connection.

(3) Dual-voltage motors which have a different locked-rotor kVA per horsepower on the two voltages shall be marked with the code letter for the voltage giving the highest locked-rotor kVA per horsepower.

(4) Motors with 60- and 50-hertz ratings shall be marked with a code letter designating the locked rotor kVA per horsepower on 60 hertz.

(5) Part-winding-start motors shall be marked with a code letter designating the locked-rotor kVA per horsepower that is based upon the locked-rotor current for the full winding of the motor.

(c) **Torque Motors.** Torque motors are rated for operation at standstill and shall be marked in accordance with paragraph (a) except that locked rotor torque shall replace horsepower.

**(d) Multimotor and Combination-Load Equipment.** Multimotor and combination-load equipment shall be provided with a visible nameplate marked with the maker's name, the rating in volts, frequency and number of phases, minimum circuit ampacity, and the maximum rating of the circuit protective device. The ampacity shall be calculated by using Section 430-25 and counting all of the motors and other loads which will be operated at the same time. The protective device rating shall not exceed the value calculated by using Section 430-53. Multimotor equipment for use on two or more circuits shall be marked with the above information for each circuit.

When the equipment is not factory-wired and the individual nameplates of motors and other loads are visible after assembly of the equipment, these nameplates may serve as the required marking.

**430-8. Marking on Controllers.** A controller shall be marked with the maker's name or identification, the voltage, the current or horsepower rating, and such other data as may be needed to properly indicate the motors for which it is suitable. A controller which includes motor running overcurrent protection, when suitable for group motor application shall be marked with the motor-running overcurrent protection and the maximum branch-circuit overcurrent protection for such applications.

Combination controllers employing adjustable instantaneous circuit breakers (without time delay) shall be clearly marked to indicate the ampere settings of the adjustable trip element.

Where a controller is built in as an integral part of a motor or of a motor-generator set, the controller need not be individually marked when the necessary data is on the motor nameplate. For controllers which are an integral part of equipment approved as a unit, the above marking may be on the equipment nameplate.

**430-9. Marking at Terminals.** Terminals of motors and controllers shall be suitably marked or colored where necessary to indicate the proper connections.

**430-10. Wiring Space in Enclosures.** Enclosures for controllers and disconnecting means for motors shall not be used as junction boxes, auxiliary gutters, or raceways for conductors feeding through or tapping off to the other apparatus unless designs are employed which provide adequate space for this purpose. See Section 373-8.

**430-11. Protection Against Liquids.** Suitable guards or enclosures shall be provided to protect exposed current-carrying parts of motors and the insulation of motor leads where installed directly under equipment, or in other locations where dripping or spraying oil, water, or other injurious liquid may occur, unless the motor is designed for the existing conditions.

**430-12. Motor Terminal Housings.**

**(a)** When motors are provided with terminal housings, the housings shall be of metal and of substantial construction.

*Exception: In other than hazardous locations, substantial nonmetallic, nonburning housings may be used on motors larger than 34 inches in diameter provided internal grounding means between the machine frame and the conduit connection is incorporated within the housing.*

See ANSI Standard Method of Test for Flammability of Rigid Plastics over 0.127CM (0.050 inch) in thickness, K65.21-1969 for non-burning test.

(b) When these terminal housings enclose wire-to-wire connections, they shall have minimum dimensions and usable volumes in accordance with the following:

**Table 430-12(b). Terminal Housing — Wire-to-Wire Connections**

Hp	Cover Opening, Minimum Dimension, Inches	Usable Volume, Minimum, Cubic Inches
1 and smaller*	1 $\frac{5}{8}$	7 $\frac{1}{2}$
1 $\frac{1}{2}$ , 2 and 3†	1 $\frac{3}{4}$	12
5 and 7 $\frac{1}{2}$	2	16
10 and 15	2 $\frac{1}{4}$	22 $\frac{1}{2}$
20 and 25	2 $\frac{7}{8}$	33
30 and 40	3	44
50 and 60	3 $\frac{1}{2}$	72 $\frac{1}{2}$
75 and 100	3 $\frac{1}{2}$	100
125 and 150	6	216

\*For motors rated one horsepower and smaller and with the terminal housing partially or wholly integral with the frame or end shield, the volume of the terminal housing shall be not less than 0.8 cubic inch per wire-to-wire connection. The minimum cover opening dimension is not specified.

†For motors rated 1 $\frac{1}{2}$ , 2 and 3 horsepower and with the terminal housing partially or wholly integral with the frame or end shield, the volume of the terminal housing shall be not less than 1.0 cubic inch per wire-to-wire connection. The minimum cover opening dimension is not specified.

(c) When these terminal housings enclose rigidly mounted motor terminals, the terminal housing shall be of sufficient size to provide minimum terminal spacings and usable volumes in accordance with the following:

**Table 430-12(c)(1). Terminal Spacings—Fixed Terminals**

Volts	Minimum Spacing, Inches	
	Between Line Terminals	Between Line Terminals and Other Uninsulated Metal Parts
250 or less	$\frac{1}{4}$	$\frac{1}{4}$
251 to 600, incl.	$\frac{3}{8}$	$\frac{3}{8}$

**Table 430-12(c)(2). Usable Volumes—Fixed Terminals**

Power-Supply Conductor Size, AWG	Minimum Usable Volume per Power-Supply Conductor, Cubic Inches
14	1.0
12 and 10	1¼
8 and 6	2¼

(d) For larger wire sizes or when motors are installed as a part of factory-wired equipment, without additional connection being required at the motor terminal housing during equipment installation, the terminal housing shall be of ample size to make connections, but the foregoing provisions for the volumes of terminal housings need not apply.

**430-13. Bushing.** Where wires pass through an opening in an enclosure, conduit box or barrier, a bushing shall be used to protect the conductors from the edges of the openings having sharp edges. The bushing shall have smooth, well-rounded surfaces where it may be in contact with the conductors. If used where there may be a presence of oils, greases, or other contaminants, the bushing shall be made of material not deleteriously affected.

For conductors, see Section 310-7.

**430-14. Location of Motors.**

(a) **Ventilation and Maintenance.** Motors shall be located so that adequate ventilation is provided and so that maintenance such as lubrication of bearings and replacing of brushes can be readily accomplished.

(b) **Open Motors.** Open motors having commutators or collector rings shall be located or protected so that sparks cannot reach adjacent combustible material. This does not prohibit the installation of these motors on wooden floors or supports.

**430-16. Overheating from Dust Accumulations.** In locations where dust or flying material will collect on or in motors in such quantities as to seriously interfere with the ventilation or cooling of motors, and thereby caused dangerous temperatures, suitable types of enclosed motors which will not overheat under the prevailing conditions, shall be used. Especially severe conditions may require the use of enclosed pipe ventilated motors, or enclosure in separate dust-tight rooms, properly ventilated from a source of clean air.

**430-17. Highest Rated (Largest) Motor.** In determining compliance with Sections 430-24, 430-53(b), 430-53(c), and 430-62(a), the highest rated (largest) motor shall be considered to be that motor which has the highest rated full-load current. The full-load current used to determine the highest rated motor shall be the equivalent value corresponding to the motor horsepower rating selected from Tables 430-147, 430-148, 430-149, and 430-150.



**B. Motor-Circuit Conductors**

**430-21. General.** The provisions of Part B specify sizes of conductors capable of carrying the motor current without overheating under the conditions specified.

(a) The provisions of Articles 250, 300, and 310 are not intended to apply to conductors which form an integral part of approved equipment, or to integral conductors of motors, motor controllers, and the like. See Sections 300-1(b) and 310-1(c).

**Table 430-22 (a-Exception). Duty-Cycle Service**

Classification of Service	Percentages of Nameplate Current Rating			
	5-Minute Rated Motor	15-Minute Rated Motor	30 & 60 Minute Rated Motor	Con- tinuous Rated Motor
Short-Time Duty Operating valves, raising or lowering rolls, etc. ....	110	120	150	...
Intermittent Duty Freight and passenger elevators, tool heads, pumps, drawbridges, turn- tables, etc. For arc welders, see Sec- tion 630-21 .....	85	85	90	140
Periodic Duty Rolls, ore and coal-handling ma- chines, etc. ....	85	90	95	140
Varying Duty .....	110	120	150	200

Any motor application is considered to be for continuous duty unless the nature of the apparatus which it drives is such that the motor will not operate continuously with load under any condition of use.

For long runs, it may be necessary in order to avoid excessive voltage drop, to use conductors of sizes larger than the minimum sizes selected from Tables 310-12 thru 310-15.

See Example No. 8, Ch. 9, and Diagram 430-1(a).

**430-22. Single Motor.**

(a) Branch-circuit conductors supplying a single motor shall have an ampacity not less than 125 percent of the motor full-load current rating.

In case of a multispeed motor, the selection of branch-circuit con- ductors on the line side of the controller shall be based on the high- est of the full-load current ratings shown on the motor nameplate; selection of branch-circuit conductors between the controller and the motor, which are energized for that particular speed, shall be based on the current rating for that speed.

*Exception: Conductors for a motor used for short-time, intermittent, periodic, or varying duty shall have an ampacity not less than the per-*

*centage of the motor nameplate current rating as shown in Table 430-22 (a-Exception) unless the authority having jurisdiction grants special permission for conductors of smaller size.*

(b) The conductors between a stationary motor rated one horse-power or less, and the separate terminal enclosures permitted in Section 430-145(b) may be smaller than No. 14 but not smaller than No. 18, provided they have an ampacity as specified above.

**430-23. Wound-Rotor Secondary.**

(a) For continuous duty the conductors connecting the secondary of a wound-rotor alternating-current motor to its controller shall have an ampacity which is not less than 125 percent of the full-load secondary current of the motor.

(b) For other than continuous duty, these conductors shall have an ampacity, in percent of full-load secondary current, not less than that specified in Table 430-22 (a-Exception).

(c) Where the secondary resistor is separate from the controller, the ampacity of the conductors between controller and resistor shall be not less than that given in Table 430-23 (c).

**Table 430-23(c). Secondary Conductor**

Resistor Duty Classification	Ampacity of Wire in Percent of Full-Load Secondary Current
Light starting duty .....	35
Heavy starting duty .....	45
Extra-heavy starting duty .....	55
Light intermittent duty .....	65
Medium intermittent duty .....	75
Heavy intermittent duty .....	85
Continuous duty .....	110

**430-24. Conductors Supplying Several Motors.** Conductors supplying two or more motors shall have an ampacity equal to the sum of the full load current rating of all the motors plus 25 percent of the highest rated motor in the group.

Where one or more motors of the group are used on short-time, intermittent, periodic, or varying duty, the ampacity of the conductors shall be calculated as follows:

(a) Determine the needed ampacity for each motor used for other than continuous duty from Table 430-22(a-Exception).

(b) Determine the needed ampacity for each continuous-duty motor based on 100 percent motor full-load current rating.

(c) Multiply the largest single motor ampacity determined from (a) or (b) above by 1.25. Add all other motor ampacities from (a) and (b) above and select the conductor for this total ampacity.

*Exception: When the circuitry is so interlocked as to prevent the starting and running of a second motor or group of motors, the conductor size shall be determined from the larger motor or group of motors that is to be operated at a given time.*

See Example No. 8, Chapter 9.

#### **430-25. Supply Conductors.**

**(a) Combination Load.** Conductors supplying a motor load, and in addition a lighting or appliance load as computed from Article 220 and other applicable Sections, shall have an ampacity sufficient for the lighting or appliance load plus the required capacity for the motor load determined in accordance with Section 430-24, or, for a single motor, in accordance with Section 430-22.

**(b) Multimotor and Combination Load Equipment.** The ampacity of the conductors supplying multimotor and combination-load equipment shall not be less than the minimum circuit ampacity marked on the equipment in accordance with Section 430-7(d).

**430-26. Feeder Demand Factor.** Where a reduced heating of the conductors results from motors operating on duty-cycle, intermittently, or from all motors not operating at one time the authority having jurisdiction may grant permission for feeder conductors to be of a capacity less than specified in Sections 430-24 and 430-25, provided the conductor is of sufficient ampacity for the maximum load determined by the sizes and number of motors supplied and the character of their loads and duties.

**430-27. Capacitors with Motors:** For provisions covering conductors where capacitors are installed on motor circuits, see Sections 460-7, 460-8, 460-9.

### **C. Motor and Branch-Circuit Running Overcurrent (Overload) Protection**

**430-31. General.** The provisions of Part C specify overcurrent devices intended to protect the motors, the motor-control apparatus, and the branch-circuit conductors against excessive heating due to motor overloads or failure to start.

**(a) Overload** in electrical apparatus is an operating overcurrent which, when it persists for a sufficient length of time, would cause damage or dangerous overheating of the apparatus. It does not include short circuits or ground faults.

**(b)** These provisions shall not be interpreted as requiring overcurrent protection where it might introduce additional or increased hazards as in the case of fire pumps See NFPA Standard for Centrifugal Fire Pumps (No. 20-1971).

#### **430-32. Continuous-Duty Motors.**

**(a) More Than One Horsepower.** Each continuous-duty motor rated more than one horsepower shall be protected against overcurrent by one of the following means:

(430-32(a) continued)

(1) A separate overcurrent device which is responsive to motor current. This device shall be rated or selected to trip at no more than the following percent of the motor full-load current rating:

Motors with a marked service factor not less than 1.15	125%
Motors with a marked temperature rise not over 40°C	125%
All other motors	115%

For a multispeed motor, each winding connection shall be considered separately. This value may be modified as permitted by Section 430-34.

When a separate motor-running overcurrent device is so connected that it does not carry the total current designated on the motor nameplate, such as for wye-delta starting, the proper percentage of nameplate current applying to the selection or setting of the overcurrent device shall be clearly designated on the equipment or the manufacturer's selection table shall take this into account.

(2) A thermal protector integral with the motor, approved for use with the motor which it protects on the basis that it will prevent dangerous overheating of the motor due to overload and failure to start. The ultimate trip current of a thermally protected motor shall not exceed the following percentage of motor full-load current given in Tables 430-148, 430-149 and 430-150:

Motor full-load current not exceeding 9 amperes—	170%
Motor full-load current 9.1 to and including 20 amperes—	156%
Motor full-load current greater than 20 amperes—	140%

If the motor current-interrupting device is separate from the motor and its control circuit is operated by a protective device integral with the motor, it shall be so arranged that the opening of the control circuit will result in interruption of current to the motor.

(3) The motor shall be considered as being properly protected where it is a part of an approved assembly which does not normally subject the motor to overloads and if there is a protective device integral with the motor which will protect the motor against damage due to failure to start.

(4) For motors larger than 1,500 horsepower, a protective device employing embedded temperature detectors which cause current to the motor to be interrupted when the motor attains a temperature rise greater than marked on the nameplate in an ambient of 40° C.

Standards for the application of embedded temperature detectors are given in Standards for Rotating Electrical Machinery, ANSI C50.2-1955 and C50.4-1965.

**(b) One Horsepower or Less, Manually Started.**

(1) Each continuous-duty motor rated at one horsepower or less which is not permanently installed, is manually started and is within sight from the controller location, shall be considered as protected against overcurrent by the overcurrent device protecting the conductors of the branch circuit. This branch-circuit overcurrent device shall not be larger than that specified in Part D, of Article 430, except that any such

motor may be used at 125 volts or less on a branch circuit protected at 20 amperes.

(2) Any such motor which is not in sight from the controller location shall be protected as specified in Section 430-32(c). Any motor rated at one horsepower or less which is permanently installed, shall be protected in accordance with Section 430-32(c).

**(c) One Horsepower or Less, Automatically Started.** Any motor of one horsepower or less which is started automatically shall be protected against overcurrent by the use of one of the following means:

(1) A separate overcurrent device which is responsive to motor current. This device shall be rated or selected to trip at no more than the following percent of the motor full-load current rating:

Motors with a marked service factor not less than 1.15	125%
Motors with a marked temperature rise not over 40°C	125%
All other motors	115%

For a multispeed motor, each winding connection shall be considered separately. This value may be modified as permitted by Section 430-34.

(2) A thermal protector integral with the motor, approved for use with the motor which it protects on the basis that it will prevent dangerous overheating of the motor due to overload and failure to start. Where the motor current interrupting device is separate from the motor and its control circuit is operated by a protective device integral with the motor, it shall be so arranged that the opening of the control circuit will result in interruption of current to the motor.

(3) The motor shall be considered as being properly protected where it is part of an approved assembly which does not normally subject the motor to overloads and if there is a protective device integral with the motor which will protect the motor against damage due to failure to start, or if the assembly is also equipped with other safety controls (such as the safety combustion controls of a domestic oil burner) which protect the motor against damage due to failure to start. Where the assembly has safety controls which protect the motor it shall be so indicated on the nameplate of the assembly where it will be visible after installation.

(4) In case the impedance of the motor windings is sufficient to prevent overheating due to failure to start, the motor may be protected as specified in Section 430-32(b)(1) for manually started motors provided that the motor is part of an approved assembly in which the motor will limit itself so that it will not be dangerously overheated.

Many alternating-current motors of less than 1/20 horsepower, such as clock motors, series motors, etc., and also some larger motors such as torque motors, come within this classification. It does not include split-phase motors having automatic switches to disconnect the starting windings.

**(d) Wound-Rotor Secondaries.** The secondary circuits of wound-rotor alternating-current motors, including conductors, controllers,

(430-32(d) continued)

resistors, etc., shall be considered as protected against overcurrent by the motor-running overcurrent device.

**430-33. Intermittent and Similar Duty.** A motor used for a condition of service which is inherently short-time, intermittent, periodic, or varying duty, as illustrated by Table 430-22 (a-Exception), shall be considered as protected against overcurrent by the branch-circuit overcurrent device, provided the overcurrent protection does not exceed that specified in Table 430-152.

Any motor application shall be considered to be for continuous duty unless the nature of the apparatus which it drives shall be such that the motor cannot operate continuously with load under any condition of use.

**430-34. Selection or Setting of Protective Device.** Where the values specified for motor-running overcurrent protection in Sections 430-32 (a)(1) and 430-32(c)(1) do not correspond to the standard sizes or ratings of fuses, nonadjustable circuit breakers, thermal cutouts, thermal relays, the heating elements of thermal-trip motor switches, or the possible settings of adjustable circuit breakers adequate to carry the load, the next higher size, rating, or setting may be used, but not higher than the following percent of motor full-load current rating:

Motors with a marked service factor not less than 1.15	140%
Motors with a marked temperature rise not over 40°C	140%
All other motors	130%

In case it is not shunted during the starting period of the motor (see Section 430-35), the protective device shall have sufficient time delay to permit the motor to start and accelerate its load.

**430-35. Shunting During Starting Period.**

(a) In the case of a motor that is manually started (including starting with a magnetic starter having pushbutton control), the running overcurrent protection may be shunted or cut out of circuit during the starting period of the motor, provided the device by which the overcurrent protection is shunted or cut out cannot be left in the starting position, and fuses or time-delay circuit breakers rated or set at not over 400 percent of the full-load current of the motor, are so located in the circuit as to be operative during the starting period of the motor.

(b) The motor-running overcurrent protection shall not be shunted or cut out during the starting period if the motor is automatically started.

**430-36. Fuses—In Which Conductor.** Where fuses are used for motor-running protection, a fuse shall be inserted in each ungrounded conductor.

*Exception: A fuse shall also be inserted in the grounded conductor when the supply system is 3-wire, 3-phase AC, one conductor grounded.*

**430-37. Devices Other Than Fuses—In Which Conductor.** Where devices other than fuses are used for motor-running overload protection, Table 430-37 shall govern the minimum allowable number and location of overcurrent units such as trip coils, relays, or thermal cutouts.

**Table 430-37 — Running Overcurrent Units**

Kind of Motor	Supply System	Number and location of overcurrent units, such as trip coils, relays or thermal cutouts
1-phase A.C. or D.C.	2-wire, 1-phase A.C. or D.C. ungrounded	1 in either conductor
1-phase A.C. or D.C.	2-wire, 1-phase A.C. or D.C., one conductor grounded	1 in ungrounded conductor
1-phase A.C. or D.C.	3-wire, 1-phase A.C. or D.C., grounded-neutral	1 in either ungrounded conductor
2-phase A.C.	3-wire, 2-phase A.C., ungrounded	2, one in each phase
2-phase A.C.	3-wire, 2-phase A.C., one conductor grounded	2 in ungrounded conductors
2-phase A.C.	4-wire, 2-phase A.C. grounded or ungrounded	2, one per phase in ungrounded conductors
2-phase A.C.	5-wire, 2-phase, A.C. grounded neutral or ungrounded	2, one per phase in any ungrounded phase wire
3-phase A.C.	Any 3-phase	*3, one in each phase

\* *Exception: Unless protected by other approved means.*

**430-38. Number of Conductors Opened by Overcurrent Device.** Motor-running protective devices, other than fuses, thermal cutouts, or thermal protectors, shall simultaneously open a sufficient number of ungrounded conductors to interrupt current flow to the motor.

**430-39. Motor Controller as Running Overcurrent Protection.** A motor controller may also serve as the running overcurrent device where the number of overcurrent units complies with Section 430-37 and where these overcurrent units are operative in both the starting and running position in the case of a direct-current motor, and in the running position in the case of an alternating-current motor. When a nonautomatic motor controller serves as the running overcurrent device, it is recommended that all ungrounded conductors be opened.

**430-40. Thermal Cutouts and Overload Relays.** Thermal cutouts, overload relays, and other devices for motor-running protection which are not capable of opening short circuits, shall be protected by fuses or circuit breakers with ratings or settings or by a motor short-circuit pro-

(430-40 continued)

lector in accordance with Section 430-52, unless approved for group installation and marked to indicate the maximum size of fuse or time-limit circuit breaker by which they must be protected.

*Exception: The fuse or circuit breaker ampere rating may be marked on the nameplate of approved equipment in which the thermal cutout or relay is used.*

For instantaneous circuit breakers or motor short-circuit protectors see Section 430-52.

**430-42. Motors on General-Purpose Branch Circuits.** Overcurrent protection for motors used on general-purpose branch circuits as permitted in Article 210, shall be provided as follows:

(a) One or more motors without individual running overcurrent protection may be connected to general-purpose branch circuits only where the limiting conditions specified for each of two or more motors in Section 430-53(a) are complied with.

(b) Motors of larger ratings than specified in Section 430-53(a) may be connected to general-purpose branch circuits only in case each motor is protected by running overcurrent protection selected to protect the motor as specified in Section 430-32. Both the controller and the motor-running overcurrent device shall be approved for group installation with the protective device of the branch circuit to which the motor is connected. See Section 430-53.

(c) Where a motor is connected to a branch circuit by means of a plug and receptacle, and individual running overcurrent protection is omitted as provided in Section 430-42(a), a rating of the plug and receptacle shall not exceed 15 amperes at 125 volts or 10 amperes at 250 volts. Where individual overcurrent protection is required as provided in Section 430-42(b) for a motor or motor-operated appliance provided with an attachment plug for attaching to the branch circuit through a receptacle, the running overcurrent device shall be an integral part of the motor or of the appliance. The rating of the plug and receptacle shall be assumed to determine the rating of the circuit to which the motor may be connected, as provided in Article 210.

(d) The overcurrent device protecting a branch circuit to which a motor or motor-operated appliance is connected shall have sufficient time delay to permit the motor to start and accelerate its load.

**430-43. Automatic Restarting.** A motor-running protective device which can restart a motor automatically after overcurrent tripping shall not be installed unless approved for use with the motor which it protects. A motor which can restart automatically after shutdown shall not be installed so that its automatic restarting can result in injury to persons.

#### **D. Motor Branch-Circuit Short-Circuit and Ground-Fault Protection**

**430-51. General.** The provisions of Part D specify overcurrent devices intended to protect the motor branch circuit conductors, the motor control apparatus, and the motors against overcurrent due to short



circuits or grounds. They are in addition to or amendatory of the provisions of Article 240.

**430-52. Rating or Setting for Individual Motor Circuit.** The motor branch-circuit overcurrent device shall be capable of carrying the starting current of the motor. Short-circuit and ground-fault overcurrent protection shall be considered as being obtained when the overcurrent device has a rating or setting not exceeding the values given in Table 430-152. An instantaneous-trip circuit breaker (without time delay) shall be used only if adjustable and if part of a combination controller having motor-running overcurrent and short-circuit protection in each conductor and the combination is especially approved for the purpose. A motor short-circuit protector may be used in lieu of devices listed in Table 430-152, provided the motor short-circuit protector is part of a combination controller having motor-running overcurrent and short-circuit protection in each conductor, will operate at not more than 1,300 percent of full-load motor current, and provided the combination is especially approved for the purpose.

In case the values for branch-circuit protective devices determined by Table 430-152 do not correspond to the standard sizes or ratings of fuses, nonadjustable circuit breakers, or thermal devices, or possible settings of adjustable circuit breakers adequate to carry the load, the next higher size, rating or setting may be used. See Section 240-5(b) for standard ratings.

*Exception: Where the overcurrent protection specified in Table 430-152 is not sufficient for the starting current of the motor:*

*a. The rating of a nontime-delay fuse or time-limit circuit breaker may be increased but shall in no case exceed 400 percent of the full-load current.*

*b. The rating of a time-delay (dual-element) fuse may be increased but shall in no case exceed 225 percent of the full-load current.*

*c. The setting of an instantaneous-trip circuit breaker (without time delay) may be increased over 700 percent but shall in no case exceed 1,300 percent of the motor full-load current.*

*d. Torque motor branch circuits shall be protected at the motor nameplate current rating. See Section 240-5(a), Exception No. 1.*

For a multispeed motor, a single short-circuit and ground-fault protective device shall be used for two or more windings of the motor provided the rating of the protective device does not exceed the above applicable percentage of the nameplate rating of the smallest winding protected.

Where maximum protective device ratings are shown in the manufacturer's heater table for use with a marked controller or are otherwise marked with the equipment, they shall not be exceeded even if higher values are allowed as shown above.

See Example No. 8, Chapter 9, and Diagram 430-1(a).

**430-53. Several Motors or Loads on One Branch Circuit.** Two or more motors or a motor(s) and other loads may be connected to the same branch circuit under any of the following conditions:

(430-53 continued)

(a) Several motors each not exceeding one horsepower in rating may be used on a branch circuit protected at not more than 20 amperes at 125 volts or less, or 15 amperes at 600 volts or less, provided that all of the following conditions are met:

(1) The full-load rating of each motor shall not exceed 6 amperes.

(2) The rating of the branch-circuit protective device marked on any of the controllers shall not be exceeded.

(3) Individual running overcurrent protection shall conform to Section 430-32.

(b) If the branch-circuit protective device is selected not to exceed that allowed by Section 430-52 for the motor of the smallest rating, two or more motors or a motor(s) and other load(s), with each motor having individual running overcurrent protection, may be connected to a branch circuit when it can be determined that the branch-circuit protective device will not open under the most severe normal conditions of service which might be encountered.

(c) Two or more motors of any rating or a motor(s) and other load(s), with each motor having individual running overcurrent protection, may be connected to one branch circuit provided all of the following conditions are complied with:

(1) Each motor-running overcurrent device must be approved for group installation with a specified maximum rating of fuse and/or circuit breaker.

(2) Each motor controller must be approved for group installation with a specified maximum rating of fuse and/or circuit breaker.

(3) Each circuit breaker must be of the time-limit type and approved for group installation.

(4) The branch circuit shall be protected by fuses or time-limit circuit breakers having a rating not exceeding that specified in Section 430-52 for the largest motor connected to the branch circuit plus an amount equal to the sum of the full-load current ratings of all other motors and the ratings of other loads connected to the circuit. Where this calculation results in a rating less than the ampacity of the supply conductors, the rating of the fuses or circuit breakers may be increased to a value not exceeding the ampacity of the supply conductors.

(5) The branch-circuit fuses or time-limit circuit breakers must not be larger than allowed by Section 430-40 for the thermal cutout or relay protecting the smallest motor of the group.

(6) The conductors of any tap supplying a single motor need not have individual branch-circuit protection, provided they comply with either of the following: (1) no conductor to the motor shall have an ampacity less than that of the branch-circuit conductors, or (2) no conductor to the motor shall have an ampacity less than one-third that of the branch-circuit conductors, with a minimum in accordance with Section 430-22; the conductors to the motor-running protective device being not more than 25 feet long and being protected from physical damage.

**430-54. Multimotor and Combination-Load Equipment.** The rating of the branch-circuit protective device for multimotor and combination load equipment shall not exceed the rating marked on the equipment in accordance with Section 430-7(d).

**430-55. Combined Overcurrent Protection.** Motor-branch-circuit overcurrent protection and motor-running overcurrent protection may be combined in a single overcurrent device when the rating or setting of the device provides the running overcurrent protection specified in Section 430-32.

**430-56. Overcurrent Devices—In Which Conductor.** Overcurrent devices shall comply with the provisions of Section 240-11.

**430-57. Size of Fuseholder.** Where fuses are used for motor-branch-circuit protection, the fuseholders shall not be of a smaller size than required to accommodate the fuses specified by Table 430-152.

*Exception: Where fuses having time delay appropriate for the starting characteristics of the motor are used, fuseholders of smaller size than specified in Table 430-152 may be used.*

**430-58. Rating of Circuit Breaker.** A circuit breaker for motor-branch-circuit protection shall have a current rating in accordance with Sections 430-52 and 430-110.

**430-59. Feeder Taps in Inaccessible Location.** If the location of the connection of a tap to the feeder conductors is not accessible, the motor-branch-circuit overcurrent device may be placed where it will be accessible, provided the conductors between the tap and the overcurrent device have the same ampacity as the feeder, or provided they have an ampacity of at least  $1/3$  that of the feeder and are not more than 25-foot long and are protected from physical damage.

### **E. Motor-Feeder Short-Circuit and Ground-Fault Protection**

**430-61. General.** The provisions of Part E specify overcurrent devices intended to protect feeder conductors supplying motors against overcurrents due to short circuits or grounds.

**430-62. Rating or Setting—Motor Load.**

(a) A feeder which supplies a specific fixed motor load and consisting of conductor sizes based on Section 430-24 shall be provided with overcurrent protection which shall not be greater than the largest rating or setting of the branch-circuit protective device, for any motor of the group (based on Table 430-152), plus the sum of the full-load currents of the other motors of the group.

Where two or more motors of equal horsepower rating are the largest in the group, one of these motors shall be considered as the largest for the above calculations.

Where two or more motors of a group must be started simultaneously, it may be necessary to install larger feeder conductors and correspondingly larger ratings or settings of feeder overcurrent protection.

See Example No. 8, Chapter 9.

(b) For large-capacity installations, where heavy-capacity feeders are installed to provide for future additions or changes, the feeder overcurrent protection may be based on the rated ampacity of the feeder conductors.

**430-63. Rating or Setting—Power and Light Loads.** Where a feeder supplies a motor load, and in addition a lighting or a lighting and appliance load, the feeder overcurrent protective device may have a rating or setting sufficient to carry the lighting or the lighting and appliance load as determined in accordance with Articles 210 and 220, plus, for a single motor, the rating permitted by Section 430-52, and for two or more motors, the rating permitted by Section 430-62.

#### F. Motor Control Circuits

**430-71. General.** Part F contains modifications of the general requirements and applies to the particular conditions of motor-control circuits.

**CONTROL CIRCUIT (Definition):** The control circuit of a control apparatus or system is the circuit which carries the electric signals directing the performance of the controller, but does not carry the main power circuit.

**430-72. Overcurrent Protection.** Conductors of control circuits shall be protected against overcurrent in accordance with Section 240-5(a), Exception No. 4.

*Exception: Such conductors shall be considered as being properly protected by the branch-circuit overcurrent devices under any one of the following conditions:*

(1) *Where the rating or setting of the branch-circuit overcurrent device is not more than 500 percent of the ampacity of the control-circuit conductors.*

(2) *Where the opening of the control circuit would create a hazard; as for example, the control circuit of fire-pump motors, and the like.*

**430-73. Mechanical Protection of Conductor.** Where damage to a control circuit would constitute a hazard, all conductors of such remote-control circuit shall be installed in a raceway or be otherwise suitably protected from physical damage outside the control device itself.

When one side of the control circuit is grounded, the control circuit shall be so arranged that an accidental ground in the remote-control devices will not start the motor.

**430-74. Disconnection.**

(a) Control circuits shall be so arranged that they will be disconnected from all sources of supply when the disconnecting means is in the open position. The disconnecting means may consist of two separate devices, one of which disconnects the motor and the controller from the source of power supply for the motor, and the other, the control circuit from its power supply. Where the two separate devices are used, they shall be located immediately adjacent one to the other.

(b) Where a transformer or other device is used to obtain a reduced voltage for the control circuit and is located in the controller, such transformer or other device shall be connected to the load side of the disconnecting means for the control circuit.

### G. Motor Controllers

**430-81. General.** The provisions of Part G are intended to require suitable controllers for all motors.

(a) **Definition.** For definition of “Controller,” see Article 100. For the purpose of this Article, the term “Controller” includes any switch or device normally used to start and stop the motor.

(b) **Stationary Motor of  $\frac{1}{8}$  Horsepower or Less.** For a stationary motor rated at  $\frac{1}{8}$  horsepower or less, that is normally left running and is so constructed that it cannot be damaged by overload or failure to start, such as clock motors and the like, the branch-circuit overcurrent device may serve as the controller.

(c) **Portable Motor of  $\frac{1}{3}$  Horsepower or Less.** For a portable motor rated at  $\frac{1}{3}$  horsepower or less, the controller may be an attachment plug and receptacle.

### 430-82. Controller Design.

(a) Each controller shall be capable of starting and stopping the motor which it controls, and for an alternating-current motor shall be capable of interrupting the stalled-rotor current of the motor.

(b) **Autotransformer.** An autotransformer starter shall provide an off position, a running position, and at least one starting position. It shall be so designed that it cannot rest in the starting position, or in any position which will render inoperative the overcurrent protective device in the circuit.

(c) **Rheostats.** Rheostats shall conform to the following:

(1) **Internal Connections.** Motor-starting rheostats shall be so designed that the contact arm cannot be left on intermediate segments. The point or plate on which the arm rests when in the starting position shall have no electrical connection with the resistor.

(2) **Undervoltage Release, Direct-Current Motors.** Motor-starting rheostats for direct-current motors operated from a constant voltage supply shall be equipped with automatic devices which will interrupt the supply before the speed of the motor has fallen to less than one-third its normal value.

**430-83. Rating.** The controller shall have a horsepower rating, which shall not be lower than the horsepower rating of the motor, except as follows:

*Exception No. 1: Stationary Motor of 2 Horsepower or Less. For a stationary motor rated at 2 horsepower or less, and 300 volts or less, the controller may be a general-use switch having an ampere rating at least twice the full-load current rating of the motor.*

*On AC circuits, general use snap switches suitable only for use on AC (not general-use AC-DC snap switches) may be used to control a*

*motor rated at 2 horsepower or less and 300 volts or less having a full-load current rating not exceeding 80 percent of the ampere rating of the switch.*

*Exception No. 2: Circuit Breaker as Controller. A branch-circuit circuit breaker, rated in amperes only, may be used as a controller. Where this circuit breaker is also used for overcurrent protection, it shall conform to the appropriate provisions of this Article governing overcurrent protection.*

*Exception No. 3: Torque Motors. The motor controller shall have a continuous-duty full-load current rating not less than the nameplate current of the motor. In case the motor controller is rated in horsepower, but is without the foregoing current rating, the equivalent current rating shall be determined from the horsepower rating by using Tables 430-147, 430-148, 430-149, or 430-150.*

**430-84. Need Not Open All Conductors.** Except when it serves also as a disconnecting means (see Section 430-111), the controller need not open all conductors to the motor.

**430-85. In Grounded Conductors.** One pole of the controller may be placed in a permanently grounded conductor provided the controller is so designed that the pole in the grounded conductor cannot be opened without simultaneously opening all conductors of the circuit.

**430-86. Motor Not in Sight from Controller.** Where a motor and the driven machinery are not in sight from the controller location, the installation shall comply with one of the following conditions:

(a) The controller disconnecting means is capable of being locked in the open position.

(b) A manually operable switch which will disconnect the motor from its source of supply is placed within sight from the motor location.

**430-87. Number of Motors Served by Each Controller.** Each motor shall be provided with an individual controller.

*Exception: For motors of 600 volts or less a single controller rated at not less than the sum of the horsepower ratings of all of the motors of the group may serve the group of motors under any one of the following conditions:*

(a) *Where a number of motors drive several parts of a single machine or piece of apparatus such as metal and woodworking machines, cranes, hoists, and similar apparatus.*

(b) *Where a group of motors is under the protection of one overcurrent device as permitted in Section 430-53(a).*

(c) *Where a group of motors is located in a single room within sight from the controller location.*

**430-88. Adjustable-Speed Motors.** Adjustable-speed motors that are controlled by means of field regulation shall be so equipped and connected that they cannot be started under weakened field, unless the motor is designed for such starting.

**430-89. Speed Limitation.** Machines of the following types shall be provided with speed limiting devices:

(a) Separately excited direct-current motors.

(b) Series motors.

(c) Motor-generators and converters which can be driven at excessive speed from the direct-current end, as by a reversal of current or decrease in load.

*Exception No. 1: Unless the inherent characteristics of the machines, the system, or the load and the mechanical connection thereto, are such as to safely limit the speed.*

*Exception No. 2: Unless the machine is always under the manual control of a qualified operator.*

**430-90. Combination Fuseholder and Switch as Controller.** The rating of a combination fuseholder and switch used as a motor controller shall be such that the fuseholder will accommodate the size of fuse specified in Part C, of Article 430, for motor-running overcurrent protection.

*Exception: Where fuses having time delay appropriate for the starting characteristics of the motor are used, fuseholders of smaller size than specified in Part C of Article 430 may be used.*

## H. Disconnecting Means

**430-101. General.** The provisions of Part H are intended to require disconnecting means capable of disconnecting motors and controllers from the circuit.

See Diagram 430-1(a).

**430-102. In Sight from Controller Location.** A disconnecting means shall be located in sight from the controller location.

**430-103. To Disconnect Both Motor and Controller.** The disconnecting means shall disconnect the motor and the controller from all ungrounded supply conductors and shall be so designed that no pole can be operated independently. The disconnecting means may be in the same enclosure with the controller. See Section 430-113.

**430-104. To Be Indicating.** The disconnecting means shall plainly indicate whether it is in the open or closed position.

**430-105. Grounded Conductors.** One pole of the disconnecting means may disconnect a permanently grounded conductor, provided the disconnecting means is so designed that the pole in the grounded conductor cannot be opened without simultaneously disconnecting all conductors of the circuit.

**430-106. Service Switch as Disconnecting Means.** Where an installation consists of a single motor, the service switch may serve as the dis-

connecting means, provided it conforms to the requirements of this Article, and is within sight from the controller location.

**430-107. Readily Accessible.** One of the disconnecting means shall be readily accessible.

**430-108. Every Switch.** Every switch in the motor branch circuit within sight from the controller location shall comply with the requirements of Part H.

**430-109. Type.** The disconnecting means shall be a motor-circuit switch, rated in horsepower, or a circuit breaker, except as follows:

*Exception No. 1: One-Eighth Horsepower or Less. For stationary motors of  $\frac{1}{8}$  horsepower or less, the branch-circuit overcurrent device may serve as the disconnecting means.*

*Exception No. 2: Two Horsepower or Less. For stationary motors rated at 2 horsepower or less and 300 volts or less, the disconnecting means may be a general-use switch having an ampere rating not less than twice the full-load current rating of the motor.*

*On AC circuits, general-use snap switches suitable only for use on AC (not general-use AC-DC snap switches) may be used to disconnect a motor having a full-load current rating not exceeding 80 percent of the ampere rating of the switch.*

*Exception No. 3: Over Two Horsepower to and Including 100 Horsepower. The separate disconnecting means required for a motor with an autotransformer-type controller may be a general-use switch where all of the following provisions are complied with:*

*a. The motor drives a generator which is provided with overcurrent protection.*

*b. The controller (1) is capable of interrupting the stalled-rotor current of the motor, (2) is provided with a no-voltage release, and (3) is provided with running-overcurrent protection not exceeding 125 percent of the motor full-load current rating.*

*c. Separate fuses or a circuit breaker, rated or set at not more than 150 percent of the motor full-load current, are provided in the motor branch circuit.*

*Exception No. 4: Exceeding 100 Horsepower. For stationary motors rated at more than 100 horsepower, the disconnecting means may be a motor-circuit switch also rated in amperes, a general-use switch, or an isolating switch.*

*Isolating switches for motors exceeding 100 horsepower, not capable of interrupting stalled-rotor currents, shall be plainly marked "Do not open under load."*

*Exception No. 5: Portable Motors. For portable motors an attachment plug and receptacle may serve as the disconnecting means.*

**430-110. Ampacity and Interrupting Capacity.**

**(a)** The disconnecting means shall have an ampacity of at least 115 percent of the full-load current rating of the motor.



(b) The disconnecting means for a torque motor shall be selected on the basis of the nameplate current as follows:

(1) The ampacity shall be at least 115 percent of the nameplate current.

(2) To determine the equivalent horsepower in complying with the requirements of Section 430-109, select the horsepower rating from Tables 430-147, 430-148, 430-149, or 430-150 corresponding to the motor current. In case the nameplate current does not correspond to a current shown in the Table, the horsepower rating corresponding to the next higher value shall be selected.

(c) Where one or more motors are used together or are used in combination with other loads, such as resistance heaters, and where the combined load may be simultaneous on a single disconnecting means, the rating and ampacity of the combined load are to be determined as follows:

(1) The rating of the disconnecting means shall be determined from the summation of all currents, including resistance loads, at the full-load condition and also at the locked-rotor condition. The combined full-load current and the combined locked-rotor current so obtained shall be considered as a single motor for the purpose of this requirement as follows:

The full-load current equivalent to the horsepower rating of each motor shall be selected from Tables 430-148, 430-149, and 430-150. These full-load currents shall be added to the rating in amperes of other loads to obtain an equivalent full-load current for the combined load.

The locked-rotor current equivalent to the horsepower rating of each motor shall be selected from Table 430-151. The locked-rotor currents shall be added to the rating in amperes of other loads to obtain an equivalent locked-rotor current for the combined load. Where two or more motors and/or other loads cannot be started simultaneously, appropriate combinations of locked-rotor and full-load current may be employed to determine the equivalent locked-rotor current for the simultaneous combined loads.

(2) The ampacity of the disconnecting means shall be at least 115 percent of the summation of all currents at the full-load condition determined in accordance with Section 430-110(c)(1).

(3) For small motors not covered by Tables 430-147, 430-148, 430-149 or 430-150, the locked-rotor current shall be assumed to be 6 times the full-load current.

(4) Where part of the concurrent load is resistance load and the disconnecting means is a switch rated in horsepower and amperes, the horsepower rating of the switch shall not be less than the combined load of the motor at the locked-rotor condition and the ampere rating shall not be less than the locked-rotor load plus the resistance load.

**430-111. Switch or Circuit Breaker as Both Controller and Disconnecting Means.** A switch or circuit breaker complying with the provisions of Section 430-83 may serve as both controller and disconnecting

means provided it opens all ungrounded conductors to the motor, is protected by an overcurrent device (which may be the branch-circuit fuses) which opens all ungrounded conductors to the switch or circuit breaker, and is of one of the following types:

(a) An air-break switch, operable directly by applying the hand to a lever or handle.

(b) A circuit breaker operable directly by applying the hand to a lever or handle.

(c) An oil switch used on a circuit whose rating does not exceed 600 volts or 100 amperes, or by special permission on a circuit exceeding this capacity where under expert supervision.

The oil switch or circuit breaker specified above may be both power and manually operable. If power operable, provision should be made to lock it in the open position.

The overcurrent device protecting the controller may be part of the controller assembly or may be separate.

An autotransformer-type controller is not included above and will require a separate disconnecting means.

**430-112. Motors Served by a Single Disconnecting Means.** Each motor shall be provided with individual disconnecting means.

*Exception: For motors of 600 volts or less a single disconnecting means may serve a group of motors under any one of the following conditions:*

*a. Where a number of motors drive several parts of a single machine or piece of apparatus such as metal and woodworking machines, cranes, and hoists.*

*b. Where a group of motors is under the protection of one set of overcurrent devices as permitted by Section 430-53(a).*

*c. Where a group of motors is in a single room within sight from the location of the disconnecting means.*

The disconnecting means shall have a rating not less than is required by Section 430-109 for a single motor the rating of which equals the sum of the horsepower or currents of all the motors of the group.

**430-113. Energy From More Than One Source.** Equipment receiving electrical energy from more than one source shall be provided with disconnecting means from each source of electrical energy immediately adjacent to the equipment served. Each source may have a separate disconnecting means.

## **J. Requirements for Over 600 Volts**

**430-121. General.** The provisions of Part J recognize the additional hazard due to the use of high voltage. They are in addition to or amendatory of the other provisions of this article. Other requirements for circuits and equipment operating at more than 600 volts are in Article 710.

**430-123. Motor Running Overcurrent (Overload) Protection.** Running overcurrent protection for a motor of over 600 volts shall consist either

of a circuit breaker, or of overcurrent units integral with the controller which shall simultaneously open all ungrounded conductors to the motor. The overcurrent device shall have a setting as specified elsewhere in this Article for motor-running overcurrent (overload) protection.

**430-124. Short-Circuit and Ground-Fault Protection.** Each motor branch circuit and feeder of more than 600 volts shall be protected against overcurrent by one of the following means:

(a) A circuit breaker of suitable rating so arranged that it can be serviced without hazard.

(b) Fuses of the oil-filled or other suitable type. Fuses shall be used with suitable disconnecting means or they shall be of a type which can also serve as the disconnecting means. They shall be so arranged that they cannot be re-fused or replaced while they are energized.

(c) Differential protection may be employed to protect an alternating-current motor, the motor control apparatus, and the branch-circuit conductors against overcurrent due to short circuits or grounds. When all these elements are included within the protected zone of a differential protective system, the ratings or settings specified in Section 430-52 do not apply.

**DIFFERENTIAL PROTECTIVE SYSTEM (definition):** A differential protective system is a combination of two or more sets of current transformers and a relay or relays energized from their interconnected secondaries.

The primaries of the current transformers are connected on both sides of the equipment to be protected, both ends of the motor phase windings being brought out for this purpose. All of the apparatus and circuits included between the sets of current-transformer primaries constitute the protected zone. The current-transformer secondaries and the relay elements are so interconnected that the relay elements respond only to a predetermined difference between the currents entering and leaving the protected zone. When actuated, the relay or relays serve to trip the branch-circuit circuit breaker, thus disconnecting the motor, control apparatus in the motor circuit and the branch-circuit conductors from the source of power and, in the case of a synchronous motor, de-energizing its field circuit.

**430-126. Disconnecting Means.** The circuit breaker or the fuses specified in Section 430-124 may constitute the disconnecting means if they conform to the other applicable requirements of this Article.

## **K. Protection of Live Parts — All Voltages**

**430-131. General.** The provisions of Part K specify that live parts shall be protected in a manner judged adequate to the hazard involved.

**430-132. Where Required.** Exposed live parts of motors and controllers operating at 50 volts or more between terminals, shall be guarded against accidental contact by enclosure, or by location as follows:

(a) By installation in a room or enclosure which is accessible only to qualified persons;

(b) By installation on a suitable balcony, gallery or platform, so elevated and arranged as to exclude unqualified persons;

(c) By elevation 8 feet or more above the floor;

(d) So that it will be protected by a guard rail when the motor operates at 600 volts or less.

*Exception: Stationary motors having commutators, collectors and brush rigging located inside of motor end brackets and not conductively connected to supply circuits operating at more than 150 volts to ground.*

**430-133. Guards for Attendants.** Where the live parts of motors or controllers operating at more than 150 volts to ground are guarded against accidental contact only by location as specified in Section 430-132, and where adjustment or other attendance may be necessary during the operation of the apparatus, suitable insulating mats or platforms shall be provided so that the attendant cannot readily touch live parts unless standing on the mats or platforms. Where necessary, steps and hand-rails should be installed on or about large machines to afford safe access to parts which must be examined or adjusted during operation.

### L. Grounding

**430-141. General.** The provisions of Part L specify the grounding of motor and controller frames to prevent a potential above ground in the event of accidental contact between live parts and frames. Insulation, isolation, or guarding are suitable alternatives to grounding of motors under certain conditions.

**430-142. Stationary Motors.** The frames of stationary motors shall be grounded where any of the following conditions exist:

(a) supplied by means of metal-enclosed wiring.

(b) located in a wet place and not isolated nor guarded.

(c) in a hazardous location. (See Articles 500 through 517)

(d) the motor operates with any terminal at more than 150 volts to ground.

Grounding of the motor frame is preferable, but where the frame of the motor is not grounded, it shall be permanently and effectively insulated from the ground.

**430-143. Portable Motors.** The frames of portable motors which operate at more than 150 volts to ground shall be guarded or grounded. See Section 250-45(d) on grounding of portable appliances in other than residential occupancies.

Frames of motors which operate at less than 150 volts to ground shall be grounded where this can be readily accomplished. See section 250-59(b) for color of grounding conductor.

**430-144. Controllers.** Controller cases, except those attached to ungrounded portable equipment and except the lined covers of snap switches, shall be grounded regardless of voltage.

**430-145. Method of Grounding.** Grounding where required shall be done in the manner specified in Article 250.

(a) **Grounding Through Terminal Housings.** Where the wiring to fixed motors is in Type AC metal-clad cable or metal raceways, junction boxes to house motor terminals shall be provided, and the armor of the cable or the metal raceways shall be connected to them in the manner specified in Article 250.

(b) **Separation of Junction Box from Motor.** The junction box required by Section 430-145(a) may be separated from the motor not more than 6 feet provided the leads to the motor are Type AC metal-clad cable or armored cord or are stranded leads enclosed in flexible or rigid conduit or electrical metallic tubing not smaller than  $\frac{3}{8}$ -inch electrical trade size, the armor or raceway being connected both to the motor and to the box. Where stranded leads are used, protected as specified above, they shall not be larger than No. 10, and shall comply with other requirements of this Code for conductors to be used in raceways.

(c) **Grounding of Controller Mounted Devices.** Instrument transformer secondaries, and exposed noncurrent-carrying metal or other conductive parts or cases of instrument transformers, meters, instruments, and relays shall be grounded as specified in Sections 250-121 through 250-125.

**Table 430-147. Full-Load Currents in Amperes  
Direct-Current Motors**

The following values of full-load currents are for motors running at base speed.

HP	120V	240V
$\frac{1}{4}$	2.9	1.5
$\frac{1}{3}$	3.6	1.8
$\frac{1}{2}$	5.2	2.6
$\frac{3}{4}$	7.4	3.7
1	9.4	4.7
$1\frac{1}{2}$	13.2	6.6
2	17	8.5
3	25	12.2
5	40	20
$7\frac{1}{2}$	58	29
10	76	38
15		55
20		72
25		89
30		106
40		140
50		173
60		206
75		255
100		341
125		425
150		506
200		675

**Table 430-148. Full-Load Currents in Amperes****Single-Phase Alternating-Current Motors**

The following values of full-load currents are for motors running at usual speeds and motors with normal torque characteristics. Motors built for especially low speeds or high torques may have higher full-load currents, and multispeed motors will have full-load current varying with speed, in which case the nameplate current ratings shall be used.

To obtain full-load currents of 208- and 200-volt motors, increase corresponding 230-volt motor full-load currents by 10 and 15 percent, respectively.

The voltages listed are rated motor voltages. Corresponding nominal system voltages are 110 to 120 and 220 to 240.

HP	115V	230V
1/6	4.4	2.2
1/4	5.8	2.9
1/3	7.2	3.6
1/2	9.8	4.9
3/4	13.8	6.9
1	16	8
1 1/2	20	10
2	24	12
3	34	17
5	56	28
7 1/2	80	40
10	100	50

**Table 430-149. Full-Load Current****Two-Phase Alternating-Current Motors (4-wire)**

The following values of full-load current are for motors running at speeds usual for belted motors and motors with normal torque characteristics. Motors built for especially low speeds or high torques may require more running current, and multispeed motors will have full-load current varying with speed, in which case the nameplate current rating shall be used. Current in common conductor of 2-phase, 3-wire system will be 1.41 times value given.

The voltages listed are rated motor voltages. Corresponding nominal system voltages are 110 to 120, 220 to 240, 440 to 480 and 550 to 600 volts.

HP	Induction Type Squirrel-Cage and Wound Rotor Amperes					Synchronous Type †Unity Power Factor Amperes			
	115V	230V	460V	575V	2300V	220V	440V	550V	2300V
1/2	4	2	1	.8					
3/4	4.8	2.4	1.2	1.0					
1	6.4	3.2	1.6	1.3					
1 1/2	9	4.5	2.3	1.8					
2	11.8	5.9	3	2.4					
3		8.3	4.2	3.3					
5		13.2	6.6	5.3					
7 1/2		19	9	8					
10		24	12	10					
15		36	18	14					
20		47	23	19					
25		59	29	24		47	24	19	
30		69	35	28		56	29	23	
40		90	45	36		75	37	31	
50		113	56	45		94	47	38	
60		133	67	53	14	111	56	44	11
75		166	83	66	18	140	70	57	13
100		218	109	87	23	182	93	74	17
125		270	135	108	28	228	114	93	22
150		312	156	125	32		137	110	26
200		416	208	167	43		182	145	35

†For 90 and 80 percent power factor the above figures should be multiplied by 1.1 and 1.25 respectively.

**Table 430-150. Full-Load Current\***  
**Three-Phase Alternating-Current Motors**

HP	Induction Type Squirrel-Cage and Wound Rotor Amperes					Synchronous Type †Unity Power Factor Amperes			
	115V	230V	460V	575V	2300V	220V	440V	550V	2300V
1/2	4	2	1	.8					
3/4	5.6	2.8	1.4	1.1					
1	7.2	3.6	1.8	1.4					
1 1/2	10.4	5.2	2.6	2.1					
2	13.6	6.8	3.4	2.7					
3		9.6	4.8	3.9					
5		15.2	7.6	6.1					
7 1/2		22	11	9					
10		28	14	11					
15		42	21	17					
20		54	27	22					
25		68	34	27		54	27	22	
30		80	40	32		65	33	26	
40		104	52	41		86	43	35	
50		130	65	52		108	54	44	
60		154	77	62	16	128	64	51	12
75		192	96	77	20	161	81	65	15
100		248	124	99	26	211	106	85	20
125		312	156	125	31	264	132	106	25
150		360	180	144	37		158	127	30
200		480	240	192	49		210	168	40

For full-load currents of 208- and 200-volt motors, increase the corresponding 230-volt motor full-load current by 10 and 15 percent, respectively.

\* These values of full-load current are for motors running at speeds usual for belted motors and motors with normal torque characteristics. Motors built for especially low speeds or high torques may require more running current, and multispeed motors will have full-load current varying with speed, in which case the nameplate current rating shall be used.

† For 90 and 80 percent power factor the above figures shall be multiplied by 1.1 and 1.25 respectively.

The voltages listed are rated motor voltages. Corresponding nominal system voltages are 110 to 120, 220 to 240, 440 to 480 and 550 to 600 volts.



**Table 430-151.****Locked-Rotor Current Conversion Table**

As Determined from Horsepower and Voltage Rating  
For Use Only With Sections 430-110, 440-12 and 440-41.

**Conversion Table**

Max HP Rating	Motor Locked-Rotor Current Amperes					
	Single Phase		Two or Three Phase			
	115 V	230 V	115 V	230 V	460 V	575 V
1/2	58.8	29.4	24	12	6	4.8
3/4	82.8	41.4	33.6	16.8	8.4	6.6
1	96	48	42	21	10.8	8.4
1 1/2	120	60	60	30	15	12
2	144	72	78	39	19.8	15.6
3	204	102	—	54	27	24
5	336	168	—	90	45	36
7 1/2	480	240	—	132	66	54
10	600	300	—	162	84	66
15	—	—	—	240	120	96
20	—	—	—	312	156	126
25	—	—	—	384	192	156
30	—	—	—	468	234	186
40	—	—	—	624	312	246
50	—	—	—	750	378	300
60	—	—	—	900	450	360
75	—	—	—	1110	558	444
100	—	—	—	1476	738	588
125	—	—	—	1860	930	744
150	—	—	—	2160	1080	864
200	—	—	—	2880	1440	1152

**Table 430-152. Maximum Rating or Setting of Motor Branch-Circuit Protective Devices**

Type of Motor	Percent of Full-Load Current			
	Nontime Delay Fuse	Dual-Element (Time-Delay) Fuse	Instantaneous Type Breaker	Time-Limit Breaker
Single-phase, all types				
No code letter .....	300	175	700	250
All AC single-phase and polyphase squirrel-cage and synchronous motors with full-voltage, resistor or reactor starting:				
No code letter .....	300	175	700	250
Code letter F to V .....	300	175	700	250
Code letter B to E .....	250	175	700	200
Code letter A .....	150	150	700	150
All AC squirrel-cage and synchronous motors with autotransformer starting:				
Not more than 30 amps				
No code letter .....	250	175	700	200
More than 30 amps				
No code letter .....	200	175	700	200
Code letter F to V .....	250	175	700	200
Code letter B to E .....	200	175	700	200
Code letter A .....	150	150	700	150
High-reactance squirrel-cage				
Not more than 30 amps				
No code letter .....	250	175	700	250
More than 30 amps				
No code letter .....	200	175	700	200
Wound-rotor — No code letter .....	150	150	700	150
Direct-current				
No more than 50 hp				
No code letter .....	150	150	250	150
More than 50 hp				
No code letter .....	150	150	175	150

For explanation of Code Letter Marking, see Table 430-7(b).

For certain exceptions to the values specified see Sections 430-52, -54. The values given in the last column also cover the ratings of nonadjustable time-limit types of circuit breakers which may be modified as in Section 430-52.

Synchronous motors of the low-torque, low-speed type (usually 450 RPM or lower), such as are used to drive reciprocating compressors, pumps, etc., which start unloaded, do not require a fuse rating or circuit-breaker setting in excess of 200 percent of full-load current.

## ARTICLE 440 — AIR-CONDITIONING AND REFRIGERATING EQUIPMENT

### A. General

#### 440-1. Scope.

The provisions of this Article apply to electric motor-driven air-conditioning and refrigerating equipment, and to the branch circuits and controllers for such equipment. It provides for the special considerations necessary for circuits supplying sealed (hermetic-type) motor-compressors and for any air-conditioning and/or refrigerating equipment which is supplied from an individual branch circuit which supplies a sealed (hermetic-type) motor-compressor.

#### 440-2. Other Articles.

(a) These provisions are in addition to, or amendatory of, the provisions of Article 430 and other Articles in this Code, which apply except as modified in this Article.

(b) The rules of Articles 422, 424, or 430, as applicable, shall apply to air-conditioning and refrigerating equipment which does not incorporate a sealed (hermetic-type) motor-compressor. Examples of such equipment are devices which employ refrigeration compressors driven by conventional motors, furnaces with air-conditioning evaporator coils installed, fan-coil units, remote forced air-cooled condensers, remote commercial refrigerators, etc.

(c) Devices such as room air conditioners, household refrigerators and freezers, drinking-water coolers, and beverage dispensers are to be considered appliances and the provisions of Article 422 shall also apply.

(d) Hermetic motor-compressors, circuits, controllers, and equipment shall also comply with the applicable provisions of the following:

Capacitors .....	Section 460-9
Garages, Aircraft Hangars, Gasoline Dispensing and Service Stations, Bulk Storage Plants, Finishing Processes and Flammable Anesthetics .....	Articles 511, 513, 514, 515, 516, and 517-E
Hazardous Locations .....	Articles 500 thru 503
Motion-Picture Studios .....	Article 530
Resistors and Reactors .....	Article 470

#### 440-3. Marking on Sealed (Hermetic-Type) Motor-Compressors and Equipment.

(a) A sealed (hermetic-type) motor-compressor shall be provided with a nameplate which shall give the manufacturer's name, trade-mark or symbol; identifying designation; the phase; voltage; and frequency. The rated-load current in amperes of the motor-compressor shall be marked on either or both the motor-compressor nameplate and the nameplate of the equipment in which the motor-compressor is used. The locked-rotor current of each single-phase motor-compressor having a rated-load current of more than 9 amperes at 115 volts

or more than 4.5 amperes at 230 volts and each polyphase motor-compressor shall be marked on the motor-compressor nameplate. Where a thermal protector complying with Sections 440-52(a)(2) and (b)(2) is used, the motor compressor nameplate or the equipment nameplate shall be marked with the words "Thermally Protected." Where a protective system, complying with Sections 440-52(a)(4) and 440-52(b)(4), is used and is furnished with the equipment, the equipment nameplate shall be appropriately marked. Where a protective system complying with Sections 440-52(a)(4) and 440-52(b)(4) is specified, the equipment nameplate shall be appropriately marked.

Note: The rated-load current for a sealed (hermetic-type) motor-compressor is the current resulting when the motor-compressor is operated at the rated load, rated voltage and rated frequency of the equipment it serves.

(b) Multimotor and combination-load equipment shall be provided with a visible nameplate marked with the maker's name, the rating in volts, frequency and number of phases, minimum circuit ampacity, and the maximum rating of the branch-circuit short-circuit and ground-fault protective device. The ampacity shall be calculated by using Part D and counting all the motors and other loads which will be operated at the same time. The branch-circuit short-circuit and ground-fault protective device rating shall not exceed the value calculated by using Part C. Multimotor or combination-load equipment for use on two or more circuits shall be marked with the above information for each circuit. For multimotor compressor equipment where the motor-compressor markings are shown on the equipment nameplate in lieu of the motor-compressor nameplate(s), as permitted in Section 440-3(a), these markings shall indicate the specific motor-compressor(s) with which the markings are associated.

*Exception: Multimotor and combination-load equipment which is suitable under the provisions of this Article for connection to a single 15- or 20-ampere, 120-volt, or a 15-ampere, 208- or 240-volt single-phase branch circuit may be marked as a single load.*

(c) Sealed (hermetic-type) motor-compressors or equipment containing such compressor(s) in which the protection system, approved for use with the motor-compressor which it protects, permits continuous current in excess of the specified percentage of nameplate rated-load current given in Section 440-52(b)(2) or (b)(4) shall also be marked with a branch-circuit selection current that complies with Section 440-52(b)(2) or (b)(4). This marking shall be on the nameplate(s) where the rated-load current(s) appears.

Note: Branch-circuit selection current is the value in amperes to be used instead of the rated-load current in determining the ratings of motor branch-circuit conductors, disconnecting means, controllers and branch-circuit short-circuit and ground-fault protective devices wherever the running overload protective device permits a sustained current greater than the specified percentage of the rated-load current.

**440-4. Marking on Controllers.** A controller shall be marked with the maker's name; trademark or symbol; identifying designation; the voltage; phase; full-load and locked-rotor current (or horsepower) rating; and such other data as may be needed to properly indicate the motor-compressor for which it is suitable.

**440-5. Ampacity and Rating.** Ampacity of conductors and rating of equipment shall be determined as follows:

(a) For a sealed (hermetic-type) motor-compressor, the rated-load current marked on the nameplate of the equipment in which the motor-compressor is employed shall be used in determining the rating or ampacity of the disconnecting means, the branch-circuit conductors, the controller, the branch-circuit short-circuit and ground-fault protection, and the separate motor overload protection. Where no rated-load current is shown on the equipment nameplate, the rated-load current shown on the compressor nameplate shall be used. For disconnecting means and controllers, see also Sections 440-12 and 440-41.

*Exception No. 1: When so marked, the branch-circuit selection current shall be used instead of the rated-load current to determine the rating or ampacity of the disconnecting means, the branch-circuit conductors, the controller, and the branch-circuit short-circuit and ground-fault protection.*

*Exception No. 2: See Section 440-22(b) for branch-circuit, short-circuit and ground-fault protection of cord- and plug-connected equipment.*

(b) For multimotor equipment employing a shaded-pole or permanent split-capacitor-type fan or blower motor, the full-load current for such motor marked on the nameplate of the equipment in which the fan or blower motor is employed shall be used instead of the horsepower rating to determine the ampacity or rating of the disconnecting means, the branch-circuit conductors, the controller, the branch-circuit short-circuit and ground-fault protection, and the separate overload protection. This marking on the equipment nameplate shall not be less than the current marked on the fan or blower motor nameplate.

**440-6. Highest Rated (Largest) Motor.** In determining compliance with this Article and with Sections 430-24, 430-53(b), 430-53(c), and 430-62(a), the highest rated (largest) motor shall be considered to be that motor which has the highest rated-load current. Where two or more motors have the same rated-load current, only one of them shall be considered as the highest rated (largest) motor. For other than sealed (hermetic-type) motor-compressors, and fan or blower motors as covered in Section 440-5(b), the full-load current used to determine the highest rated motor shall be the equivalent value corresponding to the motor horsepower rating selected from Tables 430-148, 430-149, or 430-150.

*Exception: When so marked, the branch-circuit selection current shall be used instead of the rated-load current in determining the highest rated (largest) motor-compressor.*

**440-7. Single Machine.** An air-conditioning or refrigerating system shall be considered to be a single machine under the provisions of Section 430-87 Exception and Section 430-112 Exception. The motors may be located remotely from each other.

## **B. Disconnecting Means**

**440-11. General.** The provisions of Part B are intended to require disconnecting means capable of disconnecting air-conditioning and

refrigerating equipment including motor-compressors, and controllers, from the circuit feeder. See Diagram 430-1(a).

#### **440-12. Rating and Interrupting Capacity.**

(a) A disconnecting means serving a sealed (hermetic-type) motor-compressor shall be selected on the basis of the nameplate rated-load current or branch-circuit selection current, whichever is greater, and locked-rotor current, respectively, of the motor-compressor as follows:

(1) The ampacity shall be at least 115 percent of the nameplate rated-load current or branch-circuit selection current, whichever is greater.

(2) To determine the equivalent horsepower in complying with the requirements of Section 430-109, select the horsepower rating from Tables 430-148, 430-149, or 430-150 corresponding to the rated-load current or branch-circuit selection current, whichever is greater, and also the horsepower rating from Table 430-151 corresponding to the locked-rotor current. In case the nameplate rated-load current or branch-circuit selection current and locked-rotor current do not correspond to the currents shown in Tables 430-148, 430-149, 430-150, or 430-151, the horsepower rating corresponding to the next higher value shall be selected. In case different horsepower ratings are obtained when applying these Tables, a horsepower rating at least equal to the larger of the values obtained shall be selected.

(b) Where one or more sealed (hermetic-type) motor-compressors are used together or are used in combination with other motors and/or loads such as resistance heaters and where the combined load may be simultaneous on a single disconnecting means, the rating for the combined load is to be determined as follows:

(1) The horsepower rating of the disconnecting means shall be determined from the summation of all currents, including resistance loads, at the rated-load condition and also at the locked-rotor condition. The combined rated-load current and the combined locked-rotor current so obtained shall be considered as a single motor for the purpose of this requirement as follows:

a. The full-load current equivalent to the horsepower rating of each motor, other than a sealed (hermetic-type) motor-compressor, and fan or blower motors as covered in Section 440-5(b) shall be selected from Tables 430-148, 430-149, or 430-150. These full-load currents shall be added to the motor-compressor rated-load current(s) or branch-circuit selection current(s), whichever is greater, and to the rating in amperes of other loads to obtain an equivalent full-load current for the combined load.

b. The locked-rotor current equivalent to the horsepower rating of each motor, other than a sealed (hermetic-type) motor-compressor, shall be selected from Table 430-151, and for fan and blower motors of the shaded-pole or permanent split-capacitor type marked with the locked-rotor current, the marked value shall be used. The locked-rotor currents shall be added to the motor-compressor locked-rotor current(s) and to the rating in amperes of other loads to obtain an equivalent locked-rotor current for the combined load. Where two or more

motors and/or other loads cannot be started simultaneously appropriate combinations of locked-rotor and rated-load current or branch-circuit selection current, whichever is greater, may be employed to determine the equivalent locked-rotor current for the simultaneous combined load.

*Exception: Where part of the concurrent load is a resistance load and the disconnecting means is a switch rated in horsepower and amperes, the horsepower rating of the switch shall be not less than the combined load of the motor-compressor(s) and other motor(s) at the locked-rotor condition and the ampere rating shall be not less than this locked-rotor load plus the resistance load.*

(2) The ampacity of the disconnecting means shall be at least 115 percent of the summation of all currents at the rated-load condition determined in accordance with Section 440-12(b)(1).

(c) For small motor-compressors not having the locked-rotor current marked on the nameplate, or for small motors not covered by Tables 430-147, 430-148, 430-149, or 430-150, the locked-rotor current shall be assumed to be 6 times the rated-load current. See Section 440-3(a).

(d) Where the rated-load or locked-rotor current as determined above would indicate a disconnecting means rated in excess of 100 hp, the provisions of Section 430-109, Exception No. 4, shall apply.

**440-13. Cord-Connected Equipment.** For cord-connected equipment such as room air conditioners, household refrigerators and freezers, drinking water coolers and beverage dispensers, a separable connector or an attachment plug and receptacle may serve as the disconnecting means. See also Section 422-43.

### **C. Branch-Circuit Short-Circuit and Ground-Fault Protection**

**440-21. General.** The provisions of Part C specify overcurrent devices intended to protect the branch-circuit conductors, control apparatus and motors in circuits supplying sealed (hermetic-type) motor-compressors against overcurrent due to short circuits and grounds. They are in addition to or amendatory of the provisions of Article 240.

#### **440-22. Application and Selection.**

(a) **Rating or Setting for Individual Motor-Compressor.** The motor-compressor branch-circuit short-circuit and ground-fault protective device shall be capable of carrying the starting current of the motor. The required protection shall be considered as being obtained when this device has a rating or setting not exceeding 175 percent of the motor-compressor rated-load current or branch-circuit selection current, whichever is greater, (15 amperes size minimum); provided that where the protection specified is not sufficient for the starting current of the motor, it may be increased, but shall not exceed 225 percent of the motor rated-load current or branch-circuit selection current, whichever is greater.

(b) **Rating or Setting for Equipment.** The equipment branch-circuit short-circuit and ground-fault protective device shall be capable of carrying the starting current of the equipment. Where the sealed (hermetic-type) motor-compressor is the only load on the circuit, the pro-

(440-22(b) continued)

tection shall conform with Section 440-22(a). Where the equipment incorporates more than one sealed (hermetic-type) motor-compressor or a sealed (hermetic-type) motor-compressor and other motors or other loads, the equipment protection shall conform with Section 430-53 and the following:

(1) Where a sealed (hermetic-type) motor-compressor is the largest load connected to the circuit, the rating or setting of the protective device shall not exceed the value specified in Section 440-22(a) for the largest motor-compressor plus the sum of the rated-load current or branch-circuit selection current, whichever is greater, of the other motor-compressor(s) and the ratings of the other loads supplied.

(2) Where a sealed (hermetic-type) motor-compressor is not the largest load connected to the circuit, the rating or setting of the protective device shall not exceed a value equal to the sum of the rated-load current or branch-circuit selection current, whichever is greater, rating(s) for the motor-compressor(s) plus the value specified in Section 430-53(c)(4) where other motor loads are supplied, or the value specified in Section 240-5 where only nonmotor loads are supplied in addition to the motor-compressor(s).

*Exception No. 1: A room air conditioner shall be treated as a single motor unit in determining its branch-circuit requirements when all the following conditions are met: a. The unit is cord- and plug-connected. b. Its rating is not more than 40 amperes and 250 volts, single phase. c. Total rated-load current is shown on the unit nameplate rather than individual motor currents. d. The rating of the branch-circuit short-circuit and ground-fault protective device does not exceed the ampacity of the branch-circuit conductors or the rating of the receptacle, whichever is less. See Section 422-40.*

Note: For the purpose of this paragraph, a room air conditioner is an alternating-current sealed (hermetic-type) air-cooled window, console, or in-wall room air conditioner which is installed in the conditioned room. It also applies to a room air conditioner having provisions for heating.

*Exception No. 2: Equipment which will start and operate on a 15- or 20-ampere, 120-volt or 15-ampere, 208- or 240-volt, single-phase branch circuit shall be considered as protected by the 15- or 20-ampere overcurrent device protecting the branch circuit except that where the maximum circuit protective device rating marked on the equipment is less than these values, the circuit protective device shall not exceed the value marked on the equipment nameplate.*

*Exception No. 3: The nameplate marking of cord- and plug-connected equipment rated not greater than 250 volts, single-phase, such as household refrigerators and freezers, drinking-water coolers, and beverage dispensers shall be used in determining the branch-circuit requirements, and each unit shall be considered as a single motor unless the nameplate is marked otherwise.*

(c) Where maximum protective device ratings shown on a manufacturer's heater table for use with a motor controller are less than the rating or setting selected in accordance with Sections 440-22(a) and (b), the protective device rating shall not exceed the manufacturer's values marked on the equipment.



### D. Branch-Circuit Conductors

**440-31. General.** The provisions of Part D and Articles 300 and 310 specify sizes of conductors required to carry the motor current without overheating under the conditions specified, except as modified in Section 440-5(a), Exception No. 1. The provisions of these Articles are not intended to apply to integral conductors of motors, motor controllers and the like, or to conductors which form an integral part of approved equipment. See Sections 300-1(b) and 310-1(c).

**440-32. Single Motor-Compressor.** Branch-circuit conductors supplying a single motor-compressor shall have an ampacity not less than 125 percent of either the motor-compressor rated-load current or the branch-circuit selection current, whichever is greater.

**440-33. Several Motor-Compressors.** Conductors supplying two or more motor-compressors shall have an ampacity not less than the sum of the rated-load current, or branch-circuit selection current ratings, whichever is greater, of all the motor-compressors plus 25 percent of the highest rated motor-compressor in the group.

*Exception: When the circuitry is so interlocked as to prevent the starting and running of a second motor-compressor or group of motor-compressors, the conductor size shall be determined from the largest motor-compressor or group of motor-compressors that is to be operated at a given time.*

**440-34. Combination Load.** Conductors supplying a motor-compressor load in addition to a lighting or appliance load as computed from Article 220 and other applicable Articles, shall have an ampacity sufficient for the lighting or appliance load plus the required ampacity for the motor-compressor load determined in accordance with Section 440-33, or, for a single motor-compressor, in accordance with Section 440-32.

*Exception: When the circuitry is so interlocked as to prevent simultaneous operation of the motor-compressor(s) and all other loads connected, the conductor size shall be determined from the largest size required for the motor-compressors(s) and other loads to be operated at a given time.*

**440-35. Multimotor and Combination-Load Equipment.** The ampacity of the conductors supplying multimotor and combination-load equipment shall not be less than the minimum circuit ampacity marked on the equipment in accordance with Section 440-3(b).

### E. Controllers for Motor-Compressors

#### 440-41. Rating.

(a) A motor-compressor controller shall have both a continuous-duty full-load current rating, and a locked-rotor current rating, not less than the nameplate rated-load current or branch-circuit selection current, whichever is greater, and locked-rotor current, respectively (see Sections 440-5 and 440-6) of the compressor. In case the motor controller is rated in horsepower, but is without one or both of the foregoing current ratings, equivalent currents shall be determined from

(440-41(a) continued)

the ratings as follows: Use Table 430-148, 430-149, or 430-150 to determine the equivalent full-load current rating. Use Table 430-151 to determine the equivalent locked-rotor current rating.

(b) A controller, serving more than one motor-compressor or a motor-compressor and other loads, shall have a continuous-duty full-load current rating, and a locked-rotor current rating not less than the combined load as determined in accordance with Section 440-12(b).

#### **F. Motor-Compressor and Branch-Circuit Overload Protection**

**440-51. General.** The provisions of Part F specify devices intended to protect the motor-compressor, the motor-control apparatus, and the branch-circuit conductors against excessive heating due to motor overload and failure to start. (See Section 240-5(a), Exception No. 3.)

Note: Overload in electrically driven apparatus is an operating overcurrent which, when it persists for a sufficient length of time, would cause damage or dangerous overheating. It does not include short circuits or ground faults.

#### **440-52. Application and Selection.**

(a) **Protection of Motor-Compressor.** Each motor-compressor shall be protected against overload and failure to start by one of the following means:

(1) A separate overload relay which is responsive to motor-compressor current. This device shall be selected to trip at not more than 140 percent of the motor-compressor rated-load current.

(2) A thermal protector integral with the motor-compressor, approved for use with the motor-compressor which it protects, on the basis that it will prevent dangerous overheating of the motor-compressor due to overload and failure to start. If the current-interrupting device is separate from the motor-compressor and its control circuit is operated by a protective device integral with the motor-compressor, it shall be so arranged that the opening of the control circuit will result in interruption of current to the motor-compressor.

(3) A fuse or time-limit circuit breaker responsive to motor current, which may also serve as the branch-circuit short-circuit and ground-fault protective device. This device shall be rated at not more than 125 percent of the motor-compressor rated-load current. It shall have sufficient time delay to permit the motor-compressor to start and accelerate its load. The equipment or the motor-compressor shall be marked with this maximum branch-circuit fuse or time-limit circuit-breaker rating.

*Exception: Where the standard sizes of fuses or time-limit circuit breakers are not adequate to carry the load, the next higher size or rating may be used but not higher than 140 percent of the motor-compressor rated-load current rating.*

(4) A protective system, furnished or specified and approved for use with the motor-compressor which it protects on the basis that it will prevent dangerous overheating of the motor-compressor due to overload and failure to start. If the current interrupting device is separate from the motor-compressor and its control circuit is operated

by a protective device which is not integral with the current-interrupting device, it shall be so arranged that the opening of the control circuit will result in interruption of current to the motor-compressor.

**(b) Protection of Motor-Compressor Control Apparatus and Branch-Circuit Conductors.** The motor-compressor controller(s), the disconnecting means and branch-circuit conductors shall be protected against overcurrent due to motor overload and failure to start by one of the following means which may be the same device or system protecting the motor-compressor in accordance with Section 440-52(a):

(1) An overload relay selected in accordance with Section 440-52(a)(1).

(2) A thermal protector applied in accordance with Section 440-52(a)(2) and which will not permit a continuous current in excess of 156 percent of the marked rated-load current or branch-circuit selection current.

(3) A fuse or time-limit circuit breaker selected in accordance with Section 440-52(a)(3).

(4) A protective system in accordance with Section 440-52(a)(4) and which will not permit a continuous current in excess of 156 percent of the marked rated-load current or branch-circuit selection current.

**440-53. Overload Relays.** Overload relays and other devices for motor overload protection, which are not capable of opening short circuits, shall be protected by fuses or time-limit circuit breakers with ratings or settings in accordance with Part C unless approved for group installation or for part-winding motors and marked to indicate the maximum size of fuse or time-limit circuit breaker by which they must be protected.

*Exception: The fuse or time-limit circuit-breaker-size marking may be located on the nameplate of approved equipment in which the overload relay or other overload device is used.*

**440-54. Motor-Compressors and Equipment on General-Purpose Branch Circuits.** Overload protection for motor-compressors and equipment used on general-purpose branch circuits as permitted in Article 210, shall be provided in (a), (b) and (c) below.

(a) Motor-compressors and equipment may be connected to general-purpose branch circuits only if the motor-compressor is provided with overload protection selected as specified in Section 440-52(a). Both the controller and the motor-overload protective device shall be approved for installation with a short-circuit and ground-fault protective device of the branch circuit to which the equipment is connected.

(b) Where a motor-compressor or equipment is connected to a general-purpose branch circuit by means of a cap and receptacle, the rating of the cap and receptacle shall not exceed 20 amperes at 125 volts or 15 amperes at 250 volts. See Article 210.

(c) The short-circuit and ground-fault protective device protecting a branch circuit to which a motor-compressor or equipment is connected shall have sufficient time delay to permit the motor-compressor and other motors to start and accelerate their load(s).

## ARTICLE 445 — GENERATORS

**445-1. Location.** Generators shall be located in dry places, and also so as to meet the requirements for motors in Section 430-14. Generators installed in hazardous locations as described in Articles 500-503, or in other locations as described in Articles 510-517, 520, 530, and 665, shall also comply with the provisions of those Articles.

Waterproof covers shall be provided for use in emergency.

**445-2. Marking.** Each generator shall be provided with a nameplate giving the maker's name, the rating in kilowatts or kilovolt-amperes, the normal volts and amperes corresponding to the rating, and the revolutions per minute.

**445-3. Drip Pans.** Generators shall be provided with suitable drip pans if required by the authority having jurisdiction.

**445-4. Overcurrent Protection.**

**(a) Constant-Potential Generators.** Constant-potential generators, except alternating-current generators and their exciters, shall be protected from excessive current by circuit breakers or fuses.

**(b) Two-Wire Generators.** Two-wire, direct-current generators may have overcurrent protection in one conductor only if the overcurrent device is actuated by the entire current generated, except that in the shunt field. The overcurrent device shall not open the shunt field.

**(c) 65 Volts or Less.** Generators operating at 65 volts or less and driven by individual motors shall be considered as protected by the overcurrent device protecting the motor if these devices will operate when the generators are delivering not more than 150 percent of their full-load rated current.

**(d) Balancer Sets.** Two-wire, direct-current generators used in conjunction with balancer sets to obtain neutrals for 3-wire systems shall be equipped with overcurrent devices which will disconnect the 3-wire system in the case of excessive unbalancing of voltages or currents.

**(e) 3-Wire, Direct-Current Generators.** Three-wire, direct-current generators, whether compound or shunt wound, shall be equipped with overcurrent devices, one in each armature lead, and so connected as to be actuated by the entire current from the armature. Such overcurrent devices shall consist either of a double-pole, double-coil circuit breaker, or of a 4-pole circuit breaker connected in the main and equalizer leads and tripped by two overcurrent devices, one in each armature lead. Such protective devices shall be so interlocked that no one pole can be opened without simultaneously disconnecting both leads of the armature from the system.

**445-5. Size of Conductors.** The conductors from the generator terminals to supplied equipment shall have an ampacity not less than 115 percent of the nameplate current rating of the generator. Neutral conductors shall be the same size as the conductors of the outside legs.

**445-6. Protection of Live Parts.** Live parts of generators of more than 150 volts to ground shall not be exposed to accidental contact where accessible to unqualified persons.

**445-7. Guards for Attendants.** Where necessary for the safety of attendants the provisions of Section 430-133 shall be complied with.

**445-8. Grounding.** If a generator operates at a terminal voltage in excess of 150 volts to ground, the frame shall be grounded in the manner specified in Article 250. If the frame is not grounded, it shall be permanently and effectively insulated from the ground.

**445-9. Bushings.** Where wires pass through an opening in an enclosure, conduit box, or barrier, a bushing shall be used to protect the conductors from the edges of the opening having sharp edges. The bushing shall have smooth, well rounded surfaces where it may be in contact with the conductors. If used where there may be a presence of oils, grease, or other contaminants, the bushing shall be made of a material not deleteriously affected.

## ARTICLE 450 — TRANSFORMERS AND TRANSFORMER VAULTS

(Including Secondary Ties)

**450-1. Application.** This Article applies to the installation of all transformers except:

*Exception No. 1: Current transformers.*

*Exception No. 2: Dry-type transformers which constitute a component part of other apparatus and which conform to the requirements for such apparatus.*

*Exception No. 3: Transformers which are an integral part of an X-ray or high-frequency apparatus.*

*Exception No. 4: Transformers used with Class 1 low-voltage power circuits or Class 2 remote-control, low-energy power and signal circuits which shall conform to Article 725.*

*Exception No. 5: Transformers for sign and outline lighting which shall conform to Article 600.*

*Exception No. 6: Transformers for electric-discharge lighting which shall conform to Article 410.*

This Article applies to the installation of transformers in hazardous locations except as modified by Article 500.

### A. General Provisions

**450-2. Location.** Transformers and transformer vaults shall be readily accessible to qualified personnel for inspection and maintenance.

(Exceptions on page -274)

*Exception No. 1: Dry-type transformers 600 volts or less, located in the open on walls, columns or structures, need not be readily accessible.*

*Exception No. 2: Dry-type transformers not exceeding 600 volts and 50 kVA may be installed in fire-resistant hollow spaces of buildings not permanently closed in by structure and provided they meet the ventilation requirements of Section 450-8.*

The location of oil-insulated transformers and transformer vaults is covered in Sections 450-24, 450-25, and 450-41; dry-type transformers in Section 450-21 and askarel-insulated in Section 450-23.

**450-3. Overcurrent Protection.** Overcurrent protection shall conform to the following. As used in this Section, the word "transformer" means a transformer or polyphase bank of two or three single-phase transformers operating as a unit.

**(a) Askarel- and Oil-Insulated Transformers.**

**(1) Primary Side.** Each askarel- or oil-insulated transformer shall be protected by an individual overcurrent device in the primary connection, rated or set at not more than 250 percent of the rated primary current of the transformer, except that an individual overcurrent device is not required when the primary circuit overcurrent device provides the protection specified in this Section, and except as provided in Section 450-3(a)(2).

**(2) Primary and Secondary Side.** An askarel- or oil-insulated transformer having an overcurrent device in the secondary connection, rated or set at not more than 250 percent of the rated secondary current of the transformer, or a transformer equipped with a coordinated thermal overload protection by the manufacturer, is not required to have an individual overcurrent device in the primary connection provided the primary feeder overcurrent device is rated or set to open at a current value not more than 6 times the rated current of the transformer for transformers having not more than 6 percent impedance, and not more than four times rated current of the transformer for transformers having more than 6 but not more than 10 percent impedance.

**(b) Dry-Type Transformers.**

**(1) Primary Side.** Each dry-type transformer shall be protected by an individual overcurrent device in the primary connection, rated or set in not more than 125 percent of the rated primary current of the transformer, except that an individual overcurrent device is not required when the primary circuit overcurrent device provides the protection specified in this Section, and except as provided in Section 450-3(b)(2).

**(2) Primary and Secondary Side.** A dry-type transformer having an overcurrent device in the secondary connection, rated or set at not more than 125 percent of the rated secondary current of the transformer, is not required to have an individual overcurrent device in the primary connection provided the primary feeder overcurrent device is rated or set to open at a current value not more than 250 percent of the rated primary current of the transformer.

A dry-type transformer, equipped with a coordinated thermal overload protection by the manufacturer and arranged to interrupt the

primary current, is not required to have an individual overcurrent device in the primary connection provided the primary feeder overcurrent device is rated or set to open at a current value not more than 6 times the rated current of the transformer for transformers having not more than 6 percent impedance, and not more than 4 times rated current of the transformer for transformers having more than 6 but not more than 10 percent impedance.

**(c) Potential (Voltage) Transformers.** Potential transformers installed indoors or enclosed shall be protected with primary fuses.

**450-5. Secondary Ties.** As used in this Section, the word “transformer” means a transformer or a bank of transformers operating as a unit. A secondary tie is a circuit operating at 600 volts or less between phases which connects two power sources or power supply points, such as the secondaries of two transformers. The tie may consist of one or more conductors per phase.

**(a) Tie Circuits.** Tie circuits shall be provided at each end with overcurrent protection as required in Article 240 of this Code, except under the conditions described in Sections 450-5(a)(1) and (a)(2), in which cases the overcurrent protection may be in accordance with Section 450-5(a)(3).

**(1) Loads at Transformer Supply Points Only.** Where all loads are connected at the transformer supply points at each end of the tie and overcurrent protection is not provided in accordance with Article 240, the rated ampacity of the tie shall be not less than 67 percent of the rated secondary current of the largest transformer connected to the secondary tie system.

**(2) Loads Connected Between Transformer Supply Points.** Where load is connected to the tie at any point between transformer supply points and overcurrent protection is not provided in accordance with Article 240, the rated ampacity of the tie shall be not less than 100 percent of the rated secondary current of the largest transformer connected to the secondary tie system except as otherwise provided in Section 450-5(a)(4).

**(3) Tie Circuit Protection.** Under the conditions described in Sections 450-5(a)(1) and (a)(2), both ends of each tie conductor shall be equipped with a protective device which will open at a predetermined temperature of the tie conductor under short circuit conditions. This protection shall consist of one of the following: (1) a fusible link cable connector, terminal or lug, commonly known as a limiter, each being of a size corresponding with that of the conductor and of approved construction and characteristics according to the operating voltage and the type of insulation on the tie conductors, or (2) automatic circuit breakers actuated by devices having comparable current-time characteristics.

**(4) Interconnection of Phase Conductors Between Transformer Supply Points.** Where the tie consists of more than one conductor per phase, the conductors of each phase shall be interconnected in order to establish a load supply point, and the protection specified in Section 450-5(a)(3) shall be provided in each tie conductor at this point, except as follows:

*Exception: Loads may be connected to the individual conductors of a multiple-conductor tie without interconnecting the conductors of each phase and without the protection specified in Section 450-5(a)(3) at load connection points provided; the tie conductors of each phase have a combined capacity not less than 133 percent of the rated secondary current of the largest transformer connected to the secondary tie system; the total load of such taps does not exceed the rated secondary current of the largest transformer; the loads are equally divided on each phase and on the individual conductors of each phase as far as practicable.*

**(5) Tie Circuit Control.** Where the operating voltage exceeds 150 volts to ground, secondary ties provided with limiters shall have a switch at each end which when open will de-energize the associated tie conductors and limiters. The current rating of the switch shall be not less than the rated current of the conductors connected to the switch. It shall be capable of opening its rated current, and it shall be constructed so that it will not open under the magnetic forces resulting from short-circuit current.

**(b) Overcurrent Protection for Secondary Connections.** When secondary ties are used an overcurrent device rated or set at not more than 250 percent of the rated secondary current of the transformers shall be provided in the secondary connections of each transformer, and in addition an automatic circuit breaker actuated by a reverse-current relay set to open the circuit at not more than the rated secondary current of the transformer shall be provided in the secondary connection of each transformer.

**450-6. Parallel Operation.** Transformers may be operated in parallel and switched as a unit provided that the overcurrent protection for each transformer meets the requirements of Section 450-3.

To obtain balanced division of load current, both transformers should have the same rated percent impedance and be operated on the same voltage-ratio tap.

**450-7. Guarding.** Transformers shall be guarded as follows:

**(a) Mechanical Protection.** Appropriate provisions shall be made to minimize the possibility of damage to transformers from external causes where the transformers are located where they are exposed to physical damage.

**(b) Case or Enclosure.** Dry-type transformers shall be provided with a noncombustible moisture-resistant case or enclosure which will provide reasonable protection against the accidental insertion of foreign objects.

**(c) Exposed Live Parts.** The transformer installation shall conform with the provisions for guarding of live parts in Section 110-17.

**(d) Voltage Warning.** The operating voltage of exposed live parts of transformer installations shall be indicated by signs or visible markings on the equipment or structures.

**450-8. Ventilation.** The ventilation shall be adequate to prevent a transformer temperature in excess of the values prescribed in ANSI C57.12.00-1968.



**450-9. Grounding.** Exposed noncurrent carrying metal parts of transformer installations including fences, guards, etc., shall be grounded where required under the conditions and in the manner prescribed for electrical equipment and other exposed metal parts in Article 250.

**450-10. Marking.** Each transformer shall be provided with a nameplate giving the name of the manufacturer; rated kilovolt-amperes, frequency, primary and secondary voltage; and the amount and kind of insulating liquid where used and the transformer rating exceeds 25 kVA. Where Class B insulation is used in the construction of dry-type transformers rated more than 100 kVA, the nameplate shall indicate the temperature rise for this insulation system.

### **B. Specific Provisions Applicable to Different Types of Transformers**

**450-21. Dry-Type Transformers Installed Indoors.** Transformers rated 112½ kVA or less shall have a separation of at least 12 inches from combustible material unless separated therefrom by a fire-resistant heat-insulating barrier, or unless of a rating not exceeding 600 volts and completely enclosed except for ventilating openings.

Transformers of more than 112½ kVA rating shall be installed in a transformer room of fire-resistant construction unless they are constructed with 80° C rise (Class B) or 150° C rise (Class H) insulation, and are separated from combustible material not less than 6 feet horizontally and 12 feet vertically or are separated therefrom by a fire-resistant heat-insulating barrier.

Transformers rated more than 35,000 volts shall be installed in a vault. See Part C of this Article.

**450-22. Dry-Type Transformers Installed Outdoors.** Dry-type transformers installed outdoors shall have an approved weatherproof enclosure.

**450-23. Askarel-Insulated Transformers Installed Indoors.** Askarel-insulated transformers rated in excess of 25 kVA shall be furnished with a pressure-relief vent. Where installed in a poorly ventilated place they shall be furnished with a means for absorbing any gases generated by arcing inside the case, or the pressure relief vent shall be connected to a chimney or flue which will carry such gases outside the building. Askarel-insulated transformers rated more than 35,000 volts shall be installed in a vault.

**450-24. Oil-Insulated Transformers Installed Indoors.** Oil-insulated transformers shall be installed in a vault constructed as specified in this Article except as follows:

(a) **Not Over 112½ kVA Total Capacity.** The provisions for transformer vaults specified in Part C of this Article apply except that the vault may be constructed of reinforced concrete not less than 4 inches thick.

(b) **Not Over 600 Volts.** A vault is not required provided suitable arrangements are made where necessary to prevent a transformer oil fire igniting other materials, and the total transformer capacity in one

location does not exceed 10 kVA in a section of the building classified as combustible, or 75 kVA where the surrounding structure is classified as fire-resistant construction.

**(c) Furnace Transformers.** Electric furnace transformers of a total rating not exceeding 75 kVA may be installed without a vault in a building or room of fire-resistant construction provided suitable arrangements are made to prevent a transformer oil fire spreading to other combustible material.

**(d) Detached Buildings.** Transformers may be installed in a building which does not conform with the provisions specified in this Code for transformer vaults, provided neither the building nor its contents present a fire hazard to any other building or property, and provided the building is used only in supplying electric service and the interior is accessible only to qualified persons.

**450-25. Oil-Insulated Transformers Installed Outdoors.** Combustible material, combustible buildings and parts of buildings, fire escapes, door and window openings shall be safeguarded from fires originating in oil-insulated transformers installed on, attached to, or adjacent to a building or combustible material. Space separations, fire-resistant barriers, automatic water spray systems and enclosures which confine the oil of a ruptured transformer tank are recognized safeguards. One or more of these safeguards shall be applied according to the degree of hazard involved in cases where the transformer installation presents a fire hazard. Oil enclosures may consist of fire-resistant dikes, curbed areas or basins, or trenches filled with coarse crushed stone. Oil enclosures shall be provided with trapped drains in cases where the exposure and the quantity of oil involved are such that removal of oil is important.

### **C. Provisions for Transformer Vaults**

**450-41. Location.** Vaults shall be located where they can be ventilated to the outside air without using flues or ducts wherever such an arrangement is practicable.

**450-42. Walls, Roof, and Floor.** The walls and roofs of vaults shall be constructed of reinforced concrete, brick, load bearing tile, concrete block, or other fire resistive constructions which have adequate structural strength for the conditions, and a minimum fire resistance of 3 hours according to ASTM Standard E119-67; Fire Tests of Building Construction and Materials; (NFPA No. 251-1969). The floors of vaults in contact with the earth shall be of concrete not less than 4 inches thick but when the vault is constructed with a vacant space or other stories below it, the floor shall have adequate structural strength for the load imposed thereon and a minimum fire resistance of 3 hours.

**450-43. Doorways.** Vault doorways shall be protected as follows:

**(a) Type of Door.** Each doorway leading into a building shall be provided with a tight-fitting door of a type approved for openings in Class A situations as defined in the NFPA Standard for the Installation of Fire Doors and Windows, No. 80-1970. The authority enforcing this Code may require such a door for an exterior wall opening or on each side of an interior wall opening where conditions warrant.

(b) **Sills.** A door sill or curb of sufficient height to confine within the vault the oil from the largest transformer shall be provided and in no case shall the height be less than 4 inches.

(c) **Locks.** Entrance doors shall be equipped with locks, and doors shall be kept locked, access being allowed only to qualified persons. Locks and latches shall be so arranged that the door may be readily and quickly opened from the inside.

**450-45. Ventilation Openings.** When required by Section 450-8, openings for ventilation shall be provided in accordance with the following:

(a) **Location.** Ventilation openings shall be located as far away as possible from doors, windows, fire escapes, and combustible material.

(b) **Arrangement.** Vaults ventilated by natural circulation of air may have roughly half of the total area of openings required for ventilation in one or more openings near the floor and the remainder in one or more openings in the roof or in the sidewalls near the roof; or all of the area required for ventilation may be provided in one or more openings in or near the roof.

(c) **Size.** In the case of vaults ventilated to an outdoor area without using ducts or flues the combined net area of all ventilating openings after deducting the area occupied by screens, gratings, or louvers, shall be not less than 3 square inches per kva of transformer capacity in service, except that the net area shall be not less than 1 square foot for any capacity under 50 kVA.

(d) **Covering.** Ventilation openings shall be covered with durable gratings, screens, or louvers, according to the treatment required in order to avoid unsafe conditions.

(e) **Dampers.** All ventilation openings to the indoors shall be provided with automatic closing dampers of not less than No. 10 MSG steel which operate in response to a vault fire.

(f) **Ducts.** Ventilating ducts shall be constructed of fire-resistant material.

**450-46. Drainage.** Where practicable, vaults containing more than 100-kVA transformer capacity shall be provided with a drain or other means which will carry off any accumulation of oil or water in the vault unless local conditions make this impracticable. The floor shall be pitched to the drain when provided.

**450-47. Water Pipes and Accessories.** Any pipe or duct systems foreign to the electrical installation should not enter or pass through a transformer vault. Where the presence of such foreign systems cannot be avoided, appurtenances thereto which require maintenance at regular intervals shall not be located inside the vault. Arrangements shall be made where necessary to avoid possible trouble from condensation, leaks and breaks in such foreign systems. Piping or other facilities provided for fire protection or for water-cooled transformers are not deemed to be foreign to the electrical installation.

**450-48. Storage in Vaults.** Materials shall not be used in transformer vaults.

## ARTICLE 460 — CAPACITORS

**460-1. Application.** This Article applies to installation of capacitors on electric circuits in or on buildings.

*Exception No. 1: Capacitors that are components of other apparatus shall conform to the requirements for such apparatus.*

*Exception No. 2: Capacitors in hazardous locations shall comply with additional requirements in Articles 500 through 517.*

**460-2. Location.** An installation of capacitors in which any single unit contains more than 3 gallons of combustible liquid shall be in a vault conforming to Part C of Article 450.

**460-3. Mechanical Protection.** Capacitors shall be protected from physical damage by location or by suitable fences, barriers or other enclosures.

**460-4. Cases and Supports.** Capacitors shall be provided with non-combustible cases and supports.

**460-5. Transformers Used with Capacitors.** Transformers that are components of capacitor installations and are used for the purpose of connecting the capacitor to a power circuit shall be installed in accordance with Article 450. The kVA rating shall not be less than 135 percent of the capacitor rating in kVAR.

**460-6. Drainage of Stored Charge.** Capacitors shall be provided with a means of draining the stored charge.

(a) **Time of Discharge.** The residual voltage of a capacitor shall be reduced to 50 volts or less within one minute after the capacitor is disconnected from the source of supply in the case of capacitors rated 600 volts or less and in 5 minutes in the case of capacitors rated more than 600 volts.

(b) **Means of Discharge.** The discharge circuit shall be either permanently connected to the terminals of the capacitor or capacitor bank, or provided with automatic means of connecting it to the terminals of the capacitor bank on removal of voltage from the line. Manual means of switching or connecting the discharge circuit shall not be used. The windings of motors, of transformers, or of other equipment directly connected to capacitors without a switch or overcurrent device interposed, constitutes a suitable discharge means.

**460-7. Power Factor Correction — Motor Circuit.** The total kVAR rating of capacitors which are connected on the load side of a motor controller shall not exceed the value required to raise the no-load power factor of the motor to unity.

**460-8. Conductor Rating.**

(a) The ampacity of capacitor-circuit conductors shall be not less than 135 percent of the rated current of the capacitor. The ampacity of conductors which connect a capacitor to the terminals of a motor or to motor circuit conductors, shall be not less than one-third the am-

capacity of the motor circuit conductors but not less than 135 percent of the rated current of the capacitor.

**(b) Overcurrent Protection.**

(1) An overcurrent device shall be provided in each ungrounded conductor for each capacitor bank.

*Exception: A separate overcurrent device is not required on the load side of a motor-running overcurrent device.*

(2) The rating or setting of the overcurrent device shall be as low as practicable.

**(c) Disconnecting Means.**

(1) A disconnecting means shall be provided in each ungrounded conductor for each capacitor bank.

*Exception: A separate disconnecting means is not required for a capacitor connected on the load side of a motor-running overcurrent device.*

(2) The disconnecting device need not open all ungrounded conductors simultaneously.

(3) The disconnecting device may be used for disconnecting the capacitor from the line as a regular operating procedure.

(4) The continuous ampacity of the disconnecting device shall be not less than 135 percent of the rated current of the capacitor.

**460-9. Rating or Setting of the Motor-Running Overcurrent Device.** Where a motor installation includes a capacitor connected on the load side of the motor-running overcurrent device, and the overcurrent device used can be adjusted, the rating or setting of the motor overcurrent device shall be determined as provided in Section 430-32, except that instead of using the full-load rated current of the motor as provided in that Section a lower value corresponding with the improved power-factor of the motor circuit shall be used. Section 430-22 applies with respect to the rating of the motor circuit conductors.

**460-10. Grounding.** Capacitor cases shall be grounded in accordance with Article 250.

**460-11. Guarding.** All live parts of capacitors which are connected to circuits of more than 600 volts between conductors and are accessible to unqualified persons, shall be enclosed or isolated. For isolation by elevation, see Section 710-34(f).

**460-12. Marking.** Each capacitor shall be provided with a nameplate giving the maker's name, rated voltage, frequency, kVAR, or amperes, number of phases, and if filled with a combustible liquid, the amount of liquid in gallons. When filled with a nonflammable liquid, the nameplate shall so state. The nameplate shall also indicate if a capacitor has a discharge device inside the case.

## ARTICLE 470 — RESISTORS AND REACTORS

**For Rheostats see Section 430-82.**

**470-1. Location.** Resistors and reactors shall not be placed where exposed to physical damage. Where in the immediate vicinity of easily ignitable material they shall be of the oil-immersed type or shall be enclosed in metal boxes or cabinets. See Article 500 for Hazardous Locations.

**470-2. Space Separation.** Unless attached to a switchboard or other noncombustible material, or unless mounted as provided in Section 470-3, resistors and reactors shall be separated from combustible material by a distance of not less than one foot.

**470-3. On or In Proximity to Combustible Material.** Where placed within a distance of one foot from combustible material, resistors and reactors shall be installed as follows:

(a) **Slab or Panel.** They shall be attached to a slab or panel of noncombustible, nonabsorptive material such as slate, soapstone, or marble.

(b) **Size of Slab.** The slab shall extend beyond the edges of the device and shall have a thickness proportioned to the size and weight of the device but shall not be less than ½-inch thick.

(c) **Supports.** The slab shall be secured in position by supports independent of those fastening the device to the slab. Bolts which support the device shall be countersunk at least ⅛ inch below the rear surface of the slab and shall be covered with insulating material.

**470-4. Contacts.** Fixed and movable contacts shall be so designed that arcing will be kept at a minimum.

**470-5. Reactor Materials.** Reactors shall be composed of noncombustible materials, and shall be mounted on noncombustible bases.

**470-6. Mounting.** Enclosures when mounted on plain surfaces shall make contact with such surfaces only at the point of support, an air space of at least ¼ inch being maintained between the enclosures and surfaces.

**470-7. Conductor Insulation.** Insulated conductors used for connection between resistance elements and controllers shall be suitable for an operating temperature of not less than 90°C (194°F). For elevator motor starting service, see Section 620-11(a).

*Exception: For motor starting service other conductor insulations may be used.*

**470-8. Incandescent Lamps as Resistors.** Incandescent lamps may be used as protective resistors for automatic controllers, or may by special permission be used as resistors in series with other devices and shall conform to the following:

(a) **Mounting.** They shall be mounted in porcelain receptacles or noncombustible supports.

(b) **Voltage.** They shall be so arranged that they cannot have impressed upon them a voltage greater than that for which they are rated.

(c) **Nameplate.** They shall be provided with a nameplate, permanently attached, giving the wattage and voltage of the lamp to be used in each receptacle.

(d) **Not Carry Main Current.** They shall not carry or control the main current nor constitute the regulating resistance of the device.

## ARTICLE 480 — STORAGE BATTERIES

**480-1. Scope.** The provisions of this Article shall apply to all stationary installations of storage batteries using acid or alkali as the electrolyte and consisting of a number of cells connected in series with a nominal voltage in excess of 16 volts.

**480-2. Definition of Nominal Battery Voltage.** The nominal battery voltage shall be calculated on the basis of 2.0 volts per cell for the lead-acid type, and 1.2 volts per cell for the alkali type.

**480-3. Wiring and Apparatus Supplied from Batteries.** Wiring, appliances, and apparatus supplied from storage batteries shall be subject to the requirements of this Code applying to wiring, appliances, and apparatus operating at the same voltage, except as otherwise provided for communication systems in Article 800.

**480-4. Insulation of Batteries of Not Over 250 Volts.** The provisions of this Section shall apply to storage batteries having the cells so connected as to operate at a nominal battery voltage not exceeding 250 volts.

(a) **Lead-Acid Batteries.** Cells in lead-lined wood tanks, where the number of cells in series does not exceed 25, shall be supported individually on glass or glazed porcelain insulators. Where the number of the cells in series exceeds 25, the cells shall be supported individually on oil insulators.

(b) **Alkali-Type Batteries.** Cells of the alkali type in jars made of conducting material shall be installed in trays of nonconducting material, with not over 20 cells in a series circuit in any one such tray, or the cells may be supported singly or in groups on porcelain or other suitable insulators.

(c) **Unsealed Jars.** Cells in unsealed jars made of nonconductive material shall be assembled in trays of glass or supported on glass or glazed porcelain insulators; or, where installed on a rack, shall be supported singly or in groups on glass or other suitable insulators.

(d) **Sealed Rubber Jars.** Cells in sealed rubber or composition containers shall require no additional insulating support where the total nominal voltage of all cells in series does not exceed 150 volts. Where the total voltage exceeds 150 volts, batteries shall be sectionalized into groups of 150 volts or less and each group shall have the individual cells

installed in trays or on racks. Where trays or racks are required for this type of cell, such trays or racks shall be supported on glass or glazed porcelain insulators or oil-type insulators.

(e) **Sealed Glass or Plastic Jars.** Cells in sealed glass jars or in sealed jars of approved heat resistant plastic, with or without wood trays, require no additional insulation.

**480-5. Insulation of Batteries of Over 250 Volts.** The provisions of Section 480-4 shall apply to storage batteries having the cells so connected as to operate at a nominal voltage exceeding 250 volts and, in addition, the provisions of this section shall also apply to such batteries. Cells shall be installed in groups having a total nominal voltage of not over 250 volts, in trays or on racks supported on oil insulators.

*Exception No. 1: Where each individual cell, or sub-group in the tray or rack, is supported on oil insulators, no additional insulation for the group need be provided.*

*Exception No. 2: Cells of not over 10 ampere-hour capacity in sealed glass jars may be grouped in trays, the total nominal voltage of all cells in such group not to exceed 250 volts, and each such tray to be supported on glass or glazed porcelain insulators, the trays being mounted on racks supported on oil insulators with a total nominal voltage of not over 500 volts for all cells in series on each such insulated rack.*

Maximum protection is secured by sectionalizing high-voltage batteries into cell groups insulated from each other.

**480-6. Racks and Trays.** Racks and trays shall conform to the following:

(a) **Racks.** Racks, as required in this Article, refer to frames designed to support cells or trays. They shall be substantial, and made of:

(1) Wood, so treated as to be resistant to deteriorating action by the electrolyte; or

(2) Metal, so treated as to be resistant to deteriorating action by the electrolyte, and provided with nonconducting members directly supporting the cells or with suitable insulating material on conducting members; or

(3) Other similar suitable construction.

(b) **Trays.** Trays refer to frames such as crates or shallow boxes usually of wood or other nonconducting material, so constructed or treated as to be resistant to deteriorating action by the electrolyte.

**480-7. Battery Rooms.** Battery rooms shall conform to the following:

(a) **Use.** Separate battery rooms or enclosures shall be required only for batteries in unsealed jars and tanks where the aggregate capacity at the 8-hour discharge rate exceeds 5 kilowatt hours.

(b) **Ventilation.** Provision shall be made for sufficient diffusion and ventilation of the gases from the battery to prevent the accumulation of an explosive mixture in the battery room.

(c) **Wiring Method.** In storage battery rooms, bare conductors, open wiring, Type MI cable, Type ALS cable, or conductors in rigid



conduit or electrical metallic tubing shall be used as the wiring method. Rigid metal conduit, or electrical metallic tubing, where used, shall be of corrosion-resistant material or shall be suitably protected from corrosion.

**(d) Varnished-Cambric Conductors.** Varnished-cambric-covered conductors, Type V, shall not be used.

**(e) Bare Conductors.** Bare conductors shall not be taped.

**(f) Terminals.** Where metal raceway or other metallic covering is used in the battery room, at least 12 inches of the conductor at the end connected to a cell terminal shall be free from the raceway or metallic covering and shall be bushed by a substantial glazed insulating bushing. The end of the raceway shall be sealed tightly to resist the entrance of electrolyte by spray or by creepage. Sealing compound, rubber insulating tape or other suitable material shall be used for this purpose.

## **Chapter 5. Special Occupancies**

### **ARTICLE 500 — HAZARDOUS LOCATIONS**

**500-1. Scope.** The provisions of Articles 500 through 503 apply to locations in which the authority having jurisdiction judges the apparatus and wiring to be subject to the conditions indicated by the following classifications. It is intended that each room, section or area (including motor and generator rooms, and rooms for the enclosure of control equipment) shall be considered individually in determining its classification. Except as modified in Articles 500 through 503, all other applicable rules contained in this Code shall apply to electrical apparatus and wiring installed in hazardous locations. For definitions of "approved" and "explosion-proof" as used in these Articles, refer to Article 100; "dust-ignition-proof" is defined in Section 502-1.

Equipment and associated wiring approved as intrinsically safe may be installed in any hazardous location for which it is approved, and the provisions of Articles 500 through 517 need not apply to such installation. Intrinsically safe equipment and wiring are incapable of releasing sufficient electrical energy under normal or abnormal conditions to cause ignition of a specific hazardous atmospheric mixture. Abnormal conditions will include accidental damage to any part of the equipment or wiring, insulation or other failure of electrical components, application of overvoltage, adjustment and maintenance operations, and other similar conditions.

For further information see NFPA No. 493-1969 Standard for Intrinsically Safe Process Control Equipment for use in Class I Hazardous Locations.

Through the exercise of ingenuity in the layout of electrical installations for hazardous locations, it is frequently possible to locate much of the equipment in less hazardous or in nonhazardous areas and thus to reduce the amount of special equipment required. In some cases, hazards may be reduced or hazardous areas limited or eliminated by adequate positive-pressure ventilation from a source of clean air in conjunction with effective safeguards against ventilation failure. For further information see NFPA No. 496-1967 Standard for Purged Enclosures for Electrical Equipment in Hazardous Locations. It is recommended also that the authority having jurisdiction be familiar with such recorded industrial experience as well as with

such standards of the National Fire Protection Association as may be of use in the classification of various areas with respect to hazard. For further information, see NFPA No. 30, Flammable and Combustible Liquids Code-1969; NFPA No. 32, Dry Cleaning Plants-1970; NFPA No. 35, Manufacture of Organic Coatings-1970; NFPA No. 36, Solvent Extraction Plants-1967; NFPA No. 58 (ANSI Z106.1) Storage and Handling of Liquefied Petroleum Gases-1969; and NFPA No. 59, Storage and Handling of Liquefied Petroleum Gases at Utility Gas Plants-1968.

For recommendations for protection against static electricity hazards, refer to the standards of the National Fire Protection Association on this subject.

Where rigid conduit is used in hazardous locations, it is necessary to have all threaded joints made up wrench tight to minimize sparking when fault current flows through the conduit system. Where it is impractical to make a threaded joint tight, a bonding jumper should be utilized.

All conduit referred to herein shall be threaded with a standard conduit cutting die which provides  $\frac{3}{4}$ -inch taper per foot. Such conduit shall be made up wrench tight to minimize sparking when fault current flows through the conduit system. Where it is impractical to make a threaded joint tight, a bonding jumper shall be utilized.

**500-2. Special Precaution.** The intent of Articles 500 through 503 is to require a form of construction of equipment, and of installation that will insure safe performance under conditions of proper use and maintenance. It, therefore, is assumed that inspection authorities and users will exercise more than ordinary care with regard to installation and maintenance.

The explosion characteristics of air mixtures of hazardous gases, vapors, or dusts vary with the specific material involved. Classification of a hazardous mixture into a Class I hazardous location, Group A, B, C or D, involves determinations of maximum explosion pressure, maximum safe clearance between parts of a clamped joint in an enclosure, and the minimum ignition temperature of the atmospheric mixture. For Class II location, Groups E, F, and G, the classification involves the tightness of the joints of assembly and shaft openings to prevent entrance of dust in the dust-ignition-proof enclosure, the blanketing effect of layers of dust on the equipment that may cause overheating, electrical conductivity of the dust, and the ignition temperature of the dust. It is necessary, therefore, that equipment be approved not only for the class of location but also for the specific group of the gas, vapor or dust that will be present.

For purposes of testing and approval, various air mixtures (not oxygen enriched) have been grouped on the basis of their hazardous characteristics, and facilities have been made available for testing and approval of equipment for use in the following atmospheric groups:

For Groups A, B, C and D see Table 500-2(c).

Group E, Atmospheres containing metal dust, including aluminum, magnesium, and their commercial alloys, and other metals of similarly hazardous characteristics.

(500-2 continued)

Group F, Atmospheres containing carbon black, coal or coke dust;

Group G, Atmospheres containing flour, starch, or grain dust.

Certain chemical atmospheres may have characteristics which would require safeguards beyond those required for any of the above groups. Carbon disulfide is one of these chemicals because of its low ignition temperature (100°C) and the small joint clearance required to arrest its flame. For a complete list noting properties of flammable liquids, gases and solids refer to NFPA No. 325M-1969.

**(a) Approval for Class and Properties.** Equipment shall be approved not only for the class of location but also for the explosion properties of the specific gas, vapor, or dust that will be present. In addition, equipment shall not have exposed any surface that operates at a temperature in excess of the ignition temperature of the specific gas vapor or dust.

The characteristics of various atmospheric mixtures of hazardous gases, vapors, and dusts depend on the specific hazardous material involved.

**(b) Marking.** Approved equipment shall be marked to show the Class, Group and operating temperature, or temperature range, based on operation in a 40°C ambient for which it is approved.

The temperature range, if provided, shall be indicated in identification numbers, as shown in Table 500-2(b).

Identification numbers marked on equipment nameplates shall be in accordance with Table 500-2(b).

*Exception: Equipment of the nonheat-producing type, such as junction boxes, conduit and fittings, are not required to have a marked operating temperature.*

For purposes of testing and approval, various atmospheric mixtures (not oxygen enriched) have been grouped on the basis of their hazardous characteristics, and facilities have been made available for testing and approval of equipment for use in the atmospheric groups listed in Table 500-2(c). Since there is no consistent relationship between explosion properties and ignition temperature, the two must be regarded as independent requirements.

**Table 500-2(b). Identification Numbers**

Degrees C	Maximum Temperature	Degrees F	Identification Number
450		842	T1
300		572	T2
280		536	T2A
260		500	T2B
230		446	T2C
215		419	T2D
200		392	T3
180		356	T3A
165		329	T3B
160		320	T3C
135		275	T4
120		248	T4A
100		212	T5
85		185	T6

Table 500-2(c). Chemicals by Groups

Group A Atmospheres	Group D Atmospheres
Chemical	Chemical
acetylene	acetone
Group B Atmospheres	acrylonitrile
butadiene <sup>1</sup>	ammonia <sup>3</sup>
ethylene oxide <sup>2</sup>	benzene
hydrogen	butane
manufactured gases containing more than 30% hydrogen (by volume)	1-butanol (butyl alcohol)
propylene oxide <sup>2</sup>	2-butanol (secondary butyl alcohol)
Group C Atmospheres	n-butyl acetate
acetaldehyde	isobutyl acetate
cyclopropane	ethane
diethyl ether	ethanol (ethyl alcohol)
ethylene	ethyl acetate
isoprene	ethylene dichloride
unsymmetrical dimethyl hydrazine (UDMH 1, 1-dimethyl hydrazine)	gasoline
	heptanes
	hexanes
	methane (natural gas)
	methanol (methyl alcohol)
	3-methyl-1-butanol (isoamyl alcohol)
	methyl ethyl ketone
	methyl isobutyl ketone
	2-methyl-1-propanol
	(isobutyl alcohol)
	2-methyl-2-propanol
	(tertiary butyl alcohol)
	petroleum naphtha <sup>4</sup>
	octanes
	pentanes
	1-pentanol (amyl alcohol)
	propane
	1-propanol (propyl alcohol)
	2-propanol (isopropyl alcohol)
	propylene
	styrene
	toluene
	vinyl acetate
	vinyl chloride
	xylenes

<sup>1</sup> Group D equipment may be used for this atmosphere if such equipment is isolated in accordance with Section 501-5(a) by sealing all conduit ½-inch size or larger.

<sup>2</sup> Group C equipment may be used for this atmosphere if such equipment is isolated in accordance with Section 501-5(a) by sealing all conduit ½-inch size or larger.

<sup>3</sup> For Classification of areas involving ammonia atmosphere refer to ANSI B9.1 Safety Code for Mechanical Refrigeration-1971 and ANSI K61.1 Storage and Handling of Anhydrous Ammonia-1971.

<sup>4</sup> A saturated hydrocarbon mixture boiling in the range 20–135°C (68–275°F). Also known by the synonyms benzine, ligroin, petroleum ether or naphtha.

**(c) Temperature.** The temperature marking specified in (b) above shall not exceed the ignition temperature of the specific gas or vapor to be encountered. For information regarding ignition temperatures see NFPA 325M, Fire Hazard Properties of Flammable Liquids, Gases, Volatile Solids — 1969.

Formerly the temperature limit of each Group was assumed to be the lowest ignition temperature of any material in the Group, i.e., 280°C for Group D, 180°C for Group C. To avoid revising this limit as new gases are added (see hexane in Group D and acetaldehyde in Group C) temperature will be specified in future markings.

The ignition temperature for which equipment was approved prior to this requirement may be assumed to be as follows:

Group A 280°C (536°F)

Group B 280°C (536°F)

Group C 180°C (356°F)

Group D 280°C (536°F)

**500-3. Specific Occupancies.** See Articles 510 through 517 for rules applying to garages, aircraft hangars, gasoline dispensing and service stations, bulk storage plants, finishing processes, and flammable anesthetics.

**500-4. Class I Locations.** Class I locations are those in which flammable gases or vapors are or may be present in the air in quantities sufficient to produce explosive or ignitable mixtures. Class I locations shall include the following:

**(a) Class I, Division 1.** Locations (1) in which hazardous concentrations of flammable gases or vapors exist continuously, intermittently, or periodically under normal operating conditions, (2) in which hazardous concentrations of such gases or vapors may exist frequently because of repair or maintenance operations or because of leakage, or (3) in which breakdown or faulty operation of equipment or processes which might release hazardous concentrations of flammable gases or vapors, might also cause simultaneous failure of electrical equipment.

This classification usually includes locations where volatile flammable liquids or liquefied flammable gases are transferred from one container to another; interiors of spray booths and areas in the vicinity of spraying and painting operations where volatile flammable solvents are used; locations containing open tanks or vats of volatile flammable liquids; drying rooms or compartments for the evaporation of flammable solvents; locations containing fat and oil extraction apparatus using volatile flammable solvents; portions of cleaning and dyeing plants where hazardous liquids are used; gas generator rooms and other portions of gas manufacturing plants where flammable gas may escape; inadequately ventilated pump rooms for flammable gas or for volatile flammable liquids; the interiors of refrigerators and freezers in which volatile, flammable materials are stored in open, lightly stoppered, or easily ruptured containers, and all other locations where hazardous concentrations of flammable vapors or gases are likely to occur in the course of normal operations.

**(b) Class I, Division 2.** Locations (1) in which volatile flammable liquids or flammable gases are handled, processed or used, but in which the hazardous liquids, vapors or gases will normally be confined within closed containers or closed systems from which they can escape only in case of accidental rupture or breakdown of such containers or sys-

tems, or in case of abnormal operation of equipment, (2) in which hazardous concentrations of gases or vapors are normally prevented by positive mechanical ventilation, but which might become hazardous through failure or abnormal operation of the ventilating equipment, or (3) which are adjacent to Class I, Division 1 locations, and to which hazardous concentrations of gases or vapors might occasionally be communicated unless such communication is prevented by adequate positive-pressure ventilation from a source of clean air, and effective safeguards against ventilation failure are provided.

This classification usually includes locations where volatile flammable liquids or flammable gases or vapors are used, but which, in the judgment of the authority having jurisdiction, would become hazardous only in case of an accident or of some unusual operating condition. The quantity of hazardous material that might escape in case of accident, the adequacy of ventilating equipment, the total area involved, and the record of the industry or business with respect to explosions or fires are all factors that should receive consideration in determining the classification and extent of each hazardous area.

Piping without valves, checks, meters and similar devices would not ordinarily be deemed to introduce a hazardous condition even though used for hazardous liquids or gases. Locations used for the storage of hazardous liquids or of liquefied or compressed gases in sealed containers would not normally be considered hazardous unless subject to other hazardous conditions also.

Electrical conduits and their associated enclosures separated from process fluids by a single seal or barrier shall be classed as Division 2 locations if the outside of conduit and enclosures is a nonhazardous area.

**500-5. Class II Locations.** Class II locations are those which are hazardous because of the presence of combustible dust. Class II locations shall include the following:

**(a) Class II, Division 1.** Locations (1) in which combustible dust is or may be in suspension in the air continuously, intermittently, or periodically under normal operating conditions, in quantities sufficient to produce explosive or ignitable mixtures, (2) where mechanical failure or abnormal operation of machinery or equipment might cause such mixtures to be produced, and might also provide a source of ignition through simultaneous failure of electrical equipment, operation of protection devices, or from other causes, or (3) in which dusts of an electrically conducting nature may be present.

This classification usually includes the working areas of grain handling and storage plants; rooms containing grinders or pulverizers, cleaners, graders, scalpers, open conveyors or spouts, open bins or hoppers, mixers or blenders, automatic or hopper scales, packing machinery, elevator heads and boots, stock distributors, dust and stock collectors (except all-metal collectors vented to the outside), and all similar dust producing machinery and equipment in grain processing plants, starch plants, sugar pulverizing plants, malting plants, hay grinding plants, and other occupancies of similar nature; coal pulverizing plants (except where the pulverizing equipment is essentially dust-tight); all working areas where metal dusts and powders are produced, processed, handled, packed or stored (except in tight containers); and all other similar locations where combustible dust may, under normal operating conditions, be present in the air in quantities sufficient to produce explosive or ignitable mixtures.

Combustible dusts which are electrically nonconducting include dusts produced in the handling and processing of grain and grain products, pulverized sugar and cocoa, dried egg and milk powders, pulverized spices, starch and pastes, potato and woodflour, oil meal from beans and seed, dried hay, and other organic materials which may produce combustible dusts when processed or handled. Electrically conducting nonmetallic dusts include dusts from pulverized coal, coke and charcoal. Dusts containing magnesium or aluminum are particularly hazardous and every precaution must be taken to avoid ignition and explosion.

**(b) Class II, Division 2.** Locations in which combustible dust will not normally be in suspension in the air, or will not be likely to be thrown into suspension by the normal operation of equipment or apparatus, in quantities sufficient to produce explosive or ignitable mixtures, but (1) where deposits or accumulations of such dust may be sufficient to interfere with the safe dissipation of heat from electrical equipment or apparatus, or (2) where such deposits or accumulations of dust on, in, or in the vicinity of electrical equipment might be ignited by arcs, sparks or burning material from such equipment.

Locations where dangerous concentrations of suspended dust would not be likely, but where dust accumulations might form on, or in the vicinity of electrical equipment, would include rooms and areas containing only closed spouting and conveyors, closed bins or hoppers, or machines and equipment from which appreciable quantities of dust would escape only under abnormal operating conditions; rooms or areas adjacent to locations described in Section 500-5(a), and into which explosive or ignitable concentrations of suspended dust might be communicated only under abnormal operating conditions; rooms or areas where the formation of explosive or ignitable concentrations of suspended dust is prevented by the operation of effective dust control equipment; warehouses and shipping rooms where dust producing materials are stored or handled only in bags or containers; and other similar locations.

**500-6. Class III Locations.** Class III locations are those which are hazardous because of the presence of easily ignitable fibers or flyings, but in which such fibers or flyings are not likely to be in suspension in air in quantities sufficient to produce ignitable mixtures. Class III locations shall include the following:

**(a) Class III, Division 1.** Locations in which easily ignitable fibers or materials producing combustible flyings are handled, manufactured or used.

Such locations usually include some parts of rayon, cotton and other textile mills; combustible fiber manufacturing and processing plants; cotton gins and cotton-seed mills; flax processing plants; clothing manufacturing plants; woodworking plants; and establishments and industries involving similar hazardous processes or conditions.

Easily ignitable fibers and flyings include rayon, cotton (including cotton linters and cotton waste), sisal or henequen, isle, jute, hemp, tow, cocoa fiber, oakum, baled waste kapok, Spanish moss, excelsior and other materials of similar nature.

**(b) Class III, Division 2.** Locations in which easily ignitable fibers are stored or handled (except in process of manufacture).



## ARTICLE 501 — CLASS I INSTALLATIONS — HAZARDOUS LOCATIONS

**501-1. General.** The general rules of this Code shall apply to the installation of electrical wiring and equipment in locations classified as Class I under Section 500-4 except as modified by this Article.

**501-2. Transformers and Capacitors.** The installation of transformers and capacitors shall conform to the following:

(a) **Class I, Division 1.** In Class I, Division 1 locations, transformers and capacitors shall conform to the following:

(1) **Containing a Liquid That Will Burn.** Transformers and capacitors containing a liquid that will burn shall be installed only in approved vaults, which shall conform to Sections 450-41 through 450-48, and in addition, (1) there shall be no door or other communicating opening between the vault and the hazardous area, (2) ample ventilation shall be provided for the continuous removal of hazardous gases or vapor, (3) vent openings or ducts shall lead to a safe location outside of buildings, and (4) vent ducts and openings shall be of sufficient area to relieve explosion pressures within the vault, and all portions of vent ducts within the buildings shall be of reinforced concrete construction.

(2) **Not Containing a Liquid That Will Burn.** Transformers and capacitors which do not contain a liquid that will burn shall (1) be installed in vaults conforming to the requirements of Section 501-2(a) (1), or (2) be approved for Class I locations (explosion-proof).

(b) **Class I, Division 2.** In Class I, Division 2 locations, transformers and capacitors shall conform to Sections 450-21 through 450-25.

**501-3. Meters, Instruments and Relays.** The installation of meters, instruments and relays shall conform to the following:

(a) **Class I, Division 1.** In Class I, Division 1 location, meters, instruments and relays, including kilowatt-hour meters, instrument transformers and resistors, rectifiers and thermionic tubes, shall be provided with enclosures approved for Class I locations.

(b) **Class I, Division 2.** In Class I, Division 2 locations, meters, instruments and relays shall conform to the following:

(1) **Contacts.** Switches and circuit breakers, and make-and-break contacts of pushbuttons, relays, and alarm bells or horns, shall have enclosures approved for Class I locations, unless general-purpose enclosures are provided, and current-interrupting contacts are (1) immersed in oil, (2) enclosed within a chamber hermetically sealed against the entrance of gases or vapors, or (3) in circuits which under normal conditions do not release sufficient energy to ignite a specific hazardous atmospheric mixture.

(2) **Resistors and Similar Equipment.** Resistors, resistance devices, thermionic tubes, and rectifiers, which are used in or in connection

(501-3(b-2) continued)

with meters, instruments and relays, shall conform to Section 501-3(a), except that enclosures may be of general-purpose type when such equipment is without make-and-break or sliding contacts (other than as provided in Section 501-3(b)(1)) and when the maximum operating temperature of any exposed surface will not exceed 80 percent of the ignition temperature in degrees Celsius of the gas or vapor involved as determined by ASTM test procedure (Designation D2155-66).

**(3) Without Make-or-Break Contacts.** Transformer windings, impedance coils, solenoids and other windings which do not incorporate sliding or make-and-break contacts shall be provided with enclosures which may be of the general-purpose type.

**(4) General-Purpose Assemblies.** Where an assembly is made up of components for which general-purpose enclosures are acceptable under Sections 501-3(b)(1), (b)(2), and (b)(3), a single general-purpose enclosure is acceptable for the assembly. Where such an assembly includes any of the equipment described in Section 501-3(b)(2) the maximum obtainable surface temperature of any component of the assembly shall be clearly and permanently indicated on the outside of the enclosure.

**(5) Fuses.** Where general-purpose enclosures are permitted under Sections 501-3(b)(1), (b)(2), (b)(3) and (b)(4), fuses for over-current protection of the instrument circuits may be mounted in general-purpose enclosures provided such fuses do not exceed 3-ampere rating at 120 volts and provided each such fuse is preceded by a switch conforming to Section 501-3(b)(1).

**(6) Connections.** To facilitate replacements, process control instruments may be connected through flexible cord, attachment plug and receptacle, provided:

- (1) a switch conforming to Section 501-3(b)(1) is provided so that the plug is not depended on to interrupt current, and
- (2) the current does not exceed 3 amperes at 120 volts, and
- (3) the power-supply cord does not exceed 3 feet, is of a type approved for extra-hard usage or for hard usage if protected by location and is supplied through a plug-cap and receptacle of the locking- and grounding-type, and
- (4) only necessary receptacles are provided, and
- (5) the receptacle carries a label warning against unplugging under load.

**501-4. Wiring Methods.** Wiring methods shall conform to the following:

**(a) Class I, Division 1.** In Class I, Division 1 locations, threaded rigid metal conduit or Type MI cable with termination fittings approved for the location shall be the wiring method employed. All boxes, fittings, and joints shall be threaded for connection to conduit or cable terminations, and shall be explosion-proof. Threaded joints shall be made up with at least 5 threads fully engaged. Type MI cable shall be installed and supported in a manner to avoid tensile stress at the termination fittings. Where necessary to employ flexible connections, as at motor terminals, flexible fittings approved for Class I locations (explosion-proof) shall be used.

**(b) Class 1, Division 2.** In Class 1, Division 2 locations, threaded rigid metal conduit or Type MI, MC, ALS or SNM cable with approved termination fittings shall be the wiring method employed. Type MI, MC, ALS or SNM cable shall be installed in a manner to avoid tensile stress at the termination fittings. Boxes, fittings and joints need not be explosion-proof except as required by Sections 501-5(b)(1) and (b)(2). Where provision must be made for limited flexibility, as at motor terminals, flexible metal fittings, flexible metal conduit with approved fittings, liquidtight flexible metal conduit with approved fittings, or flexible cord approved for extra-hard usage and provided with approved bushed fittings shall be used. An additional conductor for grounding shall be included in the flexible cord unless other acceptable means of grounding are provided.

**501-5. Sealing and Drainage.** Seals are provided in conduit and cable systems to prevent the passage of gases, vapors or flames from one portion of the electrical installation to another through the conduit. Such communication through Type MI cable is inherently prevented by construction of the cable, but sealing compound is used in cable termination fittings to exclude moisture and other fluids from the cable insulation, and shall be of a type approved for the conditions of use. Seals in conduit and cable systems shall conform to the following:

**(a) Class 1, Division 1.** In Class 1, Division 1 locations, seals shall be located as follows:

**(1)** In each conduit run entering an enclosure for switches, circuit breakers, fuses, relays, resistors or other apparatus which may produce arcs, sparks or high temperatures. Seals shall be placed as close as practicable and in no case more than 18 inches from such enclosures. There shall be no junction box or similar enclosure in the conduit run between the sealing fitting and the apparatus enclosure.

**(2)** In each conduit run of 2-inch size or larger entering the enclosure or fitting housing terminals, splices or taps, and within 18 inches of such enclosure or fitting.

See notes under Group B in Section 500-2.

Where two or more enclosures for which seals are required under Sections 501-5(a-1, 2) are connected by nipples or by runs of conduit not more than 36 inches long, a single seal in each such nipple connection or run of conduit would be sufficient if located not more than 18 inches from either enclosure. Conduit fittings approved for Class 1 locations (explosion-proof) and similar to the "L," "T" or "Cross" type would not usually be classed as enclosures when not larger than the trade size of the conduit.

**(3)** In each conduit run leaving the Class 1, Division 1 hazardous area. The sealing fitting may be located on either side of the boundary of such hazardous area, but shall be so designed and installed that any gases or vapors which may enter the conduit system, within the Division 1 hazardous area, will not enter or be communicated to the conduit beyond the seal. There shall be no union, coupling, box or fitting in the conduit between the sealing fitting and the point at which the conduit leaves the Division 1 hazardous area.

*Exception: Rigid unbroken conduit which passes completely through a Class 1, Division 1 area with no fittings 12 inches beyond each*

(501-5(a-3) continued)

*boundary, providing that the termination points of the unbroken conduit are in nonhazardous areas, need not be sealed.*

**(b) Class I, Division 2.** In Class I, Division 2 locations, seals shall be located as follows:

(1) For connections to enclosures which are required to be approved for Class I locations, seals shall be provided in conformance to Sections 501-5(a)(1) and (a)(2). All portions of the conduit run or nipple between the seal and such enclosure shall conform to Section 501-4(a).

(2) In each conduit run passing from the Class I, Division 2 hazardous area into a nonhazardous area. The sealing fitting may be located on either side of the boundary of such hazardous area, but shall be so designed and installed that any gases or vapors which may enter the conduit system, within the Division 2 hazardous area, will not enter or be communicated to the conduit beyond the seal. Rigid conduit shall be used between the sealing fitting and the point at which the conduit leaves the hazardous area, and a threaded connection shall be used at the sealing fitting. There shall be no union, coupling, box or fitting in the conduit between the sealing fitting and the point at which the conduit leaves the hazardous area.

*Exception: Rigid unbroken conduit which passes completely through a Class I, Division 2 area with no fittings 12 inches beyond each boundary, providing that the termination points of the unbroken conduit are in nonhazardous areas, need not be sealed.*

**(c) Class I, Divisions 1 and 2.** Where seals are required, they shall conform to the following:

(1) **Fittings.** Enclosures for connections or for equipment shall be provided with approved integral means for sealing, or sealing fittings approved for Class I locations shall be used. Sealing fittings shall be accessible.

(2) **Compound.** Sealing compound shall be approved for the purpose, shall not be affected by the surrounding atmosphere or liquids, and shall not have a melting point of less than 93° C (200°F).

(3) **Thickness of Compound.** In the completed seal, the minimum thickness of the sealing compound shall be not less than the trade size of the conduit, and in no case less than 5/8 inch.

(4) **Splices and Taps.** Splices and taps shall not be made in fittings intended only for sealing with compound, nor shall other fittings in which splices or taps are made be filled with compound.

(5) **Assemblies.** In an assembly where equipment which may produce arcs, sparks or high temperatures is located in a compartment separate from the compartment containing splices or taps, and an integral seal is provided where conductors pass from one compartment to the other, the entire assembly shall be approved for Class I locations. Seals in conduit connections to the compartment containing splices or taps shall be provided in Class I, Division 1 locations where required by Section 501-5(a)(2).

**(d) Drainage.**

**(1) Control Equipment.** Where there is probability that liquid or other condensed vapor may be trapped within enclosures for control equipment or at any point in the raceway system, approved means shall be provided to prevent accumulation or to permit periodic draining of such liquid or condensed vapor.

**(2) Motors and Generators.** Where the authority having jurisdiction judges that there is probability that liquid or condensed vapor may accumulate within motors or generators, joints and conduit systems shall be arranged to minimize entrance of liquid. If means to prevent accumulation or to permit periodic draining are judged necessary, such means shall be provided at the time of manufacture, and shall be deemed an integral part of the machine.

**(3) Canned Pumps, Etc.** Canned pumps, process connections for flow, pressure or analysis measurement, etc., frequently depend upon a single seal diaphragm or tube to prevent process fluids from entering the electrical conduit system. An additional approved seal or barrier shall be provided with an adequate drain between the seals in such a manner that leaks would be obvious.

See also the last paragraph of footnote in Section 500-4 (b).

**501-6. Switches, Circuit Breakers, Motor Controllers and Fuses.** Switches, circuit breakers, motor controllers and fuses shall conform to the following:

**(a) Class I, Division 1.** In Class I, Division 1 locations, switches, circuit breakers, motor controllers and fuses, including push buttons, relays and similar devices, shall be provided with enclosures, and the enclosure in each case together with the enclosed apparatus shall be approved as a complete assembly for use in Class I locations.

**(b) Class I, Division 2.** Switches, circuit breakers, motor controllers and fuses in Class I, Division 2 locations shall conform to the following:

**(1) Type Required.** Circuit breakers, motor controllers and switches intended to interrupt current in the normal performance of the function for which they are installed shall be provided with enclosures approved for Class I locations, unless general-purpose enclosures are provided and (1) the interruption of current occurs within a chamber hermetically sealed against the entrance of gases and vapors, or (2) the current-interrupting contacts are oil-immersed and the device is approved for locations of this class and division.

This includes service and branch-circuit switches and circuit breakers; motor controllers, including pushbuttons, pilot switches, relays and motor-overload protective devices; and switches and circuit breakers for the control of lighting and appliance circuits. Oil-immersed circuit breakers and controllers of ordinary general-use type may not confine completely the arc produced in the interruption of heavy overloads, and specific approval for locations of this class and division is therefore necessary.

**(2) Isolating Switches.** Enclosures for disconnecting and isolating switches without fuses and which are not intended to interrupt current may be of general-purpose type.

(501-6(b) continued)

**(3) Fuses.** For the protection of motors, appliances and lamps, except as provided in Section 501-6(b)(4): (1) standard plug or cartridge fuses may be used provided they are placed within enclosures approved for the purpose and for the location, or (2) fuses of a type in which the operating element is immersed in oil or other approved liquid, or is enclosed within a chamber hermetically sealed against the entrance of gases and vapors may be used provided they are approved for the purpose and are placed within general-purpose enclosures.

**(4) Fuses or Circuit Breakers for Overcurrent Protection.** When not more than 10 sets of approved enclosed fuses, or not more than 10 circuit breakers which are not intended to be used as switches for the interruption of current, are installed for branch or feeder circuit protection in any one room, area or section of this class and division, the enclosures for such fuses or circuit breakers may be of general-purpose type, provided the fuses or circuit breakers are for the protection of circuits or feeders supplying lamps in fixed positions only.

A set of fuses is construed to mean a group containing as many fuses as are required to perform a single protective function in a circuit. For example, a group of 3 fuses protecting an ungrounded 3-phase circuit, and a single fuse protecting the ungrounded conductor of an identified 2-wire single-phase circuit, would each be considered as a set of fuses. Fuses conforming to Section 501-6(b)(3) need not be included in counting the 10 sets of fuses permitted in general-purpose enclosures.

**501-7. Control Transformers and Resistors.** Transformers, impedance coils and resistors used as or in conjunction with control equipment for motors, generators and appliances shall conform to the following:

**(a) Class I, Division 1.** In Class I, Division 1 locations, transformers, impedance coils and resistors, together with any switching mechanism associated with them, shall be provided with enclosures approved for Class I locations (explosion-proof).

**(b) Class I, Division 2.** In Class I, Division 2 locations, control transformers and resistors shall conform to the following:

**(1) Switching Mechanisms.** Switching mechanisms used in conjunction with transformers, impedance coils and resistors shall conform to Section 501-6(b).

**(2) Coils and Windings.** Enclosures for windings of transformers, solenoids or impedance coils may be of the general-purpose types.

**(3) Resistors.** Resistors shall be provided with enclosures and the assembly shall be approved for Class I locations, unless resistance is nonvariable and maximum operating temperature, in degrees Celsius, will not exceed 80 percent of the ignition temperature of the gas or vapor involved as determined by ASTM test procedure (Designation D2155-66).

**501-8. Motors and Generators.** Motors and generators shall conform to the following:

**(a) Class I, Division 1.** In Class I, Division 1 locations, motors, generators and other rotating electrical machinery shall be: (1) approved for Class I locations (explosion-proof), or (2) of the totally enclosed type supplied with positive-pressure ventilation from a source

of clean air with discharge to a safe area, so arranged to prevent energizing of the machine until ventilation has been established and the enclosure has been purged with at least 10 volumes of air, and also arranged to automatically de-energize the equipment when the air supply fails, or (3) of the totally enclosed inert-gas-filled type supplied with a suitable reliable source of inert gas for pressuring the enclosure, with devices provided to insure a positive pressure in the enclosure and arranged to automatically de-energize the equipment when the gas supply fails. Totally enclosed motors of types (2) or (3) shall have no external surface with an operating temperature in degrees Celsius in excess of 80 percent of the ignition temperature of the gas or vapor involved, as determined by ASTM test procedure (Designation: D-2155-66). Appropriate devices shall also be provided to detect any increase in temperature of the motor beyond design limits and automatically de-energize the equipment. Auxiliary equipment shall be of a type approved for the location in which it is installed.

**(b) Class I, Division 2.** In Class I, Division 2 locations, motors, generators and other rotating electrical machinery in which are employed sliding contacts, centrifugal or other types of switching mechanism (including motor overcurrent devices), or integral resistance devices, either while starting or while running, shall be approved for Class I locations (explosion-proof), unless such sliding contacts, switching mechanisms and resistance devices are provided with enclosures approved for such locations.

This rule does not prohibit installation of open or nonexplosion-proof enclosed motors, such as squirrel-cage induction motors, without brushes, switching mechanism, etc., in Class I, Division 2 locations.

**501-9. Lighting Fixtures.** Lamps shall be installed in fixtures which shall conform to the following:

**(a) Class I, Division 1.** In Class I, Division 1 locations, lighting fixtures shall conform to the following:

**(1) Approved Fixtures.** Each fixture shall be approved as a complete assembly for locations of this class, and shall be clearly marked to indicate the maximum wattage of lamps for which it is approved. Fixtures intended for portable use shall be specifically approved as a complete assembly for that use.

**(2) Physical Damage.** Each fixture shall be protected against physical damage by a suitable guard or by location.

**(3) Pendant Fixtures.** Pendant fixtures shall be suspended by and supplied through threaded rigid conduit stems and threaded joints shall be provided with set-screws or other effective means to prevent loosening. For stems longer than 12 inches, permanent and effective bracing against lateral displacement shall be provided at a level not more than 12 inches above the lower end of the stem, or flexibility in the form of a fitting or flexible connector approved for the purpose and for the location shall be provided not more than 12 inches from the point of attachment to the supporting box or fitting.

**(4) Supports.** Boxes, box assemblies or fittings used for the support of lighting fixtures shall be approved for the purpose and for Class I locations.

**(b) Class I, Division 2.** In Class I, Division 2 locations, lighting fixtures shall conform to the following:

**(1) Portable Lamps.** Portable lamps shall conform to Section 501-9(a)(1).

**(2) Fixed Lighting.** Lighting fixtures for fixed lighting shall be protected from physical damage by suitable guards or by location. Where there is danger that falling sparks or hot metal from lamps or fixtures might ignite localized concentrations of flammable vapors or gases, suitable enclosures or other effective protective means shall be provided. Where lamps are of a size or type which may, under normal operating conditions, reach surface temperatures exceeding 80 percent of the ignition temperature in degrees Celsius of the gas or vapor involved, as determined by ASTM test procedure (Designation D-2155-66), fixtures shall conform to Section 501-9(a)(1).

**(3) Pendant Fixtures.** Pendant fixtures shall be suspended by threaded rigid conduit stems or by other approved means. For rigid stems longer than 12 inches, permanent and effective bracing against lateral displacement shall be provided at a level not more than 12 inches above the lower end of the stem, or flexibility in the form of a fitting or flexible connector approved for the purpose shall be provided not more than 12 inches from the point of attachment to the supporting box or fitting.

**(4) Supports.** Boxes, box assemblies, or fittings used for the support of lighting fixtures shall be approved for the purpose.

**(5) Switches.** Switches which are a part of an assembled fixture or of an individual lampholder shall conform to the requirements of Section 501-6(b)(1).

**(6) Starting Equipment.** Starting and control equipment for electric-discharge lamps shall conform to the requirements of Section 501-7(b).

**501-10. Utilization Equipment, Fixed and Portable.** Utilization equipment, fixed and portable, shall conform to the following:

**(a) Class I, Division 1.** In Class I, Division 1 locations, utilization equipment, including electrically-heated and motor-driven equipment shall be approved for Class I locations.

**(b) Class I, Division 2.** In Class I, Division 2 locations, utilization equipment, fixed and portable, shall conform to the following:

**(1) Heaters.** Electrically heated utilization equipment shall be approved for Class I locations.

**(2) Motors.** Motors of motor-driven utilization equipment shall conform to Section 501-8(b).

**(3) Switches, Circuit Breakers, and Fuses.** Switches, circuit breakers and fuses shall conform to Section 501-6(b).

**501-11. Flexible Cords, Class I, Divisions 1 and 2.** A flexible cord may be used only for connection between a portable lamp or other portable utilization equipment and the fixed portion of its supply circuit and where used shall: (1) be of a type approved for extra-hard



usage, (2) contain, in addition to the conductors of the circuit, a grounding conductor conforming to Section 400-14, (3) be connected to terminals or to supply conductors in an approved manner, (4) be supported by clamps or by other suitable means in such a manner that there will be no tension on the terminal connections, and (5) suitable seals shall be provided where the flexible cord enters boxes, fittings or enclosures of explosion-proof type.

Refer to Section 501-13 when flexible cords are exposed to liquids having a deleterious effect on the conductor insulation.

**501-12. Receptacles and Attachment Plugs, Class I, Divisions 1 and 2.**

Receptacles and attachment plugs shall be of the type providing for connection to the grounding conductor of the flexible cord, and shall be approved for Class I locations, except as provided in Section 501-3(b)(6).

**501-13. Conductor Insulation Class I, Divisions 1 and 2.** Where condensed vapors or liquids may collect on or come in contact with the insulation on conductors, such insulation shall be of a type approved for use under such conditions or the insulation shall be protected by a sheath of lead or by other approved means.

**501-14. Signal, Alarm, Remote-Control and Communication Systems.**

Signal, alarm, remote-control and communication systems shall conform to the following:

(a) **Class I, Division 1.** In Class I, Division 1 locations, all apparatus and equipment of signaling, alarm, remote-control and communication systems, irrespective of voltage, shall be approved for Class I locations, and all wiring shall conform to Sections 501-4(a) and 501-5(a) and (c).

(b) **Class I, Division 2.** In Class I, Division 2 locations, signal, alarm, remote-control and communication systems shall conform to the following:

(1) **Contacts.** Switches and circuit breakers, and make-and-break contacts of pushbuttons, relays, and alarm bells or horns, shall have enclosures approved for Class I locations, unless general-purpose enclosures are provided and current interrupting contacts are: (1) immersed in oil, or (2) enclosed within a chamber hermetically sealed against the entrance of gases or vapors, or (3) in circuits which under normal conditions do not release sufficient energy to ignite a specific hazardous atmospheric mixture.

(2) **Resistors and Similar Equipment.** Resistors, resistance devices, thermionic tubes and rectifiers shall conform to Section 501-3(b)(2).

(3) **Protectors.** Enclosures which may be of general-purpose type shall be provided for lightning protective devices and for fuses.

(4) All wiring shall conform to Sections 501-4(b) and 501-5(b) and (c).

**501-15. Live Parts, Class I, Divisions 1 and 2.** There shall be no exposed live parts.

**501-16. Grounding, Class I, Divisions 1 and 2.** Wiring and equipment shall be grounded in conformity with the following:

(501-16 continued)

**(a) Exposed Parts.** The exposed noncurrent-carrying metal parts of equipment such as the frames or metal exteriors of motors, fixed or portable lamps or other utilization equipment, lighting fixtures, cabinets, cases, and conduit, shall be grounded as specified in Article 250.

**(b) Bonding.** The locknut-bushing and double-locknut types of contacts shall not be depended upon for bonding purposes, but bonding jumpers with proper fittings or other approved means shall be used. Such means of bonding shall apply to all intervening raceways, fittings, boxes, enclosures, etc., between hazardous areas and the point of grounding for service equipment. Where flexible conduit is used as permitted in Section 501-4(b), bonding jumpers with proper fittings shall be provided around such conduit.

**(c) Lightning Protection.** Each ungrounded service conductor of a wiring system in a Class I location, when supplied from an overhead line in an area where lightning disturbances are prevalent, shall be protected by a lightning protective device of proper type. Lightning protective devices shall be connected to the service conductors on the supply side of the service disconnecting means, and shall be bonded to the raceway system at the service entrance.

Also refer to Section 502-3.

**(d) Grounded Service Conductor Bonded to Raceway.** Wiring in a Class I location, when supplied from a grounded alternating-current supply system in which a grounded conductor is a part of the service, shall have the grounded service conductor bonded to the raceway system and to the grounding conductor for the raceway system. The bonding connection to the grounded service conductor shall be made on the supply side of the service disconnecting means.

**(e) Transformer Ground Bonded to Raceway.** Wiring in a Class I location, when supplied from a grounded alternating current supply system in which no grounded conductor is a part of the service, shall be provided with a metallic connection between the supply system ground and the raceway system at the service entrance. The metallic connection shall have an ampacity not less than 1/5 that of the service conductors, and shall in no case be smaller than No. 10 when of soft copper, or No. 12 when of medium- or hard-drawn copper.

**(f) Multiple Grounds.** Where, in the application of Section 250-21, it is necessary to abandon one or more grounding connections to avoid objectionable passage of current over the grounding conductors, the connection required in Sections 501-16(d) and (e) shall not be abandoned while any other grounding connection remains connected to the supply system.

## ARTICLE 502 — CLASS II INSTALLATIONS — HAZARDOUS LOCATIONS

**502-1. General.** The general rules of this Code shall apply to the installation of electrical wiring and apparatus in locations classified as Class II under Section 500-5 except as modified by this Article.

“Dust-ignition-proof,” as used in this Article, shall mean enclosed in a manner which will exclude ignitable amounts of dusts or amounts which might affect performance or rating and which, when installation and protection are in conformance with this Code, will not permit arcs, sparks or heat otherwise generated or liberated inside of the enclosure, to cause ignition of exterior accumulations or atmospheric suspensions of a specified dust on or in the vicinity of the enclosure.

Equipment installed in Class II locations shall be able to function at full rating without developing surface temperatures high enough to cause excessive dehydration or gradual carbonization of any organic dust deposits that may occur. Dust which is carbonized or is excessively dry is highly susceptible to spontaneous ignition. In general, maximum surface temperatures under actual operating conditions shall not exceed 165°C (329°F) for equipment which is not subject to overloading, and 120°C (248°F) for equipment such as motors, power transformers, etc., which may be overloaded.

Equipment and wiring of the type defined in Article 100 as explosion-proof is not required in Class II locations, and may not be acceptable unless approved for such locations.

**502-2. Transformers and Capacitors.** The installation of transformers and capacitors shall conform to the following:

**(a) Class II, Division 1.** In Class II, Division 1 locations, transformers and capacitors shall conform to the following:

**(1) Containing a Liquid That Will Burn.** Transformers and capacitors containing a liquid that will burn shall be installed only in approved vaults conforming to Sections 450-41 through 450-48, and in addition (1) door or other openings communicating with the hazardous area shall have self-closing fire doors on both sides of the wall, and the doors shall be carefully fitted and provided with suitable seals (such as weather stripping) to minimize the entrance of dust into the vault, (2) vent openings and ducts shall communicate only with the outside air, and (3) suitable pressure-relief openings communicating with the outside air shall be provided.

**(2) Not Containing a Liquid That Will Burn.** Transformers and capacitors which do not contain a liquid that will burn shall: (1) be installed in vaults conforming to Sections 450-41 through 450-48, or (2) be approved as a complete assembly including terminal connections for Class II locations.

**(3) Metal Dusts.** No transformer or capacitor shall be installed in a location where dust from magnesium, aluminum, aluminum bronze

(502-2(a-3) continued)

powders, or other metals of similarly hazardous characteristics may be present.

**(b) Class II, Division 2.** In Class II, Division 2 locations, transformers and capacitors shall conform to the following:

**(1) Containing a Liquid That Will Burn.** Transformers and capacitors containing a liquid that will burn shall be installed in vaults conforming to Sections 450-41 through 450-48.

**(2) Containing Askarel.** Transformers containing askarel and rated in excess of 25 kVA shall: (1) be provided with pressure-relief vents, (2) be provided with means for absorbing any gases generated by arcing inside the case, or the pressure-relief vents shall be connected to a chimney or flue which will carry such gases outside the building and (3) have an air space of not less than 6 inches between the transformer cases and any adjacent combustible material.

**(3) Dry-Type Transformers.** Dry-type transformers shall be installed in vaults or shall: (1) have their windings and terminal connections enclosed in tight metal housings without ventilating or other openings, and (2) operate at voltages not exceeding 600 volts.

**502-3. Surge Protection, Class II, Divisions 1 and 2.** In geographical locations where lightning disturbances are prevalent, wiring systems in Class II locations shall, when supplied from overhead lines, be suitably protected against high-voltage surges. This protection shall include suitable lightning protective devices, interconnection of all grounds, and surge-protective capacitors.

Interconnection of all grounds shall include grounds for primary and secondary lightning protective devices, secondary system grounds if any, and grounds of conduit and equipment of the interior wiring system. For ungrounded secondary systems, secondary lightning protective devices may be provided both at the service and at the point where the secondary system receives its supply, and the intervening secondary conductors may be accepted as the metallic connection between the secondary protective devices, provided grounds for the primary and secondary devices are metallically interconnected at the supply end of the secondary system and the secondary devices are grounded to the raceway system at the load end of the secondary system.

Surge-protective capacitors shall be of a type especially designed for the duty, shall be connected to each ungrounded service conductor, and shall be grounded to the interior conduit system. Capacitors shall be protected by 30-ampere fuses of suitable type and voltage rating, or by automatic circuit breakers of suitable type and rating and shall be connected to the supply conductors on the supply side of the service disconnecting means.

**502-4. Wiring Methods.** Wiring methods shall conform to the following:

**(a) Class II, Division 1.** In Class II, Division 1 locations, threaded rigid metal conduit or Type MI cable with termination fittings approved for the location shall be the wiring method employed. Type MI cable shall be installed and supported in a manner to avoid tensile stress at the termination fittings.

**(1) Fittings and Boxes.** Fittings and boxes shall be provided with threaded bosses for connection to conduit or cable terminations, shall have close fitting covers, and shall have no openings (such as holes for attachment-screws) through which dust might enter, or through which sparks or burning material might escape. Fittings and boxes in which taps, joints or terminal connections are made, or which are used in locations where dusts are of an electrically conducting nature shall be dust-ignition-proof and approved for Class II locations.

**(2) Flexible Connections.** Where necessary to employ flexible connections, dust-tight flexible connectors, flexible metal conduit with approved fittings, liquidtight flexible metal conduit with approved fittings, or flexible cord approved for extra-hard usage and provided with bushed fittings shall be used, except that where dusts are of an electrically conducting nature, flexible metal conduit shall not be used, and flexible cords shall be provided with dust-tight seals at both ends. An additional conductor for grounding shall be provided in the flexible cord unless other acceptable means of grounding is provided. Where flexible connections are subject to oil or other corrosive conditions, the insulation of the conductors shall be of a type approved for the condition or shall be protected by means of a suitable sheath.

**(b) Class II, Division 2.** In Class II, Division 2 locations, rigid metal conduit, electrical metallic tubing, or Type MI, MC, ALS or SNM cable with approved termination fittings or dust-tight wireways shall be the wiring method employed.

**(1) Wireways, Fittings and Boxes.** Wireways, fittings and boxes in which taps, joints or terminal connections are made, shall be designed to minimize the entrance of dust, and: (1) shall be provided with telescoping or close fitting covers, or other effective means to prevent the escape of sparks or burning material, and (2) shall have no openings (such as holes for attachment screws) through which, after installation, sparks or burning material might escape, or through which adjacent combustible material might be ignited.

**(2) Flexible Connections.** Where flexible connections are necessary the provisions of Section 502-4(a)(2) shall apply.

**502-5. Sealing, Class II, Divisions 1 and 2.** Where a raceway provides communication between an enclosure which is required to be dust-ignition-proof and one which is not, suitable means shall be provided to prevent the entrance of dust into the dust-ignition-proof enclosure through the raceway. This means may be: (1) a permanent and effective seal, (2) a horizontal section not less than 10 feet long in the raceway, or (3) a vertical section of raceway not less than 5 feet long and extending downward from the dust-ignition-proof enclosure. Sealing fittings shall be accessible.

**502-6. Switches, Circuit Breakers, Motor Controllers, and Fuses.** Switches, circuit breakers, motor controllers and fuses shall conform to the following:

**(a) Class II, Division 1.** In Class II, Division 1 locations, switches, circuit breakers, motor controllers and fuses shall conform to the following:

**(1) Type Required.** Switches, circuit breakers, motor controllers and fuses, including push buttons, relays and similar devices, which are intended to interrupt current in the normal performance of the function for which they are installed, or which are installed where dusts of an electrically conducting nature may be present, shall be provided with dust-ignition-proof enclosures which, together with the enclosed apparatus in each case, shall be approved as a complete assembly for Class II locations.

This includes service and branch-circuit fuses, switches and circuit breakers, motor controllers (including push buttons, pilot switches, relays, and motor overload protective devices), and switches, fuses and circuit breakers for the control and protection of lighting and appliance circuits.

**(2) Isolating Switches.** Disconnecting and isolating switches containing no fuses and not intended to interrupt current, and which are not installed where dusts may be of an electrically conducting nature, shall be provided with tight metal enclosures which shall be designed to minimize the entrance of dust, and which shall: (1) be equipped with telescoping or close fitting covers, or with other effective means to prevent the escape of sparks or burning material, and (2) have no openings (such as holes for attachment screws) through which, after installation, sparks or burning material might escape, or through which exterior accumulations of dust or adjacent combustible material might be ignited.

**(3) Metal Dusts.** In locations where dust from magnesium, aluminum, aluminum bronze powders, or other metals of similarly hazardous characteristics may be present, fuses, switches, motor controllers and circuit breakers shall have enclosures specifically approved for such locations.

**(b) Class II, Division 2.** In Class II, Division 2 locations, enclosures for fuses, switches, circuit breakers and motor controllers including push buttons, relays and similar devices, shall conform to the requirements of Section 502-6(a)(2).

**502-7. Control Transformers and Resistors.** Transformers, solenoids, impedance coils and resistors used as or in conjunction with control equipment for motors, generators and appliances shall conform to the following:

**(a) Class II, Division 1.** In Class II, Division 1 locations, control transformers, solenoids, impedance coils and resistors, and any overcurrent devices or switching mechanisms associated with them shall have dust-ignition-proof enclosures approved for Class II locations. No control transformer, impedance coil or resistor shall be installed in a location where dust from magnesium, aluminum, aluminum bronze powders, or other metals of similarly hazardous characteristics may be present unless provided with an enclosure specifically approved for such locations.

**(b) Class II, Division 2.** In Class II, Division 2 locations, transformers and resistors shall conform to the following:

**(1) Switching Mechanisms.** Switching mechanisms (including overcurrent devices) associated with control transformers, solenoids,

impedance coils and resistors, shall be provided with enclosures conforming to Section 502-6(a)(2).

**(2) Coils and Windings.** Where not located in the same enclosure with switching mechanisms, control transformers, solenoids and impedance coils shall be provided with tight metal housings without ventilating openings.

**(3) Resistors.** Resistors and resistance devices shall have dust-ignition-proof enclosures approved for Class II locations, except that where the maximum normal operating temperature of the resistor will not exceed 120°C (248°F) nonadjustable resistors and resistors which are part of an automatically timed starting sequence may have enclosures conforming to Section 502-7(b)(2).

**502-8. Motors and Generators.** Motors and generators shall conform to the following:

**(a) Class II, Division 1.** In Class II, Division 1 locations, motors, generators and other rotating electrical machinery should be dust-ignition-proof or totally enclosed pipe-ventilated and shall be approved for Class II locations.

**(b) Class II, Division 2.** In Class II, Division 2 locations, motors, generators and other rotating electrical machinery shall be dust-ignition-proof or totally enclosed pipe-ventilated, for which maximum surface temperatures shall not exceed 120°C (248°F).

*Exception: If the authority having jurisdiction believes accumulations of nonconducting, nonabrasive dust will be moderate, and if machines can be easily reached for routine cleaning and maintenance, the following may be installed:*

*Standard open-type machines without sliding contacts, centrifugal or other types of switching mechanism (including motor overcurrent devices) or integral resistance devices.*

*Standard open-type machines with such contacts, switching mechanisms or resistance devices enclosed within tight metal housings without ventilating or other openings.*

*Self-cleaning textile motors of the squirrel-cage type.*

**502-9. Ventilating Piping.** Vent pipes for motors, generators or other rotating electrical machinery, or for enclosures for electrical apparatus or equipment, shall be of metal not lighter than No. 24 MSG, or of equally substantial noncombustible material, and shall: (1) lead directly to a source of clean air outside of buildings, (2) be screened at the outer ends to prevent the entrance of small animals or birds, (3) be protected against physical damage and against rusting or other corrosive influences. In addition, vent pipes shall conform to the following:

**(a) Class II, Division 1.** In Class II, Division 1 locations, vent pipes, including their connections to motors or to the dust-ignition-proof enclosures for other equipment or apparatus, shall be dust-tight throughout their length. For metal pipes, seams and joints shall be: (1) riveted (or bolted) and soldered, (2) welded, or (3) rendered dust-tight by some other equally effective means.

**(b) Class II, Division 2.** In Class II, Division 2 locations, vent pipes and their connections shall be sufficiently tight to prevent the entrance of appreciable quantities of dust into the ventilated equipment or enclosure, and to prevent the escape of sparks, flame or burning material which might ignite dust accumulations or combustible material in the vicinity. For metal pipes, lock seams and riveted or welded joints may be used, and tight-fitting slip joints may be used where some flexibility is necessary as at connections to motors.

**502-10. Utilization Equipment, Fixed and Portable.** Utilization equipment, fixed and portable, shall conform to the following:

**(a) Class II, Division 1.** In Class II, Division 1 locations, utilization equipment, including electrically heated and motor-driven equipment, shall be dust-ignition-proof approved for Class II locations. Where dust from magnesium, aluminum, aluminum bronze powders, or other metals of similarly hazardous characteristics may be present, such equipment shall be specifically approved for such locations.

**(b) Class II, Division 2.** In Class II, Division 2, locations, utilization equipment, fixed and portable, shall conform to the following:

**(1) Heaters.** Electrically heated utilization equipment shall be dust-ignition-proof approved for Class II locations.

**(2) Motors.** Motors of motor-driven utilization equipment shall conform to Section 502-8(b).

**(3) Switches, Circuit Breakers and Fuses.** Enclosures for switches, circuit breakers, and fuses shall conform to Section 502-6(a)(2).

**(4) Transformers, Impedance Coils and Resistors.** Transformers, solenoids, impedance coils and resistors shall conform to Section 502-7(b).

**502-11. Lighting Fixtures.** Lamps shall be installed in fixtures which shall conform to the following:

**(a) Class II, Division 1.** In Class II, Division 1 locations, lighting fixtures for fixed and portable lighting shall conform to the following:

**(1) Approved Fixtures.** Each fixture shall be dust-ignition-proof and approved for Class II locations, and shall be clearly marked to indicate the maximum wattage of the lamp for which it is approved. In locations where dust from magnesium, aluminum, aluminum bronze powders, or other metals of similarly hazardous characteristics may be present, fixtures for fixed or portable lighting, and all auxiliary equipment, shall be specifically approved for such locations.

**(2) Physical Damage.** Each fixture shall be protected against physical damage by a suitable guard or by location.

**(3) Pendant Fixtures.** Pendant fixtures shall be suspended by threaded rigid conduit stems or chains with approved fittings, or by other approved means. For rigid stems longer than 12 inches permanent and effective bracing against lateral displacement shall be provided at a level not more than 12 inches above the lower end of the stem, or flexibility in the form of a fitting or a flexible connector approved for



the purpose and for the location shall be provided not more than 12 inches from the point of attachment to the supporting box or fitting. Threaded joints shall be provided with set-screws or other effective means to prevent loosening. Where wiring between an outlet box or fitting and a pendant fixture is not enclosed in conduit, flexible cord approved for hard usage shall be used, and suitable seals shall be provided where the cord enters the fixture and the outlet box or fitting. Flexible cord shall not serve as the supporting means for a fixture.

**(4) Supports.** Boxes, box assemblies or fittings used for the support of lighting fixtures shall be approved for the purpose and for Class II locations.

**(b) Class II, Division 2.** In Class II, Division 2 locations, lighting fixtures shall conform to the following:

**(1) Portable Lamps.** Portable lamps shall be dust-ignition-proof and approved for Class II locations. They shall be clearly marked to indicate the maximum wattage of lamps for which they are approved.

**(2) Fixed Lighting.** Lighting fixtures for fixed lighting, when not of a type approved for Class II locations, shall provide enclosures for lamps and lampholders which shall be designed to minimize the deposit of dust on lamps and to prevent the escape of sparks, burning material or hot metal. Each fixture shall be clearly marked to indicate the maximum wattage of lamp which may be used without exceeding a maximum exposed surface temperature of 165°C (329°F) under normal conditions of use.

**(3) Physical Damage.** Lighting fixtures for fixed lighting shall be protected from physical damage by suitable guards or by location.

**(4) Pendant Fixtures.** Pendant fixtures shall be suspended by threaded rigid conduit stems or chains with approved fittings, or by other approved means. For rigid stems longer than 12 inches permanent and effective bracing against lateral displacement shall be provided at a level not more than 12 inches above the lower end of the stem, or flexibility in the form of a fitting or a flexible connector approved for the purpose shall be provided not more than 12 inches from the point of attachment to the supporting box or fitting. When wiring between an outlet box or fitting and a pendant fixture is not enclosed in conduit, flexible cord approved for hard usage shall be used. Flexible cord shall not serve as the supporting means for a fixture.

**(5) Supports.** Boxes, box assemblies and fittings used for the support of lighting fixtures shall be approved for that purpose.

**(6) Electric-Discharge Lamps.** Starting and control equipment for electric-discharge lamps shall conform to the requirement of Section 502-7(b).

**502-12. Flexible Cords, Class II, Divisions 1 and 2.** Flexible cords used in Class II locations shall: (1) be of a type approved for extra-hard usage, (2) contain, in addition to the conductors of the circuit, a grounding conductor conforming to Section 400-14, (3) be connected to terminals or to supply conductors in an approved manner, (4) be supported by clamps or by other suitable means in such a manner that there will be no tension on the terminal connections, and (5) be pro-

vided with suitable seals to prevent the entrance of dust where the flexible cord enters boxes or fittings which are required to be dust-ignition-proof.

### **502-13. Receptacles and Attachment Plugs.**

(a) **Class II, Division 1.** In Class II, Division 1 locations, receptacles and attachment plugs shall be of the type providing for connection to the grounding conductor of the flexible cord, and shall be dust-ignition-proof approved for Class II locations.

(b) **Class II, Division 2.** In Class II, Division 2 locations, receptacles and attachment plugs shall be of the type providing for connection to the grounding conductor of the flexible cord and shall be so designed that connection to the supply circuit cannot be made or broken while live parts are exposed.

**502-14. Signal, Alarm, Remote-Control, and Local Loud-Speaker Intercommunication Systems.** Signal, alarm, remote-control and local loud-speaker intercommunication systems shall conform to the following:

Refer to Article 800 for rules governing the installation of communication circuits as defined in Article 100.

(a) **Class II, Division 1.** In Class II, Division 1 locations, signal, alarm, remote-control and local loud-speaker intercommunication systems shall conform to the following:

(1) **Wiring Method.** Where accidental damage or breakdown of insulation might cause arcs, sparks or high temperatures, rigid metal conduit, electrical metallic tubing, or Type MI cable with approved termination fittings shall be the wiring method employed. For conduit or electrical metallic tubing, the number of conductors shall be limited only by the requirement that the cross-sectional area of all conductors shall not exceed 40 percent of the area of the raceway. Where limited flexibility is desirable or where exposure to physical damage is not severe, flexible cord approved for extra-hard usage may be used.

(2) **Contacts.** Switches, circuit breakers, relays, contactors and fuses which may interrupt other than voice currents, and current-breaking contacts for bells, horns, howlers, sirens and other devices in which sparks or arcs may be produced, shall be provided with enclosures approved for the location, unless current-breaking contacts are immersed in oil, or unless the interruption of current occurs within a chamber sealed against the entrance of dust, in which case enclosures may be of general-purpose type.

(3) **Resistors and Similar Equipment.** Resistors, transformers and choke coils which may carry other than voice currents, and rectifiers, thermionic tubes, and other heat generating equipment or apparatus shall be provided with dust-ignition-proof enclosures approved for Class II locations.

(4) **Rotating Machinery.** Motors, generators and other rotating electrical machinery shall conform to Section 502-8(a).

(5) **Electrical Conducting Dusts.** Where dusts are of an electrically conducting nature, all wiring and equipment shall be approved for Class II locations.

**(6) Metal Dusts.** Where dust from magnesium, aluminum, aluminum bronze powders, or other metals of similarly hazardous characteristics may be present, all apparatus and equipment shall be specifically approved for such conditions.

**(b) Class II, Division 2.** In Class II, Division 2 locations, signal, alarm, remote-control and local loudspeaker intercommunication systems shall conform to the following:

**(1) Contacts.** Enclosures shall conform to Section 502-14(a)(2) or contacts shall have tight metal enclosures designed to minimize the entrance of dust, and shall have telescoping or tight-fitting covers and no openings through which, after installation, sparks or burning material might escape.

**(2) Transformers and Similar Equipment.** The windings and terminal connections of transformers and choke coils shall be provided with tight metal enclosures without ventilating openings.

**(3) Resistors and Similar Equipment.** Resistors, resistance devices, thermionic tubes, and rectifiers shall conform to Section 502-14(a)(3), except that enclosures for thermionic tubes, nonadjustable resistors or rectifiers for which maximum operating temperature will not exceed 120°C (248°F) may be of general-purpose type.

**(4) Rotating Machinery.** Motors, generators and other rotating electrical machinery shall conform to Section 502-8(b).

**502-15. Live Parts, Class II, Divisions 1 and 2.** There shall be no exposed live parts.

**502-16. Grounding, Class II, Divisions 1 and 2.** Wiring and equipment shall be grounded in conformity with the following:

**(a) Exposed Parts.** The exposed noncurrent-carrying metal parts of equipment such as the frames or metal exteriors of motors, fixed or portable lamps or other utilization equipment, lighting fixtures, cabinets, cases, and conduit, shall be grounded as specified in Article 250.

**(b) Bonding.** The locknut-bushing and double-locknut types of contact shall not be depended upon for bonding purposes, but bonding jumpers with proper fittings, or other approved means shall be used. Such means of bonding shall apply to all intervening raceways, fittings, boxes, enclosures, etc., between hazardous areas and the point of grounding for service equipment. Where flexible conduit is used as permitted in Section 502-4, bonding jumpers with proper fittings shall be provided around such conduit.

**(c) Lightning Protection.** Each ungrounded service conductor of a wiring system in a Class II location, when supplied from an ungrounded overhead electrical supply system in an area where lightning disturbances are prevalent, shall be protected by a lightning protective device of proper type. Lightning protective devices shall be connected to the service conductors on the supply side of the service disconnecting means, and shall be bonded to the raceway system at the service entrance.

**(d) Grounded Service Conductor Bonded to Raceway.** Wiring in a Class II location, when supplied from a grounded alternating-current

(502-16(d) continued)

supply system in which a grounded conductor is a part of the service, shall have the grounded service conductor bonded to the raceway system and to the grounding conductor for the raceway system. The bonding connection to the grounded service conductor shall be made on the supply side of the service disconnecting means.

**(e) Transformer Ground Bonded to Raceway.** Wiring in a Class II location, where supplied from a grounded alternating-current supply system in which no grounded conductor is a part of the service, shall be provided with a metallic connection between the supply system ground and the raceway system at the service entrance. The metallic connection shall have an ampacity not less than 1/5 that of the service conductors, and shall in no case be smaller than No. 10 when of soft copper, or No. 12 when of medium- or hard-drawn copper.

**(f) Multiple Grounds.** Where, in the application of Section 250-21, it is necessary to abandon one or more grounding connections to avoid objectionable passage of current over the grounding conductors, the connection required in Section 502-16(d) or (e) shall not be abandoned while any other grounding connection remains connected to the supply system.

## ARTICLE 503 — CLASS III INSTALLATIONS — HAZARDOUS LOCATIONS

**503-1. General.** The general rules of this Code shall apply to the installation of electrical wiring and apparatus in locations classified as Class III under Section 500-6 except as modified by this Article.

Equipment installed in Class III locations shall be able to function at full rating without developing surface temperatures high enough to cause excessive dehydration or gradual carbonization of accumulated fibers or flyings. Organic material which is carbonized or is excessively dry is highly susceptible to spontaneous ignition. In general, maximum surface temperatures under operating conditions shall not exceed 165°C (329°F) for equipment which is not subject to overloading, and 120°C (248°F) for equipment such as motors, power transformers, etc., which may be overloaded.

**503-2. Transformers and Capacitors, Class III, Divisions 1 and 2.** Transformers and capacitors shall conform to Section 502-2(b).

**503-3. Wiring Methods.** Wiring methods shall conform to the following:

**(a) Class III, Division 1.** In Class III, Division 1 locations, rigid metal conduit, or approved Type MI, MC or ALS cables shall be the wiring method employed.

**(1) Boxes and Fittings.** Fittings and boxes in which taps, joints or terminal connections are made shall: (1) be provided with telescoping or close fitting covers, or other effective means to prevent the escape of sparks or burning material, and (2) shall have no openings (such as

holes for attachment-screws) through which, after installation, sparks or burning material might escape, or through which adjacent combustible material might be ignited.

**(2) Flexible Connections.** Where flexible connections are necessary the provisions of Section 502-4(a)(2) shall apply.

**(b) Class III, Division 2.** In Class III, Division 2 locations, the wiring method shall conform to Section 503-3(a), except that in sections, compartments or areas used solely for storage and containing no machinery, open wiring on insulators may be employed when installed to conform to Article 320, but only on condition that protection as required by Section 320-12 be provided where conductors are not run in roof spaces, and well out of reach of sources of physical damage.

**503-4. Switches, Circuit Breakers, Motor Controllers and Fuses, Class III, Divisions 1 and 2.** Switches, circuit breakers, motor controllers and fuses, including push buttons, relays and similar devices, shall be provided with tight metal enclosures designed to minimize entrance of fibers and flyings, and which shall: (1) be equipped with telescoping or close fitting covers, or with other effective means to prevent escape of sparks or burning material, and (2) have no openings (such as holes for attachment-screws) through which, after installation, sparks or burning material might escape, or through which exterior accumulations of fibers or flyings or adjacent combustible material might be ignited.

**503-5. Control Transformers and Resistors, Class III, Divisions 1 and 2.** Transformers, impedance coils and resistors used as or in conjunction with control equipment for motors, generators and appliances, shall conform to Section 502-7(b), with the exception that, in Class III, Division 1 locations, when these devices are in the same enclosure with switching devices of such control equipment, and are used only for starting or short-time duty, the enclosure shall conform to the requirements of Section 503-4.

**503-6. Motors and Generators.** Motors and Generators shall conform to the following:

**(a) Class III, Division 1.** In Class III, Division 1 locations, motors, generators, and other rotating electrical machinery shall be totally enclosed not ventilated, totally enclosed pipe-ventilated, or totally enclosed fan-cooled, except that in locations where, in the judgment of the authority having jurisdiction, only moderate accumulations of lint and flyings will be likely to collect on, in, or in the vicinity of a rotating electrical machine, and where such machine is readily accessible for routine cleaning and maintenance, self-cleaning textile motors of the squirrel-cage type, standard open-type machines without sliding contacts, centrifugal or other types of switching mechanism (including motor overload devices), or standard open-type machines having such contacts, switching mechanisms or resistance devices enclosed within tight metal housings without ventilating or other openings, may be installed.

**(b) Class III, Division 2.** In Class III, Division 2 locations, motors, generators, and other rotating electrical machinery shall be totally enclosed not ventilated, totally enclosed pipe-ventilated, or totally enclosed fan-cooled.

(c) **Partially Enclosed Type, Class III, Divisions 1 and 2.** Motors, generators or other rotating electrical machinery of the partially enclosed or splash-proof type shall not be installed in Class III locations.

**503-7. Ventilating Piping, Class III, Divisions 1 and 2.** Vent pipes for motors, generators or other rotating electrical machinery, or for enclosures for electrical apparatus or equipment, shall be of metal not lighter than No. 24 MSG, or of equally substantial noncombustible material, and shall: (1) lead directly to a source of clean air outside of buildings, (2) be screened at the outer ends to prevent the entrance of small animals or birds, (3) be protected against physical damage and against rusting or other corrosive influences, and (4) vent pipes and their connections shall be sufficiently tight to prevent the entrance of appreciable quantities of fibers or flyings into the ventilated equipment or enclosure, and to prevent the escape of sparks, flame or burning material which might ignite accumulations of fibers or flyings or combustible material in the vicinity. For metal pipes, lock seams and riveted or welded joints may be used, and tight fitting slip joints may be used where some flexibility is necessary as at connections to motors.

**503-8. Utilization Equipment, Fixed and Portable, Class III, Divisions 1 and 2.** Utilization equipment shall conform to the following:

(a) **Heaters.** Electrically heated utilization equipment shall be approved for Class III locations.

(b) **Motors.** Motors of motor-driven utilization equipment shall conform to Section 503-6(b). Utilization equipment which may be readily moved from one location to another should conform to requirements for the most hazardous location.

(c) **Switches, Circuit Breakers, Motor Controllers and Fuses.** Switches, circuit breakers, motor controllers and fuses shall conform to Section 503-4.

**503-9. Lighting Fixtures, Class III, Divisions 1 and 2.** Lamps shall be installed in fixtures which shall conform to the following:

(a) **Fixed Lighting.** Lighting fixtures for fixed lighting shall provide enclosures for lamps and lampholders which shall be designed to minimize entrance of fibers and flyings, and to prevent the escape of sparks, burning material or hot metal. Each fixture shall be clearly marked to show wattage of lamp which may be used without exceeding a maximum exposed surface temperature of 165°C (329° F) under operating conditions of use.

(b) **Physical Damage.** A fixture which may be exposed to physical damage shall be protected by a suitable guard.

(c) **Pendant Fixtures.** Pendant fixtures shall be suspended by stems of threaded rigid conduit or threaded metal tubing of equivalent thickness. For stems longer than 12 inches, permanent and effective bracing against lateral displacement shall be provided at a level not more than 12 inches above the lower end of the stem, or flexibility in the form of a fitting or a flexible connector approved for the purpose shall be provided not more than 12 inches from the point of attachment to the supporting box or fitting.

**(d) Supports.** Boxes, box assemblies or fittings used for the support of lighting fixtures shall be of a type approved for the purpose.

**(e) Portable Lamps.** Portable lamps shall be equipped with handles and protected with substantial guards, and lampholders shall be of unswitched type with no exposed metal parts and without provision for receiving attachment plugs. In all other respects, portable lamps shall conform to Section 503-9(a).

**503-10. Flexible Cords, Class III, Divisions 1 and 2.** Flexible cords shall conform to Section 502-12.

**503-11. Receptacles and Attachment Plugs, Class III, Divisions 1 and 2.** Receptacles and attachment plugs shall conform to Section 502-13(b).

**503-12. Signal, Alarm, Remote-Control and Local Loud-Speaker Intercommunication Systems, Class III, Divisions 1 and 2.** Signal, alarm, remote-control and local loudspeaker intercommunication systems shall conform to Section 502-14(a).

**503-13. Electric Cranes and Hoists, and Similar Equipment, Class III, Divisions 1 and 2.** Where installed for operation over combustible fibers or accumulations of flyings, traveling cranes and hoists for material handling, traveling cleaners for textile machinery, and similar equipment shall conform to the following:

**(a)** Power supply to contact conductors shall be isolated from all other systems and shall be ungrounded, and shall be equipped with an acceptable recording ground detector which will give an alarm and will automatically de-energize the contact conductors in case of a fault to ground, or with an acceptable ground-fault indicator which will give a visual and audible alarm, and maintain the alarm as long as power is supplied to the system and the ground fault remains.

**(b)** Contact conductors shall be so located or guarded as to be inaccessible to other than authorized persons, and shall be protected against accidental contact with foreign objects.

**(c)** Current collectors shall be arranged or guarded to confine normal sparking and to prevent escape of sparks or hot particles. To reduce sparking, two or more separate surfaces of contact shall be provided for each contact conductor. Reliable means shall be provided to keep contact conductors and current collectors free of accumulations of lint or flyings.

**(d)** Control equipment shall conform to Sections 503-4 and 503-5.

Where the distance of travel permits, current to the crane shall be supplied through flexible cord approved for extra hard usage and equipped with approved type of reel or takeup device.

**503-14. Electric Trucks.** Electric trucks shall conform to NFPA Standard for the Use, Maintenance and Operation of Industrial Trucks (No. 505-1971).

**503-15. Storage-Battery Charging Equipment, Class III, Divisions 1 and 2.** Storage-battery-charging equipment shall be located in separate rooms built or lined with substantial noncombustible materials so constructed as to adequately exclude flyings or lint, and shall be well ventilated.

**503-16. Live Parts, Class III, Divisions 1 and 2.** There shall be no exposed live parts except as provided in Section 503-13.

**503-17. Grounding, Class III, Divisions 1 and 2.** Wiring and equipment shall be grounded in conformity with Section 502-16.

## **ARTICLE 510 — HAZARDOUS LOCATIONS — SPECIFIC**

**510-1. Scope.** The provisions of Articles 511 through 517 shall apply to occupancies or parts of occupancies which are or may be hazardous because of atmospheric concentrations of hazardous gases or vapors, or because of deposits or accumulations of materials which may be readily ignitable. It is the intent to assist the authority having jurisdiction in the classification of areas with respect to hazardous conditions which may or may not require construction and equipment conforming to Articles 501 through 503, and to set forth such additional special requirements as are applicable to the specific occupancy.

**510-2. General.** The general rules of this Code shall apply to the installation of electrical wiring and equipment in occupancies within the scope of Articles 511 through 517, except as such rules are modified in those Articles. Where unusual conditions exist in a specific occupancy, the authority having jurisdiction shall judge with respect to the application of specific rules.

It is recommended that the authority having jurisdiction be familiar with National Fire Protection Association standards applying to occupancies included within the scopes of Articles 511 through 517.

## **ARTICLE 511 — COMMERCIAL GARAGES, REPAIR AND STORAGE**

**511-1. Scope.** These occupancies shall include locations used for service and repair operations in connection with self-propelled vehicles (including passenger automobiles, buses, trucks, tractors, etc.) in which volatile flammable liquids or flammable gases are used for fuel or power, and locations in which more than 3 such vehicles are or may be stored at one time.

For further information regarding classification of garages, refer to the NFPA Standard for Garages (No. 88-1968).

**511-2. Hazardous Areas.** Classification under Article 500.

(a) For each floor at or above grade, the entire area up to a level 18 inches above the floor shall be considered to be a Class I, Division 2 location.

(b) For each floor below grade, the entire area up to a level 18 inches above the bottom of outside doors or other openings which are



at or above grade level shall be considered to be Class I, Division 2 location. Where adequate positive-pressure ventilation is provided, the authority having jurisdiction may judge that the hazardous location extends up to a level of only 18 inches above each such floor.

(c) Any pit or depression below floor level shall be considered to be a Class I, Division 2 location which shall extend up to said floor level, except that any unventilated pit or depression may be judged by the authority having jurisdiction to be a Class I, Division 1 location.

(d) Adjacent areas in which hazardous vapors are not likely to be released such as stock rooms, switchboard rooms and other similar locations, having floors elevated at least 18 inches above adjacent garage floor, or separated therefrom by tight curbs or partitions at least 18 inches high, shall not be classed as hazardous.

(e) Adjacent areas, which by reason of ventilation, air pressure differentials or physical spacing are such that in the opinion of the authority enforcing this Code no hazard exists, shall be classified as non-hazardous.

**511-3. Wiring and Equipment in Hazardous Areas.** Within hazardous areas as defined in Section 511-2, wiring and equipment shall conform to applicable provisions of Article 501.

**511-4. Sealing.** Approved seals conforming to the requirements of Section 501-5 shall be provided, and Section 501-5(b)(2) shall apply to horizontal as well as to vertical boundaries of the defined hazardous areas. Raceways embedded in a masonry floor or buried beneath a floor shall be considered to be within the hazardous area above the floor if any connections or extensions lead into or through such area.

**511-5. Wiring in Spaces Above Hazardous Areas.**

(a) All fixed wiring shall be in metallic raceways or shall be Type MI or Type ALS cable. Cellular metal floor raceways may be used only for supplying ceiling outlets or extensions to the area below the floor, but such raceways shall have no connections leading into or through any hazardous area above the floor. No electrical conductor shall be installed in any cell, header or duct which contains a pipe for steam, water, air, gas, drainage, or other service except electrical.

(b) For pendants, flexible cord suitable for the type of service and approved for hard usage shall be used.

(c) For connection of portable lamps, motors or other utilization equipment, flexible cord suitable for the type of service and approved for extra-hard usage shall be used.

(d) When a circuit which supplies portables or pendants includes an identified grounded conductor as provided in Article 200, receptacles, attachment plugs, connectors, and similar devices shall be of polarized type, and the identified conductor of the flexible cord shall be connected to the screw shell of any lampholder or to the identified terminal of any utilization equipment supplied.

(e) When a pendant is used to supply a portable lamp or utilization equipment, the female portion of a polarized pin-plug connector or equivalent shall be attached to the lower end of the pendant, and the

(511-5(e) continued)

male portion shall be attached to the cord for the portable. The connector shall be designed to break apart readily in any position, and shall be suspended at a level not less than that specified in Section 511-2. Attachment-plug receptacles in fixed position shall be located above the level specified in Section 511-2.

#### **511-6. Equipment Above Hazardous Areas.**

(a) Equipment which is less than 12 feet above the floor level, and which may produce arcs, sparks or particles of hot metal, such as cut-outs, switches, charging panels, generators, motors or other equipment (excluding receptacles, lamps and lampholders) having make-and-break or sliding contacts, shall be of the totally enclosed type or so constructed as to prevent escape of sparks or hot metal particles.

(b) Lamps and lampholders for fixed lighting which are located over lanes through which vehicles are commonly driven or which may otherwise be exposed to physical damage, shall be located not less than 12 feet above floor level unless of totally enclosed type or so constructed as to prevent escape of sparks or hot metal particles.

(c) Portable lamps shall be equipped with handle, lampholder, hook and substantial guard attached to the lampholder or handle. All exterior surfaces which might come in contact with battery terminals, wiring terminals, or other objects shall be of nonconducting material or shall be effectively protected with insulation. Lampholders shall be of unswitched type, and shall not provide means for plug-in of attachment plugs. Outer shell shall be of moulded composition or other material approved for the purpose, and metal-shell, lined lampholders, either of switched or unswitched type, shall not be used. Unless the lamp and its cord are supported or arranged in such a manner that they cannot be used in the hazardous areas classified in Section 511-2, they shall be of a type approved for such hazardous locations.

**511-7. Battery-Charging Equipment.** Battery chargers and their control equipment, and batteries being charged shall not be located within hazardous areas classified in Section 511-2. Tables, racks, trays, and wiring shall, in addition, conform to the provisions of Article 480.

#### **511-8. Electric Vehicle Charging.**

(a) Flexible cords used for charging shall be suitable for the type of service and approved for extra hard usage. Their ampacity shall be adequate for the charging current.

(b) Connectors shall have a rating not less than the ampacity of the cord, and in no case less than 50 amperes.

(c) Connectors shall be so designed and installed that they will break apart readily at any position of the charging cable, and live parts shall be guarded from accidental contact. No connector shall be located within a hazardous area defined in Section 511-2.

(d) Where plugs are provided for direct connection to vehicles, the point of connection shall not be within a hazardous area as defined in Section 511-2, and where the cord is suspended from overhead, it shall be so arranged that the lowest point of sag is at least 6 inches above the floor. Where the vehicle is equipped with an approved plug which will

readily pull apart, and where an automatic arrangement is provided to pull both cord and plug beyond the range of physical damage, no additional connector is required in the cable or at the outlet.

## ARTICLE 512 — RESIDENTIAL STORAGE GARAGES

**512-1. Definition.** A residential storage garage is a building or room in which not more than 3 vehicles of the types described in Section 511-1 are or may be stored, but which will not normally be used for other than minor service or repair operations on such stored vehicles.

**512-2. At or Above Grade.** Where the lowest floor is at or above adjacent ground or driveway level, and where there is at least one outside door at or below floor level, the garage area shall not be classed as a hazardous location.

**512-3. Below Grade.** Where the lowest floor is below adjacent ground or driveway level, the following shall apply:

(a) The entire area of the garage or of any enclosed space which includes the garage shall be classified as a Class I, Division 2 location up to a level 18 inches above the garage floor. All electrical equipment and wiring within such hazardous location shall conform to applicable provisions of Article 501.

(b) Wiring and equipment above the defined hazardous location shall conform to the requirements of this Code for nonhazardous locations.

(c) Adjacent areas in which hazardous vapors or gases are not likely to be released, and having floors elevated at least 18 inches above the garage floor, or separated therefrom by tight curbs or partitions at least 18 inches high, shall not be classed as hazardous.

## ARTICLE 513 — AIRCRAFT HANGARS

**513-1. Definition.** This occupancy shall include locations used for storage or servicing of aircraft in which gasoline, jet fuels, or other volatile flammable liquids, or flammable gases, are used, but shall not include such locations when used exclusively for aircraft which have never contained such liquids or gases, or which have been drained and properly purged.

**513-2. Hazardous Areas.** Classification under Article 500.

(a) Any pit or depression below the level of the hangar floor shall be considered to be a Class I, Division 1 location which shall extend up to said floor level.

(b) The entire area of the hangar including any adjacent and communicating areas not suitably cut off from the hangar shall be consid-

ered to be a Class I, Division 2 location up to a level 18 inches above the floor.

(c) The area within 5 feet horizontally from aircraft power plants, aircraft fuel tanks or aircraft structures containing fuel shall be considered to be a Class I, Division 2 hazardous location which shall extend upward from the floor to a level 5 feet above the upper surface of wings and of engine enclosures.

(d) Adjacent areas in which hazardous vapors are not likely to be released such as stock rooms, electrical control rooms, and other similar locations, should not be classed as hazardous when adequately ventilated and when effectively cut off from the hangar itself by walls or partitions.

**513-3. Wiring and Equipment in Hazardous Areas.** All fixed and portable wiring and equipment which is or may be installed or operated within any of the hazardous locations defined in Section 513-2 shall conform to applicable provisions of Article 501. All wiring installed in or under the hangar floor shall conform to the requirements for Class I, Division 1. When such wiring is located in vaults, pits, or ducts, adequate drainage shall be provided, and the wiring shall not be placed within the same compartment with any other service except piped compressed air.

Attachment plugs and receptacles in hazardous locations shall be explosion-proof or shall be so designed that they cannot be energized while the connections are being made or broken.

**513-4. Wiring Not Within Hazardous Areas.**

(a) All fixed wiring in a hangar, but not within a hazardous area as defined in Section 513-2, shall be installed in metallic raceways or shall be Type MI or Type ALS cable, except that wiring in nonhazardous locations as defined in Section 513-2(d) may be of any type recognized in Chapter 3 of this Code.

(b) For pendants, flexible cord suitable for the type of service and approved for hard usage shall be used. Each such cord shall include a separate grounding conductor.

(c) For portable utilization equipment and lamps, flexible cord suitable for the type of service and approved for extra-hard usage shall be used. Each such cord shall include a separate grounding conductor.

(d) Where a circuit which supplies portables or pendants includes an identified grounded conductor as provided in Article 200, receptacles, attachment plugs, connectors, and similar devices shall be of polarized type, and the identified conductor of the flexible cord shall be connected to the screw shell of any lampholder or to the identified terminal of any utilization equipment supplied. Acceptable means shall be provided for maintaining continuity of the grounding conductor between the fixed raceway system and the noncurrent-carrying metallic portions of pendant fixtures, portable lamps, and portable utilization equipment.

**513-5. Equipment Not Within Hazardous Areas.**

(a) In locations other than those described in Section 513-2, equipment which is less than 10 feet above wings and engine enclosures of

aircraft and which may produce arcs, sparks or particles of hot metal, such as lamps and lampholders for fixed lighting, cutouts, switches, receptacles, charging panels, generators, motors, or other equipment having make-and-break or sliding contacts, shall be of totally enclosed type or so constructed as to prevent escape of sparks or hot metal particles, except that equipment in areas described in Section 513-2(d) may be of general-purpose type.

(b) Lampholders of metal-shell, fiber-lined types shall not be used for fixed incandescent lighting.

(c) Portable lamps which are or may be used within a hangar shall be approved for Class I locations.

(d) Portable utilization equipment which is or may be used within a hangar shall be of a type suitable for use in Class I, Division 2 locations.

#### **513-6. Stanchions, Rostrums and Docks.**

(a) Electric wiring, outlets and equipment (including lamps) on or attached to stanchions, rostrums or docks which are located or likely to be located in a hazardous area as defined in Section 513-2(c) shall conform to the requirements for Class I, Division 2 locations.

(b) Where stanchions, rostrums, or docks are not located or likely to be located in a hazardous area as defined in Section 513-2(c), wiring and equipment shall conform to Sections 513-4 and 513-5, except that such wiring and equipment, not more than 18 inches above the floor in any position shall conform to Section 513-6(a). Receptacles and attachment plugs shall be of locking type which will not break apart readily.

(c) Mobile stanchions with electrical equipment conforming to Section 513-6(b) shall carry at least one permanently affixed warning sign to read: "WARNING — KEEP 5 FEET CLEAR OF AIRCRAFT ENGINES AND FUEL TANK AREAS."

**513-7. Sealing.** Approved seals shall be provided in conformance with Section 501-5 and Section 501-5(a)(3) and 501-5(b)(2) and shall apply to horizontal as well as to vertical boundaries of the defined hazardous areas. Raceways embedded in a masonry floor or buried beneath a floor shall be considered to be within the hazardous area above the floor when any connections or extensions lead into or through such area.

**513-8. Aircraft Electrical Systems.** Aircraft electrical systems should be de-energized when the aircraft is stored in a hangar, and, whenever possible, while the aircraft is undergoing maintenance.

#### **513-9. Aircraft Battery — Charging and Equipment.**

(a) Aircraft batteries should not be charged when installed in an aircraft located inside or partially inside a hangar.

(b) Battery chargers and their control equipment shall not be located or operated within any of the hazardous areas defined in Section 513-2, and should preferably be located in a separate building or in an area such as described in Section 513-2(d). Mobile chargers shall carry at least one permanently affixed warning sign to read: "WARNING — KEEP 5 FEET CLEAR OF AIRCRAFT ENGINES AND FUEL

(513-9(b) continued)

**TANK AREAS.”** Tables, racks, trays, and wiring shall not be located within a hazardous area, and shall, in addition, conform to the provisions of Article 480.

**513-10. External Power Sources for Energizing Aircraft.**

(a) Aircraft energizers shall be so designed and mounted that all electrical equipment and fixed wiring will be at least 18 inches above floor level and shall not be operated in a hazardous area as defined in Section 513-2(c).

(b) Mobile energizers shall carry at least one permanently affixed warning sign to read: “**WARNING — KEEP 5 FEET CLEAR OF AIRCRAFT ENGINES AND FUEL TANK AREAS.**”

(c) Aircraft energizers should be equipped with polarized external power plugs and should have automatic controls to isolate the ground power unit electrically from the aircraft in case excessive voltage is generated by the grounding power unit.

(d) Flexible cords for aircraft energizers and ground support equipment shall be approved for the type of service and extra-hard usage and shall include a ground conductor.

**513-11. Mobile Servicing Equipment with Electrical Components.**

(a) Mobile servicing equipment (such as vacuum cleaners, air compressors, air movers, etc.) having electrical wiring and equipment not suitable for Class I, Division 2 locations shall be so designed and mounted that all such fixed wiring and equipment will be at least 18 inches above the floor. Such mobile equipment shall not be operated within the hazardous areas defined in Section 513-2(c) and shall carry at least one permanently affixed warning sign to read: “**WARNING — KEEP 5 FEET CLEAR OF AIRCRAFT ENGINES AND FUEL TANK AREAS.**”

(b) Flexible cords for mobile equipment shall be suitable for the type of service and approved for extra-hard usage, and shall include a grounding conductor. Attachment plugs and receptacles shall be approved for the location in which they are installed, and shall provide for connection of the grounding conductor to the raceway system.

(c) Equipment not of a type suitable for Class I, Division 2 locations should not be operated in areas where maintenance operations likely to release hazardous vapors are in progress.

**513-12. Grounding.** All metallic raceways, and all noncurrent-carrying metallic portions of fixed or portable equipment, regardless of voltage, shall be grounded as provided in Article 250.

## ARTICLE 514 — GASOLINE DISPENSING AND SERVICE STATIONS

**514-1. Definitions.** This classification shall include locations where gasoline or other volatile flammable liquids or liquefied flammable gases are transferred to the fuel tanks (including auxiliary fuel tanks) of self-propelled vehicles.

Other areas used as lubritoriums, service rooms and repair rooms, and offices, salesrooms, compressor rooms and similar locations shall conform to Articles 510 and 511 with respect to electrical wiring and equipment.

Where the authority having jurisdiction can satisfactorily determine that flammable liquids having a flash point below 100°F such as gasoline will not be handled, he may classify such an area as nonhazardous.

For further information regarding safeguards for gasoline dispensing and service stations see NFPA Flammable and Combustible Liquids Code (No. 30-1969).

### **514-2. Hazardous Areas.**

(a) The space within the dispenser up to 4 feet from its base and the space within 18 inches extending horizontally from the dispenser up to 4 feet from its base shall be considered a Class I, Division 1 location. This classification shall also apply to any space below the dispenser which may contain electrical wiring or equipment.

(b) In an outside location, any area (excluding Class I, Division 1, but including buildings not suitably cut off) within 20 feet horizontally from the exterior enclosure of any dispensing pump shall be considered a Class I, Division 2 location which will extend to a level 18 inches above driveway or ground level.

(c) In an outside location, any area (excluding Class I, Division 1, but including buildings not suitably cut off) within 10 feet horizontally from any tank fill-pipe shall be considered a Class I, Division 2 location which shall extend upward to a level 18 inches above driveway or ground level.

(d) Electrical wiring and equipment, any portion of which is below the surface of areas defined as Class I, Division 1 or Division 2 in 514-2(a), (b), (c) above shall be considered to be within a Class I Division 1 location which shall extend at least to the point of emergence above grade.

(e) Where the dispensing unit, including the hose and hose nozzle valve, is suspended from a canopy, ceiling or structural support, the Class I, Division 1 location shall include the volume within the enclosure and shall also extend 18 inches in all directions from the enclosure where not suitably cut off by a ceiling or wall. The Class I, Division 2 location shall extend 2 feet horizontally in all directions beyond the Division 1 classified area and extend to grade below this classified area. In addition, the horizontal area 18 inches above grade

for a distance of 20 feet, measured from a point vertically below the edge of any dispenser enclosure, shall be classified Division 2. All electrical equipment integral with the dispensing hose or nozzle shall be suitable for use in a Division 1 location.

(f) The spherical volume within a 3-foot radius from point of discharge of any tank vent-pipe shall be considered a Class I, Division 1 location and the volume between 3-foot to 5-foot radius from point of discharge of a vent shall be considered a Class I, Division 2 location. For any vent that does not discharge upward, the cylindrical volume below both the Division 1 and 2 locations extending to the ground shall be considered a Class I, Division 2 location. The hazardous area shall not extend beyond an unpierced wall.

(g) In addition to the requirements of Section 514-1 the area within any pit or space below grade in a lubrication room shall be considered a Class I, Division 1 location. The area within the entire lubrication room up to 18 inches above the floor or grade, and the area within 3 feet measured in any direction from the dispensing point of a hand-operated unit dispensing Class I liquids shall be considered a Class I, Division 2 location.

**514-3. Wiring and Equipment Within Hazardous Areas.** All electrical equipment and wiring within the hazardous areas defined in Section 514-2 shall conform to applicable provisions of Article 501.

*Exception: Except as permitted in Section 514-8.*

For special requirements for conductor insulation, see Section 501-13.

**514-4. Wiring and Equipment Above Hazardous Areas.** Wiring and equipment above hazardous areas defined in Section 514-2 shall conform to Sections 511-5 and 511-6.

**514-5. Circuit Disconnects.** Each circuit leading to or through a dispensing pump shall be provided with a switch or other acceptable means to disconnect simultaneously from the source of supply all conductors of the circuit including the grounded neutral, if any.

**514-6. Sealing.**

(a) An approved seal shall be provided in each conduit run entering or leaving a dispenser or any cavities or enclosures in direct communication therewith. The sealing fitting shall be the first fitting after the conduit emerges from the earth or concrete.

(b) Additional seals shall be provided in conformance with Section 501-5 and Sections 501-5(a)(3) and 501-5(b)(2) shall apply to horizontal as well as to vertical boundaries of the defined hazardous areas.

**514-7. Grounding.** Metallic portions of dispensing pumps, metallic raceways, and all noncurrent-carrying portions of electrical equipment, regardless of voltage, shall be grounded as provided in Article 250.

**514-8. Underground Wiring.** Underground wiring shall be installed in rigid metal conduit, or, where buried under not less than 2 feet of earth, may be installed in nonmetallic conduit conforming to the requirements of Article 347. Where nonmetallic conduit is used, a grounding conductor shall be included to provide for metallic con-



tinuity of the raceway system and for grounding of noncurrent-carrying metallic parts of equipment.

*Exception: Type MI cable may be used when installed in accordance with Article 330.*

## ARTICLE 515 — BULK-STORAGE PLANTS

**515-1. Definition.** This designation shall include locations where gasoline or other volatile flammable liquids are stored in tanks having an aggregate capacity of one carload or more, and from which such products are distributed (usually by tank truck).

### **515-2. Hazardous Areas.**

#### **(a) Pumps, Bleeders, Withdrawal Fittings, Meters and Similar Devices.**

(1) Adequately ventilated indoor areas containing pumps, bleeders, withdrawal fittings, meters and similar devices which are located in pipe lines handling flammable liquids under pressure shall be considered as Class I, Division 2 locations within a 5-foot distance extending in all directions from the exterior surface of such devices. The Class I, Division 2 location shall also extend 25 feet horizontally from any surface of these devices and extend upward to 3 feet above floor or grade level.

See Flammable and Combustible Liquids Code, NFPA No. 30-1969, for discussion of factors influencing adequacy of ventilation required to prevent formation of hazardous vapor-air mixtures.

(2) Inadequately ventilated indoor areas containing pumps, bleeders, withdrawal fittings, meters and similar devices which are located in pipe lines handling flammable liquids under pressure shall be considered as Class I, Division 1 locations within a 5-foot distance extending in all directions from the exterior surface of such devices. The Class I, Division 1 location shall also extend 25 feet horizontally from any surface of the devices and extend upward to 3 feet above floor or grade level.

(3) Outdoor areas containing pumps, bleeders, withdrawal fittings, meters and similar devices which are located in pipe lines handling flammable liquids under pressure shall be considered as Class I, Division 2 locations within a 3-foot distance extending in all directions from the exterior surface of such devices. The Class I, Division 2 location shall also extend up to 18 inches above grade level within 10 feet horizontally from any surface of the devices.

#### **(b) Transfer of Flammable Liquids to Individual Containers.**

(1) In outdoor areas or where positive and reliable mechanical ventilation is provided in indoor areas in which flammable liquids are transferred to individual containers, such areas shall be considered to be a Class I, Division 1 location within 3 feet of the vent or fill opening extending in all directions and a Class I, Division 2 location within the

(515-2(b-1) *continued*)

area extending between a 3-foot and 5-foot radius from the vent or fill opening extending in all directions, and including the area within a horizontal radius of 10 feet from the vent or fill opening and extending to a height of 18 inches above floor or grade levels.

See Flammable and Combustible Liquids Code, NFPA No. 30-1969, for discussion of factors pertaining to positive and reliable mechanical ventilation required to prevent formation of hazardous vapor-air mixtures.

(2) When positive and reliable mechanical ventilation is not provided in indoor areas in which flammable liquids are transferred to individual containers, such areas shall be considered to be a Class I, Division 1 location.

**(c) Loading and Unloading of Tank Vehicles and Tank Cars in Outside Locations.**

(1) The area extending 3 feet in all directions from the dome when loading through an open dome or from the vent when loading through a closed dome with atmospheric venting shall be considered a Class I, Division 1 location.

(2) The area extending between a 3-foot and 5-foot radius from the dome when loading through an open dome or from the vent when loading through a closed dome with atmospheric venting shall be considered a Class I, Division 2 location.

(3) The area extending within 3 feet in all directions from a fixed connection used in bottom loading or unloading, loading through a closed dome with atmospheric venting, or loading through a closed dome with a vapor recovery system, shall be considered a Class I, Division 2 location. In the case of bottom loading or unloading this classification shall also be applied to the area within a 10-foot radius from point of connection and extending 18 inches above grade.

In deciding upon extent of hazardous area, consideration should be given to the total area within which loading and unloading operation may occur such as racks, platforms, driveways, etc.

**(d) Aboveground Tanks.**

(1) The area above the roof and within the shell of a floating roof type tank shall be considered a Class I, Division 1 location.

(2) For all types of aboveground tanks the area within 10 feet from the shell, ends and roof of other than a floating roof shall be considered a Class I, Division 2 location. Where dikes are provided the area inside the dike and extending upward to the top of the dike shall be considered to be a Class I, Division 2 location.

(3) The area within 5 feet of a vent opening and extending in all directions shall be considered a Class I, Division 1 location.

(4) The area between 5 and 10 feet of a vent opening and extending in all directions shall be considered a Class I, Division 2 location.

For underground tanks see Article 514.

**(e) Pits.**

(1) Any pit or depression, any part of which lies within a Division 1 or Division 2 location as defined herein, shall be considered a Class I,

Division 1 location unless provided with positive and reliable mechanical ventilation.

(2) Any such areas when provided with positive and reliable mechanical ventilation shall be considered a Class I, Division 2 location.

See Flammable and Combustible Liquids Code, NFPA No. 30-1969, for discussion of factors pertaining to positive and reliable mechanical ventilation required to prevent formulation of hazardous vapor-air mixtures.

(3) Any pit or depression not within a Division 1 or Division 2 location as defined herein, but which contains piping, valves or fittings shall be classified as a Class I, Division 2 location.

(f) **Storage and Repair Garages for Tank Vehicles** shall be considered to be Class I, Division 2 locations up to 18 inches above floor or grade level unless in the judgment of the authority enforcing this Code conditions warrant more severe classification or a greater extent of the hazardous area.

(g) **Office Buildings, Boiler Rooms and Other Similar Locations** which are outside the limits of hazardous areas as defined herein, and which are not used for handling or storage of volatile flammable liquids or containers for such liquids, shall not be considered to be hazardous locations.

**515-3. Wiring and Equipment Within Hazardous Areas.** All electrical wiring and equipment within the hazardous areas defined in Section 515-2 shall conform to applicable provisions of Article 501.

*Exception: Except as permitted in Section 515-5.*

**515-4. Wiring and Equipment Above Hazardous Areas.** All fixed wiring above hazardous areas shall be in metallic raceways or shall be Type ALS cable. Fixed equipment which may produce arcs, sparks or particles of hot metal, such as lamps and lampholders for fixed lighting, cutouts, switches, receptacles, motors, or other equipment having make-and-break or sliding contacts, shall be of totally enclosed type or so constructed as to prevent escape of sparks or hot metal particles. Portable lamps or utilization equipment, and their flexible cords shall conform to the provisions of Article 501 for the class of location above which they are connected or used.

**515-5. Underground Wiring.**

(a) Underground wiring shall be installed in rigid metal conduit, or, where buried under not less than 2 feet of earth, may be installed in nonmetallic conduit or duct, or in the form of cable approved for the purpose. Where cable is used, it shall be enclosed in rigid metal conduit from the point of lowest buried cable level to the point of connection to the aboveground raceway.

(b) Conductor insulation shall conform to Section 501-13.

(c) Where cable with nonmetallic sheath or nonmetallic conduit is used, an additional grounding conductor shall be included to provide for metallic continuity of the raceway system and for grounding of noncurrent-carrying metallic parts of equipment.

**515-6. Sealing.** Approved seals shall be provided in conformance with Section 501-5 and Sections 501-5(a)(3) and 501-5(b)(2) shall

apply to horizontal as well as to vertical boundaries of the defined hazardous areas. Buried raceways under defined hazardous areas shall be considered to be within such areas.

**515-7. Gasoline Dispensing.** Where gasoline dispensing is carried on in conjunction with bulk station operations, applicable provisions of Article 514 shall apply.

**515-8. Grounding.** All metallic raceways, and all noncurrent-carrying metallic portions of electrical equipment shall be grounded as provided in Article 250.

## ARTICLE 516 — FINISHING PROCESSES

**516-1. Definition.** This Article shall apply to locations where paints, lacquers or other flammable finishes are regularly or frequently applied by spraying, dipping, brushing or by other means, and where volatile flammable solvents or thinners are used or where readily ignitable deposits or residues from such paints, lacquers or finishes may occur.

For further information regarding safeguards for finishing processes, such as guarding, fire protection, posting of warning signs, and maintenance, see the NFPA Standard for Spray Finishing Using Flammable and Combustible Materials, No. 33-1969 and NFPA Standard for Dip Tanks Containing Flammable or Combustible Liquids, No. 34-1966. For additional information regarding ventilation, see NFPA Standard for Blower and Exhaust Systems, No. 91-1961.

**516-2. Hazardous Areas.** Classification is with respect to flammable vapors, some sections of which are also subject to deposits of paint spray residue. For deposits and residues, see Sections 516-3(b) and (c).

(a) The interiors of spray booths and their exhaust ducts, all space within 20 feet horizontally in any direction from spraying operations more extensive than touch-up spraying and not conducted within spray booths, all space within 20 feet horizontally in any direction from dip tanks and their drain boards, and all other spaces where hazardous concentrations of flammable vapors are likely to occur, shall be considered to be Class I, Division 1 locations.

(b) All space within 20 feet horizontally in any direction from the open face of a spray booth, and all space within the room but beyond the limits for Class I, Division 1 as defined in Section 516-2(a) for extensive open spraying, for dip tanks and drain boards and for other hazardous operations, shall be considered to be Class I, Division 2 locations unless the authority having jurisdiction judges otherwise.

(c) Adjacent areas which are cut off from the defined hazardous areas by tight partitions without communicating openings, and within which hazardous vapors are not likely to be released, shall be classed as nonhazardous unless the authority having jurisdiction judges otherwise.

(d) Areas utilizing drying, curing, or fusion apparatus and provided with positive mechanical ventilation adequate to prevent formation of flammable concentrations of vapors, and provided with effective

interlocks to de-energize all electrical equipment (other than equipment approved for Class I locations) in case the ventilating equipment is inoperative, may be classed as nonhazardous when the authority having jurisdiction so judges.

For further information regarding safeguards see NFPA Standard for Ovens and Furnaces, No. 86-A-1969.

### **516-3. Wiring and Equipment in Hazardous Areas.**

(a) All electrical wiring and equipment within the hazardous areas (containing vapor only — not residues) defined in Section 516-2 shall conform to applicable provisions of Article 501.

(b) Unless approved for both readily ignitable deposits and the flammable vapor location, no electrical equipment shall be installed or used where it may be subject to hazardous accumulations of readily ignitable deposits or residues, as the susceptibility to spontaneous heating and ignition of some residues may be greatly increased at temperatures above normal. Type MI cable and wiring in threaded rigid conduit may be installed in such locations, if the explosion-proof boxes or fittings contain no taps, splices, or terminal connections which may have the possibility of being loose in service and thereby causing abnormal temperatures on external surfaces of boxes or fittings.

(c) Illumination of readily ignitable areas through panels of glass or other transparent or translucent material is permissible only where: (1) fixed lighting units are used as the source of illumination, (2) the panel effectively isolates the hazardous area from the area in which the lighting unit is located, (3) the lighting unit is approved for its specific location, (4) the panel is of a material or is so protected that breakage will be unlikely and (5) the arrangement is such that normal accumulations of hazardous residue on the surface of the panel will not be raised to a dangerous temperature by radiation or conduction from the source of illumination.

(d) Portable electric lamps or other utilization equipment shall not be used within a hazardous area during operation of the finishing process. When such lamps or utilization equipment are used during cleaning or repairing operations, they shall be of a type approved for Class I locations, and all exposed metal parts shall be effectively grounded.

(e) Electrostatic spraying or detearing equipment shall be installed and used only as provided in Section 516-4.

For further information see NFPA Standard, Spray Finishing Using Flammable and Combustible Materials, No. 33-1969.

**516-4. Fixed Electrostatic Equipment.** Where electrostatic spraying and detearing equipment is installed, such equipment shall be of an approved type and shall conform to the following requirements:

(a) Transformers, power packs, control apparatus, and all other electrical portions of the equipment, with the exception of high-voltage grids, electrodes, electrostatic atomizing heads and their connections, shall be installed outside of the hazardous area as defined in Section 516-2 or be of a type approved for the location.

(b) Electrodes and electrostatic atomizing heads shall be located in suitable noncombustible booths or enclosures provided with adequate

mechanical ventilation, shall be adequately supported in permanent locations and shall be effectively insulated from ground. Electrodes and electrostatic atomizing heads, which are permanently attached to their bases, supports, or reciprocators shall be deemed to comply with this Section. Insulators shall be nonporous and noncombustible. Fine-wire elements when used should be under tension at all times and should be of unknicked hardened steel or material of comparable strength.

(c) High-voltage leads to the electrodes shall be properly insulated and protected from mechanical injury or exposure to destructive chemicals. Electrostatic atomizing heads shall be effectively and permanently supported on suitable insulators and shall be effectively guarded against accidental contact or grounding. An automatic means shall be provided for grounding the electrode system when it is electrically de-energized for any reason.

(d) A safe distance shall be maintained between goods being painted and electrodes or electrostatic atomizing heads or conductors of at least twice the sparking distance. A suitable sign indicating this safe distance shall be conspicuously posted near the assembly.

(e) Goods being painted using this process are to be supported on conveyors. The conveyors shall be arranged so as to maintain safe distances between the goods and the electrodes or electrostatic atomizing heads at all times. Any irregularly shaped or other goods subject to possible swinging or movement shall be rigidly supported to prevent such swinging or movement which will reduce the clearance to less than that specified in (d) above.

(f) This process is not approved where goods being coated are manipulated by hand. When finishing materials are applied by electrostatic equipment that is manipulated by hand, see Section 516-5 for applicable requirements.

(g) Electrostatic apparatus shall be equipped with automatic controls which will operate without time delay to disconnect the power supply to the high-voltage transformer and to signal the operator under any of the following conditions: (1) stoppage of ventilating fans or failure of ventilating equipment from any cause; (2) stoppage of the conveyor carrying goods through the high-voltage field; (3) occurrence of a ground or of an imminent ground at any point in the high-voltage system; (4) reduction of clearances below that specified in Section 516-4 (d).

(h) All electrically conductive objects within the charging influence of the electrodes shall be adequately grounded. The equipment shall carry a prominent permanently installed warning regarding the necessity for grounding these objects.

(i) Adequate booths, fencing, railings, or guards shall be so placed about the equipment that they, either by their location or character, or both, assure that a safe isolation of the process is maintained from plant storage or personnel. Such railings, fencing, and guards shall be of conducting materials, adequately grounded, and should be at least 5 feet from processing equipment.

**516-5. Electrostatic Hand-Spraying Equipment.** Electrostatic hand-spray apparatus and devices used in connection with paint-spraying

operations shall be of approved types and shall conform to the following requirements:

(a) The equipment shall be so designed that the maximum surface temperature of the equipment in the spraying area cannot exceed 150°F under any condition. The high-voltage circuits shall be so designed as to not produce a spark of sufficient intensity to ignite any vapor air mixtures, nor result in appreciable shock hazard upon coming in contact with a grounded object under all normal operating conditions. The electrostatically charged exposed elements of a hand gun shall be capable of being energized only by a switch which also controls the paint supply.

(b) Transformers, power packs, control apparatus, and all other electrical portions of the equipment, with the exception of the hand gun itself and its connections to the power supply, shall be located outside of the hazardous area, unless approved for hazardous areas.

(c) The handle of the spraying gun shall be electrically connected to ground by a metallic connection and be so constructed that the operator in normal operating position is in intimate electrical contact with the grounded handle. This requirement is to prevent build-up of a static charge on the operator's body.

(d) All electrically conductive objects in the spraying area shall be adequately grounded. This requirement shall apply to paint containers, wash cans and any other objects or devices in the area. The equipment shall carry a prominent permanently installed warning regarding the necessity for this grounding feature.

(e) Objects being painted shall be maintained in metallic contact with the conveyor or other grounded support. Hooks shall be regularly cleaned to insure this contact and areas of contact shall be sharp points or knife edges where possible. Points of support of the object shall be concealed from random spray where feasible and where the objects being sprayed are supported from a conveyor, the point of attachment to the conveyor shall be so located as to not collect spray material during normal operation.

(f) The spraying operation shall take place within a spray area which is adequately ventilated to remove solvent vapors released from the operation. The electrical equipment shall be so interlocked with the ventilation of spraying area that the equipment cannot be operated unless the ventilation fans are in operation.

**516-6. Powder Coating.** This Section shall apply to finely ground particles of protective finishing material applied in dry powder form. The hazards associated with combustible dusts are inherent in this process. Generally speaking, the hazard rating of the powders employed is dependent upon the chemical composition of the material, particle size, shape and distribution.

(a) Coating powders are applied by means of: (1) fluidized bed; (2) electrostatic fluidized bed; (3) powder spray guns; or (4) electrostatic powder spray guns.

(b) Electrical equipment and other sources of ignition shall conform to the requirements of Section 516-3(d) and Article 501.

(c) The provisions of Sections 516-4 and 516-6(b) shall apply to fixed electrostatic spraying equipment.

(d) The provisions of Sections 516-5 and 516-6(b) shall apply to electrostatic hand-spraying equipment.

(e) Electrostatic fluidized beds and associated equipment shall be of the approved types. The maximum surface temperature of this equipment in the coating area shall not exceed 150°F. The high-voltage circuits and exposed electrodes shall be so designed as to not produce a spark of sufficient intensity to ignite any powder air mixtures nor result in appreciable shock hazard upon coming in contact with a grounded object under normal operating conditions.

(1) Transformers, power packs, control apparatus and all other electrical portions of the equipment, with the exception of the charging electrodes and their connections to the power supply, shall be located outside of the powder-coating area or shall otherwise conform to the requirements of Section 516-6(b).

(2) All electrically conductive objects within the charging influence of the electrodes shall be adequately grounded. The powder-coating equipment shall carry a prominent, permanently installed warning regarding the necessity for grounding these objects.

(3) Objects being coated shall be maintained in contact with the conveyor or other support in order to insure proper grounding. Hangers shall be regularly cleaned to insure effective contact, and areas of contact shall be sharp points or knife edges where possible.

(4) The electrical equipment shall be so interlocked with a ventilation system that the equipment cannot be operated unless the ventilation fans are in operation.

#### **516-7. Wiring and Equipment Above Hazardous Areas.**

(a) All fixed wiring above hazardous areas shall be in metallic raceways or shall be Type MI cable or Type ALS cable. Cellular metal floor raceways may be used only for supplying ceiling outlets or extensions to the area below the floor of a hazardous area, but such raceways shall have no connections leading into or through the hazardous area above the floor unless suitable seals are provided. No electrical conductor shall be installed in any cell, header or duct which contains a pipe for steam, water, air, gas, drainage, or for other service except electrical.

(b) Equipment, which may produce arcs, sparks or particles of hot metal, such as lamps and lampholders for fixed lighting, cutouts, switches, receptacles, motors, or other equipment having make-and-break or sliding contacts, where installed above a hazardous area or above an area where freshly finished goods are handled shall be of the totally enclosed type or so constructed as to prevent escape of sparks or hot metal particles.

**516-8. Grounding.** All metallic raceways, and all non-current-carrying metallic portions of fixed or portable equipment, regardless of voltage, shall be grounded as provided in Article 250.




## ARTICLE 517 — HEALTH CARE FACILITIES

### A. General

**517-1. Scope.** The provisions of this Article shall apply to health care facilities. See Article 660 for medical X-ray equipment and Article 665 for therapeutic high-frequency equipment.

**Diagram 517-1. Typical Diagram for Essential Electrical Systems**



**517-2. Definitions.**

**Alternate Power Source.** One or more generator sets intended to provide power during the interruption of the normal electrical service or the public utility electrical service intended to provide power during interruption of service normally provided by the generating facilities on the premises.

**Anesthetizing Location.** Any area in which it is intended to administer any flammable or nonflammable inhalation anesthetic agents in the course of examination or treatment and includes operating rooms, delivery rooms, emergency rooms, anesthetizing rooms, corridors, utility rooms and other areas when used for induction of anesthesia with flammable or nonflammable anesthetizing agents.

**Anesthetizing-Location Receptacle.** A receptacle designed to accept the attachment plugs recognized for use in such locations. See Figures 517-2(a) and (b).

These receptacles are of a type for use in nonhazardous areas. There are also compatible receptacles for hazardous areas.

**Continuous Power System.** An electrical system, independent of the alternate source which supplies power without appreciable interruption (1-cycle or less).

**Critical Branch.** A sub-system of the emergency system consisting of feeders and branch circuits supplying energy to task illumination and selected receptacles serving areas and functions related to patient care, and which can be connected to alternate power sources by one or more transfer switches.

**Critical Patient Care Area.** A section (rooms, wards or portions of wards) designated for the treatment of critically ill patients.

**Electrically Susceptible Patient.** A patient being treated with an externalized electric conductor, such as a probe, catheter, or other electrode connected to the heart.

**Electrically Susceptible Patient Area.** A location in a health care facility where electrically susceptible patients are cared for collectively.

**Emergency System.** A system of feeders and branch circuits meeting the requirements of Article 700, connected to alternate power sources by a transfer switch and supplying energy to an extremely limited number of prescribed functions vital to the protection of life and patient safety, with automatic restoration of electrical power within 10 seconds of power interruption.

**Equipment System.** A system of feeders and branch circuits arranged for delayed, automatic or manual connection to the alternate power source and which serves primarily 3-phase power equipment. See Appendix A of Essential Electrical Systems for Hospitals, NFPA No. 76A-1971.

**Essential Electrical Systems.** Systems comprised of alternate sources of power, transfer switches, overcurrent protective devices, distribution cabinets, feeders, branch circuits, motor controls, and all connected electrical equipment, designed to provide designated areas with continuity of electrical service during disruption of normal power sources, and also designed to minimize the interruptive effects of disruption within the internal wiring system.

**Flammable Anesthetics.** Gases or vapors such as fluroxene, cyclopropane, divinyl ether, ethyl chloride, ethyl ether, and ethylene, which may form flammable or explosive mixtures with air, oxygen, or reducing gases such as nitrous oxide.

**Flammable Anesthetizing Location.** Any operating room, delivery room, anesthetizing room, corridor, utility room, or any other area if used or intended for the application of flammable anesthetics.

**Health Care Facilities.** Buildings or parts of buildings that contain, but are not limited to, hospitals, nursing homes, extended-care facilities, clinics, and medical and dental offices, whether fixed or mobile.

**Immediate Restoration of Service.** Automatic restoration of operation with an interruption of not more than 10 seconds as applied to those areas and functions served by the emergency system, except for areas and functions for which Article 700 otherwise makes specific provisions.

**Intensive Care Units.** Groups of beds, rooms, or wards specifically designated to provide intensive care for critically ill patients and intended to be specifically staffed and organized for such service, distinct from surgical or obstetrical recovery units forming a part of a surgical or obstetrical suite.

**Life Safety Branch.** A sub-system of the emergency system consisting of feeders and branch circuits, meeting the requirements of Article 700 and intended to provide adequate power needs to insure safety to patients and personnel, and which can be connected to alternate power sources by one or more transfer switches.

**Life Support Branch.** The life support branch of the emergency system supplies power centers in electrically susceptible patient locations.

**Line Isolation Monitor.** A test instrument designed to continually check the balanced and unbalanced impedance from each line of an isolated circuit to ground and equipped with a built-in test circuit to exercise the alarm without adding to the leakage current hazard.

“Line isolation monitor” was formerly known as “ground contact indicator.”

**Nurses' Stations.** Areas intended to provide a center of nursing activity for a group of nurses working under one nurse supervisor and

serving bed patients, where the patient calls are received, nurses are dispatched, nurses' notes written, inpatient charts prepared, and medications prepared for distribution to patients. Where such activities are carried on in more than one location within a nursing unit, all such separate areas are considered a part of the nurses' station.

**Probable Failure.** One or more failures of the following:

1. Any single component.
2. Any components which might fail without detection during normal use including interruption of the grounding conductor.
3. Any components which might fail as a result of the failure of any or all of the components above.

**Reference Grounding Bus, Patient.** The terminal grounding bus which serves as the single focus for grounding the electrical equipment connected to an individual patient, or for grounding the metal or conductive furniture or other equipment within reach of the patient or a person who may be touching him.

**Reference Grounding Bus, Room.** The terminal grounding bus which serves as the single focus for grounding the patient reference grounding buses and all other metal or conductive furniture, equipment, or structural surfaces in the room.

This bus may be located in or outside the room. The room reference grounding bus and the patient reference grounding bus may be a common bus if there is only one patient reference grounding bus in the room.

**Task Illumination.** Provision for the minimum lighting required to carry out necessary tasks in the described areas, including safe access to supplies and equipment, and access to exits.

## **B. General Area Wiring Systems**

**517-3. Grounding.** All noncurrent-carrying conductive surfaces and equipment that are likely to become energized and are subject to personal contact shall be grounded by one or more of the methods detailed in Article 250.

**517-4. Wiring Methods.** Except as modified in this Article, wiring methods shall comply with the applicable requirements of Chapters 1 through 4 of this Code.

## **C. Essential Electrical Systems**


For additional information see Essential Electrical Systems for Hospitals, NFPA 76A-1971 and Installation of Centrifugal Fire Pumps, NFPA No. 20-1971.

**517-10. General.**


(a) Part C applies to hospitals serving persons. It does not apply to other types of health care facilities.

(b) The essential electrical system consists of two parts: the emergency system and the equipment system. These systems shall be capable

*(Continued on page 339)*



**Figure 517-2(a).** Two-pole, 20-ampere, 3-wire grounding-type, anesthetizing-location receptacle for use in nonhazardous areas for single-phase, 125-volt AC service. See Section 517-62(e).



**Figure 517-2(b).** Two-pole, 20-ampere, 3-wire grounding-type attachment plug for use in nonhazardous areas with the anesthetizing-location receptacle shown in Figure 517-2(a).

(Continued from page 336)

of supplying a limited amount of lighting and power service considered essential for life safety, life support and effective operation during the time the normal electrical service is interrupted for any reason. See Diagram 517-1.

(c) Each emergency and equipment system shall have adequate capacity and rating for the operation of all lighting and equipment it serves.

#### **517-11. Emergency System.**

(a) The emergency system may consist of three parts: the life safety branch, the critical branch, and the life support branch. These branches shall be limited to circuits essential to specified functions.

(b) A life safety branch and a critical branch shall be required in all hospitals.

(1) The life safety branch shall serve illumination, alarm and alerting equipment which shall be operable at all times for protection of life during emergencies.

(2) The critical branch shall serve lighting and receptacles in critical patient care areas.

(3) The life support branch shall serve only power systems, or other equipments meeting the requirements of Section 517-51, in electrically susceptible patient locations. It shall be installed as a separate branch unless combined with the critical branch at the discretion of the hospital administration and with the approval of the authority having jurisdiction.

(c) The feeders for the emergency system shall be physically separated from the normal wiring or protected in such a way as to minimize the possibility of simultaneous interruption.

(d) The life safety branch, life support branch, and critical branch of the emergency system shall be run in metal raceways.

These branches shall be kept entirely independent of all other wiring and equipment and shall not enter the same raceways, boxes or cabinets with each other or other wiring.

*Exception No. 1: As permitted in 517-11(b)(3).*

*Exception No. 2: In transfer switches.*

*Exception No. 3: In exit or emergency lighting fixtures supplied from two sources.*

(e) Only those functions utilizing illumination or equipment which are listed in Sections 517-12, -13, and -14 shall be connected to the emergency system.

(f) All branches of the emergency system shall be so installed and connected to the alternate source of power that all lighting and equipment will be automatically restored to operation within 10 seconds after interruption of the normal source.

**517-12. Life Safety Branch.** The life safety branch of the emergency

system shall serve the lighting, receptacles and other equipment which are related to the safety of life as follows:

For additional information see Essential Electrical Systems for Hospitals, NFPA No. 76A-1971.

(1) Illumination of means of egress, such as lighting required for corridors, passageways, stairways and landings at exit doors, and all necessary ways of approach to exits.

See Life Safety Code, NFPA No. 101-1970, Section 5-10.

(2) Exit signs and directional signs.

See Life Safety Code, NFPA No. 101-1970, Section 5-11.

(3) Alarm systems, including: fire alarms actuated at manual stations, electric water-flow alarm devices in connection with sprinkler systems, automatic fire or smoke or products of combustion detection devices.

See Life Safety Code, NFPA No. 101-1970, Sections 6-3211, 10-1362, and 10-2344.

(4) Alarms required for systems used for the piping of nonflammable medical gases.

See Nonflammable Medical Gas Systems, NFPA No. 56F-1970.

(5) Hospital communication systems when these are intended for issuing instructions during emergency conditions, including local power requirements for the telephone system.

(6) Generator-set location, including task illumination and selected receptacles.

**517-13. Critical Branch.** The critical branch of the emergency system shall serve only the following areas and functions related to patient care:

(1) Isolating transformers serving anesthetizing locations in existing hospitals only. See Section 517-14 for new hospitals.

(2) Task illumination and selected receptacles in: (a) infant nurseries; (b) medication preparation areas; (c) pharmacy dispensing areas; (d) selected acute nursing areas; (e) psychiatric bed areas (task illumination only); (f) nurses' stations (unless adequately lighted by corridor luminaires); (g) ward treatment rooms; (h) surgical and obstetrical suites; (i) locations such as those listed in Section 517-14.

#### **517-14. Life Support Branch.**

(a) The life support branch of the emergency system shall serve only the power systems in electrically susceptible patient locations. These systems may be located in the following areas of the hospital: (1) angiographic labs; (2) cardiac catheterization labs; (3) coronary care units; (4) delivery rooms; (5) dialysis units; (6) emergency room treatment areas; (7) human physiology labs; (8) intensive care units; (9) operating rooms; (10) post-operative recovery rooms.

(b) The power systems in the above locations may be served by an uninterruptible power supply.



**517-20. Equipment Systems.**

(a) The equipment system shall be so installed and connected to the alternate source that equipment listed in Section 517-20(d) shall be automatically restored to operation at appropriate time-lag intervals following the restoration of the emergency system to operation. This arrangement shall also provide for reconnection of equipment listed in Sections 517-20(e) and (f) by either delayed, automatic, or manual operation.

(b) The equipment systems may be installed in raceways and boxes with general wiring.

(c) The equipment system shall be connected to equipment listed in Sections 517-20(d) and (e). It may be also connected to equipment listed in Section 517-20(f).

(d) The following components of the equipment system shall be arranged for automatic restoration of operation: (1) Central vacuum and medical air systems serving medical and surgical functions; (2) Sump pumps and other equipment including associated control systems and alarms required to operate for the safety of essential apparatus.

(e) The following required components of the equipment system shall be arranged for either automatic or manual connection to the alternate power source:

(1) Heating equipment for heating of operating, delivery, labor, recovery, and patient rooms, and intensive care units and nurseries.

*Exception: Patient room heating during disruption of normal source under either of the following conditions:*

*a. The outside air design temperature is higher than  $-7^{\circ}\text{C}$ , ( $+20^{\circ}\text{F}$ ).*

This is based on the median of extremes as shown in the 1967 edition of the American Society of Heating, Air Conditioning and Refrigeration Engineers Handbook of Fundamentals.

*b. The hospital is served by at least two utility services, each supplied by separate generating sources or a network distribution system fed by two or more generators. The utility services shall be routed, connected, and protected so that a fault any place between the generators and the hospital will not likely cause an interruption of more than one of the utility services.*

(2) Elevator service that will reach every patient floor, ground floors, and floors on which surgical suites and obstetrical delivery suites are located. This shall include connections for cab lighting and control and signal systems.

In instances where interruption of power will result in an elevator stopping between floors, it may be desirable to provide throw-over facilities to allow the temporary operation of any elevator to release patients or other persons who may be trapped between floors.

(3) Supply and exhaust ventilating systems for laboratory fume hoods, and surgical suites, obstetrical suites, infant nurseries, and emergency treatment spaces where such areas contain no windows.

(517-20 continued)

(f) The following components of the equipment system may be arranged for either automatic or manual connection to the alternate source:

(1) Selected autoclaving equipment if electrically heated or controlled.

(2) Other selected equipment in locations such as kitchens, laundries, radiological and central refrigeration rooms.

It is desirable that where heavy interruption currents can be anticipated, the transferred load may be reduced by use of multiple transfer devices. For example, elevator feeders may cause less hazard to electrical continuity if they are fed through individual transfer devices.

#### **517-30. Power Sources.**

(a) Essential electrical systems shall have a minimum of two independent sources of power: a normal source generally supplying the entire hospital and an alternate source(s) for use when the normal source is interrupted.

(b) The alternate source of power shall be a generator set(s) driven by some form of prime mover, and located on the premises.

*Exception: Where the normal source consists of generating units on the premises, the alternate source shall be either another generating set, or an external utility service.*

(c) For the greatest assurance of continuity of electrical service, facilities should be served by two separate full-capacity external services (Section 700-9), connected in such a manner as to pick up the load automatically and so arranged that the load will not be transferred to the generator set(s) if either external service is energized.

(d) All equipment shall be located to minimize the hazards that might cause complete failure of the equipment, such as floods, fires and icing.

(e) Electrical characteristics of the generator set(s) shall be suitable for the operation of all lighting and equipment to be served.

#### **517-40. Switching and Overcurrent Protection.**

(a) The emergency system and the equipment system shall be so arranged that in the event of interruption of the normal power source, an alternate power source shall be automatically connected within 10 seconds to the distribution panels connected to the emergency system and to the time-delay and/or manually operated switches connected to the equipment system. Where one or more generators are provided in addition to one or more external services as alternate sources, the automatic connection sequence shall connect either the alternate external service or the generator(s), whichever is arranged for automatic connection.

If the external service and the generator(s) are both arranged for automatic connection, the order of connection to these alternate power sources is an optional design choice.

(b) Automatic switching equipment shall be approved for emergency service and shall be designed and installed with interlocking provisions

that will prevent interconnection of normal and alternate sources or any two separate sources of power in any operation of the automatic switching equipment. The equipment shall be so connected that the load will be served by the normal power source, except when the normal source is interrupted. Controls and switching equipment shall be so arranged that interruption of the normal sources will automatically start an alternate source generator, automatically disconnect the interrupted normal source of power, and connect the alternate source of power in proper sequence. If a generator is the only alternate source of power time shall be allowed, but not more than 10 seconds, for the generator to attain rated voltage before its connection. Upon transfer from the normal power source to the alternate power source the loads connected to the emergency system shall be automatically energized immediately. The loads connected onto the equipment system shall be connected either automatically or manually after a time delay in such sequential manner as not to overload the generator.

When the normal power source is restored, the automatic transfer devices shall disconnect the alternate source and restore service connection to the normal power source, permitting the operation of manual switches to reconnect the normal power source.

For automatic operation, a time-delay feature should be provided to avoid short-time re-establishment of the normal source which could cause erratic operation of the transfer switch. This time delay should be set for a minimum of 15 minutes.

(c) The provisions of Section 700-18 shall apply to switches installed in exit lighting circuits.

*Exception: As provided in Section 700-20(b) switching arrangements to transfer corridor lighting in patient areas to fixtures designed for night lighting.*

For more details, see Life Safety Code, NFPA No. 101-1970.

(d) The provisions of Section 700-18, with respect to the location and installation of switches in lighting circuits other than those controlling exit lighting and exit directional signs, shall apply. Personnel ordinarily assigned to work in an area illuminated by fixtures connected to the emergency system shall be considered as authorized personnel.

This paragraph applies particularly to ungrounded circuits in anesthetizing locations connected to emergency systems.

(e) The life safety branch, the life support branch, the critical branch and the equipment system shall be protected by overcurrent devices so that interruption of service in other wiring systems, due to internal failure, will not interrupt supply to these branches or systems.

*Exception: The life safety branch and the life support branch may be supplied through a single transfer device, provided that the life support branch load is smaller than the life safety branch load.*

*Note 1:* Some small hospitals do not have intensive care units and have only a minimum of other connections on the life support branch. The life safety and life support loads may be adequately served through a single transfer device.

(517-40(e) continued)

*Note 2:* It is extremely important that the various overcurrent devices in the emergency and equipment systems be coordinated to protect against cascading operation on short-circuit faults. Primary consideration should also be given to prevent overloading of equipment by limiting the possibilities of large current inrushes due to instantaneous re-establishment of connections to heavy loads.

(f) The electrical characteristics of the transfer switches shall be suitable for the connected load.

The capacity of transfer switches should be adequate to carry full-load currents and to withstand the thermal and electromagnetic effects of short-circuit currents.

#### **D. Electrically Susceptible Patient Areas**

**517-50. General.** It is the purpose of Part D to specify the performance criteria and/or wiring methods which will minimize the hazard by the maintenance of adequately low-potential differences between conductors which could be contacted by a patient even when pertinent inherent equipment leakage currents exceed 10 microamperes.

In a health care facility, it is not feasible to prevent the occurrence of a conductive or capacitive path from the patient's body to some grounded object, because that path may be established accidentally or through instrumentation directly connected to the patient. All other electrically conductive surfaces which may make an additional contact with the patient, or other instruments which may be connected to the patient, then become possible sources of electrical currents which can traverse the patient's body. When the current path includes a small area of direct contact with the heart, a current in excess of 10 microamperes could be hazardous. Unless special precautions are taken, the power-line-frequency impedance of the patient circuit, which includes the internal conduction path through a small contact area, could be as low as 500 ohms when measured at low-current magnitudes. Under these conditions a voltage difference between the points of patient contact in excess of 5 millivolts also is considered hazardous.

#### **517-51. Performance.**

(a) In electrically susceptible patient areas the maximum 60-hertz alternating-current potential difference between any two conducting surfaces within the reach of a patient, or those persons touching the patient, shall not exceed 5 millivolts measured across 500 ohms under normal operating conditions or in case of any probable failure.

#### **(b) Special Grounding Requirements.**

(1) A patient reference grounding bus shall be provided within 5 feet of each patient bed, and shall contain approved connectors for the grounding of all metal or conductive furnishings or other nonelectrical equipment.

The patient reference grounding bus is intended to assure that all electrically conductive surfaces within reach of the patient are at the same electrical potential (within 5 millivolts). Therefore, any such surface, which might become electrically energized, should be connected to it. This requirement is not intended to apply to devices such as bed pans and other small portable nonelectrical devices.

(2) One patient reference grounding bus may serve more than one patient, but one patient shall not be served by more than one patient reference grounding bus.

(3) A separate, insulated, continuous, stranded, copper grounding conductor, not smaller than No. 12 AWG, shall be installed with the circuit conductors in the approved wiring system which connects each patient receptacle including the receptacle grounding terminal to the same patient reference grounding bus. Receptacles grouped in a common enclosure shall be connected by a single grounding conductor to the same patient reference grounding bus.

(4) The grounding conductor connecting any receptacle for that patient and the patient reference grounding bus shall not exceed 15 feet in length.

(5) An approved means of frequent periodic testing for continuity between the patient reference grounding bus and patient-connected equipment shall be provided.

The continuity tester may be either permanently mounted or portable. It should be so designed that the testing does not endanger the patient, even if grounding integrity is lost. The continuity test must include the path through all connections and grounding conductors between each piece of equipment and the patient reference grounding bus.

(6) The patient reference grounding bus and the room reference grounding bus, where separated, shall be interconnected by a continuous, insulated, stranded, copper conductor not smaller than No. 10 AWG.

(7) The room reference grounding bus shall be connected by a continuous, insulated, stranded, copper conductor, not smaller than No. 10 AWG, to the nearest available effectively grounded structural metal member of the building or to the nearest available effectively grounded metal water pipe. The room reference grounding bus may also be connected to the grounding bus in the electrical panelboard, provided that there is an individual grounding conductor, sized in accordance with Table 250-95, connected to the building service grounding point.

(8) All exposed noncurrent-carrying conductive metal surfaces, which may be within reach of the patient or within reach of persons touching the patient (e.g., gas, suction, water, heating, and drain pipes; conduits unrelated to the electrically susceptible patient area electric power distribution system; ducts; portable partitions; structural metal door or window frames), shall be connected to the room reference grounding bus.

(517-51(b) *cont'd*)

(9) Grounding of all metallic raceways shall be assured by means of grounding bushings on all conduit terminations at the panelboard and by means of an insulated, continuous, stranded, copper grounding conductor, not smaller than No. 12 AWG, extended from the grounding bus in the panelboard to the conduit grounding bushings.

(10) Grounding of metallic switch and receptacle plates shall be provided by means of the mounting-screw connections to the device mounting yokes.

(11) When using a suitable low-voltage transformer and resistor to apply a current of approximately 20 amperes between the room reference grounding bus and each grounding terminal, including each grounding contact of each receptacle, the voltage drop measured between the test points shall not exceed one volt.

For additional information on grounding, including specifications for grounding jacks and plugs, see Inhalation Anesthetics Standard, NFPA No. 56A-1971.

#### **E. Inhalation Anesthetizing Locations**

For further information regarding safeguards for anesthetizing locations, see Inhalation Anesthetics Standard, NFPA No. 56A-1971.

#### **517-60. Hazardous Areas.**

(a) Any room or space in which flammable anesthetics or volatile flammable disinfecting agents are stored shall be considered to be a Class I, Division 1 location throughout.

(b) In a flammable anesthetizing location the entire area shall be considered to be a Class I, Division 1 location, which shall extend upward to a level 5 feet above the floor.

#### **517-61. Wiring and Equipment Within Hazardous Areas.**

(a) In hazardous areas as defined in Section 517-60, all fixed wiring and equipment, and all portable equipment, including lamps and other utilization equipment, operating at more than 8 volts between conductors, shall conform to the requirements of Sections 501-1 through 501-15 and Sections 501-16(a) and (b) for Class I, Division 1 locations. All such equipment shall be specifically approved for the hazardous atmospheres involved.

(b) Where a box, fitting or enclosure is partially, but not entirely, within a hazardous area, the hazardous area shall be considered to be extended to include the entire box, fitting or enclosure.

(c) Flexible cords, which are or may be used in hazardous areas for connection to portable utilization equipment, including lamps operating at more than 8 volts between conductors, shall be of a type approved for extra-hard usage, shall be of ample length, and shall include an addi-

tional conductor for grounding. A storage device for the flexible cord shall be provided, and shall not subject the cord to bending at a radius of less than 3 inches.

(d) Anesthetizing-location receptacles and attachment plugs in hazardous areas shall be of the approved type for services of prescribed voltage, frequency, rating, and number of conductors with provision for the connection of the grounding conductor. The attachment plugs shall be designed for use without adapters in Class I, Group C hazardous locations, and shall be interchangeable with locking-type general-purpose receptacles in nonhazardous areas [See Figures 517-2(a) and (b)]. This requirement shall apply to caps and receptacles of the two-pole, 3-wire grounding-type for single-phase 125-volt AC service.

See Section 24037 of the Inhalation Anesthetics Standard, NFPA 56A-1971, for further information.

#### **517-62. Wiring and Equipment in Nonhazardous or Above Hazardous Anesthetizing Areas.**

(a) Wiring above a hazardous area as defined in Section 517-60 or in a nonhazardous anesthetizing area shall be installed in metal raceways or shall be Type MI cable, or Type ALS cable.

(b) Equipment which may produce arcs, sparks or particles of hot metal, such as lamps and lampholders for fixed lighting, cutouts, switches, receptacles, generators, motors, or other equipment having make-and-break or sliding contacts, shall be of the totally enclosed type or so constructed as to prevent escape of sparks or hot metal particles.

(c) Surgical and other lighting fixtures shall conform to Section 501-9(b).

*Exception No. 1: The surface temperature limitations set forth in Section 501-9(b)(2) shall not apply.*

*Exception No. 2: Integral or pendant switches which are located above and cannot be lowered into the hazardous area need not be explosion-proof.*

(d) Approved seals shall be provided in conformance with Section 501-5, and Section 501-5(a)(3) shall apply to horizontal as well as to vertical boundaries of the defined hazardous areas.

*Exception: Seals may be located within 18 inches of the point at which a conduit emerges from a wall forming the boundary of an anesthetizing location if all of the following conditions are met.*

*a. The junction box, switch or receptacle contains a seal-off device between the arcing contacts and the conduit.*

*b. The conduit is continuous (without coupling or fitting) between the junction box and the sealing fitting within 18 inches of the point where the conduit emerges from the wall.*

(e) Anesthetizing-location receptacles and attachment plugs in non-hazardous or above hazardous anesthetizing areas shall be of the approved type for services of prescribed voltage, frequency, rating, and number of conductors with provision for the connection of the grounding conductor. This requirement shall apply to attachment plugs and receptacles of the two-pole, 3-wire grounding-type for single-phase 125-volt AC service as shown in Figures 517-2(a) and (b).

#### **517-63. Circuits in Anesthetizing Locations.**

(a) Except as provided in Section 517-63(f), each circuit within, or partially within, an anesthetizing location as defined in Section 517-60 shall be controlled by a switch having a disconnecting pole in each circuit conductor, and shall be isolated from any distribution system supplying areas other than anesthetizing locations. Such isolation may be obtained by means of one or more transformers having no electrical connection between primary and secondary windings, by means of motor-generator sets, or by means of suitably isolated batteries.

(b) Circuits supplying primaries of isolating transformers shall operate at not more than 300 volts between conductors, and shall be provided with proper overcurrent protection. Secondary voltage of such transformers shall not exceed 300 volts between conductors, and all circuits supplied from such secondaries shall be ungrounded and shall have an approved overcurrent device of proper rating in each conductor. Circuits supplied from batteries or from generators or motor-generator sets shall be ungrounded, and shall be protected against overcurrent in the same manner as transformer-fed secondary circuits.

(c) Transformers, motor-generator sets, batteries and battery chargers, together with their overcurrent devices, shall be installed in non-hazardous locations, and shall conform to the requirements of this Code for such locations.

(d) In addition to the usual control and overcurrent protection the ungrounded system shall be provided with a line isolation monitor so arranged that a green signal lamp, conspicuously visible to persons in the anesthetizing location, remains lighted while the system is isolated from ground. An adjacent red signal lamp and an audible warning signal shall be energized when the total current (consisting of resistive and capacitive leakage currents) from either isolated conductor to ground reads 2 milliamperes under nominal voltage conditions. The line isolation monitor shall not give warning for a total hazard current less than 1.7 ma. The line isolation monitor shall be designed to have sufficient internal impedance so that, when properly connected to the isolated system, the maximum internal current that can flow through the line isolation monitor, when any point of the isolated system is grounded, is 1 ma. An ammeter, calibrated in the total hazard current of the system, shall be mounted in a plainly visible place on the line isolation monitor with the "alarm-on" (total hazard current = 2 ma) zone at approximately the center of the scale.



For maintenance tests of the line isolation monitor see Section 3422 of the Inhalation Anesthetics Standard, NFPA No. 56A-1971.

(e) A branch circuit supplying an anesthetizing location shall supply no other location.

(f) Branch circuits supplying only fixed lighting fixtures in nonhazardous areas of anesthetizing locations other than surgical lighting fixtures, or supplying only approved permanently installed X-ray equipment may be supplied by a conventional grounded system, provided: (1) wiring for grounded and ungrounded circuits does not occupy the same raceways; (2) the lighting fixtures and the X-ray equipment (except the enclosed X-ray tube and the metal-enclosed high-voltage leads to the tube) are located at least 8 feet above the floor or outside the anesthetizing location; and (3) switches for the grounded circuits are located outside of the anesthetizing location.

*Note 1:* For a description of approved permanently installed X-ray equipment see Section 2434 of the Inhalation Anesthetics Standard, NFPA No. 56A-1971.

*Note 2:* Remote-control stations for remote-control switches may be installed in the anesthetizing location if the remote-control circuit is energized from the ungrounded distribution system.

#### **517-64. Low-Voltage Equipment and Instruments.**

(a) Low-voltage equipment which is frequently in contact with the bodies of persons or has exposed current-carrying elements shall:

- (1) Operate on an electrical potential of 8 volts or less, or
- (2) Be approved as intrinsically safe or double-insulated equipment,
- (3) Be moisture resistant.

(b) Power shall be supplied to low-voltage equipment from:

- (1) An individual isolating transformer (autotransformers shall not be used) connected to an outlet receptacle by means of an anesthetizing location cord and attachment plug, or
- (2) A common isolating transformer installed in a nonhazardous location, or
- (3) From individual dry-cell batteries, or
- (4) From common batteries made up of storage cells located in a nonhazardous location.

(c) Isolating-type transformers for supplying low-voltage circuits shall:

(1) Have approved means for insulating the secondary circuit from the primary circuit, and

(2) Have the core and case grounded in an approved manner.

(d) Resistance or impedance devices may be used to control low-voltage equipment but shall not be used to limit the maximum input voltage.

(e) Battery-powered appliances shall not be capable of being charged while in operation unless their charging circuitry incorporates an integral isolating-type transformer.

(f) Any receptacle or attachment plug used on low-voltage circuits shall be of a type which does not permit interchangeable connection with circuits of higher voltage.

It should be recognized that any interruption of the circuit, even circuits as low as 8 volts, either by any switch, or loose or defective connections anywhere in the circuit, may produce a spark sufficient to ignite flammable anesthetic agents. (See Section 2438 of the Inhalation Anesthetics Standard, NFPA No. 56A-1971).

#### **517-65. Other Equipment.**

(a) Suction, pressure, or insufflation equipment involving electrical elements, and located or used within a hazardous area shall be approved for Class I locations.

(b) X-ray equipment installed or operated in an anesthetizing location as defined in Section 517-60 shall be provided with approved means for preventing accumulation of electrostatic charges. All X-ray control devices, switches, relays, meters, and transformers shall be totally enclosed, and where installed or operated within a hazardous area, shall be approved for Class I, Group C locations. High-voltage wiring shall be effectively insulated from ground and adequately guarded against accidental contact. The entire installation shall comply with Article 660.

(c) Equipment for generating high-frequency currents or voltages used in electrocautery, diathermy, television, etc., where installed or used in an anesthetizing location, shall conform to Sections 517-61 and 517-62.

**517-66. Grounding.** In any anesthetizing area, all metallic raceways, and all noncurrent-carrying conductive portions of fixed or portable equipment including the conductive floor shall be grounded.

*Exception: Equipment operating at not more than 8 volts between conductors need not be grounded.*

#### **F. Communications, Signaling Systems, and Data Systems**

**517-80. Electrically Susceptible Patient Areas.** Isolation and grounding equivalent to that required for the electrical distribution systems

in this Article for these areas shall also be provided. See also Articles 725 and 800.

An acceptable alternate means of providing isolation for patient/nurse call systems is by the use of only nonelectrified signaling, communication or control devices held by the patient or within reach of the patient.

## ARTICLE 520 — THEATERS AND ASSEMBLY HALLS

### A. General

**520-1. Scope.** The requirements of this Article shall apply to all buildings, or part of a building, designed, intended, or used for dramatic, operatic, motion-picture or other shows, and night clubs, dance halls, armories, sporting arenas, bowling alleys, public auditoriums, television studios and like buildings used for public assembly.

**520-2. Motion-Picture Projectors.** Motion-picture equipment and its installation and use shall comply with Article 540.

**520-3. Sound Reproduction.** Sound-reproducing equipment and its installation shall comply with Article 640.

**520-4. Wiring Method.** The wiring method shall be metal raceways, Type ALS cable or Type MI cable except as follows:

*Exception No. 1: As provided in Article 640, Sound Reproduction, in Article 800, Communication Circuits, and in Article 725 for Class 2 Remote Control and Signal Circuits.*

*Exception No. 2: Where the area intended for public assembly has a capacity of less than 200 persons, Type AC metal-clad cable as provided in Article 334 may be used, or for concealed work, concealed knob-and-tube work or nonmetallic-sheathed cable as provided in Articles 324 and 336 may also be used.*

For recommendations for determination of population capacity, refer to Life Safety Code (NFPA No. 101-1970).

*Exception No. 3: The wiring for stage set lighting and stage effects and other wiring which is not fixed as to location shall be done with approved portable cables and approved flexible cords.*

**520-5. Number of Conductors in Raceway.** The number of conductors permitted in any metal conduit or electrical metallic tubing for border or stage pocket circuits or for remote-control conductors shall not exceed that shown in Table 1 of Chapter 9. When contained within an auxiliary gutter or a wireway, the sum of the cross-sectional areas of all contained conductors at any cross section shall not exceed 20 percent of the interior cross-sectional area of the auxiliary gutter or wireway. The 30-conductor limitation of Section 362-5 or 374-5 shall not apply.

**520-6. Enclosing and Guarding Live Parts.** Live parts shall be enclosed or guarded to prevent accidental contact by persons and objects. All switches shall be of the externally operable type. Rheostats shall be placed in approved cases or cabinets which enclose all live parts, having only the operating handles exposed.

## **B. Fixed Stage Switchboard**

**520-21. Dead Front.** Stage switchboards shall be of the dead-front type and shall conform to Part C of Article 384 unless approved for the purpose.

**520-22. Guarding Back of Switchboard.** Stage switchboards having exposed live parts on the back of such boards shall be enclosed by the building walls, wire mesh grills, or by other approved methods. The entrance to this enclosure shall be by means of a self-closing door.

**520-23. Control and Overcurrent Protection of Receptacle Circuits.** Means shall be provided at the stage switchboard for the control and individual overcurrent protection of branch circuits to stage and gallery receptacles used for portable stage equipment.

**520-24. Metal Hood.** A stage switchboard that is not completely enclosed dead-front and dead-rear or recessed into a wall shall be pro-

vided with a metal hood extending the full length of the board to protect all equipment on the board from falling objects.

**520-25. Dimmers.** Dimmers shall conform to the following:

**(a) Disconnection and Overcurrent Protection.** Where dimmers are installed in ungrounded conductors, each dimmer shall have overcurrent protection not greater than 125 percent of the dimmer rating, and shall be disconnected from all ungrounded conductors when the master or individual switch or circuit-breaker supplying such dimmer is in the open position.

**(b) Resistance or Reactor Type Dimmers.** Resistance or series reactor type dimmers may be placed in either the grounded or the ungrounded conductor of the circuit. Where designed to open either the supply circuit to the dimmer or the circuit controlled by it, the dimmer shall then comply with Section 380-1.

It is recommended that resistance or reactor type dimmers be placed in the grounded neutral conductor of the circuit provided they do not open the circuit.

**(c) Autotransformer-Type Dimmers.** The circuit supplying an autotransformer-type dimmer shall not exceed 150 volts between conductors. The grounded conductor shall be common to the input and output circuits. See Section 200-4.

### C. Stage Equipment — Fixed

**520-41. Circuit Loads.** Footlights, border lights, and proscenium side lights shall be so arranged that no branch circuit supplying such equipment will carry a load exceeding 20 amperes; provided that where heavy-duty lampholders only are used, such circuits may conform to the provisions of Article 210 for circuits supplying heavy-duty lampholders.

**520-42. Conductor Insulation.** Foot, border, proscenium, or portable strip light fixtures shall be wired with conductors having insulation suitable for the temperatures at which the conductors will be operated and not less than 125 °C (257°F). See Table 310-2(a).

**520-43. Footlights.**

**(a)** Where metal trough construction is employed for footlights, the trough containing the circuit conductors shall be made of sheet metal not lighter than No. 20 MSG treated to prevent oxidation. Lampholder terminals shall be kept at least ½ inch from the metal of the trough. The circuit conductors shall be soldered to the lampholder terminals.

**(b)** Where the metal trough construction specified in Section 520-43(a) is not used, footlights shall consist of individual outlets with lampholders, wired with rigid or flexible metal conduit, Type ALS cable or Type MI cable. The circuit conductors shall be soldered to the lampholder terminals. Disappearing footlights shall be so arranged that the current supply shall be automatically disconnected when the footlights are replaced in the recess designed therefor.

**520-44. Borders and Proscenium Sidelights.**

(a) Borders and proscenium sidelights shall be constructed as prescribed in Section 520-43, shall be suitably stayed and supported, and shall be so designed that the flanges of the reflectors or other adequate guards will protect the lamps from mechanical injury and from accidental contact with scenery or other combustible material.

(b) **Cables for Border Lights.** Cables for supply to border lights shall be Type S, SO, or ST flexible cord. See Table 400-11. The cables shall be suitably supported. Such cables shall be employed only where flexible conductors are necessary.

**520-45. Receptacles.** Receptacles intended for the supply of arc lamps shall have not less than 50 amperes capacity and shall be supplied by conductors not smaller than No. 6. Receptacles intended for the supply of incandescent lamps shall have not less than 20 amperes capacity and shall be supplied by conductors not smaller than No. 12. Plugs for arc and incandescent receptacles shall not be interchangeable.

**520-46. Stage Pockets.** Receptacles intended for the connection of portable stage lighting equipment shall be mounted in suitable pockets or enclosures, and shall comply with the requirements of Section 520-45.

**520-47. Lamps in Scene Docks.** Lamps installed in scene docks shall be so located and guarded as to be free from mechanical injury and provide an air space of not less than 2 inches between such lamps and any combustible material.

**520-48. Curtain Motors.** Curtain motors having brushes or sliding contacts shall comply with one of the following conditions:

(a) Be of the totally enclosed, enclosed-fan-cooled, or enclosed-pipe-ventilated types.

(b) Be enclosed in separate rooms or housings built of noncombustible materials so constructed as to exclude flyings or lint, and properly ventilated from a source of clean air.

(c) Have brush or sliding-contact end of motor enclosed by solid metal covers.

(d) Have brushes or sliding contacts enclosed in substantial, tight, metal housings.

(e) Have the upper half of brush or sliding-contact end of the motor enclosed by a wire screen or perforated metal and the lower half enclosed by solid metal covers.

(f) Have wire screens or perforated metal placed at the commutator or brush ends. No dimension of any opening in the wire screen or perforated metal shall exceed .05 inch, regardless of the shape of the opening and of the material used.

**520-49. Flue Damper Control.** Where stage flue dampers are released by an electrical device, the circuit operating the latter shall be normally closed and shall be controlled by at least two externally operable switches, one switch being placed at the electrician's station and the other where designated by the authority having jurisdiction. The device shall be designed for the full voltage of the circuit to which it is con-

nected, no resistance being inserted. The device shall be located in the loft above the scenery and shall be enclosed in a suitable iron box having a tight, self-closing door.

#### **D. Portable Switchboards on Stage**

**520-51. Supply.** Portable switchboards shall be supplied only from outlets especially provided for this purpose. Such outlets shall include externally operable, enclosed fused switches or circuit breakers mounted on the stage wall or at the switchboard in locations readily accessible from the stage floor.

**520-52. Overcurrent Protection.** Circuits from portable switchboards directly supplying equipment containing incandescent lamps of not over 300 watts shall be protected by overcurrent devices having a rating or setting of not more than 20 amperes. Circuits for lampholders over 300 watts may be used where overcurrent protection conforms to the provisions of Article 210. Other circuits shall be provided with overcurrent devices with a rating or setting not higher than the current required for the connected load.

**520-53. Construction.** Portable switchboards for use on stages shall comply with the following:

(a) **Enclosure.** Portable switchboards shall be placed within an enclosure of substantial construction which may be so arranged that the enclosure is open during operation. Enclosures of wood shall be completely lined with sheet metal of not less than No. 24 MSG and shall be well galvanized, enamelled, or otherwise properly coated to prevent corrosion or be of a corrosion-resistant material.

(b) **Live Parts.** Except as provided for dimmer faceplates in Section 520-53(e), there shall be no exposed live parts within the enclosure.

(c) **Switches and Circuit Breakers.** All switches and circuit breakers shall be of the externally operable, enclosed type.

(d) **Circuit Protection.** Overcurrent devices shall be provided in each ungrounded conductor of every circuit supplied through the switchboard. Enclosures shall be provided for all overcurrent devices in addition to the switchboard enclosure.

(e) **Dimmers.** The terminals of dimmers shall be provided with enclosures, and dimmer face plates shall be so arranged that accidental contact cannot be readily made with the face-plate contacts.

(f) **Interior Conductors.** All conductors within the switchboard enclosure shall be stranded and, except for cables feeding to or from the switchboard, shall be asbestos-covered Type AA or other types approved for a maximum operating temperature of 200°C (392°F). Each conductor shall have an ampacity at least equal to the rating of the circuit breaker, switch or fuse which it supplies, except for conductors for incandescent lamp circuits having overcurrent protection not exceeding 20 amperes. Conductors shall be enclosed in metal troughs or securely fastened in position and shall be bushed where they pass through metal.

(g) **Pilot Light.** A pilot light shall be provided within the enclosure and shall be so connected to the circuit supplying the board that the

(520-53(g) continued)

opening of the master switch will not cut off the supply to the lamp. This lamp shall be on an independent circuit having overcurrent protection of a rating or setting of not more than 15 amperes.

**(h) Supply Connections.** The supply to a portable switchboard shall be by means of flexible cord (Type S, SO, or ST) terminating within the switchboard enclosure or in an externally operable fused master switch or circuit breaker. The supply cable shall have sufficient ampacity to carry the total load on the switchboard and shall be protected by overcurrent devices.

**(i) Cable Arrangement.** Cables shall be protected by bushings where they pass through enclosures and shall be so arranged that tension on the cable will not be transmitted to the connections.

**(j) Terminals.** Terminals to which stage cables are connected shall be so located as to permit convenient access to the terminals. At terminals not provided with approved pressure connectors the following construction shall be employed:

(1) For conductors of No. 10 or larger, solder lugs shall be used.

(2) For conductors smaller than No. 10, the strands shall be soldered together where connected to clamps or binding screws not specifically approved as pressure connectors.

### **E. Stage Equipment — Portable**

**520-61. Arc Lamps.** The construction of arc lamps shall be approved by the authorities having jurisdiction.

**520-62. Portable Plugging Boxes.** Portable plugging boxes shall conform to the following:

**(a) Enclosure.** The construction shall be such that no current-carrying part will be exposed.

**(b) Receptacles and Overcurrent Protection.** Each receptacle shall have a rating of not less than 30 amperes, and shall have overcurrent protection which shall be installed in an enclosure equipped with self-closing doors.

**(c) Bus-bars and Terminals.** Bus-bars shall have an ampacity equal to the sum of the ampere ratings of all the receptacles. Lugs shall be provided for the connection of the master cable.

### **520-63. Lights on Scenery.**

**(a)** Brackets on scenery shall be wired internally and the fixture stem shall be carried through to the back of the scenery where a bushing shall be placed on the end of the stem, except that externally wired brackets or other fixtures may be used when wired with cords designed for hard usage which shall extend through scenery and without joint or splice in canopy of fixture back and terminate in an approved type stage connector located within 18 inches of the fixture, unless such location is impractical.

**(b)** Fixtures shall be securely fastened in place.

**520-64. Portable Strips.** Portable strips shall be constructed in accordance with the requirements for border lights and proscenium side



lights in Section 520-44(a). The supply cable shall be protected by bushings where it passes through metal and shall be so arranged that tension on the cable will not be transmitted to the connections. See Section 520-42 for wiring of portable strips.

**520-65. Festoons.** Joints in festoon wiring shall be staggered where practicable. Lamps enclosed in lanterns or similar devices of combustible material shall be equipped with approved guards.

**520-66. Special Effects.** Electrical devices used for simulating lightning, waterfalls, and the like, shall be so constructed and located that flames, sparks, or hot particles cannot come in contact with combustible material.

**520-67. Cable Connectors.** Cable connectors for flexible conductors shall be so constructed that tension on the cord or cable will not be transmitted to the connections. See Section 400-10. The female half of the connector shall be attached to the line end of the cord or cable.

**520-68. Conductors for Portables.** Flexible conductors used to supply portable stage equipment shall be Type S, SO or ST, except that reinforced cord may be used to supply stand lamps where the cord is not liable to severe physical damage and is protected by an overcurrent protection rated at not over 20 amperes.

#### F. Dressing Rooms

**520-71. Pendant Lampholders.** Pendant lampholders shall not be installed in dressing rooms.

**520-72. Lamp Guards.** All incandescent lamps in dressing rooms, where less than 8 feet from the floor, shall be equipped with open-end guards riveted to the outlet box cover or otherwise sealed or locked in place.

**520-73. Switches Required.** All lights and receptacles in dressing rooms shall be controlled by wall switches installed in the dressing rooms. Each switch controlling receptacles shall be provided with a pilot light to indicate when the receptacle or receptacles are energized.

#### G. Grounding

**520-81. Grounding.** All metal raceways shall be grounded. The metal frames and enclosures of equipment including border lights shall be grounded, except the frames and enclosures of portable equipment on grounded circuits operating at not over 150 volts to ground and not within reach of grounded surfaces. Grounding, when employed, shall be done in the manner specified in Article 250.

## ARTICLE 530 — MOTION-PICTURE STUDIOS AND SIMILAR LOCATIONS

### A. General

**530-1. Scope.** The requirements of this Article shall apply to television studios (except as covered in Section 520-1), motion-picture studios, exchange, factory, laboratory, stage, or a portion of the building in which motion-picture films more than  $\frac{7}{8}$  inch in width are manufactured, exposed, developed, printed, cut, edited, rewound, repaired or stored.

For the purpose of this Article, a motion-picture studio is one in which photographic film is used to record action. A television studio shall mean one which employs the use of electronic cameras only.

For recommendations for protection against cellulose nitrate film hazards refer to NFPA Standard for the Storage and Handling of Cellulose Nitrate Motion Picture Film (No. 40-1967).

### B. Stage or Set

**530-11. Permanent Wiring.** The permanent wiring shall be Type ALS cable, Type MI cable or in approved metal raceways.

*Exception: Communication circuits, and sound recording and reproducing equipment may be wired as permitted by the Articles covering those installations. (See Articles 640 and 800).*

**530-12. Portable Wiring.** The wiring for stage set lighting and stage effects, and other wiring which is not fixed as to location, shall be done with approved portable cables and approved flexible cords. This requirement shall not apply to portable lamps or other electrical equipment used as properties in a motion picture set, on a studio stage or lot, or on location.

**530-13. Stage Lighting and Effects Control.** Switches used for studio stage set lighting and effects (on the stages and lots and on location) shall be of the externally operable type. When contactors are used as the disconnecting means for fuses, an individual externally operable type switch (such as a tumbler switch) for the control of each contactor, shall be located at a distance of not more than 6 feet from the contactor, in addition to remote-control switches.

*Exception: A single externally operable switch may be used to simultaneously disconnect all the contactors on any one location board, where located at a distance of not more than 6 feet from the location board.*

**530-14. Plugging Boxes.** Each receptacle of plugging boxes shall have an ampacity of not less than 30 amperes.

**530-15. Enclosing and Guarding Live Parts.**

(a) Live parts shall be enclosed or guarded to prevent accidental contact by persons and objects.

(b) All switches shall be of the externally operable type.

(c) Rheostats shall be placed in approved cases or cabinets which enclose all live parts, having only the operating handles exposed.

(d) Current-carrying parts of "bull-switches," "location boards," "spiders," and plugging boxes shall be so enclosed, guarded, or located that persons cannot accidentally come into contact with them or bring conducting materials into contact with them.

**530-16. Portable Lamps.** Portable lamps and work lights shall be equipped with approved portable cords, approved composition or metal-sheathed porcelain sockets and substantial guards.

*Exception: The requirements of this Section shall not apply to portable lamps used as properties in a motion picture set or television stage set, on a studio stage or lot, or on location.*

**530-17. Portable Arc Lamps.** Portable arc lamps shall be substantially constructed. The arc shall be provided with an enclosure designed to retain sparks and carbons and to prevent persons or materials from coming into contact with the arc or bare live parts. The enclosures shall be ventilated. All switches shall be of the externally operable type.

**530-18. Overcurrent Protection — Short-Time Rating.\***

**General.** Automatic overcurrent protective devices (circuit breakers or fuses) for motion-picture studio stage set lighting and the stage cables for such stage set lighting, shall be as given in paragraphs (a) through (e) below.

Note: \*Special consideration is given to motion-picture studios and similar locations because filming periods are of short duration.

(a) **Stage Cables.** Stage cables for stage-set lighting shall be protected by means of overcurrent devices set at not more than 400 percent of the values given in Tables 310-12 through 310-15 and Table 400-9(b).

(b) **Feeders.** In buildings used primarily for motion-picture production the feeders from the substations to the stages shall be protected by means of overcurrent devices having suitable ampacity (generally located in the substation). The overcurrent devices may be double-pole, or two single-pole gang-operated devices may be used. There need be no pole or overcurrent coil in the neutral conductor. The overcurrent device setting for each feeder shall not exceed 400 percent of the ampacity of the feeder, as given in Table 310-12 for the kind of insulation used.

(c) **"Location Boards."** Overcurrent protection (fuses or circuit breakers) shall be provided at the "location boards." The fuses in the "location boards" shall be not larger in rating than 400 percent of the ampacity of the cables between the "location boards" and the plugging boxes.

(d) **Plugging Boxes.** Where plugging boxes are not provided with overcurrent protective devices, each cable or cord smaller than No. 8 supplied through a plugging box shall be attached to the plugging box by means of a plug containing two cartridge fuses or a circuit breaker. The rating of the fuses or the setting of the circuit breaker shall be not more than 400 percent of the safe ampacity of the cables or cords as

given in Tables 310-12, 310-13 and 400-9(b) for the kind of insulation used.

(e) **Lighting.** Work-lights, stand-lamps, and fixtures shall be connected to plugging boxes by means of plugs containing two cartridge fuses not larger than 20 amperes, or they may be connected to special outlets on circuits protected by fuses or circuit-breaker settings of not more than 20 amperes. Plug fuses shall not be used unless they are on the load side of the fuse or circuit breakers on the "location boards."

#### **530-19. Sizing of Feeder Conductors: Television Studio Sets.**

(a) **General.** The demand factors listed in Table 530-19(a) may be applied to that portion of the maximum possible connected load for studio or stage set lighting for all permanently installed feeders between substations and stages and to all permanently installed subfeeders between the main stage switchboard and stage distribution centers or location boards.

**Table 530-19(a). Demand Factors for Stage Set Lighting**

<b>Total Stage Set Lighting Load (Wattage)</b>	<b>Feeder Demand Factor</b>
First 50,000 or less at	100%
Next 50,001 to 100,000 at	75%
Next 100,001 to 200,000 at	60%
All over 200,000	50%

(b) **Portable Feeders.** A demand factor of 50 percent of maximum possible connected load may be applied to all portable feeders.

**530-20. Grounding.** Conduit, metal-clad cable or metal raceways, and all noncurrent-carrying metal parts of appliances, devices and equipment shall be grounded as prescribed in Article 250. This shall not apply to pendant and portable lamps, nor to stage lighting and stage sound equipment, nor to other portable or semiportable special stage equipment, operating at not more than 150 volts to ground.

### **C. Dressing Rooms**

**530-31. Dressing Rooms.** Fixed wiring in dressing rooms shall be installed in accordance with wiring methods covered in Chapter 3. Wiring for portable dressing rooms shall be of an approved type.

### **D. Viewing, Cutting and Patching Tables**

**530-41. Lamps at Tables.** Only approved composition or metal-sheathed porcelain keyless lampholders, equipped with suitable means to guard lamps from physical damage and from film and film scrap, shall be used at patching, viewing and cutting tables.

### **E. Film Storage Vaults**

**530-51. Lamps in Cellulose Nitrate Film Storage Vaults.** Lamps in cellulose nitrate film storage vaults shall be rigid fixtures of the glass enclosed and gasketed type. Lamps shall be controlled by a switch having a pole in each ungrounded conductor. This switch shall be located

outside of the vault and provided with a pilot light to indicate whether the switch is on or off. This switch shall disconnect from all sources of supply all ungrounded conductors terminating in any outlet in the vault.

**530-52. Motors and Other Electrical Equipment in Film Storage Vaults.** No electric motors, heaters, portable lights, or other portable electric equipment shall be located in the film storage vaults.

#### F. Substations

**530-61. Substations.** Wiring and equipment above 600 volts shall conform to Article 710.

**530-62. Low-Voltage Switchboards.** On 600 volts or less switchboards shall conform to Article 384.

**530-63. Overcurrent Protection of DC Generators.** Three-wire DC generators shall have protection consisting of overcurrent devices having current ratings or settings in accordance with the generator rating. The overcurrent protective devices may be single-pole or two-pole and need not have a pole or overcurrent coil in the neutral lead (whether it is grounded or ungrounded).

**530-64. Working Space and Guarding.** Working space and guarding in permanent fixed substations shall conform to Sections 110-16 and 110-17. For guarding of live parts on motors and generators, see Sections 430-11 and 430-14. Switchboards for voltage of not more than 250 volts DC between conductors when located in substations or switchboard rooms accessible to qualified persons only need not be dead-front.

**530-65. Portable Substations.** Wiring and equipment in portable substations shall conform to the sections applying to installations in permanent fixed substations, but, due to the limited space available, the working spaces may be reduced, provided that the equipment shall be so arranged that the operator may do his work safely, and so that other persons in the vicinity cannot accidentally come into contact with current-carrying parts or bring conducting objects into contact with them while they are energized.

**530-66. Grounding at Substations.** Noncurrent-carrying metal parts shall be grounded except the frames of DC circuit breakers installed on switchboards.

## ARTICLE 540 — MOTION-PICTURE PROJECTORS

### A. General

**540-1. Scope.** This Article applies to motion-picture projectors and associated equipment of the Professional and Nonprofessional Types.

### B. Equipment and Projectors of the Professional Type

**540-10. Professional Projector — Definition.** The professional projector employs a 35-millimeter film which is  $1\frac{3}{8}$  inch wide and has on

each edge 5.4 perforations per inch. Wider film such as 70-millimeter may be employed.

**540-11. Enclosure.** The professional type of projector, such as is commonly used in theaters and motion-picture houses, shall be located in an approved enclosure. Such enclosure shall not be considered as a hazardous location as defined in Article 500.

**540-12. Motor-Driven Projectors.** Motor-driven projectors shall be approved for the purpose as an assembly or shall comply with all of the following conditions:

- (a) An approved projector shall be used.
- (b) An approved projector lamp shall be used.
- (c) Motors shall be so designed or guarded as to prevent ignition of film by sparks or arcs.
- (d) Projectors shall be in charge of a qualified operator.

**540-13. Conductor Size.** Conductors supplying outlets for arc projectors of the professional type shall not be smaller than No. 8 and shall be of sufficient size for the projector employed. Conductors for incandescent-type projectors shall conform to normal wiring standards as provided in Section 210-25.

**540-14. Conductors on Lamps and Hot Equipment.** Asbestos covered conductors Type AA or other types of insulated conductors having a maximum operating temperature of 200°C (392°F) shall be used on all lamps or other equipment where the ambient temperature at the conductors as installed will exceed 50°C (122°F).

**540-15. Flexible Cords.** Cords approved for hard service in Table 400-11 shall be used on portable equipment.

**540-16. Lamp Guards.** Incandescent lamps in projection rooms or booths shall be provided with an approved lamp guard unless otherwise protected by noncombustible shades or other enclosures.

**540-17. Location of Equipment.** Motor-generator sets, transformers, rectifiers, rheostats, and similar equipment, for the supply or control of current to arc lamps on projectors shall, if practicable, be located in separate rooms. Where placed in the projector room, they shall be so located or guarded that arcs or sparks cannot come in contact with film, and motor-generator sets shall have the commutator end or ends protected as provided in Section 520-48.

**540-18. Construction and Ventilation.** It is recommended that the authority having jurisdiction over the construction and ventilation of rooms for professional type projectors refer to the NFPA Standard for the Storage and Handling of Cellulose Nitrate Motion Picture Film (NFPA No. 40-1967).

**540-19. Equipment Prohibited.** Switches, overcurrent devices, or other equipment not normally required or used for projectors, sound reproduction, flood, or other special effect lamps or other equipment shall not be installed in such booths or rooms.

*Exception: Remote-control switches for the control of auditorium lights or a switch for the motor operating the curtain at the motion-picture screen.*

**540-20. Approval.** Projectors and enclosures for arc or incandescent lamps, rectifiers, transformers, rheostats, and similar equipment, shall be of an approved type.

**540-21. Marking.** Projectors and other equipment as set forth in Section 540-20 shall be marked with the name or trademark of the maker and with the voltage and current for which they are designed.

**540-22. Rewinding, Examination and Storage of Extra Films.** It is recommended that the authority having jurisdiction refer to the Standard for the Storage and Handling of Cellulose Nitrate Motion Picture Film (NFPA No. 40-1967).

See Sections 530-51 and 530-52. Also see Section 530-41 for viewing tables.

### **C. Nonprofessional Type Projectors**

**540-30. Definition.** The nonprofessional projector employs film other than that used on professional-type projectors.

**540-31. Booth Not Required.** Projectors of the nonprofessional or miniature type, when employing only approved slow-burning (cellulose acetate or equivalent) film, may be operated without a booth.

**540-32. Approval.** Projectors, lamp enclosures, and current-controlling devices and similar devices shall be approved as component parts of the projector equipment.

**540-33. Source of Illumination.** The source of illumination shall be a lamp or a type approved for stereopticon use or for motion-picture projection.

**540-34. Marking.** Projectors shall be marked with name or trademark of the maker, with the current and voltage for which they are designed, and for projectors of this type using the standard 35-millimeter film, with the wording "For use with slow-burning films only."

**540-35. Nonprofessional Film Marking.** The slow-burning (cellulose acetate or equivalent) film shall have a permanent distinctive marker for its entire length identifying the manufacturer and the slow-burning character of the film stock.

### **D. Sound Recording and Reproduction**

**540-50. Sound Recording and Reproduction.** Sound recording and reproduction equipment shall comply with Article 640.

## **ARTICLE 550 — MOBILE HOMES AND MOBILE HOME PARKS**

### **550-1. Scope.**

(a) The provisions of this Article cover the electrical conductors and equipment installed within or on mobile homes, the conductors that connect mobile homes to a supply of electricity, and the installation of electrical wiring, fixtures, equipment and appurtenances related to elec-

trical installations within a mobile home park up to the mobile home service-entrance conductors or, if none, the mobile home service equipment.

Wherever the requirements of other Articles of this Code and Article 550 differ, the requirements of Article 550 shall apply.

For requirements on body and frame design, construction, and the installation of plumbing and heating systems in mobile homes refer to Standard for Mobile Homes (NFPA No. 501B-1971).

(b) A mobile home not intended as a dwelling unit, as for example, equipped for sleeping purposes only, contractor's on-site offices, construction job dormitories, mobile studio dressing rooms, banks, clinics, mobile stores or intended for the display or demonstration of merchandise or machinery, shall not be required to meet the provisions of this Article pertaining to the number or capacity of circuits required. It shall, however, meet all other applicable requirements of this Article if provided with an electrical installation intended to be energized from a 115-volt or 115/230-volt AC power supply system.

(c) The provisions of this Article apply to mobile homes intended for connection to a wiring system nominally rated 115/230 volts, 3-wire AC, with grounded neutral.

## **550-2. Definitions.**

**Feeder Assembly.** The overhead or under-chassis feeder conductors, including the grounding conductor, together with the necessary fittings and equipment or a power-supply cord approved for mobile home use, designed for the purpose of delivering energy from the source of electrical supply to the distribution panelboard within the mobile home.

**Mobile Home.** A factory-assembled structure or structures equipped with the necessary service connections and made so as to be readily movable as a unit or units on their own running gear and designed to be used as a dwelling unit(s) without a permanent foundation.

The phrase "without a permanent foundation" indicates that the support system is constructed with the intent that the mobile home placed thereon will be moved from time to time at the convenience of the owner.

**Mobile Home Accessory Building or Structure:** Any awning, cabana, ramada, storage cabinet, carport, fence, windbreak or porch established for the use of the occupant of the mobile home upon a mobile home lot.

**Mobile Home Lot:** A designated portion of a mobile home park designed for the accommodation of one mobile home and its accessory buildings or structures for the exclusive use of its occupants.

**Mobile Home Park:** A contiguous parcel of land which is used for the accommodation of occupied mobile homes.

**Mobile Home Service Equipment.** The equipment containing the disconnecting means, overcurrent protective devices, and receptacles or other means for connecting a mobile home feeder assembly.

**Park Electrical Wiring System.** All of the electrical wiring, fixtures, equipment and appurtenances related to electrical installations within a mobile home park, including the mobile home service equipment.



### A. Mobile Homes

#### 550-3. Power Supply.

(a) The mobile home service equipment shall be located adjacent to the mobile home and not mounted in or on the mobile home. The power supply to the mobile home shall be a feeder assembly consisting of not more than 3 mobile home power-supply cords, each rated 50 amperes or a permanently installed circuit.

*Exception: A mobile home that is factory-equipped with gas or oil-fired central heating equipment and cooking appliances may be provided with a mobile home power-supply cord rated 40 amperes.*

(b) If the mobile home has a power-supply cord, it shall be permanently attached to the distribution panelboard or to a junction box permanently connected to the distribution panelboard, with the free end terminating in an attachment plug cap.

(c) Cords with adapters and pigtail ends, extension cords, and similar items shall not be attached to, or shipped with, a mobile home.

(d) A suitable clamp or the equivalent shall be provided at the distribution panelboard knockout to afford strain relief for the cord to prevent strain from being transmitted to the terminals when the power supply cord is handled in its intended manner.

(e) The cord used shall be of an approved type with four conductors, one of which shall be identified by a continuous green color or a continuous green color with one or more yellow stripes for use as the grounding conductor.

(f) The attachment plug cap shall be 3-pole, 4-wire grounding type, in accordance with American National Standard Dimensions of Caps, Plugs and Receptacles, Grounding Type, General Purpose, 125/250 volts, 50 amperes, 3-pole, 4-wire (ANSI C73.17-1966), intended for use with a receptacle rated 50 amperes, 125/250 volts. It shall be molded of butyl rubber, neoprene, or other approved materials which have been found suitable for the purpose, and shall be molded to the flexible cord so that it adheres tightly to the cord at the point where the cord enters the attachment plug cap. If a right-angle cap is used, the configuration shall be so oriented that the grounding member is farthest from the cord.

(g) The overall length of a power-supply cord, measured from the end of the cord, including bared leads, to the face of the attachment plug cap shall be no less than 21 feet and shall not exceed 36½ feet. The length of the cord from the face of the attachment plug cap to the point where the outer jacket of the cord is removed shall be at least 20½ feet.

(h) The power-supply cord shall bear the following marking: "For use with mobile homes — 40 amperes" or "For use with mobile homes — 50 amperes."

(i) The point of entrance of the feeder assembly to the mobile home shall be in the exterior wall, floor, or roof, in the rear third section (away from the coupler) of the mobile home.

(i) Where a separately metered appliance is installed in the mobile home, or where the calculated load of the mobile home is between 50 amperes and 150 amperes, up to three 50-ampere power-supply cords may be installed when permitted by the authority having jurisdiction, or a feeder as provided for in Section 550-3(a) or 550-3(k) may be installed. The additional power-supply cords shall be located not more than 12 inches away from the point of entrance of the main power-supply cord. They shall not be interconnected on either the line side or the load side, except that the grounding means shall be electrically interconnected.

(k) Where the calculated load exceeds 150 amperes or where a permanent feeder is used, the supply shall be by means of:

(1) one mast weatherhead installation installed in accordance with Article 230 and shall contain 4 continuous, insulated, color-coded, feeder conductors, one of which shall be a grounding conductor; or,

(2) an approved metal raceway from the disconnecting means in the mobile home to the underside of the mobile home with provisions for the attachment to a suitable junction box or fitting to the raceway on the underside of the mobile home (with or without conductors as in Section 550-3(k)(1)).

#### **550-4. Disconnecting Means and Branch-Circuit Protective Equipment.**

The branch-circuit equipment may be combined with the disconnecting means as a single assembly. Such a combination may be designated as a distribution panel. If a fused distribution panel is used, the maximum fuse size for the mains shall be plainly marked as follows, with lettering at least  $\frac{1}{4}$  inch high where visible when fuses are changed: "Maximum Main Fuses 40 (or 50) Amp."

Plug fuses and fuseholders shall be tamper-resistant, Type "S," enclosed in dead-front fuse panels.

(a) **Disconnecting Means.** A disconnecting means shall be provided in each mobile home, consisting of circuit breakers or a switch and fuses and their accessories installed in a readily accessible location near the point of entrance of the supply cord or conductors into the mobile home. This equipment shall contain a solderless type of grounding connector or bar for the purposes of grounding with sufficient terminals for all grounding conductors. The neutral bar termination of the grounded circuit conductors shall be insulated. The disconnecting equipment shall have a rating suitable for the connected load. The distribution equipment, either circuit breaker or fused type, shall be located a minimum of 24 inches from the bottom of such equipment to the floor level of the mobile home.

Where more than one power-supply cord is installed, disconnecting means shall be provided for each cord and may be combined in a single equipment but without electrical interconnections other than for grounding purposes.

A distribution panel main circuit breaker shall be rated 50 amperes and employ a 2-pole circuit breaker rated 40 amperes for a 40-ampere supply cord, or 50 amperes for a 50-ampere supply cord. A distribution panel employing a disconnect switch and fuses shall be rated 60

amperes and shall employ a single 2-pole 60-ampere fuseholder with 40- or 50-ampere main fuses for 40- or 50-ampere supply cords, respectively. The outside of the distribution panel shall be plainly marked with the fuse size. The main circuit breakers or fuses shall be plainly marked "Main."

The distribution panel may be located with its front just inside a closet entry, or it may be located in a closet above any shelf or floor if the location is such that a clear space of 6 inches is maintained in front of the distribution panel. However, working space shall be provided as required by Section 110-16.

**(b) Branch-Circuit Protective Equipment.** Branch-circuit distribution equipment shall be installed in each mobile home and shall include overcurrent protection for each branch circuit consisting of either circuit breakers or fuses.

The branch-circuit overcurrent devices shall be rated: (1) not more than the circuit conductors; and (2) not more than 150 percent of the rating of a single appliance rated 10 amperes or more which is supplied by an individual branch circuit; but (3) not more than the fuse size marked on the air conditioner or other motor-operated appliance.

**(c) Two-Pole Circuit Breakers.** When circuit breakers are provided for branch-circuit protection, 230-volt circuits shall be protected by a 2-pole common or companion trip, or handle-tied paired circuit breakers.

**(d) Electrical Nameplates.** A metal nameplate on the outside adjacent to the supply cord entrance shall read, "This Mobile Home is Wired for 115/230 Volt, 3-wire, 60 Hertz Supply. Supply Cord 40 (or 50) amp." The voltage marking may read 120/240 Volts instead of 115/230 Volts.

**550-5. Branch Circuits.** The number of branch circuits required shall be determined in accordance with the following:

**(a) Lighting.** Based on 3 watts per square foot times outside dimensions of the mobile home (coupler excluded) divided by 115 volts to determine number of 15- or 20-ampere lighting area circuits, e.g.,

$$\frac{3 \times \text{Length} \times \text{Width}}{115 \times 15 \text{ (or 20)}} = \text{No. of 15- (or 20-) ampere circuits.}$$

**(b) Portable Appliances.** For the small appliance load in kitchen, pantry, family room, dining room, and breakfast rooms of mobile homes two or more 20-ampere appliance branch circuits in addition to the branch circuits specified in Section 550-5(a) shall be provided for all receptacle outlets in these rooms, and such circuits shall have no other outlets. Receptacle outlets supplied by at least two appliance receptacle branch circuits shall be installed in the kitchen.

**(c) General Appliances.** (Including furnace, water heater, range, and central or room air conditioner, etc.) There shall be one or more circuits of adequate rating in accordance with the following:

**(1)** Ampere rating of fixed appliances not over 50 percent of circuit rating if lighting outlets (receptacles, other than kitchen, dining area, and laundry, considered as lighting outlets) are on same circuit;

(550-5(c) continued)

(2) For fixed appliances on a circuit without lighting outlets, the sum of rated amperes shall not exceed the branch-circuit rating for other than motor loads or 80 percent of the branch-circuit rating for air conditioning or other motor loads;

(3) The rating of a single portable appliance on a circuit having no other outlets shall not exceed 80 percent of the circuit rating;

(4) The rating of range branch circuit shall be based on the range demand as specified for ranges in Section 550-11(b)(5).

For the laundry branch circuit, see Section 220-3(b).

#### **550-6. Receptacle Outlets.**

(a) All receptacle outlets:

(1) shall be of grounding type; (2) shall be installed according to Section 210-7; and (3) except when supplying specific appliances, receptacles shall be parallel-blade, 15-ampere, 125-volt, either single or duplex.

(b) There shall be an individual outlet of the grounding type for each cord-connected fixed appliance installed.

(c) Except in the bath and hall areas, receptacle outlets shall be installed at all wall spaces 2 feet wide or more, so that no point along the floor line is more than 6 feet, measured horizontally, from an outlet in that space. Except as explained in the following, receptacle outlets are not required for wall spaces occupied by kitchen or wardrobe cabinets.

In addition, a receptacle outlet shall be installed: (1) Over or adjacent to counter tops in the kitchen (at least one on each side of the sink if counter tops are on each side and 12 inches or more in width); (2) Adjacent to the refrigerator and free-standing gas-range space; (3) At counter top spaces for built-in vanities; (4) At counter top spaces under wall-mounted cabinets.

(d) Receptacle outlets shall not be installed within or adjacent to a shower or bathtub space.

#### **550-7. Fixtures and Appliances.**

(a) Electrical materials, devices, appliances, fittings, and other equipment installed, intended for use in, or attached to the mobile home shall be approved for the application and shall be connected in an approved manner when in service. Facilities shall be provided to securely fasten appliances when the mobile home is in transit. (See Section 550-9 for provisions on grounding.)

(b) (1) Specifically approved pendant-type fixtures or pendant cords may be installed in mobile homes.

(2) If a lighting fixture is provided over a bathtub or in a shower stall, it shall be of the approved enclosed and gasketed type.

(3) The switch for shower lighting fixtures and exhaust fans located over a tub or in a shower stall shall be located outside the tub or shower space.

(c) Every appliance shall be accessible for inspection, service, repair, or replacement without removal of permanent construction.

**550-8. Wiring Methods and Materials.** Except as specifically limited in this Section the wiring methods and materials included in this Code shall be used in mobile homes.

(a) Nonmetallic outlet boxes are acceptable only with nonmetallic cable.

(b) Nonmetallic cable located 15 inches or less above the floor, if exposed, shall be protected from physical damage by covering boards, guard strips, or conduit. Cable likely to be damaged by stowage shall be so protected in all cases.

(c) Metal-clad and nonmetallic cables may be passed through the centers of the wide side of 2-inch by 4-inch studs. However, they shall be protected where they pass through 2-inch by 2-inch studs or at other studs or frames where the cable or armor would be less than 1½ inches from the inside or outside surface. Steel plates on each side of the cable, or a tube, with not less than No. 16 MSG wall thickness, are required to protect the cable. These plates or tubes shall be securely held in place.

(d) Where metallic faceplates are used they shall be effectively grounded.

(e) If the range, clothes dryer, or similar appliance is connected by metal-clad cable or flexible conduit, a length of free cable or conduit should be provided to permit moving the appliance. The cable or flexible conduit should be adequately secured to the wall. Clearance space behind a range may provide the required protection when a range is connected by Type SE cable. When used, Type SE cable shall have an identified and insulated neutral plus an equipment grounding conductor. Nonmetallic-sheathed cable (Type NM) shall not be used to connect a range or dryer.

This does not prohibit the use of Type NM cable between the branch-circuit overcurrent protective device and a range or dryer receptacle.

(f) Rigid metal conduit shall be provided with a locknut inside and outside the box, and a conduit bushing shall be used on the inside. Inside ends of the conduit shall be reamed.

(g) Switches shall be rated as follows:

(1) For lighting circuits, switches shall have a 10-ampere 125-volt rating; or higher, if needed for the connected load.

(2) For motors or other loads, switches shall have ampere or horsepower ratings or both adequate for loads controlled. (An "AC general-use" snap switch may control a motor 2 horsepower or less with full-load current not over 80 percent of the switch ampere rating.)

(h) At least 4 inches of free conductor shall be left at each outlet box except where conductors are intended to loop without joints.

(i) **Under-Chassis Wiring.** (Exposed to Weather).

(1) When outdoor or under-chassis line-voltage wiring is exposed

to moisture or physical damage it shall be protected by rigid metal conduit. The conductors shall be suitable for wet locations.

*Exception: Electrical metallic tubing may be used when closely routed against frames and equipment enclosures.*

(2) The cables or conductors shall be Type NMC, TW, or equivalent.

(j) Outlet boxes of dimensions less than those required in Tables 370-6(a)(1) and 370-6(a)(2) may be used provided the box has been tested and approved for the purpose.

(k) Boxes, fittings and cabinets shall be securely fastened in place.

*Exception: Snap-in type boxes or boxes provided with special wall or ceiling brackets that securely fasten boxes in walls or ceilings may be used.*

### **550-9. Grounding.**

Grounding of both electrical and nonelectrical metal parts in a mobile home is through connection to a grounding bus in the mobile home distribution panel. The grounding bus is grounded through the green-colored conductor in the supply cord or the feeder wiring to the service ground in the service-entrance equipment located adjacent to the mobile home location. Neither the frame of the mobile home nor the frame of any appliance may be connected to the neutral conductor in the mobile home.

#### **(a) Insulated Neutral.**

(1) The grounded circuit conductor (neutral) shall be insulated from the grounding conductors and from equipment enclosures and other grounded parts. The grounded (neutral) circuit terminals in the distribution panel and in ranges, clothes dryers, counter-mounted cooking units, and wall-mounted ovens are to be insulated from the equipment enclosure. Bonding screws, straps, or buses in the distribution panel or in appliances are to be removed and discarded.

(2) Connection of ranges and clothes dryers shall be made with 4-conductor cord and 3-pole, 4-wire grounding-type plugs, or by Type AC metal-clad cable or conductors enclosed in flexible steel conduit.

#### **(b) Equipment Grounding Means.**

(1) The green-colored grounding wire in the supply cord or permanent feeder wiring shall be connected to the grounding bus in the distribution panel or disconnecting means.

(2) In the electrical system, all exposed metal parts, enclosures, frames, lamp fixture canopies, etc., shall be effectively bonded to the grounding terminal or enclosure of the distribution panel.

(3) Cord-connected appliances, such as washing machines, clothes dryers, refrigerators, and the electrical system of gas ranges, etc., shall be grounded by means of an approved cord with grounding conductor and grounding-type attachment plug.

**(c) Bonding of Noncurrent-Carrying Metal Parts.**

(1) All exposed noncurrent-carrying metal parts that may become energized shall be effectively bonded to the grounding terminal or enclosure of the distribution panelboard. A bonding conductor shall be connected between each distribution panelboard and an accessible terminal on the chassis.

(2) Grounding terminals shall be of the solderless type and approved as pressure-terminal connectors recognized for the wire size used. The bonding conductor may be solid or stranded, insulated or bare, and shall be No. 8 AWG copper minimum, or equal. The bonding conductor shall be routed so as not to be exposed to physical damage. Protection can be afforded by the configuration of the chassis.

(3) Metallic gas, water, and waste pipes and metallic air circulating ducts are considered bonded if they are connected to the terminal on the chassis (See Section 550-9(c)(1)) by clamps, solderless connectors, or by suitable grounding-type straps.

(4) Any metallic roof and exterior covering are considered bonded if the metal panels overlap one another and are securely attached to the wood or metal frame parts by metallic fasteners and if the lower panel of the metallic exterior covering is secured by metallic fasteners at each cross member of the chassis and the lower panel is bonded to the chassis by a metal strap.

**550-10. Testing.** Dielectric Strength Test. The wiring of each mobile home shall be subjected to a 1-minute, 900-volt, dielectric strength test (with all switches closed) between live parts (including neutral) and the mobile home ground. Alternatively, the test may be performed at 1,088 volts for 1 second. This test shall be performed after branch circuits are complete and after fixtures or appliances are installed.

*Exception: Fixtures or appliances which are approved shall not be required to withstand the dielectric strength test.*

**550-11. Calculations.** The following method is to be employed in computing the supply-cord and distribution-panel load for each feeder assembly for each mobile home in lieu of the procedure shown in Article 220 and is based on 3-wire, 115/230-volt supply with 115-volt loads balanced between the two legs of the 3-wire system.

**(a) Lighting and Small Appliance Load:**

Lighting Watts: Length times width of mobile home (outside dimensions, exclusive of coupler) times 3 watts per square foot; e.g.,  
 $\text{Length} \times \text{width} \times 3 = \dots\dots\dots \text{lighting watts.}$

Small Appliance Watts: Number of circuits times 1,500 watts for each 20-ampere appliance receptacle circuit (see definition of Appliance, Portable with note); e.g.,

$\text{Number of circuits} \times 1,500 = \dots\dots\dots \text{small appliance watts.}$

Total: Lighting watts plus small appliance =  $\dots\dots\dots$  total watts.

First 3,000 total watts at 100 percent plus remainder at 35 percent =  $\dots\dots\dots$  watts to be divided by 230 volts to obtain current (amperes) per leg.

(550-11 continued)

(b) Total load for determining power supply is the summation of:

(1) Lighting and small appliance load as calculated in Section 550-11(a).

(2) Nameplate amperes for motors and heater loads (exhaust fans, air conditioners,\* electric, gas, or oil heating).\*\*

\* Omit smaller of these two, except include blower motor if used as air conditioner evaporator motor.

\*\* When an air conditioner is not installed and a 40-ampere power supply cord is provided, allow 15 amperes per leg for air conditioning.

(3) 25 percent of current of largest motor in (2).

(4) Total of nameplate amperes for: disposal, dishwasher, water heater, clothes dryer, wall-mounted oven, cooking units.

Where number of these appliances exceeds 3 use 75 percent of total.

(5) Derive amperes for free-standing range (as distinguished from separate ovens and cooking units) by dividing values below by 230 volts.

Nameplate Rating	Use
10,000 watts or less	80 percent of rating
10,001-12,500 watts	8,000 watts
12,501-13,500 watts	8,400 watts
13,501-14,500 watts	8,800 watts
14,501-15,500 watts	9,200 watts
15,501-16,500 watts	9,600 watts
16,501-17,500 watts	10,000 watts

(6) If outlets or circuits are provided for other than factory-installed appliances include the anticipated load.

See following Example for illustration of application of this calculation.



**Example**

A mobile home is  $70 \times 10$  feet and has two portable appliance circuits, a 1000-watt 230-volt heater, a 200-watt 115-volt exhaust fan, a 400-watt 115-volt dishwasher and a 7000-watt electric range.

**Lighting and small appliance load**

Lighting $70 \times 10 \times 3 =$	2100 watts
Small appliance $1500 \times 2 =$	3000 watts
	<u>5100 watts</u>
1st 3000 watts at 100% .....	3000
Remainder ( $5,100 - 3,000 = 2,100$ ) at 35% .....	<u>735</u>
	3735

$$\frac{3735}{230} = 16 \text{ amperes per leg}$$

1000 watt (heater) $\div 230 =$	4.4 amp
200 watt (fan) $\div 115 =$	1.7 amp
400 watt (dishwasher) $\div 115 =$	3.5 amp
7000 watt (range) $\times .8 \div 230 =$	24. amp

**Amperes per leg**

	<i>A</i>	<i>B</i>
Lighting and appliances	16	16
Heater (230 volt)	4	4
Fan (115 volt)	2	—
Dishwasher (115 volt)	—	4
Range	<u>24</u>	<u>24</u>
Totals	46	48

Based on the higher current calculated for either leg, use one 50-ampere supply cord.

**550-12. Wiring of Expandable Units and Dual Units.**

(a) Expandable or dual-unit mobile homes utilizing permanently installed feeder conductors may use permanent-type wiring methods and materials for connecting such units to each other.

(b) Expandable or dual-unit mobile homes not having permanently installed feeders and which are to be moved from one location to another, may have disconnecting means with branch-circuit protective equipment in each unit when so located that after assembly or joining together of units the requirements of Section 550-3(j) are met.

(c) Expandable or dual-unit mobile homes, which are to be moved from one location to another, may be connected together with cord connections using approved raintight power-supply connectors or approved power-supply connectors installed in protected locations. The cords used shall be as specified in Section 550-3(e). Cord length shall be kept at a minimum with outlet boxes on each unit located where circuit conductors terminate. Such outlet boxes shall be adjacent to each other, as practical, after units are joined together.

**550-13. Outdoor Outlets, Fixtures, Air-Cooling Equipment, Etc.**

(a) Outdoor fixtures and equipments shall be recognized for outdoor use. Outdoor receptacle or convenience outlets shall be of a gasketed-cover type.

(b) A mobile home provided with a receptacle outlet designed to energize heating and/or air-conditioning equipment located outside the mobile home, shall have permanently affixed, adjacent to the outlet receptacle, a metal tag which reads:

This Connection is for Air-Conditioning Equipment  
Rated at Not More Than ..... Amperes, at  
..... Volts, 60 Hertz.

The correct voltage and ampere rating shall be given. The tag shall be not less than 0.020 inch, etched brass, stainless steel, anodized or alclad aluminum. The tag shall not be less than 3 inches by 1¾ inches minimum size.

**B. Mobile Home Parks**

**550-21. Distribution System.** The mobile home park secondary electrical distribution system to mobile home lots shall be single-phase, nominal 115/230 volts. For the purpose of Part B, where the park service exceeds 240 volts, transformers and secondary distribution panelboards shall be treated as services.

See Table 550-22 for calculation of load.

**550-22. Calculated Load.**

(a) Park electrical wiring systems shall be calculated on the basis of not less than 16,000 watts (at 115/230 volts) per each mobile home service. The demand factors which are set forth in Table 550-22 are the minimum allowable demand factors which may be used in calculating load on feeders and service. No demand factor shall be allowed for any other load, except as provided in this Code.

**Table 550-22**  
**Demand Factors for Feeders and Service-Entrance Conductors**

Number of Mobile Home Lots	Demand Factor (Percent)
1	100
2	55
3	44
4	39
5	33
6	29
7-9	28
10-12	27
13-15	26
16-21	25
22-40	24
41-60	23
61 and over	22

(b) The demand factor for a given number of lots shall apply to all lots indicated.

Example: 20 lots calculated at 25 percent of 16,000 watts result in a permissible demand of 4,000 watts per lot or a total of 80,000 watts for 20 lots.

(c) Mobile home lot feeder circuit conductors shall have adequate capacity for the loads supplied, and shall be rated at not less than 100 amperes at 115/230 volts.

#### **550-23. Mobile Home Service Equipment.**

(a) Mobile home service equipment shall be rated at not less than 100 amperes, and provision shall be made for connecting a mobile home feeder assembly by a permanent wiring method. Mobile home service equipment may also be provided with 50-ampere receptacles conforming to ANSI C73.17-1966.

(b) Mobile home service equipment may also be provided with a means for connecting a mobile home accessory building or structure or additional electrical equipment located outside a mobile home by a permanent wiring method.

(c) Additional receptacles may be provided for connection of electrical equipment located outside the mobile home.

## **ARTICLE 551 — RECREATIONAL VEHICLES AND RECREATIONAL VEHICLE PARKS**

### **A. Recreational Vehicles**

#### **551-1. Scope.**

(a) The provisions of Part A cover the electrical conductors and equipment installed within or on recreational vehicles and also the conductors that connect them to a supply of electricity. Wherever the requirements of other Articles of this Code and Article 551 differ, the requirements of Article 551 shall apply.

For requirements on the installation of plumbing and heating systems in recreational vehicles, refer to Standard for Recreational Vehicles (NFPA No. 501C-1970)

(b) A recreational vehicle not used for the purposes as defined in Section 551-2 shall not be required to meet the provisions of Part A pertaining to the number or capacity of circuits required. It shall, however, meet all other applicable requirements of this Article if the recreational vehicle is provided with an electrical installation intended to be energized from a 115- or 115/230-volt, AC power-supply system.

(c) Part A covers battery and direct-current power (12-volt or less) systems, combination electrical systems, generator installations, and nominal 115- or 115/230-volt systems.

#### **551-2. Definitions.** (See Article 100 for other definitions.)

(551-2 continued)

**Air-Conditioning or Comfort-Cooling Equipment:** All of that equipment intended or installed for the purpose of processing the treatment of air so as to control simultaneously its temperature, humidity, cleanliness and distribution to meet the requirements of the conditioned space.

**Camping Trailer:** A vehicular portable unit mounted on wheels and constructed with collapsible partial side walls which fold for towing by another vehicle and unfold at the campsite to provide temporary living quarters for recreational, camping, or travel use. (See "Recreational Vehicle.")

**Converter:** A device which changes electrical energy from one form to another, as from alternating current to direct current.

**Dead Front** (As applied to switches, circuit breakers, switchboards, and distribution panelboards): So designed, constructed and installed that no current-carrying parts are normally exposed on the front.

**Disconnecting Means:** The necessary equipment usually consisting of a circuit breaker or switch and fuses, and their accessories, located near the point of entrance of supply conductors in a recreational vehicle and intended to constitute the means of cutoff for the supply to that recreational vehicle.

Receptacles used as disconnecting means shall be accessible (as applied to wiring methods) and capable of interrupting their rated current without hazard to the operator.

**Distribution Panelboard:** A single panel or group of panel units designed for assembly in the form of a single panel; including buses, and with or without switches and/or automatic overcurrent protective devices for the control of light, heat or power circuits of small individual as well as aggregate capacity; designed to be placed in a cabinet or cut-out box placed in or against a wall or partition and accessible only from the front.

**Motor Home:** A vehicular unit built on a self-propelled motor vehicle chassis, primarily designed to provide temporary living quarters for recreational, camping, or travel use. (See "Recreational Vehicle.")

**Power-Supply Assembly:** The conductors, including the grounding conductors, insulated from one another, the connectors, attachment plug caps, and all other fittings, grommets, or devices installed for the purpose of delivering energy from the source of electrical supply to the distribution panel within the recreational vehicle.

**Recreational Vehicle:** A vehicular type unit primarily designed as temporary living quarters for recreational, camping, or travel use, which either has its own motive power or is mounted on or drawn by another vehicle. The basic entities are: travel trailer, camping trailer, truck camper and motor home.

**Transformer:** A device, which when used, will raise or lower the voltage of alternating current of the original source.

**Travel Trailer:** A vehicular portable unit, mounted on wheels, of such size or weight as not to require special highway movement permits when drawn by a motorized vehicle; primarily designed and constructed to

provide temporary living quarters for recreational, camping, or travel use; and of a body width of no more than 8 feet and a body length of no more than 32 feet when factory equipped for the road. (See "Recreational Vehicle.")

**Truck Camper:** A portable unit, designed to be loaded onto, or affixed to, the bed or chassis of a truck, constructed to provide temporary living quarters for recreational, camping, or travel use. Truck campers are of two basic types as defined below:

**a. Slide-In Camper:** A portable unit designed to be loaded onto and unloaded from the bed of a pickup truck, constructed to provide temporary living quarters for recreational, travel, or camping use.

**b. Chassis-Mount Camper:** A portable unit designed to be affixed to a truck chassis, and constructed to provide temporary living quarters for recreational, travel, or camping use.

### **551-3. Batteries and Direct-Current (12 Volts — Nominal)**

**(a) Battery Circuits.** Battery circuits furnished and installed by the recreational vehicle manufacturer, other than those related to braking, are subject to this Code. Circuits supplying lights subject to Federal or State regulations shall be in accordance with applicable government regulations but shall not be lower than provided by this Code.

#### **(b) Low-Voltage Wiring Materials.**

(1) Copper conductors shall be used for low-voltage circuits.

(2) The insulation of low-voltage conductors used in battery and direct-current circuits shall be rated at least 60°C.

(3) Conductors furnished and installed by the recreational vehicle manufacturer shall have a minimum of 30 mils thermoplastic insulation or equal.

(4) The insulation of outdoor or under-chassis wire shall be moisture and heat resistant, Type THW or equivalent.

(5) Single-wire, low-voltage conductors shall be of the stranded type.

#### **(c) Low-Voltage Wiring Methods.**

(1) Conductors shall be protected against physical damage and shall be adequately supported. Where insulated conductors are clamped to the structure, the conductor insulation shall be supplemented by an additional wrap or layer or equivalent material, except that jacketed cables need not be so protected. Wiring shall be routed away from sharp edges, moving parts or heat sources.

(2) Splices and connections shall be made in accordance with Society of Automotive Engineers (SAE) standards and recommended practices or equivalent.

(3) Battery and direct-current circuits shall be physically separated by at least a ½-inch gap or other approved means, from circuits of a different power source. This may be accomplished by clamping, routing, or equivalent means which ensure permanent total separation.

(d) **Battery Installations.** Storage batteries subject to the provisions of this Code shall be securely attached to the vehicle and installed in an area which is ventilated directly to the exterior of the vehicle.

(e) **Overcurrent Protection.**

(1) Battery and direct-current circuit wiring shall be protected by overcurrent protective devices rated not in excess of the ampacity of copper conductors, as follows:

Wire Size	Ampacity	Wire Type
18	3	Stranded only
16	9	Stranded only
14	15	Stranded or solid
12	20	Stranded or solid
10	30	Stranded or solid

For other allowable conductor ampacities, refer to Table 310-12.

(2) Circuit breakers or fuses shall be of an approved type, including automotive types conforming to the requirements of Society of Automotive Engineers (SAE) J554-1968 or Underwriters' Laboratories, Inc., Standard 275b. Fuseholders shall be clearly marked with maximum fuse size.

(3) Higher current-consuming direct-current appliances such as pumps, compressors, heater blowers and similar motor-driven appliances shall be installed in accordance with the manufacturer's instructions.

(4) The overcurrent protective device shall be installed in an accessible location on the vehicle as close as practical to the point where the power supply connects to the vehicle circuits. If located outside the recreational vehicle, the device shall be protected against weather and physical damage.

#### 551-4. Combination Electrical Systems.

(a) **General.** Vehicle wiring suitable for connection to a battery or direct-current supply source may be connected to a 115-volt source provided that the entire wiring system and equipment are rated and installed in full conformity with Part A requirements covering 115-volt electrical systems. Circuits fed from alternating-current transformers shall not supply direct-current appliances.

(b) **Voltage Converters (115-Volt Alternating Current to Low-Voltage Direct Current).** The 115-volt alternating current side of voltage converters shall be wired in full conformity with Part A requirements for 115-volt electrical systems. Converters supplied as an integral part of an approved appliance are not subject to the above. All converters and transformers shall be of an approved type.

(c) **Dual-Voltage Fixtures or Appliances.** Fixtures or appliances having both 115-volt and low-voltage connections shall be approved for dual voltage.

**(d) Autotransformers.** Autotransformers are prohibited.

**(e) Receptacle and Plug Caps.** When a recreational vehicle is equipped with separate external connections for a 115-volt alternating current system and a battery or direct-current system, receptacles and plug caps shall be of different configurations.

**(f) Identification.**

(1) When a vehicle equipped with a battery or direct-current system has an external connection for low-voltage power, the receptacle shall have a configuration that will not accept 120-volt power. The vehicle shall have permanently affixed on the outside wall adjacent to the point of entrance of the power supply conductors a tag which reads:

**THIS CONNECTION IS FOR LOW-VOLTAGE BATTERY OR DIRECT CURRENT ONLY. DO NOT CONNECT TO 120 OR 240 VOLTS AC.**

(2) The tag shall be 3 inches by 1¾ inches minimum size, made of etched, metal-stamped or embossed brass, stainless steel, anodized or alclad aluminum not less than 0.020 inch thick, or other approved material (e.g., 0.005-inch plastic laminates).

#### **551-5. Generator Installations.**

**(a) Mounting.** Generators shall be mounted in such a manner as to be effectively bonded to the recreational vehicle chassis.

**(b) Generator Protection.** Equipment shall be installed to ensure that the generator is disconnected when the vehicle is energized from an outside source and to ensure that the outside source is disconnected when the vehicle is energized by the generator. The generator field shall be protected by appropriately rated, approved equipment.

**(c) Installation of Storage Batteries and Generators.** Storage batteries and internal-combustion-driven generator units (subject to the provisions of this Code) shall be secured in place to avoid displacement from vibration and road shock and shall be installed in a compartment which is vaportight to the interior of the vehicle.

**(d) Ventilation of Generator Compartments.** Compartments accommodating internal-combustion-driven generator units shall be provided with approved ventilation in accordance with instructions provided by the manufacturer of the generator unit.

**(e) Location of Internal-Combustion-Engine Generator Exhaust.** Exhaust from generator internal-combustion engines shall not terminate adjacent to the vehicle gasoline-tank filler-spout inlet.

#### **551-6. Nominal 115- or 115/230-Volt Systems.**

**(a) General Requirements.** The electrical equipment and material of recreational vehicles indicated for connection to a wiring system nominally rated 115 volts, 2-wire with ground, or a wiring system nominally rated 115/230 volts, 3-wire with ground, shall be approved and installed in accordance with the requirements of Part A.

**(b) Materials and Equipment.** Electrical materials, devices, appliances, fittings, and other equipment installed, intended for use in, or attached to the recreational vehicle shall be approved for the application.

**551-7. Branch Circuits Required.** The branch circuits required in a recreational vehicle shall conform to Section 551-19 and be determined in accordance with subparagraphs (a), (b) and (c) below.

**(a)** Recreational vehicles with not more than 8 lighting and receptacle outlets combined shall have either:

**(1)** One 15-ampere general-purpose branch circuit to supply these outlets, provided the total rating of fixed appliances connected to this circuit does not exceed 600 watts, or

**(2)** One 20-ampere general-purpose branch circuit, to supply these outlets, provided the total rating of fixed appliances connected to this circuit does not exceed 1,000 watts.

Vehicles wired in accordance with (a)(1) or (a)(2) above shall not be equipped with electrical heating or cooking appliances.

**(b)** Recreational vehicles with more than 8 lighting and receptacle outlets combined shall have one 20-ampere appliance branch circuit, and either:

**(1)** One 15-ampere branch circuit to supply these outlets, provided this circuit does not supply receptacles in the cooking and dining area(s) or electrical heating or cooking appliances, and provided the total rating of fixed appliances connected to this circuit does not exceed 600 watts, or

**(2)** One 20-ampere branch circuit, to supply these outlets, provided this circuit does not supply receptacles in the cooking and dining area(s) or electrical heating or cooking appliances, and provided the total rating of fixed appliances connected to this circuit does not exceed 1,000 watts.

**(c) Calculations for Lighting and Appliance Load.** When Section 551-7(b) (relative to recreational vehicles with more than 8 lighting and receptacle outlets combined) is not applied, the following method shall be employed in computing the power-supply assembly and distribution panel load for the recreational vehicle:

**A. Lighting.** Length times width of vehicle (outside dimensions, exclusive of hitch and cab) times 3 watts per square foot, e.g.,

Length x width x 3 = \_\_\_\_\_ lighting watts.

**B. Small Appliance.** Number of circuits times 1,500 watts for each 20-ampere appliance receptacle circuit, e.g.,

Number of Circuits x 1,500 \_\_\_\_\_ small appliance watts.

**C. Total.** Lighting watts plus small appliance watts = ..... total watts.

**D.** First 3,000 total watts at 100 percent plus remainder at 35 percent = \_\_\_\_\_ watts to be divided by voltage to obtain current (amperes) per leg.



Amperes per Leg

A

B

Lighting and small appliance current (amperes) per leg (from D above) =

E. Add nameplate amperes for motors and heater loads (exhaust fans, air conditioners\*, electric, gas, or oil heating\*) =

\* Omit smaller of these two except include any motor common to both functions.

F. Add 25 percent of amperes of largest motor in E =

G. Add nameplate amperes for:\*\*

Disposal

Water Heater

Wall-Mounted Ovens

Cooking Units

TOTAL

\*\* When number of appliances is four or more use 75 percent of total.

H. Add amperes for free-standing range as distinguished from separate ovens and cooking units. Derive from following table by dividing watts by 230 volts.

Range	Nameplate Rating (watts)	Use (watts)
(Free-standing range as distinguished from separate oven and cooking units)	10,000 or less	80 percent of rating
	10,001-12,500	8,000
	12,501-13,500	8,400
	13,501-14,500	8,800
	15,501-16,500	9,600
	16,501-17,500	10,000

Amperes per Leg

A

B

I. If outlets or circuits are provided for other than factory-installed major appliances, the anticipated load shall be added for each.

TOTAL =

When the total for Legs A and B are unequal, use the larger to determine the distribution panel and supply cord rating. (Service amperes shall not exceed supply cord rating. See Section 551-11.)

**551-8. Receptacle Outlets Required.**

(a) Receptacle outlets shall be installed at wall spaces 2 feet wide or more so that no point along the floor line is more than 6 feet, measured horizontally, from an outlet in that space.

*Exception No. 1: Bath and hall areas.*

*Exception No. 2: Wall spaces occupied by kitchen cabinets, wardrobe cabinets, built-in furniture, behind doors which may open fully against a wall surface, or similar facilities.*

(b) Receptacle outlets shall be installed:

(1) Adjacent to counter tops in the kitchen (at least one on each side of the sink if counter tops are on each side and are 12 inches or over in width).

(2) Adjacent to the refrigerator and gas range space, except when a gas-fired refrigerator or cooking appliance, requiring no external electrical connection, is factory-installed.

(3) Adjacent to counter top spaces (and built-in vanities) which cannot be reached from a receptacle required in Section 551-8(b)(1) by a cord of 6 feet without crossing a traffic area, cooking appliance or sink.

(c) When installed adjacent to a bathroom lavatory, the receptacle outlet shall be a minimum of 30 inches from the floor. The receptacle outlet may be contained in an approved lighting fixture. A receptacle outlet shall not be installed in a tub or combination shower compartment.

**551-9. Distribution Panelboard.**

(a) An approved distribution panelboard shall be used. The distribution panelboard shall be of the insulated neutral type, with the grounding bar attached to the metal frame of the panelboard or other approved grounding means.

(b) The distribution panelboard shall be installed in a readily accessible location and may be located in a closet.

(c) The distribution panelboard shall be of the dead-front type and shall consist of one or more circuit breakers or Type S fuseholders. A main disconnecting means shall be provided where fuses are used or where more than two circuit breakers are employed.

**551-10. Branch-Circuit Protection.**

(a) The branch-circuit overcurrent devices shall be rated:

(1) Not more than the circuit conductors; and

(2) Not more than 150 percent of the rating of a single appliance rated 10 amperes or more and supplied by an individual branch circuit; but

(3) Not more than the fuse size marked on an air conditioner or other motor-operated appliances.

(b) A 20-ampere fuse or circuit breaker shall be considered adequate

protection for fixture leads, cords, or portable appliances, and No. 14 AWG tap conductors, not over 6 feet long for recessed lighting fixtures.

(c) If more than one outlet or load is on a branch circuit, a 15-ampere receptacle shall be considered protected by a 20-ampere fuse or circuit breaker.

#### **551-11. Power-Supply Assembly.**

(a) Recreational vehicles wired in accordance with Section 551-7(a)(1) shall use an approved 15-ampere, or larger, main power-supply assembly.

(b) Recreational vehicles wired in accordance with Section 551-7(a)(2) shall use an approved 20-ampere, or larger, main power-supply assembly.

(c) Recreational vehicles wired in accordance with Sections 551-7(b) or 551-7(c) shall use an approved 30-ampere, or larger, main power-supply assembly.

(d) In accordance with Section 551-7(c), any recreational vehicle with a rating in excess of 30 amperes, 115 volts, shall use an approved 40-ampere or 50-ampere 115/230-volt power-supply assembly.

*Exception: When the calculated load of the recreational vehicle exceeds 30 amperes, 115 volts, a second power-supply cord may be installed. Where a two-cord supply system is installed, they shall not be interconnected on either the line side or the load side. The grounding circuits and grounding means shall be electrically interconnected.*

#### **551-12. Dual-Supply Source.**

(a) Where a dual-supply system, consisting of a generator and a power-supply cord is installed, the feeder from the generator shall be protected by an overcurrent protective device. Installation shall be in accordance with Sections 551-5(a) and 551-5(b).

(b) Calculation of loads shall be in accordance with Section 551-7(c).

(c) The two supply sources need not be of the same capacity.

(d) If the AC generator source exceeds 30 amperes, 115 volts, it may be wired either as a 115-volt system or a 115/230-volt system, providing an overcurrent protective device of the proper rating is installed in the feeder.

(e) The external power-supply assembly may be less than the calculated load but not less than 30 amperes and shall have overcurrent protection not greater than the capacity of the external power-supply assembly.

#### **551-13. Means for Connecting to Power Supply.**

(a) **Assembly.** The power-supply assembly or assemblies shall be factory-supplied or factory-installed when of the permanently connected type as specified herein:

(1) **Separable.** When a separable power-supply assembly consisting of a cord with a female connector and molded attachment plug

(551-13(a-1) continued)

cap is provided, the vehicle shall be equipped with a permanently mounted, approved, male-recessed-type motor-base receptacle wired directly to the distribution panel by an approved wiring method. The attachment plug cap shall be of an approved type.

**(2) Permanently Connected.** Each power-supply assembly shall be connected directly to the terminals of the distribution panel or conductors within an approved junction box and provided with means to prevent strain from being transmitted to the terminals. The ampacity of the conductors between each junction box and the terminals of each distribution panel shall be at least equal to the ampacity of the power-supply cord. The supply end of the assembly shall be equipped with an attachment plug of the type described in Section 551-13(c). Where the cord passes through the walls or floors, it shall be protected by means of conduit and bushings or equivalent.

**(b) Cord.** The cord set shall be approved for use with recreational vehicles. The cord shall be not less than 20 feet as measured from the point of entrance to the recreational vehicle or the face of the motor-base attachment plug nor more than 26½ feet in length overall to the face of the attachment plug at the supply end.

**(c) Attachment Plugs.**

**(1)** Recreational vehicles having only one 15-ampere branch circuit as permitted by Section 551-7(a)(1) shall have an attachment plug which shall be 2-pole, 3-wire, grounding-type, rated 15 amperes, 125 volts, conforming to American National Standard C73.11-1966.

**(2)** Recreational vehicles having only one 20-ampere branch circuit as permitted in Section 551-7(a)(2) shall have an attachment plug which shall be 2-pole, 3-wire, grounding-type, rated 20 amperes, 125 volts, conforming to American National Standard C73.12-1966.

**(3)** Recreational vehicles wired in accordance with Sections 551-7(b) or 551-7(c) shall have an attachment plug which shall be 2-pole, 3-wire, grounding-type, rated 30 amperes, 125 volts, conforming to American National Standard C73.13-1966, intended for use with units rated at 30 amperes, 125 volts.

**(4)** Recreational vehicles having a power-supply assembly rated 40 amperes or 50 amperes as permitted by Section 551-7(c) shall have a 3-pole, 4-wire, grounding-type attachment plug rated 50 amperes, 125/250 volts, conforming to American National Standard C73.17-1966.

**(d) Labeling at Electrical Entrance.** Each recreational vehicle shall have permanently affixed to the exterior skin at or near the point of entrance of the power-supply cord(s) a tag 3 inches by 1¾ inches minimum size, made of etched, metal-stamped or embossed brass, stainless steel, anodized or alclad aluminum not less than 0.020 inch thick, or other approved material (e.g., 0.005-inch plastic laminates), which reads, as appropriate, either;

“This connection is for 110-125-volt AC, 60-Hz (Cycles) service. Do not connect to higher voltage” or

“This connection is for 3-wire 120/240-volt AC, 60-Hz (Cycles) \_\_\_\_\_ ampere service.”

(e) **Location.** The point of entrance of a power-supply assembly shall be located within 25 feet of the rear, on the left (road) side or at the rear, left of the longitudinal center of the vehicle, within 18 inches of the outside wall.

*Exception: A camping trailer not more than 17 feet in length, a motor home or a truck camper may have the electrical point of entrance located on either side, provided the drain outlet and gas connections are located on the same side.*

#### 551-14. Wiring Methods.

(a) Electrical metallic tubing, flexible metal conduit, metal-clad cable, and nonmetallic-sheathed cable with a grounding conductor, shall terminate by means of fittings, clamps or connectors approved for the purpose. Flexible metal conduit may be used as a grounding means where both the conduit and the fittings are approved for the purpose.

(b) Rigid metal conduit shall be provided with a locknut inside and outside the box, and a conduit bushing shall be used on the inside. Inside ends of the conduit shall be reamed.

(c) Nonmetallic outlet boxes are acceptable only with nonmetallic-sheathed cable.

(d) In walls and ceilings constructed of wood or other combustible material, outlet boxes and fittings shall be flush with the finished surface or project therefrom.

(e) Wall and ceiling outlets shall be mounted in accordance with Article 370.

*Exception: Snap-in type boxes or boxes provided with special wall or ceiling brackets that securely fasten boxes in walls or ceilings may be used.*

(f) The sheath of nonmetallic cable or the armor of metal-clad cable shall be continuous between outlet boxes and other enclosures.

(g) Metal-clad and nonmetallic cables may be passed through the centers of the wide side of 2-inch by 4-inch studs. However, they shall be protected where they pass through 2-inch by 2-inch studs or at other studs or frames where the cable would be less than 1½ inches from the inside or outside surface. Steel plates on each side of the cable, or a steel tube, with not less than No. 16 MSG wall thickness, are required to protect the cable. When the thickness of studs or frames makes it impractical or impossible to use metal plates or tubes, particular care shall be exercised in the design and production of the recreational vehicles so as to avoid contacting the cables with nails, screws, or other fasteners. Such care in design shall include appropriate routing of the cables through studs or frames at locations where the likelihood of their being contacted by nails, screws, or other fasteners subsequent to production is remote.

(h) No bend shall have a radius of less than 5 times the cable diameter.

(i) When connected with cable connectors or clamps, cables shall be supported within 12 inches of outlet boxes, distribution panelboards, and splice boxes on appliances. Supports shall be provided every 4½ feet at other places.

(j) Nonmetallic-sheathed cables shall be supported within 8 inches of a nonmetallic outlet box without cable clamps.

(k) Nonmetallic cable, if exposed, shall be protected from physical damage, by covering boards, guard strips or conduit. Cable likely to be damaged shall be so protected in all cases.

(l) Metallic faceplates shall be of ferrous metal not less than 0.030 inch in thickness or of nonferrous metal not less than 0.040 inch in thickness. Nonmetallic faceplates shall be of an approved type.

(m) Where metallic faceplates are used they shall be effectively grounded.

(n) Outdoor or under-chassis wiring (115-volt) exposed to moisture and physical damage shall be protected by rigid metal conduit, or electrical metallic tubing which may be used when closely routed against frames and equipment enclosures. The conductors shall be suitable for wet locations.

#### **551-15. Conductors and Outlet Boxes.**

(a) For requirements for conductors in outlet boxes, see Section 370-6.

*Exception: Outlet boxes of dimensions less than those required in Tables 370-6(a)(1) and 370-6(a)(2) of this Code may be used provided that the box has been tested and approved for the purpose.*

(b) At least 4 inches of free conductor shall be left at each outlet box except where conductors are intended to loop without joints.

**551-16. Grounded Conductors.** For use of grounded conductors, see Section 200-7.

**551-17. Connection of Terminals and Splices.** For connections of terminals and splices, see Section 110-14. If splices of the grounding wire in nonmetallic-sheathed cable are made in outlet boxes, the splices shall be insulated.

**551-18. Switches.** Switches shall be rated as follows:

(a) For lighting circuits, switches shall be rated not less than 10 amperes, 120-125 volts and in no case less than the connected load.

(b) For motors or other loads, switches shall have ampere or horsepower ratings, or both, adequate for loads controlled. (An AC general-use snap switch may control a motor 2 horsepower or less with full-load current not over 80 percent of the switch ampere rating.)

**551-19. Receptacles.** All receptacle outlets shall be: (1) of the grounding type; and (2) installed in accordance with Sections 210-21 and 210-22.

#### **551-20. Lighting Fixtures.**

(a) **General.** Any combustible wall or ceiling finish exposed between

the edge of a fixture canopy, or pan and the outlet box, shall be covered with noncombustible material of either metal equal to the thickness of the fixture or asbestos of 1/16 inch.

**(b) Shower Fixtures.** If a lighting fixture is provided over a bathtub or in a shower stall, it shall be of the enclosed and gasketed type and approved for the type of installation.

The switch for shower lighting fixtures and exhaust fans, located over a tub or in a shower stall, shall be located outside the tub or shower space.

**(c) Outdoor Outlets, Fixtures, Air-Cooling Equipment, Etc.** Outdoor fixtures and other equipment shall be approved for outdoor use.

**551-21. Grounding.** (See also Section 551-23 on bonding of non-current-carrying metal parts.)

**(a) Power-Supply Grounding.** The grounding conductor in the supply cord or feeder shall be connected to the grounding bus or other approved grounding means in the distribution panelboard.

**(b) Distribution Panelboard.** The distribution panelboard shall have a grounding bus with sufficient terminals for all grounding conductors or other approved grounding means.

**(c) Insulated Neutral.**

**(1)** The grounded circuit conductor (neutral) shall be insulated from the equipment grounding conductors and from equipment enclosures and other grounded parts. The grounded (neutral) circuit terminals in the distribution panelboard and in ranges, clothes dryers, counter-mounted cooking units, and wall-mounted ovens shall be insulated from the equipment enclosure. Bonding screws, straps or buses in the distribution panelboard or in appliances shall be removed and discarded.

**(2)** Connection of electric ranges and electric clothes dryers utilizing a grounded (neutral) conductor, if cord-connected, shall be made with 4-conductor cord and 3-pole, 4-wire grounding-type plug caps and receptacles.

**551-22. Interior Equipment Grounding.**

**(a)** In the electrical system, all exposed metal parts, enclosures, frames, lighting fixture canopies, etc., shall be effectively bonded to the grounding terminals or enclosure of the distribution panelboard.

**(b)** Bare wires, green-colored wires, or green wires with yellow stripe(s) shall be used for equipment grounding conductors only.

**(c)** Where grounding of electrical equipment is specified, it may be accomplished as follows:

**(1)** Connection by metallic raceway (conduit or electrical metallic tubing) or the sheath of metal-clad cable to metallic outlet boxes.

**(2)** A connection between the one or more grounding conductors and a metallic box by means of a grounding screw, which shall be used for no other purpose, or an approved grounding device.

(3) The grounding wire in nonmetallic-sheathed cable may be secured under a screw threaded into the fixture canopy other than a mounting screw or cover screw; or may be attached to an approved grounding means (plate) in a nonmetallic outlet box for fixture mounting (grounding means may also be used for fixture attachment screws).

(d) A connection between the one or more grounding conductors brought into a nonmetallic outlet box shall be so arranged that a connection can be made to any fitting or device in that box that requires grounding.

(e) Where more than one equipment grounding conductor of a branch circuit enters a box, all such conductors shall be in good electrical contact with each other, and the arrangement shall be such that the disconnection or removal of a receptacle, fixture, or other device fed from the box will not interfere with or interrupt the grounding continuity.

(f) Cord-connected appliances, such as washing machines, clothes dryers, refrigerators, and the electrical system of gas ranges, etc., shall be grounded by means of an approved cord with grounding conductor and grounding-type attachment plug.

#### **551-23. Bonding of Noncurrent-Carrying Metal Parts.**

(a) All exposed noncurrent-carrying metal parts that may become energized shall be effectively bonded to the grounding terminal or enclosure of the distribution panelboard.

(b) A bonding conductor shall be connected between any distribution panelboard and an accessible terminal on the chassis.

*Exception: Any recreational vehicle which employs a unitized metal chassis-frame construction to which the distribution panelboard is securely fastened with a bolt(s) and nut(s) or by welding or riveting is considered to be bonded.*

(c) Grounding terminals shall be of the solderless type and approved as pressure terminal connectors recognized for the wire size used. The bonding conductor may be solid or stranded, insulated or bare, and shall be No. 8 AWG copper minimum, or equal.

(d) The metallic roof and exterior covering are considered bonded if:

(1) The metal panels overlap one another and are securely attached to the wood or metal frame parts by metallic fasteners, and

(2) The lower panel of the metallic exterior covering is secured by metallic fasteners at each cross member of the chassis, or the lower panel is bonded to the chassis by a metal strap.

(e) The gas, water and waste pipes are considered grounded if they are bonded to the chassis. (See Section 551-23(b) for chassis bonding.)

(f) Furnace and metallic circulating air ducts shall be bonded.

**551-24. Appliance Accessibility.** Every appliance shall be accessible for inspection, service, repair and replacement without removal of permanent construction.



**551-25. Factory Tests (Electrical).**

**Electrical Factory Test.** Each recreational vehicle shall be subjected to the following tests:

(a) **Circuits of 115 volts or 115/230 volts.** Each recreational vehicle designed with a 115-volt or 115/230-volt electrical system shall withstand the applied potential without electrical breakdown of a one-minute 900-volt dielectric strength test, or a one-second 1,080-volt dielectric strength test, with all switches closed between current-carrying conductors, including neutral, and the recreational vehicle ground.

The test transformer shall be adjustable. Starting at zero the applied potential shall be increased gradually in at least four steps until either the test value is reached or breakdown occurs. During the test, all switches and other controls shall be in the "on" position. Fixtures and permanently installed appliances shall not be required to withstand this test.

(b) **Battery and Low-Voltage Circuits.** The battery or low-voltage circuit conductors in each recreational vehicle shall withstand the applied potential without electrical breakdown of a one-minute 500-volt or a one-second 600-volt dielectric strength test. The test transformer shall be adjustable. The potential shall be applied between live and grounded conductors.

**551-26. Examination of Equipment for Safety.**

The examination or inspection of equipment for safety should be conducted under uniform conditions and by organizations properly equipped and qualified for experimental testing, inspections of the run of goods at factories, and service-value determinations through field examinations.

**B. Recreational Vehicle Parks**

**551-40. Application and Scope.** Part B covers electrical systems on recreational vehicle parks. It does not apply to the electrical systems of recreational vehicles or the conductors that connect them to the park electrical supply facilities. Wherever the requirements of other Articles of this Code and Article 551 differ, the requirements of Article 551 shall apply.

**551-41. Definitions.**

**Lot:** The area in a recreational park intended for the connection of one recreational vehicle.

**Power-Supply Assembly:** The conductors, including the grounding conductors, insulated from one another, the connectors, attachment plug caps, and all other fittings, grommets, or devices installed for the purpose of delivering energy from the source of electrical supply to the distribution panel within the recreational vehicle.

**Recreational Vehicle Lot Service Equipment.** The necessary equipment usually consisting of a circuit breaker or switch and fuse and their accessories, located near the point of entrance of supply conductors to a recreational vehicle lot and intended to constitute the disconnecting means for the supply to that lot.

**551-42. Receptacles Required.** A minimum of 75 percent of all lots with electrical service equipment shall be equipped with both a 20-ampere, 125-volt receptacle conforming to ANSI Standard C73.12-1966, and a 30-ampere, 125-volt receptacle conforming to ANSI Standard C73.13-1966. The remainder of all lots with electrical service equipment shall be equipped with a 20-ampere, 125-volt receptacle conforming to ANSI Standard C73.12-1966.

**551-43. Distribution System.** The recreational vehicle park secondary electrical distribution system to recreational vehicle lots shall be derived from a single-phase 120/240-volt, 3-wire system.

**551-44. Calculated Load.**

(a) Electrical service and feeders shall be calculated on the basis of not less than 3,600 watts per lot equipped with both 20-ampere and 30-ampere supply facilities and 2,400 watts per lot equipped with only 20-ampere supply facilities. The demand factors set forth in Table 551-44 are the minimum allowable demand factors that may be used in calculating load for service and feeders.

(b) For the purpose of this Code, where the park service exceeds 240 volts, transformers and secondary distribution panelboards shall be treated as services.

**Table 551-44**  
**Demand Factors for Feeders and Service-Entrance Conductors for**  
**Park Lots**

Number of Recreational Vehicle Lots	Demand Factor (percent)	Number of Recreational Vehicle Lots	Demand Factor (percent)
1 .....	100	10-12 .....	29
2 .....	100	13-15 .....	28
3 .....	70	16-18 .....	27
4 .....	55	19-21 .....	26
5 .....	44	22-40 .....	25
6 .....	39	41-100 .....	24
7-9 .....	33	101 and over .....	23

(c) The demand factor for a given number of lots shall apply to all lots indicated. For example: 20 lots calculated at 26 percent of 3,600 watts result in a permissible demand of 936 watts per lot or a total of 18,720 watts for 20 lots.

(d) Recreational vehicle lot feeder circuit conductors shall have adequate ampacity for the loads supplied, and shall be rated at not less than 30 amperes.

**551-45. Overcurrent Protection.** Overcurrent protection shall be provided in accordance with Article 240.

**551-46. Grounding.** All electrical equipment and installations in recreational vehicle parks shall be grounded as required by Article 250.

**551-47. Recreational Vehicle Lot Service Equipment.**

(a) **Disconnecting Means.** A disconnecting switch or circuit breaker shall be provided in the lot service equipment for disconnecting the power supply to the recreational vehicle.

(b) **Access.** All lot service equipment shall be accessible by an unobstructed entrance or passageway not less than two feet wide and 6½ feet high.

(c) **Mounting Height.** Lot service equipment shall be located not less than 2 feet nor more than 6½ feet above the ground.

(d) **Working Space.** Sufficient space shall be provided and maintained about all electrical equipment to permit ready and safe operation, in accordance with Section 110-16.

**551-48. Grounding, Recreational Vehicle Lot Equipment.**

(a) Exposed noncurrent-carrying metal parts of fixed equipment, metal boxes, cabinets and fittings, which are not electrically connected to grounded equipment shall be grounded by a continuous grounding conductor run with the circuit conductors from the service equipments or from the transformer of a secondary distribution system.

(b) Each secondary distribution system shall be grounded at the transformer.

(c) The neutral conductor shall not be used as an equipment ground for recreational vehicles or equipment within the recreational vehicle park.

(d) No connection to a grounding electrode shall be made to the neutral conductor on the load side of the service disconnecting means or transformer distribution panelboard.

**551-49. Protection of Outdoor Equipment.**

(a) **Wet Locations.** All switches, circuit breakers, receptacles, control equipment and metering devices located in wet places or outside of a building shall be rainproof equipment.

(b) **Meters.** If secondary meters are installed, meter sockets without meters installed shall be blanked off with an approved blanking plate.

**551-50. Overhead Conductors.**

(a) **Vertical Clearance.** Open conductors of not over 600 volts shall have a vertical clearance of not less than 18 feet in all areas subject to recreational vehicle movement. In all other areas, vertical clearances shall conform to Section 730-18.

For clearance of conductors of over 600 volts, see National Electrical Safety Code (ANSI C2-1960).

(b) **Horizontal Clearance.** The horizontal clearance from structures and recreational vehicles for overhead conductors shall be not less than 3 feet for 600 volts or less.

**551-51. Underground Service, Feeder, Branch-Circuit and Recreational Vehicle Lot Feeder Circuit Conductors.**

(a) **General.** All direct-burial conductors, including the equipment grounding conductor if of aluminum, shall be insulated and specifically approved for the purpose. All conductors shall be continuous from fitting to fitting. All splices shall be made in approved junction boxes.

(b) **Mechanical Protection.** Where underground conductors enter or leave a building or trench, they shall have mechanical protection in the form of rigid metal conduit, electrical metallic tubing or other approved mechanical means, extending a minimum of 18 inches into the trench from the finished grade. See Section 310-6 and Article 339.

**551-52. Receptacles.** A receptacle to supply electric power to a recreational vehicle shall be of one of the following configurations:

(a) ANSI Standard C73.17-1966, 125/250 volts, 50-ampere, 3-pole, 4-wire, grounding-type for 115/230-volt systems.

(b) ANSI Standard C73.13-1966, 125-volt, 30-ampere, 2-pole, 3-wire, grounding-type for 115-volt systems.

(c) ANSI Standard C73.12-1966, 125-volt, 20-ampere, 2-pole, 3-wire, grounding-type for 115-volt systems.

## **ARTICLE 555 — MARINAS AND BOATYARDS**

**555-1. Scope.** The provisions of this Article shall apply to the installation of wiring in those areas of marinas, boatyards, boat basins and similar establishments and equipment including floating piers which are used for the construction, repair, storage, launching, berthing and fueling of small craft.

**555-2. Voltage Drop.** See Section 215-3.

**555-3. Receptacles.** Receptacles which provide shore power for boats shall be rated not less than 20 amperes and shall be single and of the locking and grounding types conforming to the configurations in ANSI C73-1971.

Ground-fault circuit protection may be provided for these circuits and where used will provide additional protection against line-to-ground shock hazard.

**555-4. Branch Circuits.** Each single receptacle which supplies shore power for a boat shall be supplied by an individual branch circuit of the voltage class and rating corresponding to the rating of the receptacle.

**555-5. Feeder and Service.** The ampacity for feeder and service conductors supplying shore power for boats shall be calculated on the basis of a minimum of 25 watts per lineal foot of slip or dock space for boat outlet circuits plus lighting and other loads. Minimum feeder conductor size shall be No. 10 AWG. Minimum service conductor size shall be No. 8 AWG.

**555-6. Wiring Methods.** Wiring methods where exposed to the weather or water shall be rigid nonmetallic conduit approved for the purpose,

Type MI cable, nonmetallic cable approved for the purpose, or corrosion-resistant rigid metal conduit approved for the purpose.

*Exception No. 1: Open wiring may be installed by special permission.*

Factors to be considered would include possible contact with masts, cranes, and other equipment.

*Exception No. 2: Underground wiring which conforms to the requirements of this Code.*

*Exception No. 3: Where flexibility is required, other approved types.*

See Fire Protection Standard for Marinas and Boatyards, NFPA No. 303-1969 for further information on wiring methods for various locations.

#### **555-7. Grounding.**

**(a) Grounding Means.** The following items shall be connected to a copper equipment grounding conductor run with circuit conductors in a raceway or cable. Such a conductor shall be insulated and the covering shall be a continuous green color or a continuous green color with one or more yellow stripes:

- (1) Boxes, cabinets and all other metallic enclosures.
- (2) Metal frames of utilization equipment.
- (3) Grounding terminals of grounding-type receptacles.

**(b) Size of Equipment Grounding Conductor.** The insulated copper equipment grounding conductor shall be sized in accordance with Section 250-95 but not smaller than No. 12 AWG.

**(c) Branch-Circuit Equipment Grounding Conductor.** The insulated equipment grounding conductor for branch circuits shall terminate at a grounding terminal in a remote panelboard or the grounding terminal in the main service equipment.

**(d) Feeder Equipment Grounding Conductors.** Where a feeder supplies a remote panelboard an insulated equipment grounding conductor shall extend from a grounding terminal in the service equipment to a grounding terminal in the remote panelboard.

**555-8. Clearance Over Water.** Wiring over navigable waterways shall be approved by the authority in charge of the specific waterway.

## Chapter 6. Special Equipment

### ARTICLE 600 — ELECTRIC SIGNS AND OUTLINE LIGHTING

#### A. General

**600-1. Scope.** The provisions of this Article shall apply to the installation of conductors and equipment for electric signs and outline lighting as defined in Article 100.

**600-2. Disconnect Required.** Each outline lighting installation, and each sign of other than the portable type, shall be controlled by an externally operable switch or breaker which will open all ungrounded conductors and shall be suitable for conditions of installation, such as exposure to the weather.

(a) **In Sight of Sign.** The switch or breaker required by Section 600-2 shall be within sight of the sign or outline lighting which it controls or may be located elsewhere when capable of being locked in the open position.

(b) **Control Switch Rating.** Switches, flashers, and similar devices controlling transformers shall be either of a type approved for the purpose, or have a current rating not less than twice the current rating of the transformers. On alternating-current circuits, general-use alternating-current snap switches may be used to control inductive loads other than motors, not exceeding the ampere rating of switch. See Section 380-14.

**600-5. Grounding.**

(a) Signs, troughs, tube terminal boxes and other metal frames shall be grounded in the manner specified in Article 250 of this Code, unless they are insulated from ground and from other conducting surfaces and are inaccessible to unauthorized persons.

(b) Isolated noncurrent-carrying metal parts of outline lighting may be bonded by No. 14 conductors and grounded in accordance with Article 250.

(c) Signs of the portable incandescent or fluorescent-lamp type in which the open circuit voltage does not exceed 150 volts to ground are not required to be grounded.

**600-6. Load of Branch Circuit.** Circuits shall be so arranged that the load imposed by outlets, lamps, and transformers connected to them, shall in no case exceed the rating of the branch circuit.

Circuits which supply lamps, ballasts, and transformers or combinations thereof may be rated not to exceed 20 amperes.

Circuits containing electric-discharge lighting transformers exclusively shall not be rated in excess of 30 amperes.

**600-7. Marking.**

(a) Signs shall be marked with the maker's name, and for incandescent-lamp signs with the number of lampholders, and for electric discharge signs with input amperes at full load and input voltage. The marking of the sign shall be visible for inspection after installation.

(b) Transformers shall be marked with the maker's name, and transformers for electric-discharge signs shall be marked with the input rating in amperes or volt-amperes, the input voltage and the open-circuit high-tension voltage.

**600-8. Enclosures.** Enclosures for signs and outline lighting shall conform to the following:

(a) **Conductors and Terminals.** Conductors and terminals in sign boxes, cabinets, and outline troughs shall be enclosed, except the supply leads.

(b) **Cutouts, Flashers, Etc.** Cutouts, flashers, and similar devices shall be enclosed in metal boxes the doors of which shall be arranged so that they can be opened without removing obstructions or finished parts of the enclosure.

(c) **Strength.** Enclosures shall have ample strength and rigidity.

(d) **Material.** Except for portable signs of the indoor type, signs and outline lighting shall be constructed of metal or other noncombustible material. Wood may be used for external decoration if placed not less than 2 inches from the nearest lampholder or current-carrying part.

(e) **Minimum Thickness — Enclosure Metal.** Sheet copper shall be at least 20 ounce (0.028 inch). Sheet steel shall be of No. 28 MSG except that for outline lighting and for electric-discharge signs sheet steel shall be of No. 24 MSG, unless ribbed, corrugated or embossed over its entire surface, when it may be of No. 26 MSG.

(f) **Protection of Metal.** All steel parts of enclosures shall be galvanized or otherwise protected from corrosion.

(g) **Enclosures Exposed to the Weather.** Enclosures for outside use shall be weatherproof and shall have an ample number of drain holes, each not larger than  $\frac{1}{2}$  inch or smaller than  $\frac{1}{4}$  inch. Wiring connections shall not be made through the bottoms of enclosures exposed to the weather unless the enclosures are of the raintight type.

**B. Signs and Outline Lighting — 600 Volts or Less**

**600-21. Installation of Conductors.** Conductors shall be installed as follows:

(a) **Wiring Method.** Conductors shall be installed as open conductors on insulators, in rigid metal conduit, flexible metal conduit, liquid-tight flexible metal conduit, electrical metallic tubing, metal-clad cable, metal troughing, Type ALS cable or Type MI cable.

(b) **Insulation and Size.** Conductors shall be of a type approved for general use and shall be no smaller than No. 14.

*(Exceptions on page 70-396)*

*Exception No. 1: Conductors in portable signs, short leads permanently attached to lampholders or ballasts, and leads in wiring channels which are permanently attached to electric-discharge lampholders or electric-discharge ballasts and which are not longer than 8 feet may be smaller than No. 14 but shall not be smaller than No. 18 and shall be of a type approved for the purpose.*

*Exception No. 2: Conductors, for signs with multiple incandescent lamps requiring one conductor from a control to one or more lamps whose total load does not exceed 250 watts, may be smaller than No. 14 but shall not be smaller than No. 18 if in an approved cable assembly of two or more conductors.*

**(c) Exposed to the Weather.** Conductors in raceways, metal-clad cable or enclosures exposed to the weather, shall be of the lead-covered type or other type specially approved for the conditions, except where rigid conduit, electrical metallic tubing or enclosures are made raintight and arranged to drain.

**(d) Number of Conductors in Raceway.** Number of conductors in raceway for sign flashers may be in accordance with Table 1 of Chapter 9.

**(e) Open Conductors.** Open conductors on insulators shall comply with the provisions of Sections 300-2 through 300-22, and, if outdoors, Article 730, except that the separation between conductors need be only 2 inches.

*Exception: Open conductors may be supported by lampholders located not more than one foot apart.*

**(f) Conductors Soldered to Terminals.** Where the conductors are fastened to lampholders other than of the pin type, they shall be soldered to the terminals and the exposed parts of conductors and terminals shall be treated to prevent corrosion. Where the conductors are fastened to pin-type lampholders which protect the terminals from the entrance of water, and which have been found acceptable for sign use, the conductors shall be of the stranded type but need not be soldered to the terminals.

**600-22. Lampholders.** Lampholders shall be of the unswitched type having bodies of suitable insulating material and shall be so constructed and installed as to prevent turning. Miniature lampholders shall not be employed for outdoor signs and outline lighting.

### **C. Signs and Outline Lighting — Exceeding 600 Volts**

**600-31. Installation of Conductors.** Conductors shall be installed as follows:

**(a) Wiring Method.** Conductors shall be installed as open work, as concealed conductors on insulators, in rigid metal conduit, in flexible metal conduit, in liquidtight flexible metal conduit, or in electrical metallic tubing.

**(b) Insulation and Size.** Conductors shall be of a type approved for the purpose and for the voltage of the circuit and shall be not smaller than No. 14.



*Exception No. 1: Leads in wiring channels which are permanently attached to electric-discharge lampholders or electric-discharge ballasts and which are not longer than 8 feet may be smaller than No. 14 but shall not be smaller than No. 18 and shall be of a type approved for the purpose.*

*Exception No. 2: Leads in show-window displays or small portable signs that run from the line ends of the tubing to the secondary windings of the transformer where they are permanently attached within the transformer enclosure and which are not longer than 8 feet may be smaller than No. 14, but shall not be smaller than No. 18 and shall be of a type approved for the purpose.*

**(c) Bends in Conductors.** Sharp bends in the conductors shall be avoided.

**(d) Open Conductors — Indoors.** Open conductors indoors shall be mounted on noncombustible, nonabsorptive insulators. Insulators of porcelain shall be glazed on all exposed surfaces. A separation of at least 1½ inches shall be maintained between conductors and between conductors and other objects. Conductors shall not be located where subject to physical damage.

**(e) Concealed Conductors on Insulators — Indoors.** Concealed conductors on insulators shall be separated from each other and from all objects other than the insulators on which they are mounted by a spacing of not less than 1½ inches for voltages above 10,000 volts, and not less than one inch for voltages of 10,000 or less. They shall be installed in channels lined with noncombustible material and used for no other purpose, except that the primary circuit conductors may be in the same channel. The insulators shall be of noncombustible, nonabsorptive material.

**(f) Conductors in Raceways.** Where the conductors are covered with lead or other metal sheathing, the covering shall extend beyond the end of the raceway, and the surface of the cable shall not be injured where the covering terminates.

**(1)** In damp or wet locations, the insulation on all conductors shall extend beyond the metal covering or raceway at least 4 inches for voltages over 10,000, 3 inches for voltages over 5,000 but not exceeding 10,000, and 2 inches for voltages of 5,000 or less.

**(2)** In dry locations the insulation shall extend beyond the end of the metal covering or raceways not less than 2½ inches for voltages over 10,000, 2 inches for voltages over 5,000 but not exceeding 10,000, and 1½ inches for voltages of 5,000 or less.

**(3)** For conductors at grounded midpoint terminals, no spacing is required.

**(4)** A metal raceway containing a single conductor from one secondary terminal of a transformer shall not exceed 20 feet in length.

**(g) Open Conductors — Outdoors.** Open conductors outdoors shall be mounted on noncombustible, nonabsorptive insulators. Insulators of porcelain shall be glazed on all exposed surfaces. A separation of at least 2 inches shall be maintained between conductors, and between conductors and other objects.

(Continued on page 70-398)

Where subject to physical damage, or where within reach from ground, roof, or window, conductors shall be enclosed in raceways or suitably guarded. Where guarded, a spacing of not less than 1½ inches shall be maintained between conductors and the enclosure unless the enclosure is nonconducting and noncombustible.

**(h) Show Windows and Similar Locations.** Conductors that hang freely in the air, away from combustible material, and where not subject to physical damage, as in some show-window displays, need not be otherwise protected.

**(i)** Conductors may be run from the ends of tubing to the grounded midpoint of transformers specifically designed for the purpose and provided with terminals at the midpoint. Where such connections are made to the transformer grounded midpoint, the connections between the high-voltage terminals of the transformer and the line ends of the tubing shall be as short as possible.

**600-32. Transformers.** Transformers shall comply with the following:

**(a) Voltage.** The transformer secondary open-circuit voltage shall not exceed 15,000 volts with an allowance on test of 1,000 volts additional. In end-grounded transformers the secondary, open-circuit voltage shall not exceed 7,500 volts with an allowance on test of 500 volts additional.

**(b) Type.** Transformers shall be of a type approved for the purpose and shall be limited in rating to a maximum of 4,500 volt-amperes.

Open core-and-coil type transformers shall be limited to 5,000 volts with an allowance on test of 500 volts, and to indoor applications in small portable signs.

Transformers for outline lighting installations shall have secondary current ratings not in excess of 30 milliamperes except where they and all wiring connected to them are installed in accordance with the provisions of Article 410 for electric-discharge lighting of the same voltage.

**(c) Exposed to Weather.** Transformers used outdoors shall be of the weatherproof type or shall be protected from the weather by enclosure in the sign body or in a separate metal box.

**(d) Transformer Secondary Connections.** The high-voltage windings of transformers shall not be connected in parallel; and shall not be connected in series, except that two transformers each having one end of its high-voltage winding connected to the metal enclosure may have their high-voltage windings connected in series to form the equivalent of a midpoint-grounded transformer. The grounded ends shall be connected by insulated conductors not smaller than No. 14.

*Exception: Transformers for small portable signs, show windows, and similar locations that are equipped with leads permanently attached to the secondary winding within the transformer enclosure and that do not extend more than 8 feet beyond the enclosure for attaching to the line ends of the tubing may have leads smaller than No. 14, but shall not be smaller than No. 18 and shall be of a type approved for the purpose.*

(e) **Accessibility.** Transformers shall be accessible.

**600-33. Electric-Discharge Tubing.** Electric-discharge tubing shall conform to the following:

(a) **Design.** The tubing shall be of such length and design as not to cause a continuous overvoltage on the transformer.

(b) **Support.** Tubing shall be adequately supported on noncombustible, nonabsorptive supports. Tubing supports should, where practicable, be adjustable.

(c) **Contact with Flammable Material and Other Surfaces.** The tubing shall be free from contact with flammable material and shall be located where not normally exposed to physical damage. Where operating in excess of 7,500 volts, the tubing shall be supported on noncombustible, nonabsorptive, insulating supports which maintain a spacing of not less than  $\frac{1}{4}$  inch between the tubing and the nearest surface.

**600-34. Terminals and Electrode Receptacles for Electric-Discharge Tubing.** Terminals and electrode receptacles for electric-discharge tubing shall comply with the following:

(a) **Terminals.** Terminals of the tubing shall be inaccessible to unqualified persons and isolated from combustible material and grounded metal or shall be enclosed. Where enclosed they shall be separated from grounded metal and combustible material by noncombustible, nonabsorptive, insulating material approved for the purpose or by  $1\frac{1}{2}$  inches of air. Terminals shall be relieved from stress by the independent support of the tubing.

(b) **Tube Connections Other Than with Receptacles.** Where tubes do not terminate in receptacles designed for the purpose, all live parts of tube terminals and conductors shall be so supported as to maintain a separation of at least  $1\frac{1}{2}$  inches between conductors or between conductors and any grounded metal.

(c) **Receptacles.** Electrode receptacles for the tubing shall be of noncombustible, nonabsorptive insulating material approved for the purpose.

(d) **Bushings.** Where electrodes enter the enclosure of outdoor signs or of an indoor sign operating at a voltage in excess of 7,500 volts, bushings shall be used unless receptacles are provided or the sign is wired with bare wire mounted on approved supports which maintain the tubing in proper position. Bushings shall be of noncombustible, nonabsorptive material. Where bare wiring is used, the conductor shall be not less than No. 14 solid copper, shall be supported so as to prevent sagging and lessening of the spacing required elsewhere in this Article, and electrode terminal assemblies shall be of an approved type and supported not more than 6 inches from the electrode terminals.

(e) **Show Windows.** In the exposed type of show-window signs, terminals shall be (1) enclosed by receptacles approved for the purpose or (2) where hanging in air, free from grounded surfaces, enclosed in sleeves of vulcanized fiber, phenolic composition, or other suitable material which overlaps all live parts by at least  $\frac{1}{2}$  inch.

(f) **Receptacles and Bushing Seals.** A flexible, nonconducting seal may be used to close the opening between the tubing and the receptacle or bushing against the entrance of dust or moisture. This seal shall not be in contact with grounded conductive material and shall not be depended upon for the insulation of the tubing.

(g) **Enclosures of Metal.** Enclosures of metal for electrodes shall be of not less than No. 24 MSG sheet metal.

(h) **Enclosures of Insulating Material.** Enclosures of insulating material shall be noncombustible, nonabsorptive and approved for the voltage of the circuit.

**600-35. Switches on Doors.** Doors or covers giving access to uninsulated parts of indoor signs or outline lighting exceeding 600 volts and accessible to the general public, shall either be provided with interlock switches which on the opening of the doors or covers disconnect the primary circuit, or shall be so fastened that the use of the other than ordinary tools will be necessary to open them.

## ARTICLE 610 — CRANES AND HOISTS

### A. Scope and Use

**610-1. Scope.** The provisions of this Article shall apply to the installation of cranes, crane runways, hoists, and monorails.

#### 610-2. Particular Locations.

(a) **Ignitable Material Hazards.** Installations in hazardous locations shall comply with the provisions of Section 503-13.

(b) **Combustible Materials.** Where a crane operates over readily combustible material, the resistors shall be placed in a well-ventilated cabinet composed of noncombustible material so constructed that it will not emit flames or molten metal.

*Exception: Resistors may be located in a cage or cab constructed of noncombustible material which encloses the sides of the cage or cab from the floor to a point at least 6 inches above the top of the resistors.*

### B. Wiring

**610-11. Wiring Method.** Conductors shall be enclosed in raceways or be Type ALS cable or Type MI cable.

*Exception No. 1: Bare conductors used as contact conductors.*

*Exception No. 2: Short lengths of open conductors at resistors, collectors, and other equipment.*

*Exception No. 3: Where flexible connections are necessary to motors and similar equipment, flexible metal conduit, liquidtight flexible metal conduit, metal-clad cable, multiple-conductor rubber-covered cable or an approved nonmetallic enclosure may be employed.*

*Exception No. 4: Where multiple-conductor cable is used with a suspended pushbutton station, the station must be supported in some satisfactory manner that will protect the electrical conductors against strain.*

**610-12. Raceway Terminal Fittings.** Conductors leaving raceways shall comply with the provisions of Section 300-16.

**610-13. Types of Conductors.** Conductors shall be of the rubber-covered or the thermoplastic type except:

*Exception No. 1: Contact conductors along runways, crane bridges and monorails may be bare and may be of hard drawn copper, or aluminum, or steel in the form of tees, angles, tee rails, or other stiff shapes.*

*Exception No. 2: Flexible conductors may be used to convey current and where practicable, cable reels or take-up devices may be employed.*

*Exception No. 3: Varnished-cambric conductors (Type V) or asbestos varnished cambric (Types AVA and AVB) may be used in dry locations.*

*Exception No. 4: Type MI cable may be used in wet or dry locations within its specified temperature ratings.*

*Exception No. 5: Conductors exposed to external heat or connected to resistors shall have an insulation approved for the temperature and location as specified in Section 310-2. Where conductors not having a flame-resistant outer covering are grouped together, the group shall be covered with a flame-resistant tape.*

#### **610-14. Conductors**

**(a) Ampacity.** The allowable ampacities of conductors shall be as shown in Table 610-14(a). For the ampacities of conductors between controllers and resistors, see Section 430-23.

**(b) Minimum.** Conductors shall not be smaller than No. 14.

*Exception: No. 16 may be used for crane and hoist motor and control circuits only when the application meets Section 610-14(a) ampacity, and provided the conductors are protected against physical damage.*

**(c) Contact Conductors.** The size of contact wires shall be not less than the following:

Distance between end strain insulators	Size of wire
0-30 feet	No. 6
31-60 feet	No. 4
over 60 feet	No. 2

**(d) Calculation of Motor Load.** The ampacity of the power supply conductors on the crane shall be not less than the combined short-time full-load ampere rating of the largest motor or group of motors for any single crane motion plus 50 percent of the combined short-time full-load ampere rating of the next largest motor or group of motors.

**(e) Other Loads.** Additional loads, such as heating, lighting, and air conditioning, shall be provided for by application of the appropriate sections of this Code.

**Table 610-14(a)**  
**Ampacities of Insulated Conductors in Raceway or Cable**  
**Used with Short-Time Rated Crane and Hoist Motors**

Max. Operating Temp.	60°C		75°C		90°C		110°C	
	Type T, TW		Type RH, RHW, THW, THWN, XHHW		Type AVB, FEP, FEPB, RHH, SA, TA, THHN, XHHW*		Type AVA	
	60 min	30 min	60 min	30 min	60 min	30 min	60 min	30 min
16	10	10	10	12				
14	20	20	25	26	31	32	38	40
12	25	25	30	33	36	40	45	50
10	35	35	40	43	49	52	60	65
8	45	50	55	60	63	69	73	80
6	57	70	76	86	83	94	93	105
5	65	80	85	95	95	106	109	121
4	77	95	100	117	111	130	126	147
3	90	115	120	141	131	153	145	168
2	107	130	137	160	148	173	163	190
1	130	150	143	175	158	192	177	215
0	160	180	190	233	211	259	239	294
00	195	225	222	267	245	294	275	331
000	245	280	280	341	305	372	339	413
0000	295	350	300	369	319	399	352	440
250	350	375	364	420	400	461	447	516
300	410	475	455	582	497	636	554	707
350	460	550	486	646	542	716	616	809
400	515	580	538	688	593	760	666	856
450	565	640	600	765	660	836	740	930
500	620	700	660	847	726	914	815	1004

Other insulations shown in Section 310-2 and approved for the temperatures and location may be substituted for those shown in Table 610-14(a).

The allowable ampacities of conductors used with 15-minute motors shall be the 30-minute ratings increased by 12 percent.

\* For dry locations only. See Table 310-2(a).

**610-15. Common Return.** Where a crane or hoist is operated by more than one motor, a common-return conductor of proper ampacity may be used.

### C. Contact Conductors

**610-21. Installation of Contact Conductors.** Bare contact conductors shall conform to the following:

(a) **Contact Wires.** Wires that are used as contact conductors shall be secured at the ends by means of approved strain insulators and shall be so mounted on approved insulators that the extreme limit of displacement of the wire will not bring the latter within less than 1½ inches from the surface wired over.

(b) **Supports Along Runways.** Main contact conductors carried along runways shall be supported on insulating supports placed at intervals not exceeding 20 feet, and these supports shall be insulating except for grounded rail conductors as provided in Section 610-21(e). Such conductors shall be separated not less than 6 inches except for monorail hoists where a spacing of not less than 3 inches may be used. Where necessary, intervals between insulating supports may be increased up to 40 feet, the separation between conductors being increased proportionately.

(c) **Supports on Bridges.** Bridge contact conductors shall be kept at least 2½ inches apart and, where the span exceeds 80 feet, insulating saddles shall be placed at intervals not exceeding 50 feet.

(d) **Supports for Rigid Conductors.** Conductors along runways and crane bridges, which are of the rigid type specified in Section 610-13, Exception No. 1, shall be carried on insulating supports spaced at intervals of not more than 80 times the vertical dimension of the conductor, but in no case greater than 15 feet, and spaced apart sufficiently to give a clear electrical separation of conductors or adjacent collectors of not less than one inch.

(e) **Track as Circuit Conductor.** Monorail, tramrail or crane-runway tracks may be used as a conductor of current for one phase of a three-phase alternating-current system furnishing power to the carrier, crane or trolley, provided all of the following conditions are fulfilled:

(1) The conductors for supplying the other two phases of the power supply shall be insulated.

(2) The power for all phases shall be obtained from an insulating transformer.

(3) The voltage shall not exceed 300 volts.

(4) The rail serving as a conductor shall be effectively grounded at the transformer and may also be grounded by the fittings used for the suspension or attachment of the rail to a building or structure.

(f) **Electrical Continuity of Contact Conductors.** All sections of bare rigid contact conductors shall be mechanically joined to provide a continuous electrical connection.

**(g) Not to Supply Other Equipment.** Contact conductors shall not be used as feeders for any equipment other than the crane or cranes which they are primarily designed to serve.

**(h) Locating or Guarding Contact Conductors.** Contact conductors shall be located or guarded in such a manner that unqualified persons cannot inadvertently touch energized current-carrying parts.

**610-22. Collectors.** Collectors shall be so designed as to reduce to a minimum sparking between them and the contact conductor, and when operated in rooms used for the storage of easily ignitable combustible fibers and materials the requirements of Section 503-13 shall be complied with.

#### **D. Control**

**610-31. Runway Conductor Disconnecting Means.** A disconnecting means shall be provided between the runway contact conductors and the power supply. Such disconnecting means shall consist of a motor-circuit switch or circuit breaker. This disconnecting means shall be readily accessible and operable from the ground, shall be arranged to be locked in the open position, shall open all ungrounded conductors simultaneously, and shall be placed within sight of the crane or hoist and the runway contact conductors.

**610-32. Disconnecting Means for Crane.** A motor-circuit switch or circuit breaker shall be provided in the leads from the runway contact conductors on all bridge cranes. Where this disconnecting means is not readily accessible from the crane operating station, means shall be provided at the crane operating station to open the power circuit to the crane motors.

**610-33. Rating of Disconnecting Means for Crane.** On both alternating-current and direct-current crane protective panels, the continuous ampacity of the switch or circuit breaker required by Section 610-32, and main line contactors, shall be not less than 50 percent of the combined short-time ampacities of the motors, nor less than 75 percent of the sum of the short-time ampacities of the motors required for any single crane motion.

**610-34. Limit Switch.** A limit switch shall be provided for upper limit of travel of crane hoists.

#### **E. Overcurrent Protection**

**610-41. Contact Conductors.** The main contact conductors shall be protected by an overcurrent device.

**610-42. Crane Motors.** Where more than one motor is employed on a crane, each motor shall have individual overcurrent protection as provided in Article 430, except that where two motors operate a single hoist, carriage, truck, or bridge, and are controlled as a unit by one controller, the pair of motors with their leads may be protected by a single overcurrent device.

#### **F. Grounding**

**610-51. Grounding.** All exposed metal parts of cranes, hoists, and accessories, including pendant controls, shall be metallically joined to-



gether into a continuous electrical conductor so that the entire crane or hoist will be grounded on installation in accordance with Article 250. Moving parts, other than removable accessories or attachments having metal-to-metal bearing surfaces, such as bridge wheels running on a track, shall be considered to be electrically connected to each other through the bearing surfaces for grounding purposes.

## ARTICLE 620 — ELEVATORS, DUMBWAITERS, ESCALATORS, AND MOVING WALKS

### A. Scope and General

**620-1. Scope.** This Article shall apply to electrical equipment and wiring used in connection with elevators, dumbwaiters, escalators, and moving walks.

For further information see ANSI Safety Code for Elevators, Dumbwaiters, Escalators and Moving Walks, A17.1-1965.

**620-2. Voltage Limitations.** The nominal voltage used for elevator, dumbwaiter, escalator, and moving-walk operating control and signal circuits, operating equipment, driving machine motors, machine brakes, and motor-generator sets shall not exceed the following:

(a) For operating control and signal circuits and related equipment including door operator motors: 300 volts except that higher potentials may be used for frequencies of 25- through 60-hertz alternating current or for direct current provided the current in the system cannot, under any conditions, exceed 8 milliamperes for alternating current or 30 milliamperes for direct current.

(b) Driving machine motors, machine brakes, and motor-generator sets: 600 volts, except that higher potentials may be used for driving motors of motor-generator sets.

**620-3. Live Parts Enclosed.** All live parts of electrical apparatus in the hoistways, at the landings, or in or on the cars of elevators and dumbwaiters or in the wellways or the landings of escalators or moving walks shall be enclosed to protect against accidental contact.

### B. Conductors

**620-11. Insulation of Conductors.** The insulation of conductors installed in connection with elevators, dumbwaiters, escalators and moving walks, shall comply with the following:

(a) **Control Panel Wiring.** Conductors from panels to main circuit resistors shall be flame-retardant and suitable for a temperature of not less than 90°C (194°F). All other wiring on control panels shall be flame-retardant, moisture-resistant.

(b) **Traveling Cables.** Traveling cables used as flexible connections between the elevator or dumbwaiter car and the raceway shall be of the types of elevator cable listed in Table 400-11 or other approved types.

(c) **Other Wiring.** All conductors in the raceways and in or on the cars of elevators and dumbwaiters and in the wellways of escalators and moving walks and in the machine room of elevators, dumbwaiters, escalators and moving walks shall have flame-retardant and moisture-resistant insulation.

(d) **Thickness of Insulation.** The thickness of the insulation of all conductors shall be suitable for the voltage to which the conductors are subjected.

**620-12. Minimum Size of Conductors.** The minimum size of conductors used for elevator, dumbwaiter, escalator, and moving walk wiring, except for conductors which form an integral part of control equipment, shall be as follows:

(a) **Traveling Cables.**

(1) For lighting circuits: No. 14.

*Exception: No. 20 or larger conductors may be used in parallel provided the ampacity is equivalent to at least that of No. 14 wire.*

(2) Operating control and signal circuits: No. 20.

(b) **Other Wiring.** All operating control and signal circuits: No. 20.

**620-13. Motor Circuit Conductors.** Conductors supplying elevator, dumbwaiter, escalator, or moving walk motors shall have an ampacity conforming to (a), (b) and (c) below based on the nameplate current rating of the motors. With generator field control, the ampacity shall be based on the nameplate current rating of the driving motor of the motor-generator set which supplies power to the elevator motor.

The heating of conductors depends on root-mean-square current values which, with generator field control, are reflected by the nameplate current rating of the motor-generator set driving motor rather than by the rating of the elevator motor which represents actual but short time and intermittent full-load current values.

(a) **Conductors Supplying a Single Motor.** Conductors supplying a single motor shall have an ampacity in conformance with Section 430-22, Table 430-22 (a-Exception).

(b) **Conductors Supplying Several Motors.** Conductors supplying several motors shall have an ampacity of not less than 125 percent of the nameplate current rating of the highest rated motor in the group plus the sum of the nameplate current ratings of the remainder of the motors in the group.

(c) **Feeder Demand Factor.** Feeder conductors of less capacity than required by (b) above may be furnished subject to the requirements of Section 430-26.

### C. Wiring

**620-21. Wiring Methods.** Conductors located in hoistways and escalators and moving walk wellways, in or on cars and machine and control rooms, not including the traveling cables connecting the car and hoistway wiring, shall be installed in rigid conduit, electrical metallic tubing, metal wireways, Type ALS cable or Type MI cable subject to the following exceptions:

*Exception No. 1: Flexible conduit or Type AC metal-clad cable may be used in hoistways and in escalator and moving walk wellways between risers and limit switches, interlocks, operating buttons, and similar devices.*

*Exception No. 2: Short runs of flexible conduit or Type AC metal-clad cable may be used on cars where so located as to be free from oil and if securely fastened in place.*

*Exception No. 3: Types S, SO, STO, or ST cords may be used as flexible connections between the fixed wiring on the car and the switches on car doors or gates. Such cords may be used as flexible connections for the top-of-car operating device or the car top work light. These devices or fixtures shall be grounded by means of a grounding conductor run with the circuit conductors.*

*Exception No. 4: Conductors between control panels and machine motors, machine brakes, and motor generator sets, not exceeding 6 feet in length, may be grouped together and taped or cored without being installed in a raceway provided the taping or cording is painted with an insulating paint. Such cable groups shall be supported at intervals of not more than three feet and so located as to be free from physical damage.*

*Where motor-generators and machine motors are located adjacent to or underneath control equipment, and are provided with extra length terminal leads not exceeding 6 feet in length, such leads may be extended to connect directly to controller terminal studs without regard to the carrying-capacity requirements of Articles 430 and 445. Auxiliary gutters may be used in machine and control rooms between controllers, starters and similar apparatus.*

#### **D. Installation of Conductors**

**620-31. Raceway Terminal Fittings.** Conductors shall comply with the provisions of Section 300-16(b). In locations where conduits project from the floor and terminate in other than a wiring enclosure, they must extend at least 6 inches above the floor.

**620-32. Metal Wireways.** Section 362-5 shall not apply to wireways. The sum of the cross-sectional area of the individual conductors in a metallic wireway shall not be more than 50 percent of the interior cross-sectional area of the wireway.

Vertical runs of wireways shall be securely supported at intervals not exceeding 15 feet and shall have not more than one joint between supports. Adjoining wireway sections shall be securely fastened together to provide a rigid joint.

**620-33. Number of Conductors in Other Raceways.** The sum of the cross-sectional area of the operating and control circuit conductors in raceways shall not exceed 40 percent of the interior cross-sectional area of the raceway.

*Exception: Wireways as permitted in Section 620-32.*

**620-34. Supports.** Supports for cables or raceways in the hoistway or escalator or moving-walk wellway shall be securely fastened to the guide rail or to the hoistway or wellway construction.

**620-35. Auxiliary Gutters (Wiring Troughs).** Auxiliary gutters shall not be subject to the restrictions of Section 374-2 as to length or of Section 374-5 as to number of conductors.

**620-36. Different Systems in One Raceway or Traveling Cable.** Conductors for operating, control, power, signal, and light circuits of 600 volts or less may be run in the same traveling cable or raceway system provided that all conductors are insulated for the maximum voltage found in the cables or raceway system and all live parts of the equipment are insulated from ground for this maximum voltage. Such a traveling cable or raceway may also include a pair of telephone conductors for the car telephone provided such conductors are insulated for the maximum voltage found in the cable or raceway system.

**620-37. Wiring in Hoistways.** Main feeders for supplying power to elevators and dumbwaiters shall be installed outside the hoistway. Only such electrical wiring, conduit and cable used directly in connection with the elevator or dumbwaiter, including wiring for signals, for communication with the car, for lighting and ventilating the car and wiring for fire-detecting systems for the hoistways, may be installed inside the hoistway.

*Exception: In existing structures, feeders for elevators or other purposes may be installed within a hoistway by special permission provided no conductors are spliced within the hoistway.*

**620-38. Electrical Equipment in Garages and Similar Occupancies.** Electrical equipment and wiring used for elevators, dumbwaiters, escalators, and moving walks in garages shall conform to the requirements of Article 511. Wiring and equipment located on the underside of the car platform shall be considered as being located in the hazardous area.

**620-39. Sidewalk Elevators.** Sidewalk elevators with sidewalk doors, located exterior to the building, shall have all electric wiring in rigid metal conduit or electrical metallic tubing and all electrical outlets, switches, junction boxes, and fittings shall be weatherproof.

### E. Traveling Cables

**620-41. Suspension.** Traveling cables shall be so suspended at the car and hoistway end as to reduce the strain on the individual copper conductors to a minimum.

Cables with an unsupported length exceeding 100 feet shall have steel supporting fillers and shall be suspended directly by the steel supporting fillers.

Where nonmetallic fillers are used, the cables shall be suspended by looping the cables around the supports, or shall be suspended from the support by a means that automatically tightens around the cable when tension is increased.

**620-42. Hazardous Locations.** In hazardous locations, traveling cables shall be of a type approved for hazardous locations and shall be secured to explosion-proof cabinets as provided in Section 501-11.

**620-43. Location of and Protection for Cables.** Traveling cable supports shall be so located as to reduce to a minimum the possibility of

damage due to the cables coming in contact with the hoistway construction or equipment in the hoistway. Where necessary, suitable guards shall be provided to protect the cables against damage.

### F. Control

**620-51. Disconnecting Means.** There shall be in addition to the elevator controller, a means for disconnecting all conductors of the circuit to the elevator motor, or in the case of generator field control, to the motor of the motor-generator set which supplies current to the elevator motor.

(a) **Type.** The disconnecting means shall be an enclosed externally operable motor circuit switch or circuit breaker arranged to be locked in the open position.

(b) **Location.** It shall be located adjacent to and be visible from the elevator machine, unless a disconnect switch in the control circuit of the motor-generator set is placed adjacent to and is visible from the elevator machine.

**620-53. Phase Protection.** Elevators driven by polyphase alternating-current machine motors shall be provided with means to prevent starting of the elevator motor when:

(a) The phase rotation is in the wrong direction, or

(b) There is a failure in any phase.

### G. Overcurrent Protection

**620-61. Overcurrent Protection.** Overcurrent protection shall be provided as follows:

(a) **Control and Operating Circuits.** Control and operating circuits and signal circuits shall be protected against overcurrent in accordance with the requirements of Section 725-18.

(b) **Motors.**

(1) Duty on elevator and dumbwaiter driving machine motors and driving motors of motor generators used with generator field control shall be classed as intermittent. Such motors shall be protected against overcurrent in accordance with Section 430-33.

(2) Duty on escalator and moving-walk driving machine motors shall be classed as continuous. Such motors shall be protected against overcurrent in accordance with Section 430-32.

(3) Escalator and moving-walk driving machine motors and driving motors of motor-generator sets shall be protected against running overcurrent as provided in Table 430-37.

### H. Machine Room

**620-71. Guarding Equipment.** Elevator, dumbwaiter, escalator, and moving-walk driving machines, motor-generator sets, controllers, auxiliary control equipment and disconnecting means shall be installed in a room or enclosure set aside for that purpose. The room or enclosure shall be secured against unauthorized access.

(Exception on page 70-410)

*Exception: Dumbwaiter, escalator, or moving-walk controllers may be installed outside the spaces herein specified, provided they are enclosed in cabinets with doors or removable panels capable of being locked in the closed position and the disconnecting means is located adjacent to the controller. Such cabinets may be mounted in the balustrading on the side away from the moving steps or moving treadway.*

**620-72. Clearance Around Control Panels.** There shall be provided sufficient clear working space around control panels to provide safe and convenient access to all live parts of the equipment necessary for maintenance and adjustment. The minimum clear working space about live parts on control panels shall not be less than set forth in Section 110-16.

The minimum working clearance for escalator and moving-walk control panels shall be as specified in Section 110-16, provided that where the control panel is mounted in the same space as the escalator or moving-walk drive machine and the clearances specified cannot be provided, they may be waived where the entire panel is arranged so that it can be readily removed from the machine space and is provided with flexible leads to all external connections.

Where control panels are not located in the same space as the drive machine they shall be so located in cabinets with doors or removable panels capable of being locked in the closed position. Such cabinets may be mounted in the balustrading on the side away from the moving steps or moving treadway.

## J. Grounding

**620-81. Metal Raceways Attached to Cars.** Conduit, Type ALS cable or Type AC metal-clad cable attached to elevator cars shall be bonded to grounded metal parts of the car with which they come in contact.

**620-82. Electric Elevators.** For electric elevators, the frames of all motors, elevator machines, controllers and the metal enclosures for all electrical devices in or on the car or in the hoistway shall be grounded.

**620-83. Nonelectric Elevators.** For elevators other than electric, when any electrical conductors are attached to the car, the metal frame of the car, where normally accessible to persons, shall be grounded.

**620-85. Inherent Ground.** Equipment mounted on members of the structural metal frame of a building shall be deemed to be grounded. Metal car frames supported by metal hoisting cables attached to or running over sheaves or drums of elevator machines shall be deemed to be grounded when the machine is grounded in accordance with Article 250.

## K. Overspeed

**620-91. Overspeed Protection for Elevators.** Under overhauling load conditions, means shall be provided on the load side of each elevator power disconnecting means to prevent the elevator from attaining a speed equal to the governor tripping speed or a speed in excess of 125 percent of the elevator rated speed, whichever is the lesser.

**620-92. Motor-Generator Overspeed Device.** Motor-generators driven by direct-current motors and used to supply direct current for the operation of elevator machine motors shall be provided with speed-limiting devices as required by Section 430-89(c), which will prevent the elevator from attaining at any time a speed of more than 125 percent of its rated speed.

## ARTICLE 630 — ELECTRIC WELDERS

### A. General

**630-1. Scope.** This Article covers electric arc welding, resistance welding apparatus, and other similar welding equipment that is connected to an electrical supply system.

**630-2. Other Articles.** This Article amplifies or modifies parts of Chapters 1 through 4 of this Code in order to properly cover the operating conditions to which electric welder installations are subjected. Accordingly, the appropriate provisions of Chapters 1 through 4 apply to the component parts of electric welder installations except as otherwise provided in this Article.

### B. AC Transformer and DC Rectifier Arc Welders

**630-11. Ampacities of Supply Conductors.** The ampacities of conductors for AC transformer and DC rectifier arc welders shall be as follows:

(a) **Individual Welders.** The rated ampacities of the supply conductors shall be not less than the current values determined by multiplying the rated primary current in amperes, given on the welder nameplate, and the following factor based upon the duty cycle or time rating of the welders:

Rated Percent Duty Cycle of Welders	Multiplying Factor
20 or less	0.45
30	0.55
40	0.63
50	0.71
60	0.78
70	0.84
80	0.89
90	0.95
100	1.00

For a welder having a time rating of one hour, the multiplying factor shall be 0.75.

(b) **Group of Welders.** The rated ampacities of conductors which supply a group of welders may be less than the sum of the currents, as determined in accordance with Section 630-11(a) of the welders supplied.

The conductor rating shall be determined in each case according to the welder loading based on the use to be made of each welder and the allowance permissible in the event that all the welders supplied by the conductors will not be in use at the same time. The load value used for each welder shall take into account both the magnitude and the duration of the load while the welder is in use.

Conductor ratings based on 100 percent of the current, as determined in accordance with Section 630-11(a), of the two largest welders, 85 percent for the third largest welder, 70 percent for the fourth largest welder, and 60 percent for all the remaining welders, should provide an ample margin of safety under high-production conditions with respect to the maximum permissible temperature of the conductors. Percentage values lower than those given are permissible in cases where the work is such that a high operating duty cycle for individual welders is impossible.

**630-12. Overcurrent Protection.** Overcurrent protection for AC transformer and DC rectifier arc welders shall be as provided in Sections 630-12(a) and (b). Where the nearest standard rating of the overcurrent device used is under the value specified in this Section, or where the rating or setting specified results in unnecessary opening of the overcurrent device, the next higher rating or setting may be used.

**(a) For Welders.** Each welder shall have overcurrent protection rated or set at not more than 200 percent of the rated primary current of the welder, except that an overcurrent device is not required for a welder having supply conductors protected by an overcurrent device rated or set at not more than 200 percent of the rated primary current of the welder.

**(b) For Conductors.** Conductors which supply one or more welders shall be protected by an overcurrent device rated or set at not more than 200 percent of the conductor rating.

**630-13. Disconnecting Means.** A disconnecting means shall be provided in the supply connection of each AC transformer and DC rectifier arc welder which is not equipped with a disconnect mounted as an integral part of the welder.

The disconnecting means shall be a switch or circuit breaker and its rating shall be not less than that necessary to accommodate overcurrent protection as specified under Section 630-12.

**630-14. Marking.** A nameplate giving the following information shall be provided for AC transformer and DC rectifier arc welders: name of manufacturer; frequency; number of phases; primary voltage; rated primary current; maximum open-circuit voltage; rated secondary current; basis of rating, i.e., the duty cycle, 60-minute rating.

### **C. Motor-Generator Arc Welders**

**630-21. Ampacities of Supply Conductors.** The ampacities of conductors for motor-generator arc welders shall be as follows:

**(a) Individual Welders.** The rated ampacities of the supply conductors shall be not less than the current values determined by multiplying the rated primary current in amperes, given on the welder nameplate,



and the following factor based upon the duty cycle or time rating of the welders:

Rated Percent Duty Cycle of Welders	Multiplying Factor
20 or less	.55
30	.62
40	.69
50	.75
60	.81
70	.86
80	.91
90	.96
100	1.00

For a welder having a time rating of one hour, the multiplying factor shall be 0.80.

**(b) Group of Welders.** The rated ampacities of conductors which supply a group of welders may be less than the sum of the currents, as determined in accordance with Section 630-21(a) of the welders supplied. The conductor rating shall be determined in each case according to the welder loading based on the use to be made of each welder and the allowance permissible in the event that all the welders supplied by the conductors will not be in use at the same time. The load value used for each welder shall take into account both the magnitude and the duration of the load while the welder is in use.

Conductor ratings based on 100 percent of the current, as determined in accordance with Section 630-21(a), of the two largest welders, 85 percent for the third largest welder, 70 percent for the fourth largest welder, and 60 percent for all the remaining welders, should provide an ample margin of safety under high-production conditions with respect to the maximum permissible temperature of the conductors. Percentage values lower than those given are permissible in cases where the work is such that a high operating duty cycle for individual welders is impossible.

**630-22. Overcurrent Protection.** Overcurrent protection for motor-generator arc welders shall be as provided in Sections 630-22(a) and (b). Where the nearest standard rating of the overcurrent device used is under the value specified in this Section, or where the rating or setting specified results in unnecessary opening of the overcurrent device, the next higher rating or setting may be used.

**(a) For Welders.** Each welder shall have overcurrent protection rated or set at not more than 200 percent of the rated primary current of the welder, except that an overcurrent device is not required for a welder having supply conductors protected by an overcurrent device rated or set at not more than 200 percent of the rated primary current of the welder.

**(b) For Conductors.** Conductors which supply one or more welders shall be protected by an overcurrent device rated or set at not more than 200 percent of the conductor rating.

**630-23. Disconnecting Means.** A disconnecting means shall be provided in the supply connection of each motor-generator arc welder.

The disconnecting means shall be a circuit breaker or motor-circuit switch and its rating shall be not less than that necessary to accommodate overcurrent protection as specified under Section 630-22.

**630-24. Marking.** A nameplate giving the following information shall be provided for each motor-generator arc welder: name of manufacturer; rated frequency; number of phases; input voltage; input current; maximum open-circuit voltage; rated output current; basis of rating, i.e., duty cycle, 60-minute rating.

**D. Resistance Welders**

**630-31. Ampacities of Supply Conductors.** The ampacities of the supply conductors for resistance welders necessary to limit the voltage drop to a value permissible for the satisfactory performance of the welder are usually greater than that required to prevent overheating as prescribed in Sections 630-31(a) and (b).

**(a) Individual Welders.** The rated ampacities for conductors for individual welders shall conform to the following:

**(1) Varying Operations.** The rated ampacities of the supply conductors for a welder which may be operated at different times at different values of primary current or duty cycle shall be not less than 70 percent of the rated primary current for seam and automatically fed welders, and 50 percent of the rated primary current for manually operated nonautomatic welders.

**(2) Specific Operation.** The rated ampacities of the supply conductors for a welder wired for a specific operation for which the actual primary current and duty cycle are known and remain unchanged shall be not less than the product of the actual primary current and the multiplier given below for the duty cycle at which the welder will be operated.

Duty Cycle										
(percent) . . . . .	.50	.40	.30	.25	.20	.15	.10	7.5	5.0	or less
Multiplier . . . . .	.71	.63	.55	.50	.45	.39	.32	.27	.22	

**(b) Groups of Welders.** The rated ampacities of conductors which supply two or more welders shall be not less than the sum of the value obtained as explained in Section 630-31(a) for the largest welder supplied, and 60 percent of the values obtained as explained in Section 630-31(a) for all the other welders supplied.

**(c) Explanation of Terms.** (1) The rated primary current is the rated kVA multiplied by 1,000 and divided by the rated primary voltage, using values given on the nameplate. (2) The actual primary current is the current drawn from the supply circuit during each welder operation at the particular heat tap and control setting used. (3) The duty cycle is the percentage of the time during which the welder is loaded. For instance, a spot welder supplied by a 60-hertz system (216,000 cycles per hour) making four hundred 15-cycle welds per hour would have a duty cycle of 2.8 percent (400 multiplied by 15, divided by 216,000, multi-

plied by 100). A seam welder operating 2 cycles "on" and 2 cycles "off" would have a duty cycle of 50 percent.

**630-32. Overcurrent Protection.** Overcurrent protection for resistance welders shall be as provided in Sections 630-32(a) and (b). Where the nearest standard rating of the overcurrent device used is under the value specified in this Section, or where the rating or setting specified results in unnecessary opening of the overcurrent device, the next higher rating or setting may be used.

(a) **For Welders.** Each welder shall have an overcurrent device rated or set at not more than 300 percent of the rated primary current of the welder, except that an overcurrent device is not required for a welder having a supply circuit protected by an overcurrent device rated or set at not more than 300 percent of the rated primary current of the welder.

(b) **For Conductors.** Conductors which supply one or more welders shall be protected by an overcurrent device rated or set at not more than 300 percent of the conductor rating.

**630-33. Disconnecting Means.** A switch or circuit breaker shall be provided by which each resistance welder and its control equipment can be isolated from the supply circuit. The ampacity of this disconnecting means shall be not less than the supply conductor rating determined as explained in this Article. The supply circuit switch may be used as the welder disconnecting means where the circuit supplies only one welder.

**630-34. Marking.** A nameplate giving the following information shall be provided for each resistance welder: name of manufacturer, frequency, primary voltage, rated kVA at 50 percent duty cycle, maximum and minimum open-circuit secondary voltage, short-circuit secondary current at maximum secondary voltage and specified throat and gap setting.

## ARTICLE 640 — SOUND-RECORDING AND SIMILAR EQUIPMENT

**640-1. Scope.** This Article shall apply to installations of equipment and wiring used for sound-recording and reproduction, centralized distribution of sound, public address, speech-input systems and electronic organs.

**640-2. Application of Other Articles.**

(a) Except as modified by this Article, wiring and equipment from source of power to and between devices connected to the interior wiring systems shall comply with the requirements of Chapters 1 through 4 of this Code.

(b) Wiring and equipment for public-address, speech-input, radio-frequency, audio-frequency systems, and amplifying equipment asso-

(640-2(b) continued)

ciated with radio receiving stations in centralized distribution systems, shall comply with Article 725.

**640-3. Number of Conductors in Raceway.** The number of conductors in a conduit or other raceway shall comply with Tables 1 through 7 of Chapter 9 except as follows:

*Exception No. 1: Special permission may be granted for the installation of two 2-conductor lead-covered cables in  $\frac{3}{4}$ -inch conduit, provided the cross-sectional area of each cable does not exceed .11 square inch.*

*Exception No. 2: Special permission may be granted for the installation of two 2-conductor No. 19 lead-covered cables in  $\frac{1}{2}$ -inch conduit, provided the sum of the cross-sectional areas of the cables does not exceed 32 percent of the internal cross-sectional area of the conduit.*

**640-4. Wireways and Auxiliary Gutters.**

(a) Wireways and auxiliary gutters shall comply with the requirements of Articles 362 and 374.

(b) Where used for sound-recording and reproduction the following exceptions are made:

*Exception No. 1: Number of Conductors in Raceway. Conductors in wireways or gutters shall not fill the raceway to more than 75 percent of its depth.*

*Exception No. 2: Auxiliary-Gutter Covers. Where the cover of auxiliary gutters is flush with the flooring and is subject to the moving of heavy objects it shall be of steel at least  $\frac{1}{4}$  inch in thickness; where not subject to moving of heavy objects, as in the rear of patch or other equipment panels, the cover shall be at least No. 10 MSG.*

*Exception No. 3: Metal-Trough Raceways. Metal-trough raceways may be installed in concealed places provided they are run in a straight line between outlets or junction boxes. Covers of boxes must be accessible. Edges of metal must be rounded at outlet or junction boxes and all rough projections smoothed to prevent abrasion of insulation or conductors. Raceways made of sections shall be bonded and grounded as prescribed in Section 250-76.*

*Exception No. 4: Grounding Wireways and Auxiliary Gutters. Metal wireways and auxiliary gutters shall be grounded in accordance with the requirements of Article 250. Where the wireway or auxiliary gutter does not contain power supply wires, the grounding conductor need not be larger than No. 14 copper or its equivalent. Where the wireway or auxiliary gutter contains power supply wires, the grounding conductor shall not be smaller than the size called for in Section 250-95.*

**640-5. Conductors.** Amplifier output circuits carrying audio-program signals of 70 volts or less and whose open circuit voltage will not exceed 100 volts, may employ Class 2 wiring as covered in Article 725.

The above is based on amplifiers whose open-circuit voltage will not exceed 100 volts when driven with a signal at any frequency from 60 to 100 hertz sufficient to produce rated output (70.7 volts) into its rated load. This

also accepts the known fact that the average program material is 12 db below the amplifier rating—thus the average RMS voltage for an open-circuit 70-volt output would be only 25 volts.

**640-6. Grouping of Conductors.** Conductors of different systems grouped in the same conduit or other metallic enclosure, or in portable cords or cables, shall comply with the following requirements:

(a) **Power-Supply Conductors.** Power-supply conductors shall be properly indicated and shall be used solely for supplying power to the equipment to which the other conductors are connected.

(b) **Leads to Motor-Generator or Rotary Converter.** Input leads to a motor-generator or rotary converter shall be run separately from the output leads.

(c) **Conductor Insulation.** The conductors shall be insulated individually, or collectively in groups, by insulation at least equivalent to that on the power supply and other conductors.

*Exception: Where the power supply and other conductors are separated by a lead sheath or other continuous metallic covering.*

**640-7. Flexible Cords.** Flexible cords and cables shall be of Types S, SJ, ST, SJO, and SJT or other types specifically approved for the purpose for which they are to be used. The conductors of flexible cords, other than power-supply conductors, may be of a size not smaller than No. 26 provided such conductors are not in direct electrical connection with the power-supply conductors and are equipped with current-limiting means so that the maximum power under any condition will not exceed 150 watts.

**640-8. Terminals.** Terminals shall be marked to show their proper connections. Terminals for conductors other than power-supply conductors shall be separated from the terminals of the power-supply conductors by a spacing at least as great as the spacing between power-supply terminals of opposite polarity.

**640-9. Storage Batteries.** Storage batteries shall comply with the following:

(a) **Installation.** Storage batteries shall be installed in accordance with Article 480.

(b) **Conductor Insulation.** Storage-battery leads shall be rubber-covered or thermoplastic-covered.

**640-10. Overcurrent Protection of "A", "B" and "C" Circuits.** Overcurrent protection shall be provided as follows:

(a) "A" circuit, where supplied by branch-lighting circuits, or by storage batteries of more than 20-ampere-hour capacity, shall have overcurrent protection not exceeding 15 amperes.

(b) "B" circuits shall have overcurrent protection not exceeding one ampere. The overcurrent protection shall be placed in each positive lead.

(c) "C" circuits where supplied from branch lighting circuits or from storage batteries of more than 20-ampere-hour capacity shall have overcurrent protection not exceeding one ampere.

(d) Overcurrent devices shall be located as near as practicable to the battery.

**640-11. Amplifiers and Rectifiers—Type.**

(a) They shall be suitably housed and shall be of a type approved for the purpose unless otherwise expressly permitted by the authority having jurisdiction.

(b) Amplifiers and rectifiers shall be so located as to be readily accessible.

(c) Amplifiers and rectifiers shall be so located as to provide sufficient ventilation to prevent undue temperature rise within the housing.

**640-12. Hazardous Locations.** Equipment used in hazardous locations shall be specifically approved for the purpose.

**640-13. Protection Against Physical Damage.** Amplifiers, rectifiers, loud-speakers and other equipment shall be so located or protected as to guard against physical damage such as might result in fire or personal hazard.

## ARTICLE 645 — DATA PROCESSING SYSTEMS

For further information see NFPA Standard for the Protection of Electronic Computer/Data Processing Equipment (No. 75-1968).

**645-1. Scope.** The provisions of this Article shall apply to equipment, power supply wiring, equipment interconnecting wiring, and grounding of data processing systems including data communications equipment used as a terminal unit.

**645-2. Supply Circuits and Interconnecting Cables.**

(a) The branch-circuit conductors to which one or more units of a data processing system are connected to a source of supply shall have an ampacity not less than 125 percent of the total connected load.

(b) The data processing system may be connected by means of computer cable or flexible cord and attachment plug cap or cord set assembly specifically approved as a part of the data processing system. Separate units may be interconnected by means of flexible cords and cables specifically approved as part of the data processing system. When run on the surface of the floor they shall be protected against physical damage.

(c) The power and communication supply cables and interconnecting cables may be installed under a raised floor provided:

(1) The raised floor is of suitable construction. See NFPA No. 75-1968.

(2) The branch-circuit supply conductors to receptacles are in rigid conduit, electrical metallic tubing, flexible metal conduit, Type

MI mineral-insulated metal-sheathed cable, or Type ALS aluminum-sheathed cable.

(3) Ventilation in the underfloor area is used for the data processing equipment and data processing area only.

**645-3. Disconnecting Means.** In addition to any integral individual disconnect switches for components or other units of the data processing system, disconnecting means shall be provided as follows:

(a) **In Data Processing Rooms.** The disconnecting means shall disconnect the ventilation system serving that room and the power to all electrical equipment in the room except lighting and shall be controlled from locations readily accessible to the operator and at designated exit doors from the data processing room.

(b) **In General Building Areas.** The disconnecting means shall disconnect all interconnected data processing equipment in the area and shall be controlled from a location readily accessible to the operator.

**645-4. Grounding.** All exposed noncurrent-carrying metal parts of a data processing system shall be grounded in accordance with Article 250.

**645-5. Marking.** Each unit of a data processing system which is intended to be supplied by a branch circuit shall be provided with a manufacturer's nameplate, which shall also include the rating in volts, the operating frequency, and the total load in amperes.

## ARTICLE 650 — ORGANS

**650-1. General.** This Article shall apply to those electric circuits and parts of electrically operated organs which are employed for the control of the sounding apparatus and keyboards. Electronic organs shall comply with the appropriate provisions of Article 640.

**650-2. Source of Energy.** The source of energy shall have a potential of not over 15 volts and shall be a self-excited generator, a two-coil transformer-type rectifier or a primary battery.

**650-3. Insulation—Grounding.** The generator shall be effectively insulated from the ground and from the motor driving it, or both the generator and the motor frames shall be grounded in the manner prescribed in Article 250.

**650-4. Conductors.** Conductors shall comply with the following:

(a) **Size.** No conductor shall be smaller than No. 26, and the common-return conductor shall be not smaller than No. 14.

(b) **Insulation.** Conductors shall have rubber, thermoplastic, asbestos, cotton, or silk insulation, except the common-return conductor which shall be rubber-covered, thermoplastic, asbestos-covered (Types AA, AI, or AIA). The cotton or silk may be saturated with paraffin if desired.

(c) **Conductors to Be Cabled.** Except the common-return conductor, and conductors inside the organ proper, the organ sections and the organ console, conductors shall be cabled. The common-return conductor may be placed under an additional covering enclosing both cable and return conductor, or may be installed as a separate conductor and may be in contact with the cable.

(d) **Cable Covering.** The cable shall be provided with one or more braided outer coverings, provided that a tape may be used in place of an inner braid. Where not installed in metal raceways the outer braid shall be flame-retardant or shall be covered with a closely wound fire-proof tape.

**650-5. Installation of Conductors.** Cables shall be securely fastened in place and may be attached directly to the organ structure without insulating supports. Cables shall not be placed in contact with other conductors.

**650-6. Overcurrent Protection.** Circuits shall be so arranged that all conductors, except the main supply conductors and the common-return conductor, shall be protected from overcurrent by an overcurrent device of not greater than 15-ampere rating.

## ARTICLE 660 — X-RAY EQUIPMENT

### A. Scope and Installation

**660-1. Scope.** The provisions of this Article shall apply to all X-ray equipment operating at any frequency or voltage for medical or industrial use, or for any other purpose.

Nothing in this Article shall be construed as specifying safeguards against the useful beam or stray X-ray radiation.

Recommendations for radiation protection by the National Council on Radiation Protection and Measurements are published as Reports of the National Council on Radiation Protection and Measurement. These reports are obtainable from NCRP Publications, P.O. Box 4867, Washington, D.C., 20008.

#### **Definitions:**

**PORTABLE** — X-ray equipment designed to be hand-carried.

**MOBILE** — X-ray equipment mounted on a permanent base with wheels and/or casters for moving while completely assembled.

**TRANSPORTABLE** — X-ray equipment to be installed in a vehicle or that may be readily disassembled for transport in a vehicle.

**LONG-TIME RATING** — A long-time rating is the rating based on an operating interval of five minutes or longer.

**MOMENTARY RATING** — A momentary rating is the rating based on an operating interval that does not exceed five seconds.

**660-2. Hazardous Locations.** Unless approved for the location, X-ray and related equipment shall not be installed or operated in hazardous locations. See Article 517, Part E.



**660-3. Connection to Supply Circuit.**


**(a) Fixed and Stationary Equipment.** Fixed and stationary X-ray equipment shall be connected to the power supply by means of a wiring method meeting the general requirements of this Code.

*Exception: Equipment properly supplied by a branch circuit rated at not more than 30 amperes may be supplied through a suitable plug cap and hard-service cable or cord.*

**(b) Portable, Mobile and Transportable.** Individual branch circuits shall not be required for portable, mobile, and transportable medical X-ray equipment requiring a capacity not exceeding 60 amperes. Receptacles installed on 50- and 60-ampere branch circuits supplying medical X-ray equipment shall be of a configuration as shown in Figure 660-3(b). Portable and mobile types of X-ray equipment of any capacity shall be supplied through a suitable cap and hard-service cable or cord. Transportable X-ray equipment of any capacity may be connected to its power supply by suitable connections and hard-service cable or cord.

**(c) More than 600-Volt Supply.** Circuits and equipment operated on a supply circuit of more than 600 volts shall comply with the provisions of Article 710.

(Continued on page 423)



**660-4. Disconnecting Means.** A disconnecting means of adequate capacity for at least 50 percent of the input required for the momentary rating or 100 percent of the input required for the long-time rating of the X-ray equipment whichever is greater shall be provided in the supply circuit and it shall be operable from a location readily accessible from the X-ray control. For equipment connected to a 120-volt branch circuit of 30 amperes or less, a grounding-type cap and receptacle of proper rating may serve as a disconnecting means.

*Exception: Portable or mobile X-ray equipment of any capacity which complies with Section 660-11.*

**660-5. Branch-Circuit and Overcurrent Protection Requirements.** Fifty percent of the momentary rating or 100 percent of the long-time rating of the X-ray equipment whichever is greater shall be used in determining the rating for branch circuits and overcurrent protective devices.

The ampacities of the branch-circuit conductors and the ratings of disconnecting means and overcurrent protection for X-ray equipment is usually recommended by the manufacturer for the specific installation.

**660-6. Wiring Terminals.** Unless provided with a permanently attached cord or a cord set, X-ray equipment shall be provided with suitable wiring terminals or leads for the connection of conductors of at least the size required by the input load corresponding to the long-time rating of the equipment.

**660-7. Number of Conductors in Raceway.** The number of control circuit conductors installed in a raceway shall be determined in accordance with Section 300-17.

**660-8. Minimum Size of Conductors.** Sizes No. 18 or 16 fixture wires as specified in Section 725-14 and flexible cords may be used for the control and operating circuits of X-ray and auxiliary equipment when protected by 20-ampere overcurrent devices.

**660-9. Equipment Installations.** All equipment used on new installations of X-ray equipment, or used or reconditioned equipment moved to and reinstalled at a new location, shall be of the approved type.

## **B. Control**

### **660-10. Fixed and Stationary Equipment.**

**(a) Separate Control Device.** A separate control device in addition to the disconnecting means, shall be incorporated in the X-ray control supply or in the primary circuit to the high-voltage transformer. This device shall be a part of the X-ray equipment, but may be located in a separate enclosure immediately adjacent to the X-ray control unit.

**(b) Protective Device.** A protective device which may be incorporated into the separate control device, shall be provided to control the load resulting from failures in the high-voltage circuit.

**660-11. Portable and Mobile Equipment.** Portable and mobile equipment shall comply with Section 660-10, but the manually controlled device shall be located in or on the equipment.

**660-12. Medical Equipment.**

(a) **Radiographic Type.** For each radiographic-type equipment there shall be a timer or automatic exposure terminating device and a manual-hold switch that actuates the timer or automatic exposure terminating device and will interrupt these devices upon release.

(b) **Fluoroscopic Type.** For each fluoroscopic-type equipment a switch shall be provided which shall be designed to open automatically.

*Exception: When held closed by the operator.*

(c) **Therapeutic Type.** For each therapeutic-type equipment a timer or automatic exposure terminating device shall be provided which is not of the repeating type.

**660-13. Industrial X-ray Equipment.**

(a) **Radiographic and Fluoroscopic Types.** All radiographic- and fluoroscopic-type equipment shall be effectively enclosed or shall have interlocks that de-energize the equipment automatically to prevent ready access to live current-carrying parts.

(b) **Industrial or Laboratory Equipment — Diffraction or Irradiation Types.** Diffraction- or irradiation-type equipment shall be provided with positive indication of energization by pilot lights, readable meter deflections or equivalent means.

*Exception: Equipment or installations effectively enclosed or provided with interlocks to prevent access to live current-carrying parts during operation.*

**660-14. Independent Control.** Where more than one piece of equipment is operated from the same high-voltage circuit, each piece or each group of equipment as a unit shall be provided with a high-voltage switch or equivalent disconnecting means. This disconnecting means shall be constructed, enclosed, or located so as to avoid contact by persons with its live parts.

**C. Transformers and Capacitors**

**660-15. General.** Transformers and capacitors which are part of an X-ray equipment shall not be required to conform to the requirements of Articles 450 and 460 of this Code.

**660-16. Capacitors.** Capacitors shall be mounted within enclosures of grounded metal or insulating material.

**D. Guarding and Grounding****660-17. General.**

(a) **High-Voltage Parts.** All high-voltage parts, including X-ray tubes, shall be mounted within grounded enclosures. Either air, oil, gas or other suitable insulating media may be used to insulate the high voltage from the grounded enclosure. The connection from the high-voltage equipment to X-ray tubes and other high-voltage components shall be made with high-voltage shielded cables.

(b) **Low-Voltage Cables.** Low-voltage connecting cables to oil-filled units such as transformers, condensers, oil coolers, and high-voltage

switches which are not completely sealed shall be of the oil-resistant type.

**660-18. Grounding.** Noncurrent-carrying metal parts of X-ray and associated equipment (controls, tables, X-ray tube stands, transformer tanks, shielded cables, X-ray tube heads, etc.) shall be grounded in the manner prescribed in Article 250.

**(a) Portable and Mobile.** Portable and mobile equipment shall be provided with an approved grounding-type plug cap.

## ARTICLE 665 — INDUCTION AND DIELECTRIC HEATING EQUIPMENT

### A. Scope and General

**665-1. Scope.** The provisions of this Article shall apply to the construction and installation of induction and dielectric heating equipment and accessories for industrial, scientific and medical applications, but not for appliances.

**665-2. Definitions.** The term “heating equipment” as used in this Article includes any equipment used for heating purposes whose heat is generated by induction or dielectric methods.

Induction heating is the heating of a nominally conducting material due to its own  $I^2R$  losses when the material is placed in a varying electromagnetic field.

Dielectric heating is the heating of a nominally insulating material due to its own dielectric losses when the material is placed in a varying electric field.

The term “therapeutic high-frequency equipment” as used in this Article shall be understood to mean generating equipment capable of producing alternating currents having frequencies greater than those frequencies which elicit neuromuscular response. In order to comply with the above, the output frequency of the therapeutic high-frequency equipment shall not be less than 2 megahertz.

**665-3. Application of Other Articles.** Wiring from the source of power to the heating equipment shall comply with Chapters 1 through 4. Circuits and equipment operating on a supply circuit of more than 600 volts shall comply with the provisions of Article 710.

**665-4. Hazardous Locations.** Induction and dielectric heating equipment shall not be installed in hazardous locations as defined in Article 500 unless the equipment and wiring is designed and approved for the locations.

### B. Motor-Generator Equipment

**665-5. Scope.** Motor-generator equipment shall include all rotating equipment designed to operate from an AC or DC motor, or by me-

chanical drive from a prime mover, producing an alternating current of any frequency for induction and/or dielectric heating.

**665-6. Ampacities of Supply Conductors.** Ampacities of supply conductors shall be determined by Article 430 of this Code.

**665-7. Overcurrent Protection.** Overcurrent protection shall be provided as specified in Article 430 of this Code for the electrical supply circuit.

**665-8. Disconnecting Means.** The disconnecting means shall be provided as specified in Article 430 of this code.

A readily accessible disconnecting means shall be provided by which each heating equipment can be isolated from the supplying circuit. The rating of this disconnecting means shall be not less than the nameplate current rating of the equipment. The supply circuit disconnecting means may be used as a heating equipment disconnecting means where the circuit supplies only one equipment.

**665-9. Output Circuit Definition.** The output circuit shall include all output components external to the generator, including contactors, transformers, bus-bars, and other conductors.

**665-10. Output Circuits.** Output circuits shall conform to the following:

(a) **Generator Output.** The output circuit shall be isolated from ground, except for the capacitive coupling inherent in the generator, which, in effect causes the generator terminals to have voltages from terminal to ground that are equal.

When rated at more than 500 volts, the output circuit shall incorporate a DC ground protector unit. The DC impressed on the output circuit shall not exceed 30 volts and shall not exceed a current capability of 5 milliamperes.

An isolating transformer for matching the load and the source may be used in the output circuit wherein the secondary is not at DC ground potential.

(b) **Component Interconnections.** The various components required for a complete induction heating equipment installation shall be connected by properly protected multiconductor cable, bus-bar, or coaxial cable. Cables shall be installed in nonferrous raceways. Bus-bar shall be protected where required by nonferrous enclosures.

**665-11. Control Enclosures.** Low-frequency AC or DC may be used in the control portion of the heating equipment. This shall be limited to a value of 150 volts. Solid or stranded wire, properly sized in No. 18 AWG or larger shall be used. Sixty-hertz components may be used to control high frequency when properly rated by the induction heating equipment manufacturer. Electronic circuits utilizing solid-state devices and tubes may use printed circuits or wire sizes, properly sized smaller than No. 18 AWG.

**665-12. Remote Control**

(a) When remote controls are used for applying power, a "Local-Remote" switch shall be provided and interlocked so as to prevent the

possibility of applying power from other than one selected control point(s).

(b) Switches operated by foot pressure shall be provided with a shield over the contact button to avoid accidental closing.

### C. Equipment Other Than Motor-Generator

**665-13. Scope.** Equipment other than motor-generators includes all static multipliers and oscillator-type units utilizing vacuum tubes and/or solid-state devices. The equipment shall be capable of converting AC, or DC to a frequency suitable for induction and/or dielectric heating.

**665-14. Ampacities of Supply Conductors.** Ampacities of supply conductors shall be determined as follows:

(a) The ampacity of the circuit conductors shall be not less than the nameplate current rating of the equipment.

(b) The ampacities of conductors supplying two or more equipments shall be not less than the sum of nameplate current ratings on all equipments.

*Exception: When simultaneous operation of two or more equipments supplied from the same feeder is not possible, the ampacity of the feeder shall not be less than the sum of the nameplate ratings for the largest group of machines capable of simultaneous operation, plus 100 percent of the standby currents of the remaining machines supplied.*

**665-15. Overcurrent Protection.** Overcurrent protection shall be provided as specified in Article 240 for the equipment as a whole. This overcurrent protection shall be provided separately or as a part of the equipment.

**665-16. Disconnecting Means.** A readily accessible disconnecting means shall be provided by which each heating equipment can be isolated from the supplying circuit. The rating of this disconnecting means shall not be less than the nameplate rating of the equipment. The supply circuit disconnecting means may be used for disconnecting the heating equipment where the circuit supplies only one equipment.

**665-17. Output Circuit Definition.** The output circuit shall include all output components external to the converting device, including contactors, transformers, bus-bars, and other conductors.

**665-18. Output Circuits.** Output circuits shall conform to the following:

(a) **Converter Output.** The output circuit (direct or coupled) shall be at DC ground potential.

(b) **Converter and Applicator Connection.** When the connections between the converter and the work applicator exceed two feet in length the connections shall be enclosed or guarded with noncombustible material.

**665-19. Line Frequency in Converter Equipment Output.** Commercial frequencies of 25- to 60-hertz alternating-current output may be coupled for control purposes, but shall be limited to a value of 150 volts available only during periods of circuit operation.

**665-20. Keying.** Where high-speed keying circuits, dependent on the effect of "oscillator blocking," are employed, the peak radio-frequency output voltage during the blocked portion of the cycle shall not exceed 100 volts in units employing radio-frequency converters.

**665-21. Remote Control.**

(a) When remote controls are used for applying power, a "Local Remote" switch shall be provided and interlocked so as to prevent the possibility of applying power from other than one selected control point or points.

(b) Switches operated by foot pressure shall be provided with a shield over the contact button to avoid accidental closing.

**D. Guarding and Grounding**

**665-22. Enclosures.** The converting apparatus (including the DC line) and high-frequency electrical circuits (excluding the output circuits and remote-control circuits), shall be completely contained in an enclosure or enclosures of noncombustible material.

**665-23. Panel Controls.** All panel controls shall be of "dead-front" construction.

**665-24. Access to Internal Equipment.** Doors or detachable panels may be employed for internal access. Where doors are used giving access to voltages from 500 to 1,000 volts AC or DC, either door locks shall be provided or interlocking shall be installed with the choice of precaution optional. Where doors are used giving access to voltages above 1,000 volts AC or DC, either mechanical lockouts, with a disconnect means to prevent access until voltage is removed from the cubicle, or both door interlocking and mechanical door locks shall be provided. Detachable panels not normally used for access to such parts shall be fastened in a manner which will make them inconvenient to remove.

**665-25. Warning Labels.** "Danger" labels shall be attached on the equipment, and shall be plainly visible even when doors are opened or panels are removed from compartments containing voltages above 250 volts AC or DC.

**665-26. Capacitors.** When capacitors in excess of 0.1 Mfd. are used in DC circuits, either as rectifier filter components, or suppressors, etc., having circuit voltages exceeding 230 volts above ground, bleeder resistors or grounding switches shall be used as grounding devices. The time of discharge shall be in accordance with Section 460-6 (a).

Where auxiliary rectifiers are used with filter capacitors in the output for bias supplies, tube keyers, etc., bleeder resistors shall be used even though the DC voltage may not exceed 230 volts.

**665-27. Work Applicator Shielding.** Protective cages or adequate shielding shall be used to guard work applicators other than induction heating coils. Induction heating coils may be protected by insulation



and/or refractory materials. Interlock switches shall be used on all hinged access doors, sliding panels or other easy access to the applicator. All interlock switches shall be connected in such a manner as to remove all power from the applicator when any one of the access doors or panels is open. Interlocks on access doors or panels are not required when the applicator is an induction heating coil at DC ground potential or operating at less than 150 volts AC.

**665-28. Grounding and Bonding.** Grounding and/or inter-unit bonding shall be used wherever required for circuit operation, for limiting to a safe value radio-frequency potentials between all exposed noncurrent-carrying parts of the equipment and earth ground, between all equipment parts and surrounding objects and between such objects and earth ground. Such grounding and bonding shall be installed in accordance with Article 250.

**665-29. Marking.** Each heating equipment shall be provided with a nameplate, giving the manufacturer's name and model identification, and the following input data: line volts, frequency, number of phases, maximum current, full-load kVA and full-load power factor.

### **E. Therapeutic Equipment**

#### **665-30. Installation.**

(a) Where portability is not essential, equipment shall be permanently installed in accordance with Chapters 1 to 3 inclusive of this Code.

(b) Where portability is essential, the power supply cord shall be a three-conductor hard-service type with an ampacity not less than the marked rating of the equipment. One conductor having a continuous green color or a continuous green color with a yellow stripe insulation shall be used solely for equipment grounding. The cord shall terminate in an approved grounding-type attachment-plug cap as described in Section 250-59(b).

**665-31. Applicators for Therapeutic Equipment.** Application of the high-frequency power to the patient may be made by means of an electric field or of an induction field. Current-carrying parts of applicators shall be so insulated or enclosed that reliable isolation of the patient shall be assured.

**665-32. Enclosure.** The converting apparatus including the DC line, and high frequency electrical circuits, but excluding the line cord for portable units and the output circuits, shall be contained in an enclosure of noncombustible material.

**665-33. Panel Controls.** All panel controls shall be of "dead-front" construction.

**665-34. Access to Internal Equipment.** Access shall be through panels not conveniently removable. Panels which need removal for access to fuses, tubes, adjustments, overload reset devices, internal tap switches, and the like, shall be labeled to indicate danger if and when removed, or shall be provided with suitable electrical interlock devices.

## ARTICLE 670 — METALWORKING MACHINE TOOLS

**For further information see NFPA Standard on Metalworking Machine Tools (No. 79-1971).**

**670-1. Scope.** The provisions of this Article apply to the size and overcurrent protection of supply conductors to metalworking machine tools and to the nameplate data required on each such tool.

**670-2. Definition of Metalworking Machine Tools.** For the purpose of this Article, metalworking machine tools are defined as follows:

A metalworking machine tool is a power-driven machine not portable by hand, used to shape or form metal by cutting, impact, pressure, electrical techniques, or a combination of these processes.

**670-3. Machine Tool Nameplate Data.** A permanent nameplate listing supply voltage, phase, frequency, full-load currents (see note), ampere rating of largest motor, short-circuit interrupting capacity of the machine overcurrent protective device if furnished, and diagram number shall be attached to the control equipment enclosure or machine where plainly visible after installation.

**NOTE 1.** The full-load current shall be not less than the sum of the full load currents required for all motors and other equipment which may be in operation at the same time under normal conditions of use. Where unusual type loads, duty cycles, etc., require oversized conductors, the required capacity shall be included in the marked "full-load current."

**NOTE 2.** Where more than one incoming supply circuit is to be provided, the nameplate shall state the above information for each circuit.

### **670-4. Conductors Supplying a Machine Tool.**

(a) The supply circuit conductor shall have an ampacity of not less than the marked full-load current rating plus 25 percent of the full-load current rating of the highest rated motor as indicated on the nameplate. For the protection of supply conductors to the machine tool, refer to Section 240-5.

(b) A machine tool conforming with NFPA No. 79-1971 shall be considered individual unit equipment. It is provided with a disconnecting means and may be supplied by branch circuits protected by either fuses or circuit breakers.

(c) The disconnecting means may or may not incorporate overcurrent protection. Where the machine tool nameplate is marked "Overcurrent protection provided at machine supply terminals," the supply conductors are to be considered either as feeders, or taps as covered by Section 240-15.

"Overcurrent protection provided at machine supply terminals" means that provision has been made in the machine tool for each set of supply conductors to terminate in a single circuit breaker or set of fuses.

## ARTICLE 680 — SWIMMING AND WADING POOLS

### A. General

**680-1 Scope.** The provisions of this Article apply to the construction and installation of electric wiring for equipment in or adjacent to all swimming and wading pools, whether permanently installed or storable and to metallic appurtenances in or within 5 feet of the pool, and to the auxiliary equipment, such as pumps, filters and similar equipment. No electric appliances or wiring shall be installed in the water or in the enclosing walls of a swimming pool, except as provided in this Article.

The requirements of Article 680 will add to the safety of decorative and therapeutic pools; however, additional safeguards may be necessary.

**680-2 Approval of Equipment.** All equipment shall be approved for the purpose.

**680-3. Application of Other Articles.** Except as modified by this Article, wiring and equipment in or adjacent to swimming pools shall comply with the applicable requirements of Chapters 1 through 4 of this Code. See Section 370-13 for junction boxes, Section 347-3 for rigid nonmetallic conduit and Article 720 for low-voltage lighting.

#### **680-4. Definitions.**

**(a) Permanently Installed Swimming or Wading Pool.** One that is constructed in the ground, on the ground, or in a building in such a manner that the pool cannot be readily disassembled for storage.

**(b) Storable Swimming or Wading Pool.** One that is so constructed that it may be readily disassembled for storage and reassembled to its original integrity.

**(c) Forming Shell.** A metal structure designed to support a wet-niche lighting fixture assembly and intended for mounting in a swimming pool structure.

**(d) Wet-Niche Lighting Fixture.** A fixture intended for installation in a metallic forming shell mounted in a swimming pool structure where the fixture will be completely surrounded by pool water.

**(e) Dry-Niche Lighting Fixture.** A fixture intended for installation in the wall of the pool in a niche which is sealed against the entry of pool water by a fixed lens.

**(f) Ground-Fault Circuit-Interrupter.** A device whose function is to interrupt the electric circuit to the load when a fault current to ground exceeds some predetermined value that is less than that required to operate the overcurrent protective device of the supply circuit.

#### **680-5. Transformers and Ground-Fault Circuit-Interrupters.**

**(a) Transformers.** Transformers used for the supply of fixtures, together with the transformer enclosure, shall be approved for the pur-

pose. The transformer shall be a two-winding type having a grounded metal barrier between the primary and secondary voltage windings.

(b) **Wiring.** Conductors on the load side of a ground-fault circuit-interrupter or of a transformer, used to comply with the provisions of Section 680-20(a)(2), shall be kept entirely independent of all other wiring and electrical equipment.

**680-6. Location and Protection of Receptacles.** No outdoor receptacles on the property shall be located within 10 feet of the inside walls of the pool. All outdoor receptacles located between 10 feet and 15 feet of the inside walls of the pool shall be protected by a ground-fault circuit-interrupter. See Section 400-4 for prohibited uses of flexible cords. See also Section 210-22(d) for outdoor residential receptacles.

On pools located inside a permanent structure, receptacles within the pool enclosure shall be at least 10 feet from the inside walls of the pool. All receptacles located between 10 feet and 15 feet of the inside walls of the pool shall be protected by a ground-fault circuit-interrupter.

Note: In determining the above dimensions, the distance to be measured is the shortest path which the supply cord of an appliance connected to the receptacle would follow without piercing a building floor, wall, ceiling, or other solid permanent barrier.

**680-7. Cord- and Plug-Connected Equipment.** Fixed or stationary equipment rated 20 amperes or less, other than an underwater lighting fixture for a permanently installed pool, may be connected with a flexible cord to facilitate the removal or disconnecting for maintenance or repair. The flexible cord shall not exceed 3 feet in length and shall have a copper equipment grounding conductor not smaller than No. 12 AWG with a grounding-type attachment plug. See Section 680-24(f) for connection with flexible cords.

**680-8. Overhead Conductor Clearances.** The following parts of swimming pools shall not be placed under existing service-drop conductors or any other open overhead wiring; nor shall such wiring be installed above the following:

(a) Swimming pool and the area extending 10 feet horizontally from the inside of the walls of the pool.

(b) Diving structure.

(c) Observation stands, towers or platforms.

## **B. Permanently Installed Pools**

### **680-20. Underwater Lighting Fixtures**

#### **(a) General.**

(1) The provisions of Section 680-20 apply to all lighting fixtures installed below the normal water level of the pool.

(2) Underwater lighting fixtures supplied either directly from a branch circuit or by a transformer meeting the requirements of Section 680-5(a) shall perform reliably under any likely combination of

fault conditions so that there is no shock hazard. Compliance with this requirement shall be assured by one of the following:

- a. The design and construction of the fixtures; or
- b. The use of a ground-fault circuit-interrupter; or
- c. Other acceptable means.

(3) No lighting fixtures shall be installed for operation at more than 150 volts between conductors.

(4) Lighting fixtures mounted in walls shall be installed with the top of the fixture lens at least 18 inches below the normal water level of the pool. A lighting fixture facing upward shall have the lens adequately guarded to prevent contact by any person.

*Exception: Lights approved for the purpose may be installed at a depth of at least 4 inches below the normal water level of the pool.*

**(b) Wet-Niche Fixtures.**

(1) Approved metal forming shells shall be installed for the mounting of all wet-niche underwater fixtures and shall be equipped with provisions for threaded conduit entries. Rigid metal conduit of brass or other approved corrosion-resistant metal, or rigid nonmetallic conduit, shall extend from the forming shell to a suitable junction box or other enclosure located as provided in Section 680-21. Where rigid nonmetallic conduit is used a No. 8 AWG insulated, solid copper conductor shall be installed in this conduit with provisions for terminating in the forming shell and the junction box or other enclosure. Metal parts of the fixture and forming shell in contact with the pool water shall be of brass or other approved corrosion-resistant metal.

(2) The end of the flexible-cord jacket and the flexible-cord conductor terminations within a fixture shall be covered with or encapsulated in a suitable potting compound to prevent the entry of water into the fixture through the cord or its conductors. In addition, the grounding connection within a fixture shall be similarly treated to protect such connection from the deteriorating effect of pool water in the event of water entry into the fixture.

(3) The fixture shall be bonded to and secured to the forming shell by a positive locking device which will assure a low-resistance contact and which will require a tool to remove the fixture from the forming shell.

**(c) Dry-Niche Fixtures:** A dry-niche lighting fixture shall be provided with:

(1) provision for drainage of water; and

(2) means for accommodating one equipment grounding conductor for each conduit entry.

Approved rigid metal or rigid nonmetallic conduit shall be installed from the fixture to the service equipment or panelboard. A junction box is not required, but if used, need not be elevated or located as specified in Section 680-21(a)(4) if the fixture is specifically approved for the purpose.

**680-21. Junction Boxes and Enclosures for Transformers and Ground-Fault Circuit-Interrupters.**

(a) A junction box connected to a conduit which extends directly to an underwater pool-light forming shell shall be:

- (1) equipped with provisions for threaded conduit entries; and
- (2) of copper, brass, suitable plastic or other approved corrosion-resistant material; and
- (3) provided with electrical continuity between every connected metallic conduit and the grounding terminals by means of copper, brass, or other approved corrosion-resistant metal that is integral with the box; and
- (4) located not less than 8 inches, measured from the inside of the bottom of the box, above the ground level, pool deck, or maximum pool water level, whichever provides the greatest elevation, and located not less than 4 feet from the inside wall of the pool unless separated from the pool by a solid fence, wall or other permanent barrier.

*Exception: On lighting systems of 15 volts or less, a flush deck box may be used provided:*

*a. An approved potting compound is used to fill the box to prevent the entrance of moisture, and*

*b. The flush deck box is located not less than 4 feet from the inside wall of the pool.*

(b) An enclosure for a transformer, ground-fault circuit-interrupter, or a similar device connected to a conduit which extends directly to an underwater pool-light forming shell shall be:

- (1) equipped with provisions for threaded conduit entries; and
- (2) provided with an approved seal, such as duct seal at the conduit connection, that prevents circulation of air between the conduit and the enclosures; and
- (3) provided with electrical continuity between every connected metallic conduit and the grounding terminals by means of copper, brass, or other approved corrosion-resistant metal that is integral with the enclosures; and
- (4) located not less than 8 inches, measured from the inside bottom of the enclosure to the ground level, pool deck, or maximum pool water level, whichever provides the greatest elevation; and
- (5) located not less than 4 feet from the inside wall of the pool unless separated from the pool by a solid fence, wall or other permanent barrier.

(c) Junction boxes and enclosures mounted above the grade of the finished walkway around the pool shall not be located in the walkway unless afforded additional protection, such as by location under diving boards, adjacent to fixed structures, and the like.

(d) Junction boxes, transformer enclosures and ground-fault circuit-interrupter enclosures shall be provided with a number of grounding terminals which shall be one more than the number of conduit entries.

**680-22. Bonding.**

(a) The following parts shall be bonded together by a solid copper conductor not smaller than No. 8 AWG:

(1) All metallic parts of the pool structure, including the reinforcing steel.

(2) Forming shell.

(3) All metallic fittings within or attached to the pool structure.

(4) Metal parts of electrical equipment associated with the pool water circulating system, including pump motors.

(5) Metallic conduit and metallic piping within 5 feet of the inside walls of the pool and that are not separated from the pool by a permanent barrier.

(6) All fixed metallic parts that are within 5 feet of the inside walls of the swimming pool and that are not separated from the pool area by a permanent barrier.

*Exception No. 1: The usual steel tie wires are considered suitable for bonding the reinforcing steel together, and welding or special clamping will not be required.*

*Exception No. 2: Structural reinforcing steel or the walls of welded metal pool structures may be used as a common bonding grid for non-electrical parts where connections can be made in accordance with Section 250-113.*

(b) For pool water heaters having a rating of more than 50 amperes and having specific instructions regarding the parts of the equipment to be bonded to the other pool components, and the parts of the equipment to be grounded, only those parts designated to be bonded shall be bonded, and only those parts designated to be grounded shall be grounded.

**680-23. Grounding.** The following equipment shall be grounded: (1) Wet-niche underwater lighting fixtures; (2) Dry-niche underwater lighting fixtures; (3) All electrical equipment located within 5 feet of the inside wall of the pool; (4) All electrical equipment associated with the recirculating system of the pool; (5) Junction boxes; (6) Transformer enclosures; (7) Panelboards that are not part of the service equipment and that supply any electrical equipment associated with the pool.

**680-24. Methods of Grounding.**

(a) The following provisions shall apply to the grounding of underwater lighting fixtures, metallic junction boxes, metallic transformer enclosures and other metallic enclosures:

(1) Wet-niche lighting fixtures that are supplied by a flexible cord or cable shall have all exposed noncurrent-carrying metal parts grounded by an insulated, copper equipment grounding conductor that is an integral part of the cord or cable. This grounding conductor shall be

(680-24(a-1) continued)

connected to a grounding terminal in the supply junction box, transformer enclosure or other enclosure. This grounding conductor shall be equal in size to the supply conductors but not smaller than No. 16 AWG copper.

(2) The junction box, transformer enclosure or other enclosure in the supply circuit to a wet-niche lighting fixture and the field-wiring chamber of a dry-niche lighting fixture shall be grounded to the equipment grounding terminal of the panelboard. This terminal shall be directly connected to the panelboard enclosure. The equipment grounding conductor shall be installed without joint or splice.

*Exception No. 1: Where more than one underwater lighting fixture is supplied by the same branch circuit, the equipment grounding conductor, installed between the junction boxes, transformer enclosures or other enclosures in the supply circuit to wet-niche fixtures or between the field-wiring compartments of dry-niche fixtures, may be terminated on approved grounding terminals.*

*Exception No. 2: Where the underwater lighting fixture is supplied from a transformer, and the transformer is located between the panelboard and a junction box connected to the conduit that extends directly to the underwater lighting fixture, the equipment grounding conductor may terminate on approved grounding terminals in the transformer enclosure.*

(b) Other electrical equipment shall be grounded to the equipment grounding terminal of the panelboard.

(c) A panelboard, not part of the service equipment, shall have an equipment grounding conductor installed between its grounding terminal and the grounding terminal of the service equipment.

(d) An equipment grounding conductor shall be sized in accordance with Table 250-95 but not smaller than No. 12 AWG. It shall be an insulated copper conductor and shall be installed with the circuit conductors in an approved rigid metal conduit or rigid nonmetallic conduit.

*Exception No. 1: The equipment grounding conductor specified in Section 680-24(a)(1).*

*Exception No. 2: The equipment grounding conductor between the wiring chamber of the secondary winding of a transformer and a junction box shall be sized in accordance with the overcurrent device in this circuit. See Section 680-24(a)(2), Exception No. 2.*

*Exception No. 3: The equipment grounding conductor between an existing, remote panelboard and the service equipment need not be in conduit if the interconnection is by means of an approved cable assembly with an insulated or covered copper equipment grounding conductor.*

(e) The equipment grounding conductor between a remote panelboard and the service equipment shall be sized in accordance with the overcurrent devices protecting the conductors supplying the panelboard. See Table 250-95.



(f) Where fixed or stationary equipment is connected with a flexible cord to facilitate removal or disconnection for maintenance, repair or storage (see Section 680-7) the equipment grounding conductors specified in Section 680-24(a) shall be connected to a fixed metallic part of the assembly. The removable part shall be mounted on or bonded to the fixed metallic part.

### **C. Storable Pools**

**680-30. Pumps.** A cord-connected swimming-pool filter pump shall incorporate an approved system of double insulation or its equivalent, and shall be provided with means for grounding only the internal and nonaccessible noncurrent-carrying metal parts of the appliance.

The means for grounding shall be an equipment grounding conductor run with the power supply conductors in the flexible cord that is properly terminated in a grounding-type attachment plug having a fixed grounding contact member.

**680-31. Ground-Fault Circuit-Interrupters Required.** All electrical equipment used with storable swimming pools shall be supplied by circuits protected by ground-fault circuit-interrupters.

## Chapter 7. Special Conditions

### ARTICLE 700 — EMERGENCY SYSTEMS

#### A. General

**700-1. Scope.** The provisions of this Article apply to the installation, operation and maintenance of circuits, systems and equipment intended to supply illumination and power in the event of failure of the normal supply or in the event of accident to elements of a system supplying power and illumination essential for safety to life and property where such systems or circuits are legally required by Municipal, State, Federal or other Codes, or by any governmental agency having jurisdiction.

Emergency systems are generally installed in places of assembly where artificial illumination is required, such as buildings subject to occupancy by large numbers of persons, hotels, theaters, sports arenas, hospitals and similar institutions. Emergency systems may provide power for such functions as essential refrigeration, operation of mechanical breathing apparatus, ventilation when essential to maintain life, illumination and power for hospital operating rooms, fire alarm systems, fire pumps, industrial processes where current interruption would produce serious hazards, public address systems and similar functions.

See NFPA Life Safety Code (NFPA No. 101-1970) for specification of locations where emergency lighting is considered essential to life safety.

**700-2. Other Requirements.** All requirements of this Code shall apply to emergency systems, except as modified by this Article.

**700-3. Equipment Approval.** All equipment shall be approved for use on emergency systems.

#### **700-4. Tests and Maintenance.**

(a) The authority having jurisdiction shall conduct or witness a test on the complete system upon installation and periodically afterward.

(b) The battery charger shall be capable of fully recharging the batteries within twelve (12) hours after partial or total discharge with suitable trickle charge to maintain the battery at full charge.

(c) Where battery systems or unit equipments are involved, including batteries used for starting or ignition in auxiliary engines, the authority having jurisdiction shall require periodic maintenance.

(d) A written record shall be kept of such tests and maintenance.

**700-5. Capacity.** Emergency systems shall have adequate capacity and rating for the emergency operation of all equipment connected to the system.

#### B. Sources of Power

**700-6. Systems.** Current supply shall be such that in event of failure of the normal supply to or within the building or group of buildings concerned, emergency lighting, or emergency power, or both emergency

lighting and power, will be immediately available. The supply system for emergency purposes may comprise one or more of the types of system covered in Sections 700-7 through 700-10. Unit equipments in accordance with Section 700-22 shall satisfy the applicable requirements of this Article.

Consideration must be given to the type of service to be rendered, whether of short time duration, as for exit lights of a theater, or of long duration as for supplying emergency power and lighting due to a long period of current failure from trouble either inside or outside the building, as in the case of a hospital.

Assignment of degree of reliability of the recognized emergency supply system depends upon the careful evaluation of the variables at each particular installation.

**700-7. Storage Battery.** One service, in accordance with Article 230, and a storage battery of suitable rating and capacity to supply and maintain at not less than 87½ percent of system voltage the total load of the circuits supplying emergency lighting and emergency power for a period of at least 1½ hours.

Batteries whether of the acid or alkali type shall be designed and constructed to meet the requirements of emergency service. When of the lead-acid type, this shall include low-gravity acid (1.20 to 1.22 SP-GR), relatively thick and rugged plates and separators, and a transparent jar.

**700-8. Generator Set.** One service, in accordance with Article 230, and a generator set driven by some form of prime mover and of sufficient capacity and proper rating to supply circuits carrying emergency lighting or lighting and power, with suitable means for automatically starting the prime mover on failure of the normal service. For hospitals, the transition time from instant of failure of the normal power source to the emergency generator source shall not exceed 10 seconds.

See Section 700-4.

**700-9. Separate Service.** Two services, each in accordance with Article 230, with separate service drops or laterals, widely separated electrically and physically to minimize possibility of simultaneous interruption of supply.

**700-10. Connection Ahead of Service Disconnecting Means.** Connections on the line side of the main service disconnecting means if sufficiently separated from the main service disconnecting means to prevent simultaneous interruption of supply through an occurrence within the building or groups of buildings served. See Section 230-73.

**700-11. Auxiliary Source.** The requirements of Sections 700-5 and Section 700-6 shall also apply to installations where the entire electrical load on a service or sub-service is arranged to be supplied from a second source. Current supply from a standby power plant shall satisfy the requirements of availability in Section 700-6.

**700-12. Derangement Signals.** Audible and visual signal devices shall be provided. The signal devices shall be located in a regularly traversed area and shall be installed so as to be readily heard or observed by the personnel in charge for the following purposes:

(a) To give warning of derangement of the emergency or auxiliary source.

(b) To indicate that the battery or generator set is carrying load.

(c) To indicate by a visual signal that a battery charger is functioning properly.

### C. Emergency Circuits for Lighting and Power

**700-13. Loads on Emergency Branch Circuits.** No appliances and no lamps, other than those specified as required for emergency use shall be supplied by emergency lighting circuits.

**700-14. Emergency Illumination.** Emergency illumination shall include all required exit lights and all other lights specified as necessary to provide sufficient illumination.

Emergency lighting systems should be so designed and installed that the failure of any individual lighting element, such as the burning out of a light bulb, cannot leave any space in total darkness.

**700-15. Circuits for Emergency Lighting.** Branch circuits intended to supply emergency lighting shall be so installed as to provide service immediately when the normal supply for lighting is interrupted. Such installations shall provide either one of the following:

(a) An emergency lighting supply, independent of the general lighting system with provisions for automatically transferring, by means of devices approved for the purpose, the emergency lights upon the event of failure of the general lighting system supply.

(b) Two or more separate and complete systems with independent power supply, each system providing sufficient current for emergency lighting purposes. Unless both systems are used for regular lighting purposes and are both kept lighted, means shall be provided for automatically energizing either system upon failure of the other. Either or both systems may be part of the general lighting system of the protected occupancy if circuits supplying lights for emergency illumination are installed in accordance with other sections of this Article.

**700-16. Circuits for Emergency Power.** For branch circuits which supply equipment classed as emergency, there shall be an emergency supply source to which the load will be transferred automatically and immediately upon the failure of the normal supply.

**700-17. Independent Wiring.** Emergency circuit wiring shall be kept entirely independent of all other wiring and equipment and shall not enter the same raceway, box or cabinet with other wiring except:

*Exception No. 1: In transfer switches.*

*Exception No. 2: In exit or emergency lighting fixtures supplied from two sources.*

*Exception No. 3: In a common junction box attached to exit or emergency lighting fixtures supplied from two sources.*

### D. Control

**700-18. Switch Requirements.** The switch or switches installed in emergency lighting circuits shall be so arranged that only authorized persons will have control of emergency lighting except:

*Exception No. 1: Where two or more single-throw switches are con-*

*nected in parallel to control a single circuit, at least one of these switches shall be accessible only to authorized persons.*

*Exception No. 2: Additional switches which act only to put emergency lights into operation but not disconnect them are permissible.*

Switches connected in series or 3- and 4-way switches shall not be used.

#### **700-19. Switch Location.**

(a) All manual switches for controlling emergency circuits shall be in locations convenient to authorized persons responsible for their actuation. In places of assembly such as theaters a switch for controlling emergency lighting systems shall be located in the lobby or at a place conveniently accessible thereto.

(b) In no case shall a control switch for emergency lighting in a theater or motion-picture theater be placed in a motion-picture projection booth or on a stage, except that where multiple switches are provided, one such switch may be installed in such location when so arranged that it can energize, but not disconnect, the circuit.

#### **700-20. Other Switches.**

(a) **Exterior Lights.** Those lights on the exterior of the building which are not required for illumination when there is sufficient daylight may be controlled by an automatic light-actuated device approved for the purpose.

(b) **Hospital Corridors.** Switching arrangements to transfer corridor lighting in patient areas of hospitals from overhead fixtures to fixtures designed to provide night lighting may be permitted, provided the switching system is so designed that switches can only select between two sets of fixtures and cannot extinguish both sets at the same time.

### **E. Overcurrent Protection**

**700-21. Accessibility.** The branch-circuit overcurrent devices in emergency circuits shall be accessible to authorized persons only.

### **F. Unit Equipments**

**700-22. Unit Equipments.** Where permitted by the authority having jurisdiction, in lieu of other methods specified elsewhere in this Article, individual unit equipments for emergency illumination shall consist of (a) a rechargeable battery, (b) a battery charging means, (c) provisions for one or more lamps mounted on the equipment and may have terminals for remote lamps, and (d) a relaying device arranged to energize the lamps automatically upon failure of the normal supply to the building. The batteries shall be of suitable rating and capacity to supply and maintain at not less than 87½ percent of the nominal battery voltage for the total lamp load associated with the unit for a period of at least 1½ hours. Storage batteries whether of the acid or alkali type shall be designed and constructed to meet the requirements of emergency service. When of the lead-acid type the storage battery shall have a transparent jar.

Unit equipments shall be permanently fixed in place (i.e., not portable) and shall have all wiring to each unit installed in accordance with

(700-22 continued)

the requirements of any of the wiring methods in Chapter 3. They shall not be connected by flexible cord. The supply circuit between the unit equipment and the service, feeders, or the branch-circuit wiring shall be installed as required by Section 700-17. Emergency illumination fixtures which obtain power from a unit equipment and are not part of the unit equipment shall be wired to the unit equipment as required by Section 700-17 and by one of the wiring methods of Chapter 3.

## ARTICLE 710 — OVER 600 VOLTS — GENERAL

### A. General

**710-1. Scope.** This Article applies in general to all circuits and equipment operated at more than 600 volts. For specific installation see the Articles referred to in Section 710-2.

**710-2. Installations Covered in Other Articles.** Provisions applicable to specific types of installations are included in Article 230, Services; Article 346, Rigid Metal Conduit; Article 347, Rigid Nonmetallic Conduit; Article 365, Cablebus; Article 430, Motors, Motor Circuits and Controllers; Article 450, Transformers and Transformer Vaults; Article 460, Capacitors; Article 730, Outside Branch Circuits and Feeders; Article 410, Lighting Fixtures, Lampholders, Lamps, Receptacles and Rosettes; Article 600, Electric Signs and Outline Lighting; Article 660, X-ray Equipment, and Article 665, Induction and Dielectric Heating Equipment.

### 710-3. Wiring Methods.

**(a) Aboveground Conductors.** They shall be installed in rigid metal conduit, in cablebus, in other suitable raceways or as open runs of metal-clad cable suitable for the use and purpose.

In locations accessible to qualified persons only, open runs of non-metallic-sheathed cable, bare conductors and bare bus-bars may also be used.

**(b) Underground Conductors.** Conductors shall be suitable for the voltage and conditions under which they are installed. Conductors installed in rigid metal conduit or direct burial cable, if of the construction where the energized conductors are surrounded by effectively grounded, multiple, concentric conductors, closely and evenly spaced circumferentially and meeting the requirements of Section 250-51 shall be buried at least 30 inches deep. Where other wiring methods are used the conductors shall be at a minimum depth of 42 inches and preferably at least 6 inches below other utilities.

*Exception No. 1: Under streets or roadways — conductor depth may be reduced to 24 inches if installed in rigid metal conduit.*

*Exception No. 2: Airport runways — in airport runways, including adjacent defined areas where trespass is prohibited, cable may be buried no less than 18 inches deep and without raceways or concrete encasement.*

*Exception No. 3: Lesser depths for unusual conditions — the above depths may be reduced 12 inches for each additional 2 inches of protective layer of concrete above the conductors.*

**710-4. Braid-Covered Insulated Conductors — Open Installation.** Open runs of braid-covered insulated conductors shall have a flame-retardant braid. When the conductors used do not have this protection, a flame-retardant saturant shall be applied to the braid covering after installation. This treated braid covering shall be stripped back a safe distance at conductor terminals, according to the operating voltage. This distance should be not less than one inch for each kilovolt of the conductor-to-ground voltage of the circuit, where practicable.

**710-5. Shielding of Solid Dielectric Insulated Conductors.** Where solid dielectric-insulated conductors for permanent installations operate at voltages higher than those indicated in Table 710-5 and under the conditions mentioned, they shall be of a type having shielding for the purpose of confining their dielectric field.

Table 710-5

## Shielding of Solid Dielectric Insulated Conductors

Voltage in kV (L-L) Above Which Shielding is Required  
100 and 133 Percent Insulation Level

1. Single conductor (including assemblies of Single Conductors)
  - a. With metallic sheath or armor ..... 5kV
  - b. All others ..... 2kV
2. Multiple conductor with common covering
  - a. With discharge-resisting jacket ..... 5kV
  - b. With nondischarge-resisting jacket ..... 2kV
  - c. With fibrous covering ..... 2kV
  - d. With metallic sheath or armor ..... 5kV

**710-6. Grounding of Shielding Tape.** The metallic shielding or any other static-voltage shields on shielded cable shall be stripped back to a safe distance according to the circuit voltage, at all terminations of the shielding, as in potheads and joints. At such points, suitable methods such as the use of potheads, terminators, stress cones or similar devices shall be employed for stress reduction and the metallic shielding tape shall be grounded.

**710-7. Grounding.** Wiring and equipment installations shall conform with the applicable provisions of Article 250.

**710-8. Moisture or Mechanical Protection for Metal-Sheathed Cables.** Where cable conductors emerge from a metal sheath and where protection against moisture or mechanical injury is necessary, the insulation of the conductors shall be protected by a pothead or other approved means.

### **B. Equipment — General Provisions**

**710-10. Indoor Installations.** Indoor electrical equipment installations shall conform with Sections 710-10(a) and (b).

**(a) In Places Accessible to Unqualified Persons.** Electrical installations which are open to unqualified persons shall be made with metal enclosed equipments or shall be enclosed in a vault or in an area access to which is controlled by a lock. Metal-enclosed switchgear, unit substations, transformers, pull boxes, connection boxes, and other similar associated equipment shall be marked with appropriate caution signs. Openings in ventilated dry-type transformers or similar openings in other equipment shall be designed so that foreign objects inserted through these openings will be deflected from energized parts.

**(b) In Places Accessible to Qualified Persons Only.** Electrical installations shall conform with Sections 710-31 through 710-34.

**710-11. Outdoor Installations.**

**(a) In Places Accessible to Unqualified Persons.** Electrical installations which are open to unqualified persons shall conform with Article 730.

For clearances of conductors over 600 volts see National Electrical Safety Code — ANSI C2-1960.

**(b) In Places Accessible to Qualified Persons Only.** Outdoor electrical installations having exposed live parts shall be accessible to qualified persons only and shall conform with Sections 710-31 through 710-34.

**710-12. Metal-Enclosed Equipments.** Installations consisting of metal-enclosed equipments such as metal-clad switchgear, transformers, and the like, which have no exposed live parts, need not comply with Section 710-31. Ventilating or similar openings in equipment shall be so designed that foreign objects inserted through these openings will be deflected from energized parts. Where exposed to physical damage from vehicular traffic suitable guards shall be provided. Metal-enclosed equipment located outdoors accessible to the general public shall be designed



so that exposed nuts or bolts cannot be readily removed, permitting access to live parts.

### **C. Equipment — Specific Provisions**

See also references to specific types of installations in Section 710-2.

#### **710-21. Circuit Interrupting Devices.**

##### **(a) Circuit Breakers.**

(1) Indoor installations shall consist of metal-enclosed units or fire-resistant cell-mounted units except that open mounting of circuit breakers is permissible in locations accessible to qualified persons only.

(2) Circuit breakers shall be trip-free in all positions. In every installation the circuit-breaker rating in respect to closing, carrying or interrupting capabilities shall not be less than the short-circuit duty at the point of application.

(3) Circuit breakers used to control oil-filled transformers should be located outside the transformer vault.

(4) Circuit breakers shall have a means of indicating the open and closed position of the breaker at the point(s) from which they may be operated.

(5) Oil circuit breakers shall be so arranged or located that adjacent readily combustible structures or materials are safeguarded in an approved manner. Adequate space separation, fire-resistant barriers or enclosures, trenches containing sufficient coarse crushed stone and properly drained oil enclosures such as dikes or basins are recognized as suitable for this purpose.

##### **(b) Fuseholders and Fuses.**

(1) Fuses which expel flame in opening the circuit shall be so designed or arranged that they will function properly without hazard to persons or property.

(2) Fuseholders shall be designed so that they can be de-energized while replacing a fuse unless the fuse and fuseholder are designed to permit fuse replacement by qualified persons using equipment designed for the purpose without de-energizing the fuseholder.

Metal-enclosed switchgear and substations which utilize high-voltage fuses shall be provided with a gang-operated disconnecting switch. Isolation of the fuses from the circuit shall be provided by either connecting a switch between the source and the fuses or providing roll-out switch and fuse type of construction. The switch shall be of the load-interrupter type, unless mechanically or electrically interlocked with a load-interrupting device arranged to reduce the load to the interrupting capability of the switch.

(3) When high-voltage fused cutouts are installed in a building or a transformer vault, they shall be of a type designed for use in buildings. Where such cutouts are not suitable to interrupt the circuit manually while carrying full load, an approved switch or contactor shall be provided which is capable of interrupting the entire load. In addi-

(710-21(b-3) continued)

tion, the cutouts shall be interlocked with the approved interrupter or bear a conspicuous sign reading "Do Not Open Cutout Under Load."

The cutouts shall be so located that they may be readily and safely operated and re-fused. Fuses shall be accessible from a clear floor space.

**(c) Load Interrupters.** Load-interrupter switches may be used providing suitable fuses or circuit breakers are applied in conjunction with these devices to interrupt fault currents. When these devices are used in combination they shall be so coordinated electrically that they will safely withstand the effects of closing, carrying or interrupting all possible currents up to the assigned maximum short-circuit rating.

**710-22. Isolating Means.** Means shall be provided to completely isolate an item of equipment. The use of isolating switches is not necessary where there are other ways of de-energizing the equipment for inspection and repairs such as metal-enclosed switchgear units, and removable truck panels. Isolating switches should be interlocked with the associated circuit-interrupting device to prevent their being opened under load, otherwise signs warning against opening them under load shall be provided. Barriers should be provided on both sides of each pole of indoor open-type isolating switches. A fuseholder and fuse, designed for the purpose, may be used as an isolating switch.

#### **D. Installations Accessible To Qualified Persons Only**

**710-31. Enclosure for Electrical Installations.** Electrical installations in a vault, room, closet or in an area surrounded by a wall, screen or fence, access to which is controlled by lock and key or other approved means, are considered to be accessible to qualified persons only. The height of the wall, screen or fence should not be less than 8 feet over-all, unless designed to provide an equivalent degree of isolation. The type of enclosure used in a given case shall be designed and constructed according to the nature and degree of the hazard(s) associated with the installation. Article 450 covers minimum construction requirements for oil-filled-transformer vaults.

Isolation by elevation is covered in Sections 710-11 and 710-34.

**710-32. Circuit Conductors.** They may be installed in conduit; in duct systems; as metal-clad cable; as bare wire, cable and buses, or as nonmetallic-sheathed cables or conductors as provided in Sections 710-3 through 710-6. Bare live conductors shall conform with Sections 710-33 and 710-34.

Insulators, together with their mounting and conductor attachments, when used as supports for wires, single-conductor cables and bus-bars, shall be capable of safely withstanding the maximum magnetic forces which would prevail when two or more conductors of a circuit were subjected to short-circuit current.

Open runs of insulated wires and cables, having a bare lead sheath or a braided outer covering, shall be supported in a manner designed to

prevent physical damage to the braid or sheath. Supports for lead-covered cables shall be designed to prevent electrolysis of the sheath.

**710-33. Minimum Space Separation Between Live Parts and Adjacent Surfaces.** The minimum indoor air separation between bare live conductors and between such conductors and adjacent surfaces shall be not less than the values given in Table 710-33. This Section applies to interior wiring design and construction. It does not apply to the space separation provided in electrical apparatus and wiring devices.

**Table 710-33. Minimum Air Separation in Inches, Indoors\***

Circuit Voltage, kV	Between Bare Live Conductors	Between Bare Live Conductors and Adjacent Surfaces
2.5	5	4
5.0	6	5
7.5	7	6
15.0	12	7
23.0	15	10
34.5	18	13
46.0	21	17
69.0	31	25

\* The values given are the minimum permissible space separation under favorable service conditions. They should be increased under unfavorable service conditions or wherever space limitations permit.

#### **710-34. Work Space and Guarding.**

**(a) Working Space.** The minimum clear working space in front of electrical equipment, such as switchboards, control panels, switches, circuit breakers, motor controllers, relays and similar equipment shall not be less than set forth in Table 710-34(a) unless otherwise specified in this Code.

**Table 710-34(a)**

#### **Minimum Clear Working Space in Front of Electrical Equipment**

Voltage to Ground	Conditions		
	1	2	3
601-2500	3 ft.	4 ft.	5 ft.
2501-7500	4 ft.	5 ft.	6 ft.
over 7500	5 ft.	6 ft.	9 ft.

Where the "Conditions" are as follows:

**(1)** Exposed live parts on one side and no live or grounded parts on the other side of the working space or exposed live parts on both sides effectively guarded by suitable wood or other insulating materials.

(710-34(a-1) continued)

Insulated wire or insulated bus-bars operating at not more than 300 volts shall not be considered live parts.

(2) Exposed live parts on one side and grounded parts on the other side. Concrete, brick or tile walls will be considered as grounded surfaces.

(3) Exposed live parts on both sides of the work space (not guarded as provided in Condition 1) with the operator between.

*Exception: Working space is not required in back of assemblies such as dead-front switchboards or control assemblies when there are no renewable or adjustable parts such as fuses or switches on the back and when all connections are accessible from other locations than the back.*

**(b) Separation from Low-Potential Equipment.** When switches, cut-outs or other equipment operating at 600 volts or less are installed in a room or enclosure where there are exposed live parts or exposed wiring operating at more than 600 volts the high-potential equipment shall be effectively separated from the space occupied by the low-potential equipment by a suitable partition, fence, or screen.

*Exception: Switches or other equipment operating at 600 volts or less and serving only equipment within the high-voltage vault, room or enclosure may be installed in the high-voltage enclosure, room or vault if accessible to qualified persons only.*

**(c) Locked Rooms or Enclosures.** The entrances to all buildings, rooms or enclosures containing exposed live parts or exposed conductors operating in excess of 600 volts shall be kept locked, except where such entrances are at all times under the observation of a qualified attendant.

Where the voltage exceeds 600 volts permanent and conspicuous warning signs shall be provided, reading substantially as follows: "Warning — High Voltage — Keep Out."

**(d) Illumination.** Adequate illumination shall be provided for all working spaces about electrical equipment. The light outlets shall be so arranged that persons changing lamps or making repairs on the lighting system will not be endangered by live parts or other equipment.

The points of control shall be so located that persons are not liable to come into contact with any live part or moving part of the equipment while turning on the lights.

**(e) Headroom.** The minimum headroom above working spaces about switching equipment where there are live parts exposed at any time shall be not less than 6½ feet.

**(f) Elevation of Unguarded Live Parts.** Unguarded live parts above working space shall be maintained at elevations not less than required by Table 710-34(f).

**Table 710-34(f)**  
**Elevation of Unguarded Live Parts Above the Working Space**

Voltage Between Phases	Minimum Vertical Clearance of Unguarded Parts	
	Feet	Inches
601–6600	8	0
6601–11000	9	0
11001–22000	9	3
22001–33000	9	6
33001–44000	9	10
44001–66000	10	5
66001–88000	11	0
88001–110000	11	7
110001–132000	12	2

## ARTICLE 720 — CIRCUITS AND EQUIPMENT OPERATING AT LESS THAN 50 VOLTS

**720-1. Scope.** This Article shall apply to installations operating at less than 50 volts, direct-current or alternating-current, except such as are treated in Articles 650 and 725.

**720-2. Hazardous Locations.** Circuits or equipment coming within the scope of this Article and installed in hazardous locations shall comply with the appropriate provisions of Articles 500 through 517.

**720-3. Larger Current at Lower Voltage.** Conductors, devices, and equipment shall have current ratings sufficient for the greater current required to deliver equal power at the lower voltage than at usual voltages.

**720-4. Conductors.** Conductors shall be not smaller than No. 12 AWG copper or equivalent, and for appliance branch circuits supplying more than one appliance, or appliance receptacle, conductors shall be not smaller than No. 10 AWG copper or equivalent.

**720-5. Lampholders.** Standard lampholders of rating not less than 660 watts shall be used.

**720-6. Receptacle Rating.** Receptacles shall have a rating not less than 15 amperes.

**720-7. Receptacles Required.** Receptacles of not less than 20-ampere rating shall be provided in kitchens, laundries, and other locations where portable appliances are likely to be used.

**720-8. Overcurrent Protection.** Overcurrent protection shall comply with the provisions of Article 240.

**720-9. Batteries.** See Article 480.

**720-10. Grounding.** See Sections 250-5(a) and 250-45.

## **ARTICLE 725 — REMOTE-CONTROL, LOW-ENERGY POWER, LOW-VOLTAGE POWER, AND SIGNAL CIRCUITS**

### **A. Scope and General**

**725-1. Scope.** Provisions of this Article shall apply to remote-control circuits, including low-voltage relay switching, low-energy power circuits, low-voltage circuits, and signal circuits, as defined in Article 100, Definitions.

The provisions of this Article are not intended to apply to remote-control, low-energy or signal circuits which form an integral part of a device or appliance.

**725-2. Hazardous Locations.** Circuits or equipment coming within the scope of this Article and installed in hazardous locations shall also comply with the appropriate provisions of Articles 500 through 517.

**725-3. Classification.** Remote-control and signal circuits shall be classified as follows:

(a) **Class 1 Circuits.** Control and signal circuits in which power is not limited in accordance with Section 725-31.

(b) **Class 2 Circuits.** Control and signal circuits in which the power is limited in accordance with Section 725-31.

**725-4. Low-Energy Power Circuits.** Circuits, which are neither remote-control nor signal circuits, but which have the power limited in accordance with Section 725-31, shall, for the purpose of this Code, be treated as Class 2 remote-control circuits.

**725-5. Low-Voltage Power Circuits.** Circuits which are neither remote-control nor signal circuits but which operate at not more than 30 volts, where the current is not limited in accordance with Section 725-31, and which are supplied from a source not exceeding 1,000 volt-amperes shall for the purpose of this Code be treated as Class 1 remote-control circuits.

**725-6. Safety-Control Devices.** Remote-control circuits to safety-control devices, the failure of operation of which would introduce a direct fire or life hazard, shall be considered as Class 1 circuits.

Room thermostats, service hot-water temperature regulating devices, and similar controls used in conjunction with electrically controlled domestic heating equipment, are not considered to be safety-control devices.

**725-7. Remote-Control and Signal Circuits in Communication Cables.** Remote-control and signal circuits, which use conductors in the same cable with communication circuits, shall, for the purpose of this Article, be classified as communication circuits and meet the requirements of Article 800 of this Code.

**B. Class 1 System**

**725-11. Wiring Method.** Conductors and equipment of Class 1 remote-control and signal systems and low-voltage power circuits shall be installed in accordance with the requirements of the appropriate Articles in Chapter 3 of this Code, except as provided in Sections 725-12 through 725-15.

**725-12. Other Articles.** The wiring method required in Section 725-11 does not apply where other Articles of this Code specifically permit or require other methods for remote-control or signal circuits. See Article 620, Elevators, for example.

**725-13. Conductor Sizes.** Nos. 18 and 16 AWG conductors may be used provided they are installed in a raceway or a cable approved for the purpose, or in flexible cords in accordance with the provisions of Article 400.

**725-14. Conductor Insulation.** Conductors larger than No. 16 shall conform to Article 310. Conductors of sizes No. 18 and No. 16 shall be Types RF-2, FF-2, RFH-2, FFH-2, TF, TFF, TFN, TFFN, PF, PGF, PFF, PGFF, PTF, PTF, SF-2, SFF-2, or MTW. Conductors with other type and thickness of insulation may be used if approved for the purpose.

**725-15. Number and Ampacities of Conductors in Raceways.**

(a) Where only remote-control or signal circuits are in a raceway, the number of conductors shall be determined in accordance with Section 300-17. Note 8 to Tables 310-12 through 310-15 shall apply only if such conductors carry continuous loads.

(b) Where power-supply conductors and Class 1 system conductors are permitted in a raceway in accordance with Section 725-16, Note 8 to Tables 310-12 through 310-15 shall apply as follows:

(1) To all conductors when the Class 1 system conductors carry continuous loads and when the total number of conductors are more than three.

(2) To the power-supply conductors only, when the Class 1 system conductors do not carry continuous loads and when the number of power-supply conductors are more than three.

**725-16. Conductors of Different Systems.** Conductors of two or more Class 1 remote-control and/or signal circuits may occupy the same enclosure or raceway without regard to whether the individual systems or circuits are alternating-current or direct-current, provided all conductors are insulated for the maximum voltage of any conductor in the enclosure or raceway. Conductors of remote-control, low-energy power and signal circuits, in which the current is limited as for Class 2 systems, shall be considered as Class 1 system conductors for the purpose of this requirement if insulated and installed in accordance with the provisions for Class 1 system conductors. Power-supply conductors may occupy the same enclosure or raceway with Class 1 system conductors when supplying only equipment to which Class 1 system conductors are connected.

**725-17. Mechanical Protection of Remote-Control Circuits.** Where damage to a remote-control circuit would introduce a hazard as covered in Section 725-6, all conductors of such remote-control circuits shall be installed in conduit, electrical metallic tubing, Type MI cable or be otherwise suitably protected from physical damage.

**725-18. Overcurrent Protection.** Conductors shall be protected against overcurrent in accordance with the ampacities of Tables 310-12 through 310-15.

*Exception No. 1: Other Articles. Where other Articles of this Code specifically permit or require other overcurrent protection. See Sections 430-72 and 620-61.*

*Exception No. 2: Conductors of Nos. 18 and 16. Conductors of Nos. 18 and 16 shall be considered as protected by overcurrent devices of 20-ampere rating or setting.*

*Exception No. 3: Omission of Overcurrent Protection. In remote-control and signal circuits having main and branch circuits, the branch circuits need not be individually protected against overcurrent where the operating voltage does not exceed 30 volts.*

**725-19. Location of Overcurrent Protection.** Overcurrent devices shall be located at the point where the conductor to be protected receives its supply unless the overcurrent device protecting the larger conductor also protects the smaller conductor in accordance with Tables 310-12 through 310-15.

**725-20. Circuits Extending Beyond One Building.** Class 1 circuits which extend aerially beyond one building shall also meet the requirements of Article 730.

**725-21. Grounding.** Class 1 remote-control and signal circuits and equipment shall be grounded in accordance with Article 250.

### **C. Limitation of Low-Voltage Power Circuit**

**725-22. Overcurrent Protection.** Transformer devices supplying low-voltage power circuits shall be provided with overcurrent protection in the secondary circuit rated or set at not more than 250 percent of the rated secondary current of the transformer. Such protection and mounting shall be approved for the purpose. Overcurrent protection required shall not be interchangeable with protection of a higher rating. The overcurrent protection may be an integral part of a transformer or other power-supply device approved for the purpose.

**725-23. Transformer Rating.** Transformer devices supplying low-voltage power circuits shall be approved for the purpose and be restricted in their rated output to not exceeding 1,000 volt-amperes and to not exceeding 30 volts. They shall be marked where plainly visible to show their rated output and the voltage to be applied to the circuit.

A transformer is considered as meeting the 1,000 volt-ampere requirement where the approximate temperature limit is reached at 1,000 volt-ampere load.



#### **D. Class 2 System Voltage and Current Limits**

**725-31. Limits of Class 2 Systems.** Class 2 remote-control and signal systems, depending on the voltage shall have the current limited as follows:

**(a) Maximum 15 Volts: 5 Amperes.** Circuits in which the open-circuit voltage does not exceed 15 volts and having overcurrent protection of not more than 5-ampere rating. Where the current supply is from a transformer or other device having energy-limiting characteristics and approved for the purpose, or from primary batteries, the overcurrent protection may be omitted.

**(b) 15 to 30 Volts: 3.2 Amperes.** Circuits in which the open-circuit voltage exceeds 15 volts but does not exceed 30 volts and having overcurrent protection of not more than 3.2 amperes rating. Where the current supply is from a transformer or other device having energy-limiting characteristics and approved for the purpose, or from primary batteries, the overcurrent protection may be omitted.

**(c) 30 to 60 Volts: 1.6 Amperes.** Circuits in which open-circuit voltage exceeds 30 volts but does not exceed 60 volts and having overcurrent protection of not more than 1.6 amperes rating. Where the current supply is from a transformer or other device having energy-limiting characteristics and approved for the purpose, the overcurrent protection may be omitted.

**(d) 60 to 150 Volts: One Ampere.** Circuits in which the open-circuit voltage exceeds 60 volts but does not exceed 150 volts, and having overcurrent protection of not more than one-ampere rating, provided that such circuits are equipped with current-limiting means other than overcurrent protection which will limit the current as a result of a fault to not exceeding one ampere.

**(e) Maximum 150 Volts: 5 Milliamperes.** Circuits in which the open-circuit voltage does not exceed 150 volts provided that such circuits are equipped with current-limiting means, other than overcurrent protection, which are approved for the purpose and which will limit the current as a result of a fault to not exceeding 5 milliamperes.

**725-32. Overcurrent Protection and Mounting.** Where current is limited in Class 2 systems by means of overcurrent protection, such protection and its mounting shall be approved for the purpose. Overcurrent protection required shall not be interchangeable with protection of a higher rating. The overcurrent protection may be an integral part of a transformer or other power supply device approved for the purpose.

**725-33. Transformer Rating.** Transformer devices supplying Class 2 systems shall be approved for the purpose and be restricted in their rated output to not exceeding 100 volt-amperes. Such devices shall not be paralleled or otherwise interconnected. They shall be marked where plainly visible to show the voltage to be applied to the circuit.

A transformer is considered as meeting the 100 volt-ampere requirement if the approximate temperature limit is reached at a 100-volt-ampere load.

**725-34. Transformer Leads.** The primary leads of transformers supplying Class 2 remote-control and signal circuits may be smaller than No. 14 but not smaller than No. 18, provided they are not over 12 inches long, have insulation at least equal to Type RF-2 rubber-covered fixture wire, or approved equivalent.

### **E. Installation of Class 2 Remote-Control and Signal Circuits**

**725-41. On Supply Side of Overcurrent Protection, Transformers or Current-Limiting Devices.** Conductors and equipment on supply side of overcurrent protection, transformers or current-limiting devices shall be installed in accordance with the appropriate requirements of Chapter 3 of this Code. Transformers or other devices supplied from electric light and power circuits shall be protected by an overcurrent device with a rating or setting not exceeding 20 amperes.

**725-42. On Load Side of Overcurrent Protection, Transformer or Current-Limiting Devices.** Conductors on load side of overcurrent protection, transformers, or current-limiting devices shall be insulated and shall comply with the following:

(a) **Separation from Other Conductors.** Conductors shall be separated from conductors of electric light and power circuits as follows:

(1) **Open Conductors.** Conductors shall be separated at least 2 inches from any light or power conductors or Class 1 signal or control circuits not in a raceway nor in metal-sheathed, metal-clad, nonmetallic-sheathed or Type UF cables unless permanently separated from the conductors of the other system by a continuous and firmly fixed nonconductor, such as porcelain tubes or flexible tubing, additional to the insulation on the wire.

(2) **In Raceways and Boxes.** Conductors of Class 2 remote-control and signal circuits shall not be placed in any raceway, compartment, outlet box or similar fitting with conductors for either light and power circuits or Class 1 signal and control circuits, unless the conductors of the different systems are separated by a partition; provided that this shall not apply to conductors in outlet boxes, junction boxes or similar fittings or compartments where power-supply conductors are introduced solely for supplying power to the remote-control or signal equipment to which the other conductors in the enclosure are connected. See Section 725-16.

(3) **In Shafts.** Conductors may be run in the same shaft with conductors for light and power where the conductors of the two systems are separated at least 2 inches, or where the conductors of either system are encased in noncombustible tubing. Where the lighting or power conductors are run in a raceway, or in metal-sheathed or metal-clad or nonmetallic-sheathed or Type UF cables, neither the 2-inch separation nor the noncombustible tubing is required. In hoistways

conductors shall be installed in rigid conduit or electrical metallic tubing except as provided for in Section 620-21, Exception Nos. 1 and 2.

**(b) Vertical Runs.** Conductors in a vertical run in a shaft or partition shall have a fire-resistant covering capable of preventing the carrying of fire from floor to floor except where conductors are encased in tubing or other outer covering of noncombustible material or are located in a fireproof shaft having fire stops at each floor.

Where 3 or more conductors are used, it is recommended that such conductors be grouped under a common braid or covering.

**(c) Conductor Insulation.** Conductor insulation shall comply with the following:

**(1) 30 Volts or Less.** The insulation shall be suitable for the particular application.

The kind of insulation for the conductors is not specified in further detail as reliance is placed on current limitation to stop dangerous currents.

**(2) 30 to 150 Volts. Maximum Fault Current 5 Milliamperes.** The insulation shall be suitable for the particular application.

The kind of insulation for the conductors is not specified in further detail as reliance is placed on current limitation to stop dangerous currents.

**(3) 30 to 150 Volts. Greater than 5 Milliamperes.** Conductors of a cable shall be of solid or stranded copper not smaller than No. 22 AWG, and shall have thermoplastic insulation of not less than 12 mils nominal (10 mils minimum) thickness. The cable conductors shall have a thermoplastic jacket over-all having a nominal thickness of not less than 35 mils (30 mils minimum). Where the number of conductors in a cable exceeds 4, the thickness of the thermoplastic jacket over-all shall be increased so as to provide equivalent performance characteristics. Similarly, where the size of conductors in a cable exceeds No. 16 AWG, the thickness of the conductor insulation shall be increased so as to provide equivalent performance characteristics.

Two-conductor assemblies of No. 16 AWG or smaller, may be in a flat parallel construction with a 30-mil nominal integral-insulation jacket and a 47-mil minimum web. Approved low-energy circuit cable may be used.

Other insulation having equivalent performance characteristics may be acceptable.

Where single conductors are used they shall be not smaller than No. 18 AWG and shall be insulated in conformity with Section 725-14.

**725-43. Circuits Extending Beyond One Building.** Class 2 remote-control and signal circuits which extend beyond one building and are so run as to be subject to accidental contact with light or power conductors operating at a potential exceeding 300 volts, shall also meet the requirements of Sections 800-2, 800-11 and 800-12.

**725-44. Grounding.** Class 2 remote-control and signal circuits and equipment shall be grounded in accordance with Article 250.

ARTICLE 730 — OUTSIDE BRANCH CIRCUITS  
AND FEEDERS

**730-1. Scope.** This Article applies to electrical equipment and wiring for the supply of utilization equipment located on or attached to the outside of public and private buildings, or run between buildings, structures or poles on other premises served.

For additional information on wiring over 600 volts see the National Electrical Safety Code, ANSI C2-1960 and supplements C-2.2A-1965 and C-2.2B-1967.

**730-2. Application of Other Articles.** Application of other Articles, including additional requirements to specific cases of equipment and conductors, are as follows:

	Article
Branch Circuits .....	210
Communication Circuits .....	800
Community Antenna Television and Radio Distribution Systems .....	820
Electric Signs and Outline Lighting .....	600
Feeders .....	215
Fixed Outdoor Electric De-icing and Snow-Melting Equipment .....	426
Grounding .....	250
Hazardous Locations, General .....	500
Hazardous Locations, Specific .....	510
Marinas and Boatyards .....	555
Over 600 Volts, General .....	710
Radio and Television Circuits .....	810
Remote-Control, Low-Energy Power, Low-Voltage Power and Signal Circuits .....	725
Services .....	230
Swimming and Wading Pools .....	680
Use and Identification of Grounded Conductors .....	200

**730-3. Calculation of Load.**

(a) **Branch Circuits.** The load on every outdoor branch circuit is to be determined by the applicable provisions of Article 220.

(b) **Feeders.** The load to be expected on every outdoor feeder is to be determined by the procedure specified in Article 220.

**730-4. Conductor Covering.** Where within 10 feet of any building or structure, open conductors supported on insulators shall be insulated or covered. Conductors in cables or raceways, except Type MI Cable, shall be of the rubber-covered type or thermoplastic type and in wet locations shall comply with Section 310-5. Conductors for festoon lighting shall be of the rubber-covered or thermoplastic type.

**730-5. Size of Conductors.** The ampacity of outdoor branch circuits and feeder conductors shall be according to the rating in Tables 310-12 through 310-15 in order to carry the loads determined under Section 730-3.

**30-6. Minimum Size of Conductor.**

(a) **Overhead Spans.** Overhead conductors shall not be smaller than No. 10 for spans up to 50 feet in length, and not smaller than No. 8 for longer spans.

(b) **Festoon Lighting.** Overhead conductors for festoon lighting shall not be smaller than No. 12 unless supported by messenger wires. (See section 730-25.)

**DEFINITION:** Festoon lighting is a string of outdoor lights suspended between two points more than 15 feet apart.

(c) **Over 600 Volts.** Overhead conductors operating at more than 600 volts shall not be smaller than No. 6 when open individual conductors nor smaller than No. 8 when in cable.

**730-7. Lighting Equipment on Poles or Other Structures.**

(a) For the supply of lighting equipment installed on a single pole or structure, the branch circuits shall comply with the requirements of Article 210 and paragraph (c) below.

(b) A common neutral may be used for a multiwire branch circuit consisting of the neutral and not more than 8 ungrounded conductors. The ampacity of the neutral conductor shall be not less than the calculated sum of the currents in all ungrounded conductors connected to any one phase of the circuit.

(c) The voltage to ground of branch circuits supplying lampholders or lighting fixtures mounted on the outside of buildings or on poles or structures for area illumination of residential, commercial or industrial property shall not exceed 150 volts.

*Exception No. 1: The voltage to ground on branch circuits supplying lighting fixtures for illumination of outdoor areas of industrial establishments, office buildings, schools, stores and other commercial or public buildings shall not exceed 300 volts provided:*

*a. The fixtures are mounted on the outside of buildings or out of doors on poles or other structures.*

*b. The fixtures are not less than 8 feet above grade or other surface accessible to individuals other than those charged with fixture maintenance and supervision.*

*c. The fixtures are not less than 3 feet from windows, platforms, fire escapes and the like.*

*Exception No. 2: The voltage between conductors supplying only ballasts for permanently installed electric-discharge lighting fixtures for area illumination shall not exceed 500 volts provided the fixtures are mounted on poles at a height of not less than 22 feet or on other structures at a height of not less than 18 feet.*

**730-8. Disconnection.** For branch circuits and feeders see Section 240-18.

**730-9. Overcurrent Protection.**

- (a) For branch circuits as required in Article 210.
- (b) For feeders as required in Article 215.

**730-10. Wiring on Buildings.** Outside wiring on surfaces of buildings may be installed for circuits when not in excess of 600 volts as open conductors on insulating supports, as multiple-conductor cable approved for the purpose, as aluminum-sheathed cable or Type MI cable, in rigid metal conduit, in busways as provided in Article 364, or in electrical metallic tubing. Circuits of more than 600 volts shall be installed as provided for services in Section 230-101. Circuits for sign and outline lighting shall be installed as provided in Article 600.

**730-11. Circuit Exits and Entrances.** Where outside branch and feeder circuits exit from or enter into buildings the installation shall comply with those requirements of Article 230 which apply to service-entrance conductors.

**730-12. Open-Conductor Supports.** Open conductors shall be supported on glass or porcelain knobs, racks, brackets, or strain insulators, approved for the purpose.

**730-13. Festoon Supports.** In spans exceeding 40 feet the conductors shall be supported by a messenger wire supported by approved strain insulators. Conductors or messenger wires shall not be attached to any fire escape, downspout, or plumbing equipment.

**730-14. Open-Conductor Spacings.** Conductors shall conform to the following spacings:

- (a) **Open Conductors Exposed to the Weather.** As provided in Section 230-47.
- (b) **Open Conductors Not Exposed to Weather.** As provided in Section 230-48.
- (c) **Over 600 Volts.** As provided in Section 230-101(c).
- (d) **Separation from Other Circuits.** Open conductors shall be separated from open conductors of other circuits or systems by not less than 4 inches.
- (e) **Conductors on Poles.** Conductors on poles shall have a separation of not less than one foot except when placed on racks or brackets. Conductors supported on poles shall provide a horizontal climbing space not less than the following:

Power conductors, below communication conductors .....	30 inches
Power conductors alone or above communication conductors:	
Less than 300 volts .....	24 inches
Exceeding 300 volts .....	30 inches
Communication conductors below power conductors .....	same as power conductors
Communication conductors alone or above power conductors .....	no requirement

**730-15. Supports over Buildings.** See Section 230-25.

**730-16. Point of Attachment to Buildings.** See Section 230-26.

**730-17. Means of Attachment to Buildings.** See Section 230-27.

**730-18. Clearance from Ground.** Open conductors of not over 600 volts shall conform to the following:

10 feet — above finished grade, sidewalks or from any platform or projection from which they might be reached;

12 feet — over residential driveways and commercial areas such as parking lots and drive-in establishments not subject to truck traffic;

15 feet — over commercial areas, parking lots, agricultural or other areas subject to truck traffic;

18 feet — over public streets, alleys, roads, and driveways on other than residential property.

NOTE: For clearances of conductors of over 600 volts see National Electrical Safety Code, ANSI C2-1960.

**730-19. Clearances from Buildings for Conductors Not in Excess of 600 Volts.**

**(a) Clearance over Roof.** Open conductors shall have a clearance of not less than 8 feet from the highest point of roofs over which they pass with the following exceptions:

*Exception No. 1: Where the voltage between conductors does not exceed 300 volts and the roof has a slope of not less than 4 inches in 12 inches, the clearance may be not less than 3 feet.*

*Exception No. 2: Open conductors of 300 volts or less which do not pass over other than a maximum of 4 feet of the overhang portion of the roof for the purpose of terminating at a through-the-roof raceway or approved support may be maintained at a minimum of 18 inches from any portion of the roof over which they pass.*

For service-drop conductors see Section 230-22(a).

**(b) Horizontal Clearances.** Open conductors not attached to a building shall have a minimum horizontal clearance of 36 inches.

**(c) Final Spans.** Final spans of feeders or branch circuits to buildings which they supply or from which they are fed may be attached to the building but they shall be kept 3 feet from windows, doors, porches, fire escapes or similar locations.

**(d) Zone for Fire Ladders.** Where buildings exceed 3 stories, or 50 feet in height, overhead lines shall be arranged where practicable so that a clear space (or zone) at least 6 feet wide will be left either adjacent to the buildings or beginning not over 8 feet from them, to facilitate the raising of ladders when necessary for fire fighting.

Note: For clearance of conductors over 600 volts, consult National Electrical Safety Code, ANSI C2-1960.

**730-20. Mechanical Protection of Conductors.** Mechanical protection of conductors on buildings, structures or poles shall be as provided for services, Section 230-46.

**730-21. Conductors Entering Buildings.** Conductors entering buildings shall be as provided for services, Sections 230-44, 230-49, and 230-51.

**730-22. Multiple-Conductor Cables on Exterior Surfaces of Buildings.** Multiple-conductor cables on exterior surfaces of buildings shall be as provided for service cable, Section 230-50.

**730-23. Raceways on Exterior Surfaces of Buildings.** Raceways on exterior surfaces of buildings shall be made raintight and suitably drained.

**730-24. Underground Circuits.** Underground circuits shall be as provided for services, Sections 230-32 and 230-33.

**730-25. Outdoor Lighting Equipment — Lampholders.** Lampholders shall be of molded composition, or other approved material of the weatherproof type, and where they are attached as pendants shall have the connections to the circuit wires staggered. Where lampholders have terminals of a type which puncture the insulation and make contact with the conductors, they shall be attached only to conductors of the stranded type.

**730-26. Outdoor Lighting Equipment — Location of Lamps.** Location of lamps for outdoor lighting shall be below all live conductors, transformers, or other electrical equipment, unless clearances or other safeguards are provided for relamping operations, or unless the installation is controlled by a disconnecting means which can be locked in the open position.

## ARTICLE 750 — STAND-BY POWER GENERATION SYSTEMS

**750-1. Scope.** The provisions of this Article apply to the installation, operation, and maintenance of circuits, systems and equipment intended to supply on-site generated power to selected loads (other than those of Article 700, Emergency Systems), automatically or manually, in the event of failure of the normal source of electrical service.

Stand-by systems are generally installed to provide an alternate source of electrical energy to serve loads, such as heating and refrigeration systems, communications systems, industrial processes which, when stopped during any power outage, could cause discomfort, serious interruption of the process, or damage to the product or process or the like.

The systems covered by this Article shall consist only of those which are permanently installed in their entirety including the prime movers.

**750-2. Other Requirements.** All applicable requirements of this Code shall apply to the stand-by systems, except as modified by this Article.

**750-3. Equipment Approval.** All equipment shall be approved for the use intended.



**750-4. Tests.** The complete system after installation should be test operated as directed by the authority having jurisdiction.

**750-5. Generator Set.** A generator, driven by and connected to a permanently installed prime mover shall comprise the generator set.

**750-6. Capacity of the System.** The stand-by system shall have adequate capacity and rating for the operation of all equipment to be supplied at one time.

**750-7. Controls and Transfer Equipment.** Equipment shall be suitable for intended use and be so designed and installed as to prevent the inadvertent interconnection of normal and stand-by sources of supply in any operation of the transfer equipment.

A time-delay feature should be provided to avoid short-time operation of the stand-by system.

**750-8. Systems Protection.** Transfer equipment and wiring associated with the stand-by system shall be provided with suitably rated protective devices.

**750-9. Wiring.** The stand-by system wiring is not subject to the provisions of Section 700-17, and the wiring of this system may occupy the same raceways, boxes, cabinets, and panelboards with other wiring, except that the wiring shall not occupy the same raceways, boxes or cabinets as wiring for emergency systems.

## Chapter 8. Communication Systems

### ARTICLE 800 — COMMUNICATION CIRCUITS

#### A. General

**800-1. Scope.** The provisions of this Article shall apply to telephone, telegraph (except radio), district messenger, fire and burglar alarms and similar central station systems and to telephone systems not connected to a central station system but using similar type of equipment, methods of installation and maintenance.

Such protective measures as are essential to safeguard these systems under the various conditions to which they are subjected are outlined in these rules.

For detailed requirements for fire alarm, sprinkler, supervisory, or watchman systems, see the Standards of the National Fire Protection Association.\*

#### B. Protection

**800-2. Protective Devices.** A protector approved for the purpose shall be provided on each circuit run partly or entirely in aerial wire or aerial cable not confined within a block. Also, a protector approved for the purpose shall be provided on each circuit, aerial or underground, so located within the block containing the building served as to be exposed to accidental contact with light and power conductors operating at a potential exceeding 300 volts.

The word "block" as used in this Article shall be construed to mean a square or portion of a city, town, or village enclosed by streets and including the alleys so enclosed but not any street.

The word "exposed" as used in this Article means that the circuit is in such a position that in case of failure of supports or insulation, contact with another circuit may result.

**(a) Location.** The protector shall be located in, on or immediately adjacent to the structure or building served and as close as practicable to the point at which the exposed conductors enter or attach.

**(b) Hazardous Locations.** The protector shall not be located in any hazardous location as defined in Article 500, nor in the vicinity of easily ignitable material.

**(c) Protector Requirements.** The protector shall consist of an arrester connected between each line conductor and ground in an appropriate mounting. Protector terminals shall be marked to indicate line and ground as applicable.

**(1)** Fuseless type protectors may be used under any of the following conditions:

\* The NFPA standards on fire alarm and supervisory systems are published by the NFPA in the 1970 National Fire Codes, Vol. 7 and in separate pamphlet form by the NFPA (NFPA Nos. 71-1970, 72A-1967, 72B-1967, 72C-1967, 72D-1967, and 73-1967).

a. Where circuits enter a building through metallic-sheathed cable, or through a nonmetallic-sheathed cable having a metallic grounding shield between the sheath and the conductor assembly, provided the metallic sheath or shield of the cable is effectively grounded and the conductors in the cable shall safely fuse on all currents greater than the ampacity of the protector, and the protector grounding conductor.

b. Where insulated conductors in accordance with Section 800-11(c)(1) or (c)(2) are used to extend circuits to a building from a metallic-sheathed cable or from a nonmetallic-sheathed cable having a metallic grounding shield between the sheath and the conductor assembly provided the metallic sheath or shield is effectively grounded and the conductors in the cable or cable stub, or the connections between the insulated conductors and the exposed plant, shall safely fuse on all currents greater than the ampacity of the protector, the associated insulated conductors, and the protector grounding conductor.

c. Where insulated conductors, in accordance with Section 800-11(c)(1) or (c)(2) are used to extend circuits to a building from other than a grounded metallic-sheathed or shielded cable, provided (1) the protector is approved for this purpose, and (2) the protector grounding conductor is connected to a water pipe electrode or the grounding conductor or grounding electrode of a multigrounded neutral power system, and (3) the connections of the insulated conductors to the exposed plant, or the conductors of the exposed plant shall safely fuse on all currents greater than the ampacity of the protector, the associated insulated conductors, and the protector grounding conductor.

d. Where insulated conductors in accordance with Sections 800-11(c)(1) or (c)(2) are used to extend circuits aerially to a building from an unexposed buried or underground circuit.

Effectively grounded means permanently connected to earth through a ground connection of sufficiently low impedance and having sufficient ampacity to prevent the building up of voltages which may result in undue hazard to connected equipment or to persons.

(2) Where the requirements listed under Section 800-2(c)(1a) (1b) (1c) or (1d) are not fulfilled, fused-type protectors shall be used. Fused-type protectors shall consist of an arrester connected between each line conductor and ground, a fuse in series with each line conductor, and an appropriate mounting arrangement. Protector terminals shall be marked to indicate line, instrument, and ground, as applicable.

**800-3. Installation of Conductors.** Conductors from the protector to the equipment or, where no protector is required, conductors attached to the outside of, or inside the building shall comply with the following:

(a) **Separation from Other Conductors.** Conductors shall be separated from conductors of electric light and power circuits as follows:

(1) **Open Conductors.** Conductors shall be separated at least two inches from any light or power conductors or Class 1 signal or control circuits not in a raceway nor in metal-sheathed, metal-clad, nonmetallic-sheathed or Type UF cables unless permanently separated from the conductors of the other system by a continuous and firmly fixed nonconduc-

(800-3(a-1) continued)

tor, additional to the insulation on the wire, such as porcelain tubes or flexible tubing.

**(2) In Raceways and Boxes.** Communication conductors shall not be placed in any raceway, compartment, outlet box, junction box or similar fitting with conductors for light and power circuits or Class 1 signal and control circuits unless the conductors of the different systems are separated by a partition; provided that this shall not apply to conductors in outlet boxes, junction boxes or similar fittings or compartments where such conductors are introduced solely for power supply to communication equipment or for connection to remote-control equipment.

**(3) In Shafts.** Conductors may be run in the same shaft with conductors for light and power provided the conductors of the two systems are separated at least 2 inches, or where the conductors of either system are encased in noncombustible tubing. Where the lighting or power conductors are run in a raceway, or in metal-sheathed or metal-clad or nonmetallic-sheathed or Type UF cables, neither the 2-inch separation nor the noncombustible tubing is required.

**(b) Vertical Runs.** Conductors bunched together in a vertical run in a shaft shall have a fire-resistant covering capable of preventing the carrying of fire from floor to floor, except where conductors are encased in noncombustible tubing or are located in a fireproof shaft having fire stops at each floor.

The conductors referred to in this Section would ordinarily be insulated but the kind of insulation is not specified as reliance is placed on the protective device to stop all dangerous voltages and currents.

**(c) Prevention of Spread of Fire.** Installations shall be so made that the possible spread of fire through fire walls, fire partitions or fire-resistive floors is reduced to a minimum.

### C. Outside Conductors

**800-11. Overhead Conductors.** Overhead conductors entering buildings shall comply with the following:

**(a) On Poles.** Where communication conductors and light or power conductors are supported by the same pole, the following conditions shall be met:

**(1) Relative Location.** The conductors should preferably be located below the light or power conductors.

**(2) Attachment to Crossarms.** Conductors shall not be attached to a crossarm which carries light or power conductors.

**(3) Climbing Space.** The climbing space through signal conductors shall comply with the requirements of Section 730-14(e).

**(b) On Roofs.** Conductors passing over buildings shall be kept at least 8 feet above any roof which may be readily walked upon, except small auxiliary buildings such as garages and the like.

**(c) Circuits Requiring Protectors.** Circuits which require protectors (see Section 800-2) shall comply with the following:

(1) **Insulation, Single or Paired Conductors.** Each conductor, from the last outdoor support to the protector, shall have 30-mil rubber insulation, except that when such conductors are entirely within a block the insulation on the conductor may be less than 30 mils, but not less than 25 mils in thickness. In addition, the conductor, either individually or over the pair, shall be covered with a substantial fibrous covering or equivalent protection. Conductors approved for the purpose having rubber insulation of a thickness less than specified above, or having other kinds of insulation may be used.

(2) **Insulation, Cables.** Conductors within a cable of the metal-sheathed type, or within a cable having a rubber sheath of at least 30-mil thickness and covered with a substantial fibrous covering, may have paper or other suitable insulation. Where the metal or rubber sheath is omitted, each conductor shall be insulated as required in Section 800-11(c)(1), and the bunched conductors shall be covered with a substantial fibrous covering or equivalent covering.

(3) **On Buildings.** Open conductors shall be separated at least 4 inches from light or power conductors not in conduit or cable, unless permanently separated from conductors of the other system by a continuous and firmly fixed nonconductor additional to the insulation on the wires, such as porcelain tubes or flexible tubing. Open conductors exposed to accidental contact with light and power conductors operating at over 300 volts, and attached to buildings, shall be separated from woodwork by being supported on glass, porcelain or other insulating material approved for the purpose except that such separation is not required where fuses are omitted as provided for in Section 800-2(c)(1) or where conductors approved for the purpose are used to extend circuits to a building from a cable having a grounded metal sheath.

(4) **Entering Buildings.** Where a protector is installed inside the building, the conductors shall enter the building either through a non-combustible, nonabsorptive insulating bushing, or through a metal raceway. The insulating bushing may be omitted where the entering conductors (1) are in metal-sheathed cable, (2) pass through masonry, (3) are approved for the purpose and fuses are omitted as provided for in Section 800-2(c)(1), or (4) are approved for the purpose and are used to extend circuits to a building from a cable having a grounded metal sheath. Raceways or bushings shall slope upward from the outside or, where this cannot be done, drip loops shall be formed in the conductors immediately before they enter the building. Raceways shall be equipped with an approved service head. More than one conductor may enter through a single raceway or bushing. Conduits or other metallic raceways located ahead of the protector shall be grounded.

**800-12. Lightning Conductors.** Where practicable, a separation of at least 6 feet shall be maintained between open conductors of communication systems on buildings and lightning conductors.

#### **D. Underground Circuits**

**800-21. Underground Circuits.** Underground conductors of communication circuits entering buildings shall comply with the following:

(800-21 continued)

**(a) With Electric Light or Power Conductors.** Underground conductors in a duct, handhole, or manhole containing electric light or power conductors, shall be in a section separated from such conductors by means of brick, concrete, or tile partitions.

**(b) Underground Block Distribution.** Where the entire street circuit is run underground and the circuit within the block is so placed as to be free from liability of accidental contact with electric light or power circuits of over 300 volts, the insulation requirements of Section 800-11 (c)(1) and (c)(4) shall not apply, the conductors need not be placed on insulating supports and no bushings shall be required where the conductors enter the building.

### E. Grounding

**800-31. Grounding.** Equipment shall be grounded as follows:

**(a) Cable Sheath.** The metal sheath of aerial cables entering buildings which are exposed to contact with electric light or power conductors shall be grounded or shall be interrupted close to the entrance to the building by an insulating joint or equivalent device.

**(b) Protector Ground.** The protector ground shall comply with the following:

**(1) Insulation.** The grounding conductor shall have a 30-mil rubber insulation and shall be covered by a substantial fibrous covering. Conductors approved for the purpose having less than 30-mil rubber insulation or having other kinds of insulation may be used.

**(2) Size.** The grounding conductor shall not be smaller than No. 18 AWG copper or equivalent.

**(3) Run in Straight Line.** The grounding conductor shall be run in as straight a line as practicable to the grounding electrode.

**(4) Physical Damage.** Where necessary, the grounding conductor shall be guarded from physical damage.

**(5) Electrode.** The grounding conductor shall be connected as follows:

- a. To an available water pipe electrode, or
- b. To the power service conduit, service-equipment enclosure, or grounding electrode conductor where the grounded conductor of the power service is connected to a water-pipe electrode at the building, or
- c. Where the grounding means in (a) or (b) above are not available, to the service conduit, service-equipment enclosure, grounding electrode conductor or grounding electrode of the power service of a multigrounded neutral power system, or
- d. Where the grounding means in (a), (b) or (c) are not available, to (1) a concrete-encased electrode of not less than 20 feet of bare copper conductor not smaller than No. 4 encased by at least

2 inches of concrete and located within and near the bottom of a concrete foundation footing that is in direct contact with the earth, (2) an effectively grounded metal structure, or (3) to a ground rod or pipe driven into permanently damp earth. Steam or hot-water pipes, lightning-rod conductors or pipe or rod electrodes grounding other than multigrounded neutral power circuits shall not be employed as electrodes for protectors.

**(6) Electrode Connection.** The grounding conductor shall be attached to a pipe electrode by means of a bolted clamp to which the conductor is connected in an effective manner. Where a gas pipe electrode is used, connection shall be made between the gas meter and the street main. In every case the connection to the grounding electrode shall be made as close to the earth as practicable.

**(7) Bonding of Electrodes.** A bond not smaller than No. 6 copper or equivalent shall be placed between the communication and power grounding electrodes where the requirements of (5) above result in the use of separate electrodes. All separate grounding electrodes shall be bonded together. See Section 250-86.

## ARTICLE 810 — RADIO AND TELEVISION EQUIPMENT

### A. General

**810-1. Scope.** This Article shall apply to radio and television receiving equipment and to amateur radio transmitting and receiving equipment, but shall not apply to equipment and antennas used for coupling carrier current to power line conductors.

The authority enforcing this Code shall be freely consulted as to the specific methods to be followed in any case of doubt relative to installation of antenna conductors and the the National Electrical Safety Code, Part 5, be followed.

**810-2. Application of Other Articles.** Wiring from the source of power to and between devices connected to the interior wiring system shall comply with Chapters 1 to 4, inclusive, except as modified by Sections 640-3, 640-4 and 640-5. Wiring for radio-frequency and audio-frequency equipment and loud speakers shall comply with Article 640.

**810-3. Community Television Antenna.** The antenna shall comply with the requirements of this Article. The distribution system shall comply with Article 820.

**810-4. Radio Noise Suppressors.** Radio interference eliminators, interference capacitors or radio noise suppressors connected to power supply leads shall be of a type approved for the purpose. They shall not be exposed to physical damage.

### **B. Receiving Equipment Only**

#### **Antenna Systems — General**

**810-11. Material.** Antennas and lead-in conductors shall be of hard-drawn copper, bronze, aluminum alloy, copper-clad steel or other high-strength, corrosion-resistant material. Soft-drawn or medium-drawn copper may be used for lead-in conductors where the maximum span between points of support is less than 35 feet.

**810-12. Supports.** Outdoor antennas and lead-in conductors shall be securely supported. The antennas shall not be attached to the electrical service mast. They shall not be attached to poles or similar structures carrying electric light or power wires or trolley wires of more than 250 volts between conductors. Insulators supporting the antenna conductors shall have sufficient mechanical strength to safely support the conductors. Lead-in conductors shall be securely attached to the antennas.

**810-13. Avoidance of Contacts with Conductors of Other Systems.** Outdoor antennas and lead-in conductors from an antenna to a building shall not cross over electric light or power circuits and shall be kept well away from all such circuits so as to avoid the possibility of accidental contact. Where proximity to electric light and power service conductors of less than 250 volts between conductors cannot be avoided, the installation shall be such as to provide a clearance of at least 2 feet. It is recommended that antenna conductors be so installed as not to cross under electric light or power conductors.

**810-14. Splices.** Splices and joints in antenna spans shall be made with approved splicing devices or by such other means as will not appreciably weaken the conductors.

Soldering may ordinarily be expected to weaken the conductor. Therefore, the joint should be mechanically secure before soldering.

**810-15. Grounding.** Masts and metal structures supporting antennas shall be permanently and effectively grounded, without intervening splice or connection.

#### **Antenna Systems — Receiving Station**

##### **810-16. Size of Wire-Strung Antenna.**

(a) Outdoor antenna conductors for receiving stations shall be of a size not less than given in Table 810-16(a).

(b) **Self-Supporting Antennas.** Outdoor antennas, such as vertical rods or dipole structures, shall be of noncorrodible materials and of strength suitable to withstand ice and wind loading conditions, and shall be located well away from overhead conductors of electric light and power circuits of over 150 volts to ground so as to avoid the possibility of the antenna or structure falling into or making accidental contact with such circuits.



**810-17. Size of Lead-In.** Lead-in conductors from outside antennas for receiving stations, shall, for various maximum open span lengths, be of such size as to have a tensile strength at least as great as that of the conductors for antenna as specified in Section 810-16. Where the lead-in consists of two or more conductors which are twisted together or are enclosed in the same covering or are concentric, the conductor size shall, for various maximum open span lengths, be such that the tensile strength of the combination will be at least as great as that of the conductors for antennas as specified in Section 810-16.

**Table 810-16(a)**  
**Size of Receiving-Station Outdoor Antenna Conductors**

Material	Minimum Size of Conductors		
	When Maximum Open Span Length is Less than 35 feet	35 feet to 150 feet	Over 150 feet
Aluminum alloy, hard- drawn copper . . . . .	19	14	12
Copper-clad steel, bronze or other high strength material . . . . .	20	17	14

For very long span lengths larger conductors will be required, depending on the length of the span and the ice and wind loading.

**810-18. Clearances.**

**(a) On Buildings Outside.** Lead-in conductors attached to buildings shall be so installed that they cannot swing closer than 2 feet to the conductors of circuits of 250 volts or less between conductors, or 10 feet to the conductors of circuits of more than 250 volts between conductors, except that in the case of circuits not exceeding 150 volts between conductors, where all conductors involved are supported so as to insure permanent separation, the clearance may be reduced but shall not be less than 4 inches. The clearance between lead-in conductors and any conductor forming a part of a lightning rod system shall be not less than 6 feet unless the bonding referred to in Section 250-86 is accomplished.

**(b) Antennas and Lead-Ins — Indoors.** Indoor antennas and indoor lead-ins shall not be run nearer than 2 inches to conductors of other wiring systems in the premises unless:

- (1) such other conductors are in metal raceways or cable armor, or
- (2) unless permanently separated from such other conductors by a continuous and firmly fixed nonconductor such as porcelain tubes or flexible tubing.

**810-19. Electric Supply Circuits Used in Lieu of Antenna.** Where an electric supply circuit is used in lieu of an antenna, the device by which the radio receiving set is connected to the supply circuit shall be specially approved for the purpose.

### **Antenna Discharge Units**

**810-20. Antenna Discharge Units — Receiving Stations.** Each conductor of a lead-in from an outdoor antenna shall be provided with an antenna discharge unit approved for the purpose, except that where the lead-in conductors are enclosed in a continuous metallic shield the antenna discharge unit may be installed to protect the shield or may be omitted where the shield is permanently and effectively grounded. Antenna discharge units shall be located outside the building, or inside the building between the point of entrance of the lead-in and the radio set or transformers, and as near as practicable to the entrance of the conductors to the building. The antenna discharge unit shall not be located near combustible material nor in a hazardous location as defined in Article 500.

### **Grounding Conductors — General**

**810-21. Material.** The grounding conductor shall, unless otherwise specified, be of copper, aluminum, copper-clad steel, bronze, or other corrosion-resistant material.

**810-22. Insulation.** The grounding conductors may be uninsulated.

**810-23. Supports.** The grounding conductors shall be securely fastened in place and may be directly attached to the surface wired over without the use of insulating supports. Where proper support cannot be provided the size of the grounding conductor shall be increased proportionately.

**810-24. Mechanical Protection.** The grounding conductor shall be protected where exposed to physical damage or the size of the grounding conductor shall be increased proportionately to compensate for the lack of protection.

**810-25. Run in Straight Line.** The grounding conductor shall be run in as straight a line as practicable from the antenna mast and/or the antenna discharge unit to the grounding electrode.

**810-26. Grounding Electrode.** The grounding conductor shall be connected to a metallic underground water piping system as specified in Section 250-81. Where the building is not supplied with a water system the connection shall be made to the metal frame of the building when effectively grounded or to a grounding electrode as specified in Section 250-83. At a penthouse or similar location the ground conductor may be connected to a water pipe or rigid conduit.

### **Grounding Conductors — Receiving Stations**

**810-27. Inside or Outside Building.** The grounding conductor may be run either inside or outside the building.

**810-28. Size.** The grounding conductor shall be not smaller than No. 10 copper or No. 8 aluminum or No. 17 copper-clad steel or bronze.

**810-29. Common Ground.** A single grounding conductor may be used for both protective and operating purposes.

Where a single conductor is so used, the ground terminal of the equipment should be connected to the ground terminal of the protective device.

**C. Amateur Transmitting and Receiving Stations****Antenna System**

**810-51. Other Sections.** In addition to conforming to the requirements of Part C, antenna systems for amateur transmitting and receiving stations shall also comply with Sections 810-11 through 810-15.

**810-52. Size of Antenna.** Antenna conductors for amateur transmitting and receiving stations shall be of a size not less than given in Table 810-52.

**Table 810-52****Size of Amateur-Station Outdoor Antenna Conductors**

Material	Minimum Size of Conductors	
	When Maximum Open Span Length Is Less than 150 feet	Over 150 feet
Hard-drawn copper .....	14	10
Copper-clad steel, bronze or other high-strength material .....	14	12

For very long span length larger conductors will be required, depending on the span length and the ice and wind loadings.

**810-53. Size of Lead-In Conductors.** Lead-in conductors for transmitting stations shall, for various maximum span lengths, be of a size at least as great as that of conductors for antennas as specified in Section 810-52.

**810-54. Clearance on Building.** Antenna conductors for transmitting stations, attached to buildings, shall be firmly mounted at least 3 inches clear of the surface of the building on nonabsorptive insulating supports, such as treated pins or brackets, equipped with insulators having not less than 3-inch creepage and airgap distances. Lead-in conductors attached to buildings shall also conform to these requirements, except when they are enclosed in a continuous metallic shield which is permanently and effectively grounded. In this latter case the metallic shield may also be used as a conductor.

**810-55. Entrance to Building.** Except where protected with a continuous metallic shield which is permanently and effectively grounded, lead-in conductors for transmitting stations shall enter buildings by one of the following methods:

(a) Through a rigid, noncombustible, nonabsorptive insulating tube or bushing.

(b) Through an opening provided for the purpose in which the entrance conductors are firmly secured so as to provide a clearance of at least 2 inches.

(c) Through a drilled window pane.

**810-56. Protection Against Accidental Contact.** Lead-in conductors to radio transmitters shall be so located or installed as to make accidental contact with them difficult.

**810-57. Antenna Discharge Units — Transmitting Stations.** Each conductor of a lead-in for outdoor antenna shall be provided with an antenna discharge unit or other suitable means which will drain static charges from the antenna system.

*Exception No. 1: Where protected by a continuous metallic shield which is permanently and effectively grounded.*

*Exception No. 2: Where the antenna is permanently and effectively grounded.*

### **Grounding Conductors — General**

**810-58. Other Sections.** All grounding conductors for amateur transmitting and receiving stations shall comply with Sections 810-21 through 810-27.

**810-59. Size of Protective Ground.** The protective ground conductor for transmitting stations shall be as large as the lead-in, but not smaller than No. 10 copper, bronze, or copper-clad steel.

**810-60. Size of Operating Grounding Conductor.** The operating grounding conductor for transmitting stations shall be not less than No. 14 copper or its equivalent.

### **Interior Installation — Transmitting Stations**

**810-70. Clearance from Other Conductors.** Except as provided in Article 640, all conductors inside the building shall be separated at least 4 inches from the conductors of any other light or signal circuit unless separated therefrom by conduit or some firmly fixed nonconductor such as porcelain tubes or flexible tubing.

**810-71. General.** Transmitters shall comply with the following:

(a) **Enclosing.** The transmitter shall be enclosed in a metal frame or grille, or separated from the operating space by a barrier or other equivalent means, all metallic parts of which are effectually connected to ground.

(b) **Grounding of Controls.** All external metallic handles and controls accessible to the operating personnel shall be effectually grounded.

No circuit in excess of 150 volts between conductors should have any parts exposed to direct contact. A complete dead-front type of switchboard is preferred.

(c) **Interlocks on Doors.** All access doors shall be provided with interlocks which will disconnect all voltages in excess of 350 volts between conductors when any access door is opened.

(d) **Audio-Amplifiers.** Audio-amplifiers which are located outside the transmitter housing shall be suitably housed and shall be so located as to be readily accessible and adequately ventilated.

## ARTICLE 820 — COMMUNITY ANTENNA TELEVISION AND RADIO DISTRIBUTION SYSTEMS

### A. General

**820-1. Scope.** The provisions of this Article shall apply to coaxial cable distribution of radio-frequency signals typically employed in Community Antenna Television (CATV) systems. Where the wiring system employed is other than coaxial, the provisions of Article 800 — Communication Circuits shall apply.

The coaxial cable may be used to deliver low energy power to equipment directly associated with this radio-frequency distribution system provided the voltage is not in excess of 60 volts and where the current supply is from a transformer or other device having energy limiting characteristics.

**820-2. Material.** Coaxial cable used for the radio-frequency distribution system shall be suitable for the application.

### B. Protection

**820-3. Ground of Outer Conductive Shield of a Coaxial Cable.** Where coaxial cable is exposed to lightning or to accidental contact with lightning arrester conductors or power conductors operating at a potential exceeding 300 volts, the outer conductive shield of the coaxial cable shall be grounded at the building premises as close to the point of cable entry as practicable.

Where the outer conductive shield of a coaxial cable is grounded, no other protective devices are required.

### C. Installation of Cable

Coaxial cable installation for radio-frequency distribution shall comply with the following:

**820-4. Outside Conductors.** Prior to the point of grounding, as defined in Section 820-3.

(a) **On Poles.** On poles, the conductors should preferably be located below the light and power conductors and shall not be attached to a cross arm which carries light or power conductors.

(b) **Lead-in Clearance.** Lead-in or aerial-drop cables from a pole or other support including the point of initial attachment to a building or structure shall be kept away from electric light or power circuits so as to avoid the possibility of accidental contact. Where proximity to electric light and power service conductors cannot be avoided, the installation shall be such as to provide clearances of not less than 12 inches from light and power service drops.

(c) **Over Roofs.** Cables passing over buildings shall be at least 8 feet above any roof which is accessible for pedestrian traffic.

**(d) Between Buildings.** Cables extending between buildings, and also the supports or attachment fixtures shall be acceptable for the purpose, and shall have sufficient strength to withstand the loads to which they may be subjected, except that where cable does not have sufficient strength to be self-supporting, it shall be attached to a supporting messenger cable which together with the attachment fixtures or supports shall be acceptable for the purpose and shall have sufficient strength to withstand the loads to which they may be subjected.

**(e) On Buildings.** When attached to buildings, cables shall be securely fastened in such a manner that they shall be separated from other conductors as follows:

**(1) Light and Power.** The coaxial cable shall have a separation of at least 4 inches from light or power conductors not in conduit or cable, unless permanently separated from conductors of the other system by a continuous and firmly fixed nonconductor additional to the insulation on the wires.

**(2) Other Communication Systems.** Coaxial cable shall be installed so that there will be no unnecessary interference in the maintenance of the separate systems. In no case shall the conductors, cables, messenger strand or equipment of one system cause abrasion to the conductors, cable, messenger strand or equipment of any other system.

**(3) Lightning Conductors.** Where practicable, a separation of at least 6 feet shall be maintained between any coaxial cable and lightning conductors.

**820-5. Entering Buildings.** Coaxial cable shall slope upward from the outside where entering a building, or, where this is impracticable, drip loops shall be formed in the cable at the point of entrance.

**820-6. Conductors Inside Buildings.** Beyond the point of grounding, as defined in Section 820-3, cable installation shall comply with the following:

**(a) Light and Power.** Coaxial cable shall be separated at least two inches from any light or power conductors or Class 1 signal or control circuits not in a raceway nor in metal-sheathed, metal-clad, nonmetallic-sheathed or Type UF cables unless permanently separated from the conductors of the other system by a continuous and firmly fixed nonconductor, additional to the insulation on the wire, such as porcelain tubes or flexible tubing.

**(b) In Raceways and Boxes.** Coaxial cable shall not be placed in any raceway, compartment, outlet box, junction box or other enclosures with conductors for light and power circuits or Class 1 signal and control circuits unless the conductors of the different systems are separated by a permanent partition; provided that this shall not apply to conductors in outlet boxes, junction boxes or similar fittings or compartments where such conductors are introduced solely for power supply to the coaxial cable system distribution equipment or for power connection to remote control equipment.

**(c) In Shafts.** Coaxial cable may be installed in the same shaft with conductors for light and power provided the conductors of the two sys-

tems are separated at least 2 inches or where the conductors of either system are encased in noncombustible tubing.

Where the lighting or power conductors are run in a raceway, or in metal-sheathed or metal-clad or nonmetallic-sheathed or Type UF cables,<sup>2</sup> neither the 2-inch separation nor the noncombustible tubing is required.

**(d) Vertical Runs.** Conductors or coaxial cables bunched together in a vertical run in a shaft shall have a fire-resistant covering capable of preventing the carrying of flame from floor to floor except where conductors are encased in noncombustible tubing or are located in a fire-proof shaft having fire stops at each floor.

**(e) Other Conductors.** There is no specific separation requirement between Class 2 signal and control circuits, wired distribution system cables and communication cables or conductors other than the clearance necessary to prevent conflict or abrasion.

#### D. Underground Circuits

**820-7. Underground Coaxial Cable.** Underground coaxial cable entering buildings shall comply with the following:

**(a) With Light and Power Conductors.** Underground conductors in a duct, pedestal, handhole, or manhole containing electric light or power conductors shall be in a section permanently separated from such conductors by means of a suitable barrier.

#### E. Grounding

**820-8. Cable Grounding.** Coaxial cable shall be grounded as follows:

**(a) Ground Circuit.** The coaxial cable ground shall comply with the following:

**(1) Insulation.** The grounding conductor shall have a rubber or other suitable kind of insulation.

**(2) Material.** The ground conductor shall be copper or other corrosion-resisting conductive material, stranded or solid.

**(3) Size.** The grounding conductor shall not be smaller than No. 18 AWG; it shall have a conductivity approximately equal to that of the outer conductor of the coaxial cable.

**(4) Run.** The grounding conductor shall be run in as straight a line as practicable to the grounding electrode.

**(5) Physical Protection.** Where necessary, the grounding conductor shall be guarded from physical damage.

**(6) Electrode.** The grounding conductor shall preferably be connected to a water pipe electrode. Where a water pipe is not readily available and the grounded conductor of the power service is connected to the water pipe at the building, the grounding conductor may be connected to the power service conduit, service equipment enclosures, or grounding conductor of the power service. In the absence of a water pipe, connection may be made to an effectively grounded metallic structure, or to a ground rod or pipe driven into permanently damp earth,

(820-8(a-6) continued)

or a concrete-encased electrode of not less than 20 feet of bare copper conductor not smaller than No. 4 encased by at least 2 inches of concrete and located within and near the bottom of a concrete foundation footing that is in direct contact with earth. Steam or hot water pipes, or lightning rod conductors shall not be employed as grounding electrodes. A driven rod or pipe used for grounding power circuits shall not be used for grounding unless the driven rod or pipe is connected to the grounded conductor of a multigrounded neutral power system. The requirements for separate made electrodes for power and lighting system grounds, those for communication systems, and those for a lightning rod installation shall not prohibit the bonding together of all such made electrodes.

(7) **Electrode Connection.** The grounding conductor shall be attached to a pipe electrode by means of a bolted clamp to which the conductor is connected in an effective manner. In every case the connection to the grounding electrode shall be made as close to the earth as practicable.

(8) **Bonding of Electrodes.** A bond not smaller than No. 6 copper or equivalent shall be placed between the antenna systems and power grounding electrodes where the requirements of (6) above result in the use of separate electrodes. All separate grounding electrodes may be bonded together. See Section 250-86.

**820-9. Equipment Grounding.** Unpowered equipment and enclosures or equipment powered by the coaxial cable are deemed to be grounded when connected to the metallic cable shield.

#### F. General

**820-10. Prevention of Spread of Fire.** Installations shall be so made that the possible spread of fire through fire walls, fire partitions or fire-resistive floors is reduced to a minimum.



## Chapter 9 — Tables and Examples

### A. Tables

#### Notes to Tables

1. Tables 3A, 3B and 3C apply only to complete conduit or tubing systems and are not intended to apply to short sections of conduit or tubing used to protect exposed wiring from physical damage.

2. Equipment grounding conductors, when installed, shall be included when calculating conduit or tubing fill. The actual dimensions of the equipment grounding conductor (insulated or bare) may be used in the calculation.

3. When conduit nipples having a maximum length not to exceed 24 inches are installed between boxes, cabinets, and similar enclosures, the nipple may be filled to 60 percent of its total cross-sectional area, and Note 8 of Tables 310-12 through 310-15 does not apply to this condition.

4. For conductors not included in Chapter 9 use actual dimensions.

5. See Table 1 for allowable percentage of conduit or tubing fill.

**Table 1**  
**Percent of Cross Section**  
**of Conduit and Tubing for Conductors**  
**(See Table 2 for Fixture Wires)**

Number of Conductors	1	2	3	4	Over 4
All conductor types except lead-covered (new or rewiring)	53	31	40	40	40
Lead-covered conductors	55	30	40	38	35

Note 1. See Tables 3A, 3B and 3C for number of conductors all of the same size in trade sizes of conduit ½ inch through 6 inch.

Note 2. For conductors larger than 750 MCM or for combinations of conductors of different sizes use Tables 4 through 8, Chapter 9, for dimensions of conductors, conduit and tubing.

Note 3. Where the calculated number of conductors, all of the same size, includes a decimal fraction, the next higher whole number shall be used where this decimal is 0.8 or larger.

Note 4. When bare conductors are permitted by other Sections of this Code, the dimensions for bare conductors in Table 8 of Chapter 9 may be used.

Table 2  
Maximum Number of Fixture Wires in Trade Size of Conduit or Tubing  
(40 Percent Fill Based on Individual Diameters)

Conduit Trade Size (Inches)	1/2			3/4			1			1 1/4			1 1/2			2		
	18"	16	14	18	16	14	18	16	14	18	16	14	18	16	14	18	16	14
Wire Types																		
PTF, PTFE, PGFF, PGF, PFF, PF	23	18	14	40	31	24	65	50	39	115	90	70	157	122	95	257	200	156
TFEN, TFN	19	15		34	26		55	43		97	76		132	104		216	169	
SF-1	16			29			47			83			114			186		
SFF-1, FF-1, FFH-1	15			26			43			76			104			169		
CF	13	10	8	23	18	14	38	30	23	66	53	40	91	72	55	149	118	90
TF	11	10		20	18		32	30		57	53		79	72		129	118	
RFH-1, RF-1	11			20			32			57			79			129		
TFE	11	10		20	17		32	27		56	49		77	66		126	109	
AF	11	9	7	19	16	12	31	26	20	55	46	36	75	63	49	123	104	81
SFF-2	9	7	6	16	12	10	27	20	17	47	36	30	65	49	42	106	81	68
SF-2	9	8	6	16	14	11	27	23	18	47	40	32	65	55	43	106	90	71
FF-2, FFH-2	9	7		15	12		25	19		44	34		60	46		99	75	
RFH-2	7	5		12	10		20	16		36	28		49	38		80	62	
RF-2	7	6		12	10		20	16		36	29		49	40		80	65	

**Table 3A**  
**Maximum Number of Conductors in Trade Sizes of Conduit or Tubing**  
**(Based on Table 1, Chapter 9)**

Conduit Trade Size (Inches)		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	4 1/2	5	6
Type Letters	Conductor Size AWG, MCM													
TW, T, RUH, RRRW, THW, (14 thru 8) XXHHW	14	9	15	25	44	60	99	142	171	176				
	12	7	12	19	35	47	78	111	131	97	124			
	10	5	9	15	26	36	60	85						
	8	3	5	8	14	20	33	47	72					
RRHW and RHH (without outer covering), THW	14	6	10	16	29	40	65	93	143	192				
	12	4	8	13	24	32	53	76	117	157				
	10	4	6	11	19	26	43	61	95	127	163			
	8	1	4	6	11	15	25	36	56	75	96	121	152	
TW, T, THW, (6 thru 2), RUH, (6 thru 2), RRRW (6 thru 2), FEPB (6 thru 2), RRHW and RHH (with- out outer covering)	6	1	2	4	7	10	16	23	36	48	62	78	97	141
	4	1	1	3	5	7	12	17	27	36	47	58	73	106
	3	1	1	2	4	6	10	15	23	31	40	50	63	91
	2	1	1	2	4	5	9	13	20	27	34	43	54	78
	1	1	1	1	3	4	6	9	14	19	25	31	39	57
	0		1	1	2	3	5	8	12	16	21	27	33	49
	00		1	1	1	3	5	7	10	14	18	23	29	41
	000		1	1	1	2	4	6	9	12	15	19	24	35
	0000		1	1	1	1	3	5	7	10	13	16	20	29
	250			1	1	1	2	4	6	8	10	13	16	23
300			1	1	1	2	2	3	5	7	9	11	20	
350				1	1	1	1	3	4	6	8	10	14	
400				1	1	1	1	2	3	4	6	9	12	
500				1	1	1	1	1	3	4	6	7	11	
600						1	1	1	3	4	5	6	7	11
700						1	1	1	2	3	4	5	7	10
750						1	1	1	2	3	4	5	6	9

Table 3B  
Maximum Number of Conductors in Trade Sizes of Conduit or Tubing  
(Based on Table 1, Chapter 9)

Conduit Trade Size (Inches)		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	4 1/2	5	6
Type Letters	Conductor Size AWG, MCM													
THWN, FEP (14 thru 2), FEPB (14 thru 8),	14	13	24	39	69	94	154	164	160	125	160			
	12	10	18	29	51	70	114	104	93					
	10	6	11	18	32	44	73	60						
	8	3	6	10	19	26	42							
THHN, FEP (14 thru 2), FEPB (14 thru 8),	6	1	4	6	11	15	26	37	57	76	98	125	154	
	4	1	2	4	7	9	16	22	35	47	60	75	94	137
	3	1	1	3	6	8	13	19	29	39	51	64	80	116
	2	1	1	3	5	7	11	16	25	33	43	54	67	97
XHHW (4 thru 500MCM)	1	1	1	1	3	5	8	12	18	25	32	40	50	72
	0		1	1	3	4	7	10	15	21	27	33	42	61
	00		1	1	2	3	6	8	13	17	22	28	35	51
	000		1	1	1	3	5	7	11	14	18	23	29	42
	0000		1	1	1	2	4	6	9	12	15	19	24	35
	250			1	1	1	3	4	7	10	12	16	20	28
	300			1	1	1	3	4	6	8	11	13	17	24
	350			1	1	1	2	3	5	7	9	12	15	21
	400			1	1	1	1	3	5	6	8	10	13	19
	500				1	1	1	2	4	5	7	9	11	16
	600				1	1	1	1	3	4	5	7	9	13
	700					1	1	1	3	4	5	6	8	11
XHHW	750					1	1	1	2	3	4	6	7	11
	6	1	3	5	9	13	21	30	47	63	81	102	128	185
	600			1	1	1	1	1	3	4	5	7	9	13
	700				1	1	1	1	3	4	5	6	7	11
	750					1	1	1	2	3	4	6	7	10

**Table 3C**  
**Maximum Number of Conductors in Trade Sizes of Conduit or Tubing**  
 (Based on Table 1, Chapter 9)

Conduit Trade Size (Inches)		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	4 1/2	5	6
Type Letters	Conductor Size AWG, MCM													
RHW,	14	3	6	10	18	25	41	58	90	121	155			
	12	3	5	9	15	21	35	50	77	103	132			
	10	2	4	7	13	18	29	41	64	86	110	138		
	8	1	2	4	8	10	17	25	39	52	67	84	105	152
RHH (with outer covering)	6	1	1	2	5	6	11	15	24	32	41	51	64	93
	4	1	1	1	3	5	8	12	18	24	31	39	50	72
	3	1	1	1	3	4	7	10	16	22	28	35	44	63
	2	1	1	1	3	4	6	9	14	19	24	31	38	56
	1		1	1	1	3	5	7	11	14	18	23	29	42
	0		1	1	1	2	4	6	9	12	16	20	25	37
	00			1	1	1	3	5	8	11	14	18	22	32
	000			1	1	1	2	4	7	9	12	15	19	28
	0000			1	1	1	2	4	6	8	10	13	16	24
	250				1	1	1	3	5	6	8	11	13	19
	300				1	1	1	3	4	5	7	9	11	17
	350				1	1	1	2	4	5	6	8	10	15
	400				1	1	1	1	3	4	6	7	9	14
	500				1	1	1	1	3	4	5	6	8	11
	600					1	1	1	2	3	4	5	6	9
	700					1	1	1	1	3	3	4	6	8
	750						1	1	1	3	3	4	5	8

Tables 4 through 8, Chapter 9. Tables 4 through 8 give the nominal size of conductors and conduit or tubing recommended for use in computing size of conduit or tubing for various combinations of conductors. The dimensions represent average conditions only, and while variations will be found in dimensions of conductors and conduits of different manufacture, these variations will not affect the computation.

Table 4. Dimensions and Percent Area of Conduit and of Tubing  
Areas of Conduit or Tubing for the Combinations of Wires Permitted in Table 1, Chapter 9.

		Area—Square Inches								
Trade Size	Internal Diameter Inches	Not Lead Covered				Lead Covered				
		Total 100%	2 Cond. 31%	Over 2 Cond. 40%	1 Cond. 53%	1 Cond. 55%	2 Cond. 30%	3 Cond. 40%	4 Cond. 38%	Over 4 Cond. 35%
1/2	.622	.30	.09	.12	.16	.17	.09	.12	.11	.11
3/4	.824	.53	.16	.21	.28	.29	.16	.21	.20	.19
1	1.049	.86	.27	.34	.46	.47	.26	.34	.33	.30
1 1/4	1.380	1.50	.47	.60	.80	.83	.45	.60	.57	.53
1 1/2	1.610	2.04	.63	.82	1.08	1.12	.61	.82	.78	.71
2	2.067	3.36	1.04	1.34	1.78	1.85	1.01	1.34	1.28	1.18
2 1/2	2.469	4.79	1.48	1.92	2.54	2.63	1.44	1.92	1.82	1.68
3	3.068	7.38	2.29	2.95	3.91	4.06	2.21	2.95	2.80	2.58
3 1/2	3.548	9.90	3.07	3.96	5.25	5.44	2.97	3.96	3.76	3.47
4	4.026	12.72	3.94	5.09	6.74	7.00	3.82	5.09	4.83	4.45
4 1/2	4.506	15.94	4.94	6.38	8.45	8.77	4.78	6.38	6.06	5.56
5	5.047	20.00	6.20	8.00	10.60	11.00	6.00	8.00	7.60	7.00
6	6.065	28.89	8.96	11.56	15.31	15.89	8.67	11.56	10.98	10.11

**Table 5. Dimensions of Rubber-Covered and Thermoplastic-Covered Conductors**

Size AWG MCM	Types RF-2, RFH-2, RH, RHH,*** RHW,*** SF-2		Types TF, T, THW,† TW, RUH,** RUW**		Types TFN, THHN, THWN		Types **** FEP, FEPB, TFE, PF, PGF, PTF		Type XHHW	
	Approx. Diam. Inches	Approx. Area Sq. In.	Approx. Diam. Inches	Approx. Area Sq. In.	Approx. Diam. Inches	Approx. Area Sq. In.	Approx. Diam. Inches	Approx. Area Sq. Inches	Approx. Diam. Inches	Approx. Area Sq. In.
Col. 1	Col. 2	Col. 3	Col. 4	Col. 5	Col. 6	Col. 7	Col. 8	Col. 9	Col. 10	Col. 11
18	.146	.0167	.106	.0088	.089	.0064	.081	.0052	...	....
16	.158	.0196	.118	.0109	.100	.0079	.092	.0066	...	....
14	30 mils .171	.0230	.131	.0135	.105	.0087	.105 .105	.0087 .0087		
14	45 mils .204*	.0327*	...	....	...	....	...	....		
14	.....	....	.162†	.0206†	...	....	...	....		
12	30 mils .188	.0278	.148	.0172	.122	.0117	.121 .121	.0115 .0115	.129	.0131
12	45 mils .221*	.0384*	...	....	...	....	...	....		
12	.....	....	.179†	.0251†	...	....	...	....	.146	.0167
10	.....	....	.168	.0224	.153	.0184	.142 .142	.0159 .0159	.166	.0216
10	.....	....	.199†	.0311†	...	....	...	....		
8	.....	.0760	.228	.0408	.201	.0317	.189 .169	.0280 .0225		
8	.....	....	.259†	.0526†	...	....	...	....	.224	.0394
6	.397	.1238	.323	.0819	.257	.0519	.244 .302	.0467 .0716	.282	.0625
4	.452	.1605	.372	.1087	.328	.0845	.292 .350	.0669 .0962	.328	.0845
3	.481	.1817	.401	.1263	.356	.0995	.320 .378	.0803 .1122	.356	.0995
2	.513	.2067	.433	.1473	.388	.1182	.352 .410	.0973 .1316	.388	.1182
1	.588	.2715	.508	.2027	.450	.1590	.420 ...	.1385 ....	.450	.1590
0	.629	.3107	.549	.2367	.491	.1893	.462 ...	.1676 ....	.491	.1893
00	.675	.3578	.595	.2781	.537	.2265	.498 ...	.1974 ....	.537	.2265
000	.727	.4151	.647	.3288	.588	.2715	.560 ...	.2463 ....	.588	.2715
0000	.785	.4840	.705	.3904	.646	.3278	.618 ...	.2999 ....	.646	.3278

Table 5-Continued

Size AWG MCM	Types RF-2, RFH-2, RH, RHH,*** RHW,*** SF-2		Types TF, T, THW,† TW, RUH,** RUW**		Types TFN, THHN, THWN		Types **** FEP, FEPB, PF, PGF, TFE, PTF		Type XHHW	
	Approx. Diam. Inches	Approx. Area Sq. In.	Approx. Diam. Inches	Approx. Area Sq. In.	Approx. Diam. Inches	Approx. Area Sq. In.	Approx. Diam. Inches	Approx. Area Sq. In.	Approx. Diam. Inches	Approx. Area Sq. In.
Col. 1	Col. 2	Col. 3	Col. 4	Col. 5	Col. 6	Col. 7	Col. 8	Col. 9	Col. 10	Col. 11
250	.868	.5917	.788	.4877	.716	.4026	...	....	.716	.4026
300	.933	.6837	.843	.5581	.771	.4669	...	....	.771	.4669
350	.985	.7620	.895	.6291	.822	.5307	...	....	.822	.5307
400	1.032	.8365	.942	.6969	.869	.5931	...	....	.869	.5931
500	1.119	.9834	1.029	.8316	.955	.7163	...	....	.955	.7163
600	1.233	1.1940	1.143	1.0261	1.058	.8792	...	....	1.073	.9043
700	1.304	1.3355	1.214	1.1575	1.129	1.0011	...	....	1.145	1.0297
750	1.339	1.4082	1.249	1.2252	1.163	1.0623	...	....	1.180	1.0936
800	1.372	1.4784	1.282	1.2908	1.196	1.1234	...	....	1.210	1.1499
900	1.435	1.6173	1.345	1.4208	1.259	1.2449	...	....	1.270	1.2668
1000	1.494	1.7531	1.404	1.5482	1.317	1.3623	...	....	1.330	1.3893
1250	1.676	2.2062	1.577	1.9532	...	....	...	....	1.500	1.7672
1500	1.801	2.5475	1.702	2.2748	...	....	...	....	1.620	2.0612
1750	1.916	2.8895	1.817	2.5930	...	....	...	....	1.740	2.3779
2000	2.021	3.2079	1.922	2.9013	...	....	...	....	1.840	2.6590

\* The dimensions of Types RHH and RHW.

\*\* No. 14 to No. 2.

† Dimensions of THW in sizes 14 to 8. No. 6 THW and larger is the same dimension as T.

\*\*\* Dimensions of RHH and RHW without outer covering are the same as THW.

No. 18 to No. 8, solid; No. 6 and larger, stranded.

\*\*\*\* In Columns 8 and 9 the values shown for sizes No. 1 thru 0000 are for TFE only. The right-hand values in Columns 8 and 9 are for FEPB only.



**Table 6. Dimensions of Lead-Covered Conductors**

Types RL, RHL, and RUL

Size AWG-MCM	Single Conductor		Two Conductor		Three Conductor	
	Diam. Inches	Area Sq. Ins.	Diam. Inches	Area Sq. Ins.	Diam. Inches	Area Sq. Ins.
14	.28	.062	.28 x .47	.115	.59	.273
12	.29	.066	.31 x .54	.146	.62	.301
10	.35	.096	.35 x .59	.180	.68	.363
8	.41	.132	.41 x .71	.255	.82	.528
6	.49	.188	.49 x .86	.369	.97	.738
4	.55	.237	.54 x .96	.457	1.08	.916
2	.60	.283	.61 x 1.08	.578	1.21	1.146
1	.67	.352	.70 x 1.23	.756	1.38	1.49
0	.71	.396	.74 x 1.32	.859	1.47	1.70
00	.76	.454	.79 x 1.41	.980	1.57	1.94
000	.81	.515	.84 x 1.52	1.123	1.69	2.24
0000	.87	.593	.90 x 1.64	1.302	1.85	2.68
250	.98	.754	.....	.....	2.02	3.20
300	1.04	.85	.....	.....	2.15	3.62
350	1.10	.95	.....	.....	2.26	4.02
400	1.14	1.02	.....	.....	2.40	4.52
500	1.23	1.18	.....	.....	2.59	5.28

The above cables are limited to straight runs or with nominal offsets equivalent to not more than two quarter bends.

Note — No. 14 to No. 8, solid conductors; No. 6 and larger, stranded conductors. Data for 30-mil insulation not yet compiled.

**Table 7. Dimensions of Asbestos-Varnished-Cambric  
Insulated Conductors**  
Types AVA, AVB, and AVL

Size AWG MCM	Type AVA		Type AVB		Type AVL	
	Approx. Diam. Inches	Approx. Area Sq. Ins.	Approx. Diam. Inches	Approx. Area Sq. Ins.	Approx. Diam. Inches	Approx. Area Sq. Ins.
14	.245	.047	.205	.033	.320	.080
12	.265	.055	.225	.040	.340	.091
10	.285	.064	.245	.047	.360	.102
8	.310	.075	.270	.057	.390	.119
6	.395	.122	.345	.094	.430	.145
4	.445	.155	.395	.123	.480	.181
2	.505	.200	.460	.166	.570	.255
1	.585	.268	.540	.229	.620	.300
0	.625	.307	.580	.264	.660	.341
00	.670	.353	.625	.307	.705	.390
000	.720	.406	.675	.358	.755	.447
0000	.780	.478	.735	.425	.815	.521
250	.885	.616	.855	.572	.955	.715
300	.940	.692	.910	.649	1.010	.800
350	.995	.778	.965	.731	1.060	.885
400	1.040	.850	1.010	.800	1.105	.960
500	1.125	.995	1.095	.945	1.190	1.118
550	1.165	1.065	1.135	1.01	1.265	1.26
600	1.205	1.140	1.175	1.09	1.305	1.34
650	1.240	1.21	1.210	1.15	1.340	1.41
700	1.275	1.28	1.245	1.22	1.375	1.49
750	1.310	1.35	1.280	1.29	1.410	1.57
800	1.345	1.42	1.315	1.36	1.440	1.63
850	1.375	1.49	1.345	1.43	1.470	1.70
900	1.405	1.55	1.375	1.49	1.505	1.78
950	1.435	1.62	1.405	1.55	1.535	1.85
1000	1.465	1.69	1.435	1.62	1.565	1.93

Note: No. 14 to No. 8, solid, No. 6 and larger, stranded; except AVL where all sizes are stranded.

**Varnished-Cambric Insulated Conductors**  
**Type V**

The insulation thickness for varnished-cambric conductors, Type V, is the same as for rubber-covered conductors, Type RHH, except for No. 8 which has 45-mil insulation for varnished-cambric, and 60-mil insulation for rubber-covered conductors. See Table 310-2(b). Table 3C may, therefore, be used for the number of varnished-cambric insulated conductors in a conduit or tubing.

Table 8. Properties of Conductors

Size AWG MCM	Area Cir. Mils	Concentric Lay Stranded Conductors		Bare Conductors		D. C. Resistance Ohms/M Ft. At 25°C. 77°F.		
		No. Wires	Diam. Each Wire Inches	Diam. Inches	*Area Sq. Inches	Copper		Alumini- um
						Bare Cond.	Tin'd. Cond.	
18	1620	Solid	.0403	.0403	.0013	6.51	6.79	10.7
16	2580	Solid	.0508	.0508	.0020	4.10	4.26	6.72
14	4110	Solid	.0641	.0641	.0032	2.57	2.68	4.22
12	6530	Solid	.0808	.0808	.0051	1.62	1.68	2.66
10	10380	Solid	.1019	.1019	.0081	1.018	1.06	1.67
8	16510	Solid	.1285	.1285	.0130	.6404	.659	1.05
6	26240	7	.0612	.184	.027	.410	.427	.674
4	41740	7	.0772	.232	.042	.259	.269	.424
3	52620	7	.0867	.260	.053	.205	.213	.336
2	66360	7	.0974	.292	.067	.162	.169	.266
1	83690	19	.0664	.332	.087	.129	.134	.211
0	105600	19	.0745	.372	.109	.102	.106	.168
00	133100	19	.0837	.418	.137	.0811	.0843	.133
000	167800	19	.0940	.470	.173	.0642	.0668	.105
0000	211600	19	.1055	.528	.219	.0509	.0525	.0836
250	250000	37	.0822	.575	.260	.0431	.0449	.0708
300	300000	37	.0900	.630	.312	.0360	.0374	.0590
350	350000	37	.0973	.681	.364	.0308	.0320	.0505
400	400000	37	.1040	.728	.416	.0270	.0278	.0442
500	500000	37	.1162	.813	.519	.0216	.0222	.0354
600	600000	61	.0992	.893	.626	.0180	.0187	.0295
700	700000	61	.1071	.964	.730	.0154	.0159	.0253
750	750000	61	.1109	.998	.782	.0144	.0148	.0236
800	800000	61	.1145	1.030	.833	.0135	.0139	.0221
900	900000	61	.1215	1.090	.933	.0120	.0123	.0197
1000	1000000	61	.1280	1.150	1.039	.0108	.0111	.0177
1250	1250000	91	.1172	1.289	1.305	.00863	.00888	.0142
1500	1500000	91	.1284	1.410	1.561	.00719	.00740	.0118
1750	1750000	127	.1174	1.526	1.829	.00616	.00634	.0101
2000	2000000	127	.1255	1.630	2.087	.00539	.00555	.00885

\* Area given is that of a circle having a diameter equal to the over-all diameter of a stranded conductor.

The values given in the Table are those given in Handbook 100 of the National Bureau of Standards except that those shown in the 8th column are those given in Specification B33 of the American Society for Testing and Materials, and those shown in the 9th column are those given in Standard No. S-19-81 of the Insulated Power Cable Engineers Association and Standard No. WC3-1964 of the National Electrical Manufacturers Association.

The resistance values given in the last three columns are applicable only to direct current. When conductors larger than No. 4/0 are used with alternating current the multiplying factors in Table 9, Chapter 9 should be used to compensate for skin effect.

**Table 9. Multiplying Factors for Converting DC Resistance to 60-Hertz AC Resistance**

Size		Multiplying Factor			
		For Nonmetallic Sheathed Cables in Air or Nonmetallic Conduit		For Metallic Sheathed Cables or all Cables in Metallic Raceways	
		Copper	Aluminum	Copper	Aluminum
Up to	3 AWG	1.	1.	1.	1.
	2	1.	1.	1.01	1.00
	1	1.	1.	1.01	1.00
	0	1.001	1.000	1.02	1.00
	00	1.001	1.001	1.03	1.00
	000	1.002	1.001	1.04	1.01
	0000	1.004	1.002	1.05	1.01
	250 MCM	1.005	1.002	1.06	1.02
	300 MCM	1.006	1.003	1.07	1.02
	350 MCM	1.009	1.004	1.08	1.03
	400 MCM	1.011	1.005	1.10	1.04
	500 MCM	1.018	1.007	1.13	1.06
	600 MCM	1.025	1.010	1.16	1.08
	700 MCM	1.034	1.013	1.19	1.11
	750 MCM	1.039	1.015	1.21	1.12
	800 MCM	1.044	1.017	1.22	1.14
	1000 MCM	1.067	1.026	1.30	1.19
	1250 MCM	1.102	1.040	1.41	1.27
	1500 MCM	1.142	1.058	1.53	1.36
	1750 MCM	1.185	1.079	1.67	1.46
	2000 MCM	1.233	1.100	1.82	1.56

## B. Examples

**Selection of Conductors.** In the following examples, the results are generally expressed in amperes. To select conductor sizes refer to Tables 310-12 through 310-15 and the Notes that pertain to such tables.

**Voltage.** For uniform application of the provisions of Articles 210, 215 and 220 a nominal voltage of 115 and 230 volts shall be used in computing the ampere load on the conductor.

**Fractions of an Ampere.** Except where the computations result in a major fraction of an ampere (larger than 0.5), such fractions may be dropped.

**Ranges.** For the computation of the range loads in these examples Column A of Table 220-5 has been used. For optional methods, see Columns B and C of Table 220-5.

### Example No. 1. Single-Family Dwelling

Dwelling has a floor area of 1500 sq. ft. exclusive of unoccupied cellar, unfinished attic, and open porches. It has a 12-kw range.

**Computed Load** (see Section 220-4)

General Lighting Load:

1500 sq. ft. at 3 watts per sq. ft. = 4500 watts.

**Minimum Number of Branch Circuits Required** (see Section 220-3)

General Lighting Load:

$4500 \div 115 = 39.1$  amperes: or three 15-ampere 2-wire circuits; or two 20-ampere 2-wire circuits

Small Appliance Load: Two 2-wire 20-ampere circuits (Section 220-3(b) )

Laundry Load: One 2-wire 20-ampere circuit (Section 220-3(b) )

**Minimum Size Feeders Required** (see Section 220-4)

Computed Load

General Lighting .....	4500	watts
Small Appl. Load .....	3000	watts
Laundry .....	<u>1500</u>	watts
Total (without range) .....	9000	watts
3000 watts at 100% .....	3000	watts
9000 — 3000 = 6000 watts at 35% =	<u>2100</u>	watts
Net computed load (without range)	5100	watts
Range Load (see Table 220-5) .....	<u>8000</u>	watts
Net computed load (with range)	13,100	watts

For 115/230-volt 3-wire system feeders,  $13,100 \div 230 = 57$  amperes

Net computed load exceeds 10 kw. so service conductors shall be 100 amperes (see Section 230-41, Exception No. 1).

**Example No. 1(a). Single-Family Dwelling**

Same conditions as Example No. 1, plus addition of one 6-ampere 230-volt room air-conditioning unit and three 12-ampere 115-volt room air-conditioning units. See Article 422, Part F.

From Example No. 1, feeder current is 57 amperes (3 wire, 230 volt)

Line A	Neutral	Line B	
57		57	amperes from Example No. 1
6		6	one 230-volt air cond. motor
12		12	two 115-volt air cond. motors
—		12	one 115-volt air cond. motor
3		3	25% of largest motor (Section 430-24)
78		90	amperes per line

**Example No. 1(b). Single-Family Dwelling  
Optional Calculation for Single-Family Dwelling (Section 220-7)**

Dwelling has a floor area of 1500 sq. ft. exclusive of unoccupied cellar, unfinished attic and open porches. It has a 12-kw range, a 2.5-kw water heater, a 1.2-kw dishwasher, 9 kw of electric space heating installed in five rooms, a 5-kw clothes dryer, and a 6-amp. 230-volt room air-conditioning unit.

Air conditioner kw is  $6 \times 230 \div 1000 = 1.38$  kw

1.38 kw is less than the connected load of 9 kw of space heating; therefore, the air conditioner load need not be included in the service calculation (see Section 220-4(l) ).

1500 sq. ft. at 3 watts .....	4.5 kw
Two 20-amp. appliance outlet circuits at 1500 watts each .....	3.0 kw
Laundry circuit .....	1.5 kw
Range (at nameplate rating) .....	12.0 kw
Water heater .....	2.5 kw
Dishwasher .....	1.2 kw
Space heating .....	9.0 kw
Clothes dryer .....	5.0 kw
	38.7 kw

First 10 kw at 100% = 10.00 kw

Remainder at 40% ( $28.7 \text{ kw} \times .4$ ) = 11.48 kw

Calculated load for service size 21.48 kw = 21,480 watts

$21,480 \div 230 = 93$  amperes

Therefore, this dwelling may be served by a 100-ampere service.

**Example No. 1(c). Single-Family Dwelling  
Optional Calculation for Single-Family Dwelling (See Section 220-7)**

Dwelling has a floor area of 1,500 sq. ft. exclusive of unoccupied cellar, unfinished attic and open porches. It has two 20-ampere small appliance circuits, one 20-ampere laundry circuit, two 4-kw wall-mounted ovens, one 5.1-kw counter-mounted cooking unit, a 4.5-kw water heater, a 1.2-kw dishwasher, a 5-kw combination clothes washer and dryer, six 7-ampere 230-volt room air-conditioning units and a 1.5-kw permanently installed bathroom space heater.

Air conditioning kw calculation

Total amperes $6 \times 7 =$	42.00 amperes
25% of largest motor $.25 \times 7 =$	1.75 amperes
	43.75 amperes

$43.75 \times 230 \div 1000 = 10.1$  kw of air-conditioner load

(Example 1(c) Continued Next Page)

**Example No. 1(c) (Continued)****Load included at 100%**

Air conditioning .....	10.1kw
Space heater (omit, see Section 220-4(l) )	

**Other Load**

	kW
1,500 sq. ft. at 3 watts .....	4.5
Two 20-amp small appliance circuits	
at 1500 watts .....	3.0
Laundry circuit .....	1.5
2 ovens .....	8.
1 cooking unit .....	5.1
Water heater .....	4.5
Dishwasher .....	1.2
Washer/dryer .....	5.0
Total other load .....	32.8

1st 10 kw at 100% ..... 10.0 kw

Remainder at 40% ( $22.8 \text{ kw} \times .4$ ) ..... 9.12 kw

Total calculated load ..... 29.22 kw = 29,220 watts  
 $29,220 \div 230 = 127$  amperes (service rating)

**Example No. 2. Small Roadside Fruitstand with No Show Windows**

A small roadside fruitstand with no show windows has a floor area of 150 square feet. The electrical load consists of general lighting and a 1,000-watt flood light. There are no other outlets.

**Computed Load (Section 220-4)****\*General Lighting**

150 sq. ft. at 3 watts/sq. ft.  $\times 1.25 = 562$  watts

(3 watts/sq. ft. for stores)

$562 \text{ watts} \div 115 = 4.88$  amperes

One 15-ampere 2-wire branch circuit required (Section 220-3)

**Minimum Size Service Conductor Required (Section 230-41 Exception No. 2)**

Computed load ..... 562 watts

Floodlight load ..... 1000 watts

Total load ..... 1562 watts

$1562 \div 115 = 13.6$  amperes

Use No. 8 service conductor (Section 230-41, Exception No. 2)

Use a 30-ampere service switch or breaker (Section 230-71(a), Exception No. 2)

**Example No. 3. Store Building**

A store 50 feet by 60 feet, or 3,000 square feet, has 30 feet of show window.

**Computed Load (Section 220-4)****\*General lighting load:**

3,000 square feet at 3 watts per square foot  $\times 1.25$  ..... 11,250 watts

**\*\*Show window lighting load:**

30 feet at 200 watts per foot ..... 6,000 watts

**Minimum Number of Branch Circuits Required (Section 220-3)**

\*\*\*General lighting load:  $11,250 \div 230 = 49$  amperes for 3 wire, 115/230 volts;  
 or 98 amperes for 2 wire, 115 volts:

*(Example 3 Continued Next Page)*

**Example No. 3 (Continued)**

Three 30-ampere, 2-wire; and one 15-ampere, 2-wire circuits; or  
 Five 20-ampere, 2-wire circuits; or  
 Three 20-ampere, 2-wire, and three 15-ampere, 2-wire circuits; or  
 Seven 15-ampere, 2-wire circuits; or  
 Three 15-ampere, 3-wire, and one 15-ampere, 2-wire circuits.

Special lighting load (show window): (Sections 220-2 Exception No. 1 and 220-4(c)):  $6,000 \div 230 = 26$  amperes for 3-wire, 115/230 volts; or 52 amperes for 2-wire, 115 volts:

Four 15-ampere, 2-wire circuits; or  
 Three 20-ampere, 2-wire circuits; or  
 Two 15-ampere, 3-wire circuits.

**Minimum Size Feeders (or Service Conductors) Required (Section 215-2):**

For 115/230-volt, 3-wire system:

Ampere load:  $49 \text{ plus } 26 = 75$  amperes. (Section 220-2):

For 115-volt system:

Ampere load:  $98 \text{ plus } 52 = 150$  amperes. (Section 220-2):

\* The above examples assume that the entire general lighting is a continuous load and the load is therefore increased by 25 percent in accordance with Section 220-2. The 25 percent increase is not applicable to any portion of the load that is not continuous.

\*\* If show window load is computed as per Section 220-2, the unit load per outlet shall be increased 25 percent.

\*\*\* The load on each general lighting branch circuit shall not exceed 80 percent of the branch-circuit rating (Section 210-23b).

**Example No. 4. Multi-Family Dwelling**

Multi-family dwelling having a total floor area of 32,000 square feet with 40 apartments.

Meters in two banks of 20 each and individual sub-feeders to each apartment.

One-half of the apartments are equipped with electric ranges of not exceeding 12 kw each.

Area of each apartment is 800 square feet.

Laundry facilities on premises available to all tenants. Add no circuit to individual apartment. Add 1,500 watts for each laundry circuit to house load and add to the example as a "house load."

**Computed Load for Each Apartment (Article 220):**

General lighting load:

800 square feet at 3 watts per square foot ..... 2,400 watts

Special appliance load:

Electric range ..... 8,000 watts

**Minimum Number of Branch Circuits Required for Each Apartment**

(Section 220-3):

General lighting load:  $2,400 \div 115 = 21$  amperes or two 15-ampere, 2-wire circuits; or two 20-ampere, 2-wire circuits.

Small appliance load: Two 2-wire circuits of No. 12 wire. (See Section 220-3 (b)).

Range circuit:  $8,000 \div 230 = 35$  amperes or a circuit of two No. 8's and one No. 10 as permitted by Section 210-19(c).

*(Example 4 Continued Next Page)*



**Example No. 4 (Continued)****Minimum Size Sub-Feeder Required for Each Apartment (Section 215-2):**

Computed load (Article 220):

General lighting load .....	2,400 watts
Small appliance load, two 20-ampere circuits .....	3,000 watts

Total computed load (without ranges) .....	5,400 watts
--	-------------

Application of Demand Factor:

3,000 watts at 100% .....	3,000 watts
2,400 watts at 35% .....	840 watts

Net computed load (without ranges) .....	3,840 watts
--	-------------

Range load .....	8,000 watts
------------------	-------------

Net computed load (with ranges) .....	11,840 watts
---------------------------------------	--------------

For 115/230-volt, 3-wire system (without ranges):

Net computed load,  $3,840 \div 230 = 16.7$  amperes.

Size of each sub-feeder (see Section 215-2).

For 115/230-volt, 3-wire system (with ranges):

Net computed load,  $11,840 \div 230 = 51.5$  amperes.

Sub-feeder Neutral:

Lighting and small appliance load .....	3,840 watts
---	-------------

Range load, 8,000 watts at 70% (see Section 220-4(e)) .....	5,600 watts
---	-------------

Net computed load (neutral) .....	9,440 watts
-----------------------------------	-------------

 $9,440 \div 230 = 41$  amperes**Minimum Size Feeders Required from Service Equipment to Meter Bank**

(For 20 Apartments—10 with Ranges):

Total Computed Load:

Lighting and small appliance load, $20 \times 5,400$ .....	108,000 watts
--	---------------

Application of Demand Factor:

3,000 watts at 100% .....	3,000 watts
---------------------------	-------------

105,000 watts at 35% .....	36,750 watts
----------------------------	--------------

Net computed lighting and small appliance load .....	39,750 watts
--	--------------

Range load, 10 ranges (less than 12 kw; Col. A, Table 220-5) .....	25,000 watts
--	--------------

Net computed load (with ranges) .....	64,750 watts
---------------------------------------	--------------

For 115/230-volt, 3-wire system:

Net computed load,  $64,750 \div 230 = 282$  amperes.

Feeder Neutral:

Lighting and small appliance load .....	39,750 watts
---	--------------

Range load: 25,000 watts at 70% (see Section 220-4(e)) .....	17,500 watts
--	--------------

Computed load (neutral) .....	57,250 watts
-------------------------------	--------------

 $57,250 \div 230 = 249$  amperes.

Further Demand Factor (Section 220-4(e)):

200 amperes at 100%	= 200 amperes
---------------------	---------------

49 amperes at 70%	= 34 amperes
-------------------	--------------

Net computed load (neutral) .....	234 amperes
-----------------------------------	-------------

**Minimum Size Main Feeder (or Service Conductors) Required**

(For 40 Apartments—20 with Ranges):

Total Computed Load:

Lighting and small appliance load, $40 \times 5,400$ .....	216,000 watts
--	---------------

*(Example 4 Continued Next Page)*

Example No. 4 (Continued)

Application of Demand Factor:

3,000 watts at 100% .....	3,000 watts
117,000 watts at 35% .....	40,950 watts
96,000 watts at 25% .....	24,000 watts

Net computed lighting and small appliance load .....	67,950 watts
Range load, 20 ranges (less than 12 kw, Col. A, Table 220-5)	35,000 watts

Net computed load ..... 102,950 watts  
For 115/230-volt, 3-wire system:  
Net computed load,  $102,950 \div 230 = 448$  amperes.

Feeder Neutral:

Lighting and small appliance load .....	67,950 watts
Range load, 35,000 watts at 70% (see Section 220-4(e) ) ....	24,500 watts

Computed load (neutral) ..... 92,450 watts  
 $92,450 \div 230 = 402$  amperes.

Further Demand Factor (see Section 220-4(e) ):

200 amperes at 100%	= 200 amperes
202 amperes at 70%	= 141 amperes

Net computed load (neutral) ..... 341 amperes  
See Tables 310-12 through 310-15, Notes 8 and 10.

Example No. 4(a). Optional Calculation for Multi-Family Dwelling

Multi-family dwelling equipped with electric cooking and space heating or air conditioning and having a total floor area of 32,000 square feet with 40 apartments.

Meters in two banks of 20 each plus house metering and individual sub-feeders to each apartment.

Each apartment is equipped with an electric range of 8-kW nameplate rating, four 1.5-kW separately controlled 230-volt electric space heaters, and a 2.5-kW 230-volt electric water heater.

A common laundry facility is available to all tenants (Section 210-22(b), Exception No. 1).

Area of each apartment is 800 square feet.

Computed Load for each apartment (Article 220)

General Lighting Load:

800 square ft. at 3 watts per sq. ft. ....	2400 watts
Electric range .....	8000 watts
Electric heat 6 kw .....	6000 watts
(or air conditioning if larger)	
Electric water heater .....	2500 watts

Minimum Number of Branch Circuits Required for Each Apartment

General lighting load  $2400 \text{ watts} \div 115 = 21$  amperes or two 15-ampere 2-wire circuits or two 20 amp 2-wire circuits.

Small appliance load: Two 2-wire circuits of No. 12 (See Section 220-3(b) )

Range circuit  $8000 \text{ watts} \times 80\% \div 230 = 28$  amperes on a circuit of three No. 10 as permitted in Column C of Table 220-5

Space Heating  $6000 \text{ watts} \div 230 = 26$  amperes

No. of circuits (See Section 220-3(a))

(Example 4(a) Continued Next Page)

**Example No. 4(a) (Continued)****Minimum Size Sub-Feeder required for each Apartment (Section 215-2)**

Computed load (Article 220):

General lighting load .....	2400 watts
Small appliance load, two 20-amp circuits .....	3000 watts
Total computed load (without range and space heating) .....	5400 watts

Application of Demand Factor:

3000 watts at 100% .....	3000 watts
2400 watts at 35% .....	840 watts

Net computed load (without range and space heating) ....	3840 watts
Range load .....	6400 watts
Space heating Section 220-4(f) .....	6000 watts
Water heater .....	2500 watts

Net computed load for individual apartment ..... 18,740 watts

For 115/230-volt 3-wire system

Net computed load  $18,740 \div 230 = 81$  amperes

Sub-Feeder Neutral (Section 220-4(e) )

Lighting and small appliance load .....	3840 watts
Range load 6400 watts at 70% (see Section 220-4(e) ) .....	4480 watts
Space and water heating (no neutral) 230 volt .....	0 watts

Net computed load (neutral) ..... 8320 watts

 $8320 \div 230 = 36$  amperes**Minimum Size Feeder Required from Service Equipment to Meter Bank for 20 Apartments**

Total Computed Load:

Lighting and small appliance load $20 \times 5400$ ....	108,000 watts
Water and space heating load $20 \times 8500$ .....	170,000 watts
Range load $20 \times 8000$ .....	160,000 watts

Net computed load (20 apartments) ..... 438,000 watts

Net Computed using Optional Calculation (Table 220-9)

 $438,000 \times .38$  ..... 166,440 watts $166,440 \div 230 = 724$  amperes

Feeder Neutral

Lighting and small appliance load	
$108,000 \times 38\%$ (Table 220-9) = .....	41,040 watts
Range load $8000 \times 20 = 160,000$ watts	
$160,000 \times 38\%$ (Table 220-9) .....	60,800 watts

computed load (neutral) ..... 101,840 watts

 $101,840 \div 230 = 443$  amperes**Minimum Size Mains Feeder Required (less house load)**

(For 40 Apartments)

Total Computed Load:

Lighting and small appliance load $40 \times 5400$ ....	216,000 watts
Water and space heating $40 \times 8500$ .....	340,000 watts
Range load $40 \times 8000$ .....	320,000 watts

Net computed load (40 apartments) ..... 876,000 watts

Net computed using Optional Calculation (Table 220-9)

 $876,000 \times 28\%$  ..... 245,280 watts $245,280 \div 230 = 1066$  amperes

(Example 4(a) Continued Next Page)

**Example No. 4(a) (Continued)**

Feeder Neutral

Lighting and small appliance load  $40 \times 5400 \times 28\%$ 

(Table 220-9) ..... 60,480 watts

Range load  $8000 \times 40 \times 28\%$  (Table 220-9) ... 89,600 watts

Computed load (neutral) ..... 150,080 watts

 $150,080 \div 230 = 653$  amperes

Add to obtain size of service conductors, the entire house load including laundry circuit(s) in accordance with applicable Sections of Article 220.

**Example No. 5. Calculation of Feeder Neutral**

(See Section 220-4)

The following example illustrates the method of calculating size of a feeder neutral for the computed load of a 5-wire, 2-phase system, where it is desired to modify the load in accordance with provisions of Section 220-4.

An installation consisting of a computed load of 250 amperes connected between the feeder neutral and each ungrounded feeder conductor.

Feeder Neutral (maximum unbalance of load  $250 \text{ amp.} \times 140\% = 350$  amperes):

200 amperes (first) at 100% = 200 amperes

150 amperes (excess) at 70% = 105 amperes

Computed load

305 amperes

**Example No. 6. Maximum Demand for Range Loads**

Table 220-5, Column A applies to ranges not over 12 kw. The application of Note 1 to ranges over 12 kw (and not over 27 kw) is illustrated in the following examples:

**A. Ranges all of same rating.**

Assume 24 ranges each rated 16 kw.

From Column A the maximum demand for 24 ranges of 12 kw rating is 39 kw.

16 kw exceeds 12 kw by 4.

 $5\% \times 4 = 20\%$  (5% increase for each kw in excess of 12). $39 \text{ kw} \times 20\% = 7.8 \text{ kw increase.}$  $39 + 7.8 = 46.8 \text{ kw: value to be used in selection of feeders.}$ **B. Ranges of unequal rating.**

Assume 5 ranges each rated 11 kw.

2 ranges each rated 12 kw.

20 ranges each rated 13.5 kw.

3 ranges each rated 18 kw.

 $5 \times 12 = 60$  Use 12 kw for range rated less than 12. $2 \times 12 = 24$  $20 \times 13.5 = 270$  $3 \times 18 = 54$ 30408 kw $408 \div 30 = 13.6 \text{ kw (average to be used for computation)}$ *(Example 6 Continued Next Page)*

**Example No. 6 (Continued)**

From Column A the demand for 30 ranges of 12 kw rating is  $15 + 30 = 45$  kw.

13.6 exceeds 12 by 1.6 (use 2.).

$5\% \times 2 = 10\%$  (5% increase for each kw in excess of 12).

$45 \text{ kw} \times 10\% = 4.5 \text{ kw increase.}$

$45 + 4.5 = 49.5 \text{ kw} = \text{value to be used in selection of feeders.}$

**Example No. 7. Ranges on a 3-Phase System**

(Section 220-4(j))

Thirty ranges rated at 12 kw each are supplied by a 3-phase, 4-wire, 120/208-volt feeder, 10 ranges on each phase.

As there are 20 ranges connected to each ungrounded conductor, the load should be calculated on the basis of 20 ranges (or in case of unbalance, twice the maximum number between any two phase wires) since diversity applies only to the number of ranges connected to adjacent phases and not the total.

The current in any one conductor will be one-half the total watt load of two adjacent phases divided by the line-to-neutral voltage. In this case, 20 ranges, from Table 220-5, will have a total watt load of 35,000 watts for two phases; therefore, the current in the feeder conductor would be:

$$17,500 \div 120 = 146 \text{ amperes.}$$

On a 3-phase basis the load would be:

$$3 \times 17,500 = 52,500 \text{ watts}$$

and the current in each feeder conductor—

$$\frac{52,500}{208 \times 1.73} = 146 \text{ amperes}$$

**Example No. 8. Motors, Conductors, and Overcurrent Protection**

(See Sections 430-22, 430-24, 430-32, 430-52, 430-62, and Tables 430-150, and 430-152).

Determine the conductor size, the motor-running overcurrent protection, the branch-circuit protection, and the feeder protection, for one 25-h.p. squirrel-cage induction motor (full-voltage starting, service factor 1.15, Code letter F), and two 30-h.p. wound-rotor induction motors (40°C rise), on a 460-volt, 3-phase, 60-hertz supply.

**Conductor Loads**

The full-load current of the 25-h.p. motor is 34 amperes (Table 430-150). A full-load current of 34 amperes  $\times 1.25 = 42.5$  amperes (Section 430-22). The full-load current of the 30-h.p. motor is 40 amperes (Table 430-150). A full-load current of 40 amperes  $\times 1.25 = 50$  amperes (Section 430-22).

The feeder ampacity will be 125 percent of 40 plus 40 plus 34, or 124 amperes (Section 430-24).

**Overcurrent Protection**

**Running.** The 25-h.p. motor, with full-load current of 34 amperes, must have running overcurrent protection of not over 42.5 amperes. The 30-h.p. motor with full-load current of 40 amperes must have running overcurrent protection of not over 50 amperes.

*(Example 8 Continued Next Page)*

**Example No. 8 (Continued)**

**Branch Circuit.** The branch circuit of the 25-h.p. motor must have branch-circuit overcurrent protection of not over 300 percent for a nontime-delay fuse (Table 430-152) or  $3.00 \times 34 = 102$  amperes. The next larger size standard fuse is 110 amperes. (See Section 430-52.)

For the 30-h.p. motor the branch-circuit overcurrent protection is 150 percent (Table 430-152) or  $1.50 \times 40 = 60$  amperes. Where the maximum value of overcurrent protection is not sufficient to start the motor the value for a nontime-delay fuse may be increased to 400 percent (Section 430-52 Exception (a) ).

**Feeder Circuit.** The maximum rating of the feeder overcurrent protection device is based on the sum of the largest branch-circuit protective device (110-ampere fuse) plus the sum of the full-load currents of the other motors or  $110 \text{ plus } 40 \text{ plus } 40 = 190$  amperes. The nearest standard fuse which does not exceed this value is 175 amperes.




SAMUEL GRONICH  
Member, Electrical Contractor  
Chairman




V. CARLISLE SMITH  
Member, Representative of a  
National Organization of  
Professional Chemical Engineers  
Clerk




FREDERICK J. LAWSON  
Member, Representative of a  
National Organization of  
Electrical Engineers




JOSEPH W. MANNIX  
Member, Inspector of Wires



FREDERICK W. JOHNSON  
Member, Representative of a  
National Organization of  
Mechanical Engineers




JOSEPH B. CORLETO  
Member, Representative of  
Owners of Buildings Subject to  
Chapter 143, G.L.




EDWARD B. CALLAHAN  
Member  
Head of a Fire Department



WILLIAM H. CHAFFEE  
Member, Representative of a  
National Organization of  
Fire Underwriters



WILLIAM H. MORK  
Member, Representative of  
Blasting Association




JOSEPH G. SNEIDER  
Member Ex-Officio  
State Fire Marshal


NOV 9 11 27 AM '72  
SECRETARY OF STATE  
PUBLIC RECORDS DIVISION

Approved as to matters of form:

ROBERT H. QUINN  
Attorney General


By:   
Assistant Attorney General

Received on




JOHN F. KEHOE, JR.  
Commissioner of Public Safety

Deposited with the Secretary of the  
Commonwealth on November 9, 1972  
in accordance with the provisions of  
General Laws (as amended), Chapter 22,  
Section 14; Chapter 143, Section 3L,  
Chapter 30, Section 37 and Chapter 30A,  
Section 5.



JOHN F. KEHOE, JR.  
Commissioner of Public Safety

A true copy, Attest:



JOHN F. KEHOE, JR.  
Commissioner of Public Safety





# I N D E X

- AC and DC Conductors in Same Enclosures**, 300-3(a)
- AC-DC, General-Use Snap Switches**  
 Definitions, Switches, Art. 100  
 Marking, 380-15  
 Motors, 430-83, Ex. 1  
 Ratings, Type loads, 380-14  
 Signs, 600-2(b)
- AC-DC Resistance Conversion**, Table 9, Chap. 9
- AC Metal-Clad Cable**, (see Metal-Clad Cable and Art. 334)
- AC Systems**  
 Conductor to be grounded, 250-25  
 Grounding Connections for, 250-23  
 Grounding of, 250-5  
 In same metallic enclosures, 300-20
- Access and Working Space, Electrical Equipment**  
 Over 600 volts, 710-D  
 Not over 600 volts, 110-16
- Accessible, Readily Accessible**  
 Definitions, Art. 100  
 Junction, pull, and outlet boxes, 370-19  
 Sealing fittings (see also Hazardous locations)  
 Splices and taps in auxiliary gutters, 374-8(a)  
 Splices and taps in wireways, 362-6  
 Structural raceways, 357-9  
 Transformers and vaults, 450-2  
 Transformers, signs, outline lighting, 600-32(e)  
 Unfinished attics, roof spaces, knob-and-tube wiring, 324-8(b)
- Aerial Cable**, Art. 342 (see Nonmetallic Extensions)
- Air-Conditioning and Refrigerating Equipment**, Art. 440  
 Branch-Circuit  
 Conductors, 440-D  
 Ampacity Determination of, 440-5  
 Combination Loads, for, 440-34  
 General, 440-31  
 Multimotor equipment, for, 440-35  
 Several Motor-Compressors, for, 440-33  
 Single Motor-Compressor, for, 440-32  
 Ratings, 440-C  
 Equipment, for, 440-22(b)  
 General, 440-21  
 Individual Motor-Compressor, for, 440-22(a)  
 Selection Current  
 Definition, 440-3(c) Note  
 Marking on Nameplate, 440-3(c)  
 Controllers for, 440-41(a-b)  
 Marking, 440-4  
 Disconnecting Means, 440-B  
 Cord-Connected as, 440-13  
 Horsepower Rating of, 440-12  
 Locked-Rotor Current Rating of, 440-12(a-d)  
 Nameplate Requirements, 440-3  
 Overload Protection, 440-F
- Air-Conditioning, etc. (Continued)**  
 Application and Selection of, 440-52  
 Branch-Circuit Conductors, for, 440-52(b)  
 General, 440-51  
 Motor-Compressors, for, 440-52  
 On General-Purpose Circuits, 440-54  
 Rated-Load Current  
 Definition, 440-3(a) Note  
 Marking on Nameplate, 440-3(a)  
 Room Air Conditioners, 422-40, 440-22(b), Exc. 1  
 Single Machine, When Considered, 440-7
- Air-Conditioning Units, Room**, 422-F  
 Branch-circuit requirements, 422-42  
 Definition and nameplate marking, 422-40, 440-22(b), Exc. 1  
 Disconnecting means, 422-43  
 Grounding, 422-41
- Aircraft Hangars**, Art. 513
- Air Plenums**, Wiring in, 300-22
- Airport Runways**, Underground Conductors, buried, 710-3(b), Ex. 2
- Alarm, Signal**, Remote-Control, Low-energy, Low-Voltage Circuits, Art. 725 (see also Hazardous Locations)
- Alarms**, Fire and Burglar, Art. 800
- Alternators**, (Generators) Art. 445
- Aluminum Conductors** (see also Conductors)  
 In concrete and earth, 300-5(b) (see also Rigid Metal Conduit)
- Aluminum Sheathed Cable** (Type ALS), Art. 331
- Aluminum Siding**, 250-44 (Note)
- Ampacities**  
 Bus-bars, copper, aluminum, in auxiliary gutters, 374-6  
 Conductors, Tables 310-12 thru 310-15  
 Crane and hoist conductors, Table 610-14(a)  
 Fixture Wires, Table 402-4  
 Flexible Cords, Table 400-9(b)
- Anesthetics**, Flammable, Art. 517-E (see also Hazardous Locations)
- Antenna Discharge Systems**, 810-20
- Antenna Systems, Radio-Television**, Art. 810  
 Community TV & Radio Distribution Systems, Art. 820
- Appliance(s)** (see also Motors, Art. 430), Art. 422  
 Branch-circuit calculations, 220-3  
 Branch circuits, definition, Art. 100  
 Branch circuits for, 210-24  
 Control and protection, 422-D  
 Cords, (see Cords, Flexible)  
 Definition, Art. 100  
 Disconnecting means, 422-20, 422-26  
 Feeder calculations for, 220-4  
 Fixed, Definition, Art. 100  
 Grounding, fixed and portable, 250-E, 550-9, 551-22

**Appliance(s)** (*Continued*)

- Hazardous locations, (see Hazardous Locations)
- Household cooking appliances
  - Demand loads for, Table 220-5
- Installation, 422-C
- Load calculations, 220-3, 220-4, Table 220-5
- Marking, 422-E
- Mobile Homes, in, 550-5(b-c), 550-7
- Motor-operated, load, 210-23
- Overcurrent protection, single, 210-20(b), 422-27(e)
- Overcurrent protection, general, 422-27
- Portable, definition, Art. 100
- Recreational Vehicles, in, 551-7
- Stationary, definition, Art. 100
- Terminals, identification, 200-10(e-f)

**Approval, Approved**

- Definition, Art. 100
- Equipment and Materials, 90-7, 90-8, 110-2, 500-1, 500-2

**Arc Lamps**

- General, 410-51
- Portable
  - Motion Picture Studios, 530-17
  - Stage Equipment, 520-61

**Arcing Parts, Enclosure of** (see also Enclosures)

- General, 110-18
- Motors, 430-14(b)

**Arc Welder(s)**, Art. 630**Arc-Welder Motors**, 630-C

- Ampacities of Conductors, Table 430-22 (a-Exception)
- Nameplate Marking, 630-24

**Arenas**, Art. 520

- Emergency Lighting, Systems for, Art. 700

**Armored Cable**, Art. 334 (see Metal-clad Cable)**Armories**, Art. 520

- Emergency Lighting Systems for, Art. 700

**Arresters, Lightning**, Art. 280 (see also Antenna Discharge Systems, 810-20)**Askarel**

- Definition, Art. 100
- Transformers, 450-23

**Assembly Halls**, Art. 520

- Emergency Lighting, Art. 700

**Atmospheric Groups** (see Hazardous Locations)**Attachment Plugs** (Caps) (see also Hazardous Locations)

- Construction of, 410-52(d)
- Definition, Art. 100
- Flexible Cord, on, 400-16
- Grounding Type, 410-55

**Attics**

- Knob and Tube, 324-8
- Metal-Clad Cable, 334-13
- Nonmetallic Sheathed Cable, 336-9
- Open Wiring, 320-13

**Auditoriums**, Art. 520

- Emergency Lighting, Art. 700

**Automatic**, Definition, Art. 100**Autotransformers**

- Ballast, Electric-Discharge Lighting Systems, 410-76
- Branch Circuits, 200-4
- Motor Starting, 430-82(b)

**Auxiliary Gutters**, Art. 374

- Ampacities, bare and insulated conductors, 374-6
- Clearance, bare live parts, 374-7
- Construction, installation, 374-9
- Covers, 374-4
- Elevator uses, 620-35
- Extension beyond equipment, 374-2
- Number of conductors, 374-5
- Sound recording, similar equipment, 640-4
- Splices, taps, 374-8
- Supports, 374-3

**Auxiliary Source**

- Emergency Systems, 700-11

**Ballasts**, Electric Discharge Lamps, 410-74

- (a), 410-75
- Protection, in fluorescent fixtures, 410-71 (e)

**Bare Conductor(s)**

- Ampacities, Note 4, Tables 310-12 thru 310-15
- Contact conductors, cranes and hoists, 610-C
- Definition, Art. 100
- Dimensions and resistance, Table 8, Chap. 9
- Sizing conduits for, Note 4 to Table 1, Ch. 9
- Underground ducts, conduits, grounded neutral, 230-30, Exc.

**Basement** (Cellars)

- Metal-clad cable, 334-12(c)
- Nonmetallic sheathed cable, 336-8

**Batteries, Storage** (see Storage Batteries)**Battery Charging Equipment** (see also Hazardous Locations)**Bell Circuits**, Art. 725**Bends** (see Wiring system involved)**Boatyards**, see Marinas and Boatyards, Art. 555**Bonding**, 250-G

- Grounding-type receptacles, 250-74
- Hazardous locations (see Hazardous Locations)
- Jumpers, 250-79
- Loosely jointed raceways, 250-77
- Other enclosures, 250-75
- Piping systems, 250-80
- Receptacles, at, 250-74
- Service equipment, 250-71, 250-72
- Service raceway, flexible metal conduit, 230-63(c)

**Bored Holes Through Studs, Joists**, 300-8(a)**Bowling Alleys**, Art. 520

- Emergency Lighting Systems, Art. 700

**Boxes**, Outlet, Switch, Pull, and Junction, Art. 370 (see also Hazardous Locations, Junction Boxes)

- Accessibility, 370-19
- Concealed Work, 370-14
- Conductors, number in box, 370-6
- Construction specifications, 370-C
- Covers, 370-15, 370-18(c), 370-21
- Cutout
  - Definition, Art. 100
  - Installation, Art. 373
- Damp locations, 370-5
- Depth, 370-14
- Exposed extensions, 370-12
- Floor, for receptacles, 370-17
- Gas pipes, fastened to, 370-16
- Grounding, 250-E, 250-114, 300-9

**Boxes (Continued)**

- Insulating (see nonmetallic)
- Junction, pull, size, 370-18(a)
- Lighting outlets, 370-17, 410-C, 410-16
- Metallic, 370-4
- Nonmetallic, 324-9, 336-12, 370-3, 370-7(c), 370-23
- Portable, in theaters, 520-62
- Remote Control, signal circuits, 725-42(a-2)
- Repairing plaster around, 370-11
- Round, 370-2
- Secured, 300-11, 370-13
- Snap switches over 300 volts not ganged, 380-8
- Unused openings, closed, 370-8
- Vertical raceway runs, 300-19
- Wall, 370-10
- Wet locations, 370-5
- Where required, 300-15

**Branch Circuits, Art. 210, 220**

- Air conditioners, 422-42, 440-D
- Busways, as branch circuits
  - Length, 364-13
  - Overcurrent protection, 364-11
  - Rating, 364-12
- Calculation of loads, 220-2, Part B, Chap. 9
- Definition, Art. 100
- General provisions, 210-A
- Individual, definition, Art. 100
- Infrared lamps, 422-15
- Maximum load, 210-23
- Mobile homes, 550-5
- Motor, on individual branch circuit, 430-B
- Multiwire, definition, Art. 100
- Outside and feeders, Art. 730
- Overcurrent protection, 210-20, 240-5
- Permissible loads, 210-24
- Recreational Vehicles, 551-7
- Table of requirements for, Table 210-25
- Taps from, 210-19(c), 210-25, 240-5, Ex. 2 and 6
- Through fixtures, 410-11, 410-26
- Two or more outlets on, 210-24
- Voltage, permitted rating, 210-6
- Voltage drop, 210-6(d)
- X-ray equipment, 660-3, 660-5

**Building, Definition, Art. 100****Building Wire (see Conductors)****Bulk Storage Plants, Art. 515****Burglar Alarm Systems, Art. 800****Bushing**

- Generators, 445-9
- Insulating, Lampholders, Attached to flexible cord, 410-24
- Motors, 430-13
- Outlet boxes and fittings, 370-22
- Rigid Metal Conduit, 346-8
- Use in lieu of box or terminal fitting, 300-16(b)

**Busways, Art. 364**

- Branch circuits, 364-11
- Branches from, 364-7
- Dead ends closed, 364-5
- Extension thru walls and floors, 364-4
- Length, as branch circuits, 364-13
- Marking, 364-14
- Overcurrent protection, 364-8, 364-9, 364-12
- Reduction in size, 364-10
- Support, 364-3
- Use, 364-2

**Cabinets and Cutout Boxes, Art. 373**

- Construction specifications, 373-B
- Damp, wet locations, 373-2
- Definitions, Art. 100
- Deflection of conductors, 373-6
- Insulation at bushings, 373-6(b)
- In walls, 373-3
- Switch enclosures, splices, taps, 373-8
- Unused openings, 373-4
- Wiring space, 373-9

**Cablebus, Art. 365**

- Conductors, 365-3
- Overcurrent Protection, 365-5
- Terminations, 365-8
- Fittings, 365-7
- Grounding, 365-9
- Marking, 365-10
- Support, 365-6
- Conductor, 365-3(d)
- Use, 365-2

**Cable(s) (see also Heating Cable)**

- Border Lights, Theaters, Assembly Halls, 520-44(b)
- Communication, Remote-control, Signal Circuits, 725-7
- Continuous, outlet to outlet, fitting to fitting, 300-12
- Flat, Assemblies, Art. 363
- Metal-clad, Art. 334
- Mineral Insulated-Metal Sheathed, Art. 330
- Nonmetallic Sheathed, Art. 336
- Nonmetallic Extension, Art. 342
- Secured, 300-11, 370-7(b), (c)
- Service
  - Definition, Art. 100
  - Entrance, Art. 338
  - Shielded Nonmetallic, Art. 337
  - Splices in Boxes, 300-15
  - Stage, 530-18(a)
  - Through studs, joists, rafters, 300-8
  - Underground, 230-D, 300-7, 310-6
  - Underground Feeder and Branch Circuit, Art. 339
- Underplaster Extensions, Art. 344

**Cable End Fittings, changing from cable to knob and tube, 300-16(a)****Cable Trays (see Continuous Rigid Cable Supports)****Calculations (see Loads)****Canopies**

- Boxes and Fittings, 370-15
- Lighting Fixtures,
  - Conductors, Space for, 410-10
  - Cover
    - At boxes, 410-12
    - Combustible Finishes, Covering required between Canopy and Box, 410-13
- Live parts exposed, 410-3

**Caps (see Attachment Plug)****Capacitors, Art. 460 (see also Hazardous Locations)**

- Connections at Services, 230-73
- Draining Charge, 460-6
- Induction, Dielectric Heating, 665-26
- X-ray Equip., 660-16

**Capacity, Interrupting, General, 110-9****Cartridge Fuses, 240-F**

- Disconnection, 240-18

**Cellars (see Basement)****Cellular Concrete Floor Raceways, Art. 358**

- Connection to Cabinets, 358-4

**Cellular Concrete Raceways** (Continued)

Discontinued Outlets, 358-11  
Header Ducts, 358-3  
Inserts, 358-7  
Junction Boxes, 358-5  
Markers, 358-6  
Number of Conductors, 358-9  
Size of Conductors, 358-8  
Splices, 358-10  
Use, 358-2

**Cellular Metal Floor Raceways**, Art. 356

Connection to Cabinets, 356-11  
Discontinued Outlets, 356-7  
General, 356-12  
Inserts, 356-10  
Junction Boxes, 356-9  
Markers, 356-8  
Number of Conductors, 356-5  
Size of Conductors, 356-4  
Use, 356-2

**Churches** (see Public Assemblies)**Cinder Fill**

Metal conduits and electrical metallic tubing, in or under, 346-3, 348-1

**Circuit(s)**

Branch (see Branch Circuits)  
Burglar Alarm, Art. 800  
Central Station, Art. 800  
Communication, Art. 800  
Definition, Art. 100  
Control, Definition, 430-71  
Fire Alarm, Art. 800  
Grounding, Art. 250  
Impedance, 110-10  
Less than 50 Volts, Art. 720  
Grounding, 250-5  
More than 600 Volts, Art. 710  
Services, 230-L  
Motor, Art. 430-B  
Power, Signal, Remote-control, Low Energy, Art. 725  
Remote-control, Motors, Controllers, 430-F  
Signal Circuits, Art. 725  
Telegraph, Art. 800  
Telephone, Art. 800  
Unidentified, 200-5

**Circuit Breakers**, Art. 240 (see also Hazardous Locations.)

Accessibility and Grouping, 380-8  
Circuits Over 600 Volts, 230-106, 710-21  
Definition, Art. 100  
Disconnection of Grounded Conductors, 380-1  
Enclosures, 380-3  
General, 110-9, 240-H  
Overcurrent Protection  
Generators, 445-4  
Motors, 430-58  
Transformers, 450-3  
Panelboards, 384-B  
Rating, Motor Branch Circuits, 430-58  
Rating, Nonadjustable Trip, 240-5(a)  
Exc. No. 1, 240-25(e)  
Service Overcurrent Protection, 230-90  
Services, Disconnecting Means, 230-70  
Over 600 Volts, 230-106  
Setting, Adjustable Trip, 240-5(a)  
Switches, Use as, 380-11  
Wet Locations, in, 380-4

**Circuit Directory**, panelboards, 110-22**Clamp, Ground**, 250-115, 250-116, 250-117**Class 1 and 2 Circuits**, Remote-Control, Low-Energy Power, Signal Circuits, Art. 725**Class I, Class II, Class III Locations** (see Hazardous Locations)**Cleaning and Dyeing Plants**, Hazardous Liquids in, 500-4, Art. 501**Clean Surfaces**, grounding connections, 250-118**Clearance(s)** (see also Enclosures, Isolating, and Space)

Antennas, 810-13, 810-18, 810-54  
Community Antenna Systems, Art. 820  
Conductors, Open, Outside Branch Circuits and Feeders, 730-18, 730-19  
Elevators, Dumbwaiters, Escalators and Moving Walk Panels, 620-72  
Lighting Fixtures, Flush, Recessed, 410-64, 410-74(b)

**Live Parts**

Bare Conductors, Auxiliary Gutters, 374-7

Circuits Over 600 Volts, 710-D  
Switchboards, Panelboards, 384-7, 384-8

**Climbing Space**

Line Conductors on Poles, 730-14(e)

**Clock Outlets**, Connection to Branch circuits in dwellings, 220-3(b)**Clothes Closets**, Light Fixtures, 410-8**Clothes Dryers**

Calculations for, 220-4(o)  
Feeder Demand Factors, Table 220-6(b)  
Grounding, 250-60

**Clothing Manufacturing Plants**, 500-6, Art. 503 (Hazardous Locations)**Collectors**, Cranes and Hoists, 610-22**Color Code**

Branch Circuits, 210-5  
Grounding conductor, 210-5, 250-57(b), 400-14  
Switchboards and Panelboards, 384-25

**Combustible Dusts** (see Hazardous Locations), Art. 502**Common Grounding Electrode**, 250-54**Common Neutral**

Feeders, 215-5  
Outside Wiring, 730-7

**Communication Circuits**, Art. 800

Bonding at Electrode, 800-31(b-7)  
Definition, Art. 100  
General, 800-A  
Grounding, 800-E  
Cable Sheath, 800-31(a)  
Protector Ground, 800-31(b)  
Electrode, 800-31(b-5)  
Electrode Connection, 800-31(b-6)  
Insulation, 800-31(b-1)  
Physical Damage, 800-31(b-4)  
Run in Straight Line, 800-31(b-3)  
Size, 800-31(b-2)  
Outside Overhead Conductors, 800-C  
Protection, 800-B  
Installation, Conductors, 800-3  
Separation, 800-3(a)  
Vertical Runs, 800-3(b)  
Protective Devices, 800-2  
Underground Circuits, 800-D  
Circuits, 800-21

**Community Antenna Television and Radio Distribution Systems**, Art. 820

General, 820-A, 820-F  
Material, 820-2  
Prevention, Fire Spread, 820-10  
Grounding, 820-E  
Cable

**Com. Antenna TV (Continued)**

- Electrode, Electrode Connection, 820-8(a-6, 7)
- Insulation, 820-8(a-1)
- Protection, 820-8(a-5)
- Straight Line, 820-8(a-4)
- Size, 820-8(a-3)
- Equipment, 820-9
- Installation, 820-C
- Entering Buildings, 820-5
- Inside Buildings, 820-6
- Outside Buildings, 820-4
- Protection, 820-B
- Underground Circuits, 820-D

**Compressors, Refrigeration** (see Art. 440)**Concealed**

- Definition, Art. 100
- Knob-and-Tube, Art. 324

**Concentric Knockouts**, Bonding Jumpers, Service, 250-72(d)**Concrete**

- Encased electrodes, 250-82(d), 250-83(a)
- Metal raceways and equipment in, 300-5(b)

**Conductor Fill**, Maximum permitted

- Auxiliary gutters, 374-5, 374-8
- Cellular concrete floor raceways, 358-9
- Cellular metal floor raceways, 356-5
- Continuous rigid cable supports (cable trays), 318-6, Table 318-6(a)
- Electrical metallic tubing, 348-6
- Flexible Metal conduit, 350-1, 350-3, Table 350-3
- Liquidtight flexible metal conduit, 351-4
- Rigid metal conduits, 346-6
- Rigid nonmetallic conduits, 347-11
- Structural raceways, 357-6
- Surface metal raceways, 352-4
- Wireways, 362-5, 362-6

**Conductors** (see also Cords, Flexible; and Fixture Wires)

- Aluminum and Copper-Clad Aluminum, Ampacities of, Tables 310-14, 310-15
- Aluminum, Properties of, Table 8, Chap. 9
- Ampacities, 310-11, Tables 310-12 thru 310-15
- Motors, 430-B
- Raceway (More than three in) Note 8, Tables 310-12 thru 310-15
- Amplifier Circuits, 640-5
- Application, 310-2, Table 310-2(a)
- Bare, Definition, Art. 100
- Boxes and Fittings, Junction, 370-6, 370-7
- Branch Circuits, Art. 210
- Buried, 310-6
- Busways, Art. 364
- Cabinets and Cutout Boxes, 373-5, 373-6
- Cablebus, Art. 365
- Capacitor Circuits, 460-8
- Cellular Concrete Floor Raceways, Art. 358
- Cellular Metal Floor Raceways, Art. 356
- Circuit,
  - Less than 50 Volts, Art. 720
  - Power, Signal, Remote-Control, Low-energy, Art. 725
  - Over 600 Volts, Art. 710
- Combinations, Table 1, Chap. 9
- Computations of, Examples, Chap. 9, Part B
- Concealed Knob-and-Tube, Art. 324
- Conduit or Tubing, Number in, 346-6, Table 350-3, Tables 3A-3C, Chap. 9
- Construction, General, 310-2, 310-12

**Conductors (Continued)**

- Copper, Ampacities, Tables 310-12, 310-13
- Copper, Properties, Table 8, Chap. 9
- Cords, Flexible, Art. 400
- Corrosive conditions, 310-7
- Covered, Definition, Art. 100
- Cranes and Hoists, 610-B, 610-C, 610-31, 610-41
- Different Systems, 300-3, 318-4(e) 725-16
- Dimension of
  - Asbestos-Varnished-Cambric Insulated, Table 7, Chap. 9
  - Lead-covered, Table 6, Chap. 9
  - Rubber-covered and Thermoplastic-covered, Table 5, Chap. 9
- Electrical Metallic Tubing, Art. 348
- Elevators, Dumbwaiters, Escalators, and Moving Walks, 620-B, 620-C, 620-D
- Enclosure, Grounding, 250-1, 250-D
- Fixture Wires, Art. 402
- Flat Cable Assemblies, Art. 363
- Flexible Metal Conduit, Art. 350
- Gages, General Provisions, 110-6
- General Provisions, 110-7
- Generators, Size, 445-5
- Grounded
  - Alternating Current Systems, 250-23, 250-25, Identification, 200-6, 200-7
  - Overcurrent Protection, 230-90(b)
  - Service, Disconnection, 230-70(i)
  - Overcurrent Protection, 230-90(b)
  - Size, Change in, 240-13
  - Switches, Disconnection, 380-1
  - Use and Identification, Art. 200
- Grounding, 250-J
  - Connections, 250-K
- Induction and Dielectric Heating Equipment
  - Capacity of Supply, 665-6, 665-14
  - Power Supply for Therapeutic Equipment, 665-30(b)
- Inserting into raceways, 300-18
- Insulating materials, 310-3
- Insulation, Art. 310
  - Fixtures, Flush, Recessed, 410-65
  - Hazardous Locations, Class I Installations, 501-13
  - Motion Picture Projectors, 540-14
  - Resistors and Reactors, 470-7
  - Theaters, Assembly Halls, 520-42
- Insulation at bushings, No. 4 and Larger, 373-6(b)
- Lighting Fixtures, 410-E
- Lightning Rods, Spacing from, 250-46
- Liquid-Tight Flexible Metallic Conduit, Art. 351
- Metal Enclosures, Spacing from Lightning Rods, 250-46
- Metal-clad Cable, Art. 334
- Mineral Insulated-Metal Sheathed Cable, Art. 330
- Minimum size, 310-8
- Motion Picture Projectors, Sizes, 540-13
- Motor Circuits, 430-B
- Multioutlet Assembly, Art. 353
- Multiple, 250-79(c), 250-95, 300-20, 310-10
- Nonmetallic Sheathed Cable, Art. 336
- Nonmetallic Extensions, Art. 342
- Number of, in
  - Auxiliary Gutters, 374-5
  - Cellular Concrete Floor Raceways, 358-9
  - Cellular Metal Floor Raceways, 356-5
  - Continuous Rigid Cable Supports, 318-6, Table 318-6(a)

**Conductors (Continued)**

- Electrical Metallic Tubing, 348-6
- Elevators, 620-32, 620-33
- Flexible Metal Conduit, Table 350-3
- General Installations, 300-17
- Remote Control Circuits, 725-15
- Rigid Metal Conduit, 346-6, 402-7
- Rigid Nonmetallic Conduit, 347-11
- Signs and Outline Lighting, 600-21(d)
- Sound Recording, 640-3
- Structural Raceways, 357-6
- Surface Raceways, 352-4, 352-25
- Theaters, Assembly Halls, 520-5
- Underfloor Raceways, 354-5
- Wireways, 362-5
- Organs, 650-4, 650-5
- Outlet Boxes, Temp. Limits, 410-11
- Outside Wiring, Art. 730
- Over 600 Volts, Art. 710
- Overcurrent Protection, 240-5
- Parallel, 250-79(c), 250-95, 300-20, 310-10
- Properties of, Table 8, Chap. 9
- Raceways, Number of Conductors in (see Conductors, Number of, in)
- Radio and Television
  - Antenna Distribution Systems, Art. 820
  - Antenna Systems, 810-B, 810-C
  - Grounding, 810-58 thru 810-60
  - Transmitting Stations, 810-70
- Railway, Power and Light from, General Provisions, 110-19
- Remote Control and Signal Circuits, Art. 725
- Rigid Metal Conduit, Art. 346
- Selection of, Examples, Chap. 9, Part B
- Service (see Service Cable and Service Conductors)
- Service-Entrance, Definition, Art. 100
- Service-Entrance, Art. 230, 338
- Shielded Nonmetallic Sheathed Cable, Art. 337
- Signs and Outline Lighting, Installation, 600-21, 600-31
- Simplified Wiring Tables, Tables 310-20, 310-21, Sections 310-20, 310-21
- Sizes of
  - Asbestos-Varnished-Cambric Insulated, Table 7, Chap. 9
  - Lead-covered, Table 6, Chap. 9
  - Rubber Covered, Table 5, Chap. 9
  - Thermoplastic-covered, Table 5, Chap. 9
- Sound Recording and Similar Equipment, 640-3 thru 640-7, 640-9(b)
- Stranded, 310-9
- Support of, in vertical raceways, 300-19
- Surface Raceway, Art. 352
- Switchboards and Panelboards, 384-3, 384-9
- Temperature Limitations of, 310-4
- Theaters, Assembly Halls, Portable Stage Equipment, 520-68
- Underfloor Raceway, Art. 354
- Underground Feeder and Branch Circuit Cable, Art. 339
- Underplaster Extensions, Art. 344
- Ungrounded, Services, 230-90(a)
- Welders, Electric
  - Capacity of Supply, 630-11, 630-31
  - Overcurrent Protection, 630-12(b), 630-32(b)
- Wet Locations, 310-5
- Wireways, Art. 362
- X-ray Equipment, 660-3, 660-7

**Conduit Nipples**, Note 3, Chap. 9, Notes to Tables

**Conduit, Rigid Metal**, Art. 346**Conduits**

- Circuits, Mechanical Protection of Remote control, 725-17
- Conductors, Number in, Tables 1, 2, 3A, 3B, 3C, Chap. 9
- Dimensions, Table 4, Chap. 9
- Electrical metallic tubing, Art. 348
- Flexible, Grounding, Services, 230-63(c)
- Flexible Metal, Art. 350
- Liquid-tight Flexible Metal, Art. 351
- Metallic, grounding runs 25 ft., 250-33
- Outside Wiring, 730-10
- Rigid Metal, Art. 346
- Rigid Nonmetallic, Art. 347

**Connections**

- Aluminum, copper conductors, 110-14
- Cabinets and Extensions Cellular Metal Floor Raceways, 356-11
- Grounding conductor, 250-K
- Knife switches, 380-7
- Terminals, General Provisions, 110-14

**Connectors**

- Boxes, 370-7
- Cable, Theaters, and Assembly Halls, 520-67
- Electrical metallic tubing, 348-8, 348-14(c)
- Metal-clad cable, 334-10
- Pressure (Solderless), Definition, Art. 100
- Rigid metallic conduit, 346-9
- Rigid nonmetallic conduit, 347-6

**Constant-Potential Generators**, Art. 445

- Overcurrent protection for, 445-4(a)

**Construction Specifications** (see listed in Articles covered)**Continuity**

- Electrical, metal raceways and cables, 250-75, 250-76; service equipment, 250-71, 250-72
- Grounding, metal boxes, grounding-type receptacles, 250-74, 250-114
- Mechanical, raceways and cables, 300-12; conductors, 300-13
- Neutral of Multiwire Circuits, 300-13

**Continuous Duty**, Definition, Art. 100**Continuous Load**

- Applications, 210-23(b), 220-2, 220-4(a), 384-16(c)
- Definition, Art. 100

**Continuous Rigid Cable Supports**, Art. 318

- Ampacity, 318-6
- Construction, 318-3
- Extension Through Walls, 318-4(g)
- Grounding, 318-5
- Installation, 318-4
- Spacing of Cables, Table 318-6(a)

**Control** (see also Hazardous Locations)

- Panels, Clearance around, Elevators, 620-72

**Remote**

- Induction and Dielectric Heating Equipment, 665-12
- Low-Energy Power and Signal Circuits, Art. 725
- Overcurrent Protection, 240-5(a), Ex. 4
- X-ray Equipment, 660-B

**Control Centers**

- Guarding live parts, 110-17
- Headroom, 110-16(f)
- Illumination at, 110-16(e)
- Working spaces, 110-16

**Controller(s)** (see also **Hazardous Locations**)

- Cases, Grounding, 250-43(b)
- Definition, Art. 100
- Motor, Art. 430-G
- Resistors and Reactors
- Incandescent Lamps as Resistors, 470-8

**Convenience Outlet**, (see **Receptacles**)**Conversion Table, DC to AC conductor resistances**, Table 9, Chap. 9**Cooking Unit, Counter-Mounted**, Definition, Art. 100 (see also **Ranges**) (see also **Ovens**)**Copper Conductors** (see **Conductors, Copper**)**Cords** (see also **Heater Cords**) (see also **Hazardous Locations**)

- Flexible Cords, Art. 400
- Ampacities, Table 400-9(b)
- Lampholders, Insulating Bushings, 410-24
- Lighting Fixtures, 410-14
- Motion-Picture Projectors, 540-15
- Overcurrent Protection, 240-5, 400-9
- Power and Signal Circuits, Remote-control, Low-energy, 725-13
- Prohibited uses, 400-4
- Pull at joints and terminals, 400-10
- Sound Recording, Similar Equipment, Grouping Conductors, 640-7
- Splices and Taps prohibited, 400-5
- Types, Table 400-11
- Tinsel, minimum size, 400-7
- Overcurrent Protection, 400-9
- Uses, 400-3

**Corrosion, Protection**, metal equipment, 300-5**Corrosive Conditions**

- Conductor Insulation, 310-7
- General, 110-11

**Couplings**

- Electrical metallic tubing, 348-8
- Rigid metal conduit, 346-9
- Rigid nonmetallic conduit, 347-6
- Running threads at, 346-9(b)

**Cove Lighting, Space for**, 410-9**Covers**

- Auxiliary Gutters, 374-4
- Boxes and Fittings, 370-15

**Cranes(s)**, Art. 610

- Conductors, 610-B, 610-C
- Control, 610-D
- Flexible Cords, 400-3
- Grounding, 250-7, 250-43, 610-F
- Hazardous Locations, 503-13
- Motors and Controllers, Disconnecting Means, 430-112
- Overcurrent Protection, 610-E

**Cross-Sectional Areas**,

- Conductors, Tables 5, 6, 7, 8, Chap. 9
- Conduits, Table 4, Chap. 9

**Current-Carrying Capacities** (see **Ampacities**)**Current-Limiting Devices** (see **Circuit Breakers and Fuses**)**Curtain Motors**, Theaters, Halls, etc., 520-48**Cutout**

- Bases (see **Fuseholders**)
- Box, Definition, Art. 100
- Boxes and Cabinets, Art. 373

**Cutout** (*Continued*)

Thermal (see **Thermal Cutout**)

**Cutting Tables**, Motion Picture, 530-D**Damp Location**, Definition, Art. 100**Damp or Wet Locations**

- Boxes and Fittings, 370-5
- Cabinets and Cutout Boxes, 373-2
- General, 110-11
- Lampholders, 410-43
- Lighting Fixtures, 410-4
- Open Wiring, 320-14
- Overcurrent Protection, Enclosure, 240-17
- Panelboards, 384-17
- Receptacles, 410-54
- Rosettes, 410-58

**Damper** (Flue), Control, Fixed Stage Equipment, 520-49**Dance Halls**, Art. 520**Data Processing Systems**, Art. 645

- Circuits and Interconnecting Cables, 645-2
- Disconnecting Means
- General Building Areas, 645-3(b)
- Processing Rooms, 645-3(a)
- Grounding, 645-4
- Marking, 645-5

**Dead Ends**

- Busways, 364-5
- Cablebus, 365-7
- Flat Cable Assemblies, 363-12
- Wireways, 362-9

**Dead Front, Stage Switchboards**, 520-21**Definitions**

- 90-4, Art. 100

**Deflection of Conductors**

- Auxiliary gutters, 374-9(e)
- Cabinets and cutout boxes, 373-6

**Deicing and Snow Melting Installations** (see **Fixed Outdoor Electric De-icing and Snow Melting Equipment**)**Delta-Connected, 4-Wire, 3-Phase Supply**, Identifying high leg, 200-6(c)**Demand Factor** (see also **Load(s)**), Definition, Art. 100**Demand Loads for Household Cooking Appliances**, Table 220-5**Depth of Boxes**, Boxes and Fittings, 370-14**Detached Buildings**, Oil-insulated transformers in, 450-24(d)**Detearing Equipment, Electrostatic**, 516-4**Deteriorating Agencies**, General, 110-11**Device**, Definition, Art. 100**Diagrams**

- Feeders, 215-6
- Health Care Facilities, 517-1
- Motor Feeder and Branch Circuits, 430-1(a)

**Dielectric Heat Generating Equipment**, Art. 665 (see **Inductive and dielectric Heat Generating Equip.**)**Differential Protection**

- Motors over 600 volts, 430-124(c)

**Different Systems, Conductors**, in same enclosure, 300-3, 318-4(e), 725-16**Dimensions**

- Conductors, Tables 5 thru 8, Chap. 9.

**Dimensions (Continued)**

Conduit and Tubing, Percent Area, Table 4, Chap. 9

**Dimmers**, Stage Switchboards, 520-25, 520-53(e)

**Dip Tanks, Paint**, Art. 516

**Direct Burial**

Over 600 Volts, 710-3(b)

Rigid nonmetallic conduit, 18 in., 347-2(a); Bulk-storage plants, 515-5(a); service stations, 514-8

Underground feeder and branch circuit cable, not less than 18 in. when unprotected, 339-3(c)

Underground service cable, 230-32(a), 310-6

**DC Resistance, Conversion to AC Resistance**, Table 9, Chap. 9

**DC Systems**, Grounding, 250-3, 250-22

**Disconnecting Means**

Air Conditioning and Refrigerating Equipment, 440-B

Appliances, 422-D

Capacitors, 460-8(c)

Cranes, 610-D

Definition, Art. 100

Electric Space Heating Equipment, 424-C

Elevators, 620-51

Fuses and Thermal Cutouts, 240-18

Induction and Dielectric Heating Equipment, 665-8

Mobile Homes, 550-4

Motor and Controllers, 430-H, 430-126

Recreational Vehicles, 551-9

Services, 230-J

Connections, Ahead of, 230-73

Over 600 Volts, 230-103

Signs, 600-2

Welders, Resistance, 630-33

X-ray Equipment, 660-4, 660-14

**Discontinued Outlets**

Cellular Concrete Floor Raceways, 358-11

Cellular Metal Floor Raceways, 356-7

Underfloor Raceways, 354-7

**Dissimilar Metals**, 110-14, 250-116, 346-1, 348-1

**Door(s)**, Transformer vaults, 450-43

**Double Insulated, Appliances and Tools**, 250-45

**Drainage**

Capacitor charge, 460-6

Equipment, 501-5(d)

Oil-insulated outdoor transformers, 450-25

Oil-insulated lightning arresters, 280-22

Raceways, 230-52, 230-101(g), 730-23

Transformer vaults, for, 450-46

**Dressing Rooms**

Motion Picture Studios, 530-C

Theaters, Assembly Halls, etc., 520-F

**Drip Loops**, Conductors Entering Buildings, 230-49

Service heads, 230-51

**Driveways**

Clearance of conductors, 730-18

Clearance of service drop, 230-26

Protection of service-entrance cables, 230-46

**Drop, Service**, Definition, Art. 100

**Drop, Voltage**, 210-6(d), 215-3

**Dry Location**, Definition, Art. 100 (see damp or wet locations)

**Dryers, Clothes**

Grounding, 250-60

Demand factors, 220-4(o), Table 220-6(b)

**Dry-Type Transformers**, 450-2, 450-3(b), 450-21

**Dual-Voltage Motor**, Locked rotor rating, 430-7(b-3)

**Duct(s)**

Air Handling, 300-21, 300-22

Bare grounded neutral underground, 230-30

Lighting fixtures in, 410-4(c)

Sealing at building from underground system, 230-33

Underground services, 230-32(a)

Ventilating, 300-21, 300-22

Wiring in, 300-22

**Duct Heaters**

Installation of, 424-F

**Dumbwaiters** (see Elevators), Art. 620

**Dusts** (see Hazardous Locations)

**Dust-Ignition-Proof**, 502-1

**Dustproof**, Definition, Art. 100

**Dust-tight**, Definition, Art. 100

**Duty, Type**, Definition, Art. 100

**Duty Cycle** (Welding), 630-31

**Dwellings** (see also Appliances, Boxes, Branch Circuits, Fixtures, Grounding, and similar general categories)

Branch Circuit Voltages, 210-6(b)

Clothes Dryers, Demand Factors, Table 220-6(b)

Farm, services, 220-4(n)

Feeder Load, Calculations for, 220-4, 220-7, 220-8, 220-9, Part B, Chap. 9

Lighting Loads for, Table 220-2(a)

Panelboards as services, 384-16(a), 384-3(c)

Ranges, Demand Load, Table 220-5

Receptacle Circuits Required, 220-3(b)

Receptacle Outlets Required, 210-22(b)

Protection by Ground-Fault Circuit-Interruption, Outdoors, Residences, 210-22(d)

**Elbows, Metallic, Protection from Corrosion**, 300-5

**Electric Discharge Lighting**

Connection to Fixtures, 410-14

More than 1000 Volts, 410-Q

1000 Volts or less, 410-P

Signs and Outline Lighting, Art. 600

Wiring, Equipment, 410-P, 410-Q

**Electric Space Heating Equipment**, see Fixed Electric Space Heating Equipment

**Electric Welders** (see Welders)

**Electrical Metallic Tubing**, Art. 348

Bends, How Made, 348-9

Bends, Number in one run, 348-10

Connectors and couplings, 348-8

Construction Specifications, 348-B

Minimum and maximum sizes, 348-5

Number of Conductors in, 348-6

Reaming of, 348-11

Supports for, 348-12

Threads on, 348-7

Uses permitted for, 348-1

Wet Locations, in, 348-4

**Electrode, Grounding**

Common, to be Used to Ground Con-



**Electrode, Grounding** (*Continued*)

ductor Enclosures and Equipment, 250-54

Concrete encased, 250-82(d), 250-83(a)  
Gas Piping as, 250-82(b)

Made (wire or rods in concrete footing, driven Pipe, Rod, or Buried Plate), 250-82(d), 250-83

Metal Frame of Building as, 250-82(a)

Metallic Water Piping System, 250-81

Resistance to Ground of, 250-84

**Electrostatic Equipment**, Spraying and Detearing, Paint, 516-4**Elevators, Dumbwaiters, Escalators, and Moving Walks**, Art. 620

Cables, 620-E

Conductors, 620-B, 620-C, 620-D

Control, 620-F

Grounding, 250-43(c), 620-J

Machine Room, 620-H

Overcurrent Protection, 620-G

Overspeed Equipment, 620-K

**Emergency Systems**, Art. 700 (see also Stand-By Power Generation Systems, Art. 750 and Health Care Facilities, Art. 517)

Circuits, 700-C

Connection at Services, 230-73, 230-74

Control, 700-D

Overcurrent Protection, 700-E, 700-21

Power, Supply, 700-B

Service Disconnecting Means, 230-74

Service-drop Conductors, 230-2, Exc. 2

Unit Equipment, 700-F

**Enamel, Coating of**

Electrical Metallic Tubing, 348-1

General Equipment, Indoor Use Only 300-5(a)

Metal Boxes, 370-20

Metal Cabinets, 373-10(a)

Removing, for grounding connections, 250-75

Rigid Metal Conduit, 346-1

**Enclosed**, Definition, Art. 100**Enclosure(s)** (see also Hazardous Locations)

Arcing Parts, General, 110-18

Cabinets, Cutout Boxes, Space, 373-7, 373-9, 373-11

Cranes Hoists, Resistors, 610-2

Elevators, Dumbwaiters, Escalators, Moving Walks

Live Parts, 620-3

Machine, Controller, 620-H

Induction and Dielectric Heating, 665-22

Installations over 600 Volts, 710-31

Mercury-Vapor Lamp Aux. Equip., 410-50

Overcurrent Protection, 240-C

Panelboards, 384-18

Radio Equip., 810-71(a)

Signs, Outline Lighting, 600-8, 600-34(g), (h)

Switches, 380-3

**Energy-Limiting, Class 2 Control and Signal Circuits**, 725-31**Enforcement, Code**, 90-7**Equipment** (see also separately listed items)

Approval, 110-2

Definitions, Art. 100

Examination of, 90-8, 110-4

Grounding, 250-E

Installation, General Provisions, Art. 110

Less than 50 Volts, Art. 720

**Equipment** (*Continued*)

More than 600 Volts, Art. 710

Mounting of, 110-13

Sealable, Definition, Art. 100

Service, Definition, Art. 100

**Equipment Grounding Conductors**

Connections at Outlets, 250-74, 250-114

Definition, Art. 100

Installation, 210-7, 215-7, 250-92(b)

Outlets, Connections at, 250-74, 250-114

Sizing, 250-95

Types Recognized, 250-57(a), 250-92(b)

**Escalators** (see Elevators), Art. 620**Examination of Equipment for Safety**, 90-8**Examples** (Computations) Chap. 9, Part B**Exciter(s)**

Leads in same enclosure as motor, control, relay, and ammeter Conductors, 300-3(e)

Overcurrent Protection for, when used with constant potential AC Generators, 445-4(a)

**Exhaust Ducts, Wiring in**, 300-22(a)**Exits**, Emergency Lighting for, Art. 700**Expansion Joints**, 300-6(b), 347-9**Explosive Atmospheres**, Gases, Liquids, Dusts, Ignitable Fibers, Lints and Flyings (see Hazardous Locations)**Explosion-Proof**, Definition, Art. 100 (see also Hazardous Locations)**Exposed** (see also Enclosure)

Extensions, Boxes, and Fittings, 370-12

Live Parts, Definition, Art. 100

General, 110-16

Wiring Methods, Definition, Art. 100

**Extension(s)**

Auxiliary Gutters, Beyond Equipment, 374-2

Boxes and Fittings, Exposed, 370-12

Cellular Concrete Floor Raceways, 358-4

Cellular Metal Floor Raceways, Connection to Cabinets, 356-11

Flat Cable Assemblies, 363-15

Nonmetallic, Art. 342

Underfloor Raceways, 354-15

Underplaster, Art. 344

Wireways, From Wireways, Through Walls, 362-8, 362-10

**Externally Operable**, Definition, Art. 100**Faceplates, Switches, Receptacles, to Grounding**, 410-95(a)

Minimum Thicknesses for, 380-9, 410-52(b)

Mounting Surfaces, Against, 380-10(b), 410-52(c)

**Farm Buildings, Feeder Calculations**, 220-4(m)**Feeder(s)**, Art. 215, Art. 220

Calculation of Loads, 220-4, 220-7, Part B, Chap. 9

Definition, Art. 100

Farm Buildings, for, 220-4(m)

Ground-Fault Interrupters, with, 215-8

Grounding Means, 215-7

Motor, Art. 430-B

Outside Branch Circuits, Art. 730

Overcurrent Protection

Motor, 430-E

Taps in Inaccessible Locations, Motors, 430-59

**Feeder(s)** (*Continued*)

- Taps, 10 ft. and 25 ft., 240-15 Excs. 5, 6 and 7

**Feed-Through Connections of Neutral Conductors**, 300-13**Ferrous Metals, Protection from Corrosion**, 300-5**Festoon Lighting, Outside Wiring**, 730-6, 730-13

- Supports, outside Circuits, 730-13

**Festoons, Portable Stage Equipment**, 520-65**Fiber Bushings, AC Cable Ends**, 334-10(b)**Fibers, Lint, Flyings, Ignitable** (see Hazardous Locations), Art. 503**Film(s), Motion Picture**

- Projectors, Art. 540
- Projectors, Marking, 540-34
- Storage, 530-E, 540-22
- Viewing, Cutting, Patching Tables, 530-41

**Finishing Processes**, Art. 516**Fire Alarms**

- Circuits, Art. 800
- Connections at Services, 230-73, 230-94(d)

**Fire Pump(s)**

- Connections at Services, 230-73, 230-94(d)
- Emergency Power Supply, Art. 700
- Motors, Overcurrent Protection, 430-31
- Remote-control Circuits, 430-72
- Service Drops, 230-2

**Fire Spread**, prevention of, thru walls, floors, etc., 300-21, 800-3(c), 820-10**Fire-Stopped Partitions**, 300-21**Firewall(s)**

- Dividing Buildings, Definition of Building, Art. 100
- Wiring Through, 300-21

**Fitting(s)** (see also Wiring Types)

- Boxes and, Art. 370
- Definition, Art. 100

**Fixed Electric Space Heating Equipment**, Art. 424

- Boilers, Protection of, 424-22(c), Exc.
- Branch Circuits for, 424-3
- Cables and Panels, 424-E
- Area Restrictions, 424-38
- Clearances, Wiring
- Ceilings, 424-36
- Other Objects, Openings, 424-39
- Walls, 424-37
- Construction, 424-34
- Finish, Ceilings, 424-42
- Installation
- Cables, 424-44
- General, 424-48
- Nonheating Leads, 424-43
- Marking
- Cables, 424-35(a)
- Panels, 424-35(b)
- Panels
- Complete Units, 424-47
- General, 424-46
- Splices, 424-40
- Tests, 424-45
- Control and Protection, 424-C
- Controllers, 424-20
- Disconnecting Means, 424-19, 424-20, 424-21

**Fixed Elect. Space Heating** (*Continued*)

- Location, 424-19(c)
- Indicating, 424-21
- Motor Driven Equip., 430-H
- Overcurrent Protection, 424-22
- Duct Heaters, 424-F
- Air Flow, 424-59
- Approval, 424-58
- Condensation, 424-62
- Disconnecting means, Location, 424-65
- Elevated Inlet Temperature, 424-60
- Fan Circuit Interlock, 424-63
- Installation, 464-61, 464-66
- Limit Controls, 464-64
- Installation, 424-B
- Grounding, 424-14
- Location
- Exposed to Physical Damage, 424-12(a)
- Wet Areas, 424-12(b)
- Spacing, Combustible Materials, 424-13
- Special Types, 424-10
- Supply Conductors, 424-11
- Marking, 424-D
- Heating Elements, 424-29
- Nameplate, 424-28
- Overcurrent Protection for, 424-22

**Fixed Equipment**, Grounding, 250-42 through 250-44, 250-57, 250-58**Fixed Outdoor Electric De-Icing and Snow-Melting Equipment**, Art. 426

- Approved type, to be, 426-9
- Branch Circuits for, 210-24, 426-3
- Complete Units, to be, 426-11
- Disconnecting Means for, 426-20
- Grounding, 426-28
- Installation
- Heating Cables, etc., 426-24
- Nonheating leads, 426-25
- Junction Boxes for, 426-27
- Marking of, 426-26
- Nonheating leads for, 426-11, 426-23, 426-25, 426-26
- Overcurrent Protection of, Art. 210, 426-22
- Special-Type Equipment, 426-12
- Thermostats for, 426-21
- Tests of, 426-29
- Use of, 426-10

**Fixture Stud**, Construction, 410-34**Fixture Wires**, Art. 402

- Ampacities, Table 402-4
- Number in conduits, 402-7, Table 2, Ch. 9
- Types, Table 402-6

**Fixtures** (see Lighting Fixtures)**Flammable Anesthetics**, 517-E**Flammable Gases and Vapors** (see Hazardous Locations)**Flammable Liquids** (see Hazardous Locations)**Flashers, Time Switches, Similar Devices**, 380-5**Flat Cable Assemblies** (Type FC), Art. 363

- Branch-Circuit Rating, 363-17
- Conductor Insulations for, 363-9
- Dead Ends, 363-12
- Definition, 363-2
- Extensions from, 363-15
- Fittings for, 363-14
- Fixture Hangers for, 363-13
- Identification of, 363-20

**Flat Cable Assemblies** (Continued)

- Installation of, 363-6
- Marking of, 363-18
- Number of Conductors in, 363-7
- Protective Covers for, 363-19
- Size of Conductors in, 363-8
- Splices, 363-10
- Supports for, 363-16
- Taps and tap devices, 363-11
- Terminal Block Coding, 363-21
- Uses, 363-4, 363-5

**Flatirons, Smoothing**, 422-13

- Signals required, 422-12
- Stands for, 422-11
- Temperature-limiting means required, 422-12, 422-13

**Flexible Cords** (see Cords, Flexible), Art. 400**Flexible Metal Conduit**, Art. 350

- Minimum size, 350-3
- Supports, 350-4
- Use, 350-2

**Floors, Receptacles**, 370-17**Flue-damper Control, Fixed Stage Equipment**, 520-49**Fluorescent Lighting Fixtures**

- Auxiliary equipment remote from, 410-75
- Ballast protection required, 410-71(e)
- Connection of, 410-14
- Load calculations
  - Ampere ratings, ballasts 210-23(b)
  - Branch circuits, 210-24
- Raceways, 410-26
- Snap Switches for, 380-14(a-1), (b-2)
- Special provisions, 1000 volts or less, 410-P

**Fluoroscopic Equipment**, Art. 660**Footlights**, Theaters, Assembly Halls, etc. 520-43**Forming Shells, Underwater Swimming Pool Lighting Fixtures**, 680-20(b)**Full-load Current, Motors**

- Alternating Current
  - Single Phase, Table 430-148
  - Three Phase, Table 430-150
  - Two Phase, Table 430-149
- Direct Current, Table 430-147

**Fundamental Rules**, 90-5**Furnace**, Circuits, Grounding, Transformers, Installation, 450-24(c)**Fuseholders**

- Cartridge Fuses, 240-F
- Over 600 Volts, 710-21(b)
- Plug Fuses, 240-E
- Rating, Motor Controllers, 430-90
- Type S, 240-22

**Fuses**, Art. 240 (see also Hazardous Locations)

- Cartridge, 240-F
- Disconnecting Means, 240-18
- Enclosures, 240-C
- General, 240-6
- Generators, Constant-Potential, 445-4(a)
- Group installation of motors, 430-53(c)
- In parallel, not permitted, 240-14
- Location, 240-19(a), 240-16
- Marking, 240-20(c), 240-22(i), 240-23(c)
- Motor-Running Overcurrent Protection, 430-C
- Motor Branch Circuit Protection, 430-D
- Plug, Edison-base Type, Classification

**Fuses** (Continued)

- and Marking, 240-E
- Potential (Voltage) Transformers, 450-3(c)
- Ratings, 240-5(b)
- Services Over 600 Volts, 230-106(c)
- Spaces in Cabinets and Cutout Boxes, 373-11(a)
- Type S, 240-22

**Garage(s)**

- Commercial, Art. 511
- Definition, Art. 100
- Elevators, Dumbwaiters, Escalators, Moving Walks, in, 620-38
- Grounding, Fixed Equip., 250-43
- Residential, Art. 512

**Gases** (see Hazardous Locations)**Gas Pipe**

- As Grounding Electrode, 250-82(b)
- Grounding Conductor, Point of Attachment, 250-112

**Gasoline Bulk-Storage Plants**, Art. 515 (see also Hazardous Locations)**Gasoline Dispensing and Service Stations**, Art. 514 (see also Hazardous Locations)

- Conductor Insulations where exposed to gasoline, 501-13

**Gages, Conductor**, General, 110-6**General Provisions, Installation of Wiring and Equipment**, Art. 110**General Requirements for Wiring Methods**, Art. 300

- Boxes or Fittings, Each Outlet, 300-15
- Changing Raceway, Cable to Open Wiring, 300-16(a)
- Conductors,
  - Different Systems, 300-3
  - Inserting in Raceways, 300-18
  - Insulating Bushings, for Raceways No. 4 or Larger, 373-6(b)
  - Number of, in Raceways, 300-17
  - Supporting, Vertical Raceways, 300-19
- Expansion Joints, Raceways, 300-6(b)
- Exhaust and Ventilating Ducts, Wiring 300-22
- Feed-Through Neutral Connections, 300-13
- Free Length of Wire at Outlets, 300-14
- Grounding Metal Enclosures, 300-9
- Induced Currents in Metal Enclosures, 300-20
- Mechanical and Electrical Continuity, Conductors, Raceways, Cables, 300-10, 300-12, 300-13
- Protection Against
  - Corrosion, 300-5
  - Physical Damage, 300-4
- Prevention of Fire Spread, 300-21
- Sealing, Raceways, Change in Temperature, 300-6(a)
- Secured in Place, Wiring and Equipment, 300-11
- Through Studs, Joists, Rafters, 300-8
- Underground Runs, 300-7
- Voltage Limitations, 300-2

**Generator(s)**, Art. 445

- Bushings, 445-9
- Conductor Sizes, 445-5
- Drip Pans, 445-3
- Emergency Systems, 700-8
- Grounding, 250-43, 445-8
- Guards for Attendants, 445-7
- Location, 445-1
- Marking, 445-2

**Generator(s)** *(Continued)*

- Overcurrent Protection, 445-4
- Protection of Live Parts, 445-6
- Recreational Vehicles, 551-5
- Set, Emergency System, 700-8
- Stand-by Power, Art. 750

**Goosenecks, Service Cables, Forming and Connecting to Service-Drops** 230-51**Ground**

- Clamps, 250-116
- Definition, Art. 100
- Voltage to, Definition, Art. 100

**Grounded**, Definition, Art. 100**Grounded, Effectively, Communication System**, Definition, 800-2(c) (1)**Grounded Conductor** (see also Conductors)

- Definition, Art. 100

**Grounded System**, Polarity Identification, 200-6**Ground-Fault Circuit Interrupters**

- Personnel Protection, for,
- Permitted Uses, 215-8, 210-22(d)
- Receptacles
  - Construction Sites, at, 210-7
  - Marinas and Boatyards, used at, 555-3
  - Outdoor, in residential occupancies, 210-22(d)
  - Pools between 10-15 ft of, 680-6
- Service Disconnecting Means, at, 230-95
- Storable Pools, 680-31

**Grounding**, Art. 250

- AC Systems, 250-5, 250-23, 250-25
- Air Conditioning Units, 250-45
- Antenna (see Grounding, Radio and TV)
- Appliances, 422-16
- Bonding, 250-G
- Capacitors, 460-10
- Circuits, 250-A, 250-B
  - Less than 50 Volts, 720-10
- Clothes Dryers, 250-60
- Clothes Washers, 250-45
- Conductor(s), 250-J
  - Connections, 250-K, 250-113
  - Definition, Art. 100
  - Enclosures, 250-D
  - Installation, 250-92
  - Sizes, 250-95
- Connections, Location, 250-C, 250-K
- Continuity, 250-75
- Control Circuits, Class 1, 725-21; Class 2, 725-44
- Controls, Radio Equipment, 810-71(b)
- Cranes and Hoists, 610-51
- Deicing, Snow Melting Systems, 426-28
- Dish Washers, 250-45(c), (d)
- DC Systems, 250-3, 250-22
- Electrodes, 250-H
- Elevators, 620-J
- Enclosures, Metal, Wiring Methods, 300-9
- Equipment, Cord Connected, 250-45
- Fixed Equipment, 250-42, 250-43
- Fixtures, Lampholders, etc., 410-R
- Freezers, 250-45
- Generators, 445-8
- Hazardous Locations, 501-16, 502-16, 503-17
- Induction and Dielectric Heating Equipment, 665-D
- Instrument Transformers, Relays, etc.,

**Grounding** *(Continued)*

- 250-L
  - Lightning Arresters, 250-M
  - Location of Connections, 250-C, 250-K
  - Metal Faceplates 8 ft. Vertically or 5 ft. Horizontally from Grounded Surfaces, 410-95(a)
  - Metal Enclosures for Conductors, 250-33
  - Metal Siding, 250-44
  - Methods, 250-F
  - Mobile Homes, 550-9
  - More than 600 Volts Between Conductors, 710-6, 710-7
  - Motion Picture Studios, 530-20, 530-66
  - Motors and Controllers, 430-L
  - Nonelectrical Equipment, 250-44
  - Organs, 650-3
  - Portable Equipment, 250-45
  - Radio and Television, 810-15, 810-21 thru 810-29, 810-58 thru 810-60, 810-71
  - Ranges and Similar Appliances, 250-60
  - Receptacles, 250-74, 410-55 (see also Hazardous Locations)
    - Bonding at boxes, 250-74, 250-114
    - Branch Circuits must Include Grounding Conductor for, 210-7
    - Connections to Circuits of Two or More Outlets, Minimum and Maximum Ratings of, 210-21(b)
    - Design of, 410-55
    - Grounding-Type, 210-7, 250-74, 410-55
    - Minimum Rating of, 410-52(a)
    - When Required, for New Work and as Replacements, 210-21(b)
  - Recreational Vehicles, 551-21, -22, -46, -48
  - Refrigerators, 250-45(c-d)
  - Separately Derived Systems, 250-26
  - Services, 230-63
  - Signs and Outline Lighting, 600-5
  - Sound Recording Equip., 640-4(b), Exc. 4
  - Swimming Pools, 680-23, -24
  - Switchboard Frames, 384-11
  - Switches, 380-12
  - Systems and Circuits, 250-A, 250-B
  - Theaters, Assembly Halls, etc., 520-81
  - Tools, Motor Operated, 250-45
  - Transformers, 450-9
  - X-ray Equipment, 660-D
- Grounding Electrode Conductor**
- Connection to Electrodes, 250-K
  - Definition, Art. 100
  - Installation, 250-92
  - Material, 250-91
  - Sizing, 250-94(a-b)
- Grounding Type Attachment Plugs**, Design of, and Use with Movable, Self-restoring-type Grounding Members, 410-55
- Grounding-Type Receptacles**, See **Grounding**, Receptacles
- Grouping, Switches, Circuit Breakers**, 380-8
- Group Installation, Motors**, 430-53
- Guarded**, Definition, Art. 100
- Guarding, Guards** (see also Enclosures and Live Parts)
- Circuit Breaker Handles, 240-19(b)
  - Elevators, Dumbwaiters, Escalators, Moving Walks, 620-71
  - Generators, 445-7
  - Handlamps, Portable, 410-37
  - Lamps

**Guarding, Guards (Continued)**

Motion-Picture Projectors, 540-16  
Theaters, Assembly Halls, Dressing Rooms, etc., 520-44, 520-47, 520-61, 520-65, 520-71, 520-72  
Live Parts, General Provisions, 110-17  
Motion Picture Studios, 530-15, 530-64  
Motors, Motor Controllers, Live Parts, 430-K  
Motors, Portable, 430-143  
Over 600 Volts, 710-6, 710-34  
Transformers, 450-7

**Gutters, Auxiliary** (see Auxiliary Gutters)**Handlamps, Portable**, 410-37**Hangars, Aircraft**, Art. 513**Hazardous Areas** (see Hazardous Locations), Art. 500**Hazardous Atmospheres**, Art. 500

Class I Locations, 500-4  
Class II Locations, 500-5  
Class III Locations, 500-6  
Specific Occupancies, 500-3  
Special Precautions and Groups A-G, 500-2

**Hazardous Locations**, Art. 500

Aircraft Hangars, Art. 513  
Anesthetics, Flammable, 517-E  
Approval for Class and Properties, 500-2(c)  
Bulk Storage Plants, Art. 515  
Chemicals by Groups, Table 500-2(c)  
Dusts, Explosive, Art. 502  
Fibers, Flyings, Lint, Highly Combustible Materials, Art. 503  
Finishing Processes, Art. 516  
Garages, Commercial, Art. 511  
Garages, Residential, Art. 512  
Gases, Flammable, Art. 500, 501  
Gasoline Service Stations, Art. 514  
Group Designations, 500-2  
Identification Numbers, Table 500-2(b)  
Liquids, Flammable, Art. 500, 501  
Marking, 500-2(b)  
Vapors, Flammable, Art. 500, 501

**Hazardous Location(s), Class I**, Art. 501

Bonding, 501-16(b), (d), (e)  
Circuit Breakers and Fuses, 501-6  
Conductor Insulation, 501-13  
Control Transformers and Resistors, 501-7  
Drainage of Equipment, 501-5(d)  
Flexible Cords, 501-11  
Fuses and Circuit Breakers, 501-6  
General, 501-1  
Grounding, 501-16  
Lighting Fixtures, 501-9  
Lightning Protection, 501-16(c)  
Live Parts, 501-15  
Meters, Instruments, and Relays, 501-3  
Motor Controllers, 501-6  
Motors and Generators, 501-8  
Receptacles and Attachment Plugs, 501-12  
Sealing Fittings and Compound, 501-5  
Signal, Alarm, Remote-control, and Communication Systems, 501-14  
Switches, 501-6  
Transformers and Capacitors, 501-2  
Utilization Equipment, 501-10  
Wiring Methods, 501-4  
502 (Dusts)  
Bonding, 502-16(b), (d), (e)

**Hazardous Location(s), Class II**, Art.

Circuit Breakers and Fuses, 502-6  
Control Transformers, Resistors, 502-7  
Flexible Cords, 502-12  
Fuses and Circuit Breakers, 502-6  
General, 502-1  
Grounding, 502-16  
Lighting Fixtures, 502-11  
Lightning Protection, 502-16(c)  
Live Parts, 502-15  
Motor Controllers, 502-6  
Motors and Generators, 502-8  
Receptacles and Attachment Plugs, 502-13  
Sealing, 502-5  
Signal, Alarm, Remote-control, and Intercom Systems, 502-14  
Surge Protection, 502-3  
Switches, 502-6  
Transformers and Capacitors, 502-2  
Utilization Equipment, 502-10  
Ventilating Piping, 502-9  
Wiring Methods, 502-4

**Hazardous Location(s), Class III**,

Art. 503 (Fibers, Flyings, Lint)  
Circuit Breakers and Fuses, 503-4  
Control Transformers, Resistors, 503-5  
Electric Cranes and Hoists, 503-13  
Electric Trucks, 503-14  
Flexible Cords, 503-10  
Fuses and Circuit Breakers, 503-4  
General, 503-1  
Grounding, 503-17  
Lighting Fixtures, 503-9  
Live Parts, 503-16  
Motor Controllers, 503-4  
Motors and Generators, 503-6  
Receptacles and Attachment Plugs, 503-11  
Signal, Alarm, Remote-Control and Intercom Systems, 503-12  
Storage-Battery Charging, 503-15  
Switches, 503-4  
Transformers and Capacitors, 503-2  
Utilization Equipment, 503-8  
Ventilating Piping, 503-7  
Wiring Methods, 503-3

**Header(s)**

Cellular Metal Floor Raceways, 356-1, 356-2, 356-5, 356-6  
Cellular Concrete Floor Raceways, 358-1, 358-2, 358-3, 358-6, 358-7  
Structural Raceways, 357-1(b), 357-5, 357-7

**Header Duct(s)**, Art. 356, 358**Health Care Facilities**, Art. 517

Communication, Signaling Systems, and Data Systems, 517-F  
Definition of, 517-2  
Electrically Susceptible Patient Areas, 517-D  
General, 517-50  
Performance, 517-51(a)  
Potential Difference (Max.) 517-51(a)  
Special Grounding Requirements, 517-51(b)  
Essential Electrical Systems, 517-C  
Critical Branch, 517-13  
Emergency System, 517-11(a-f)  
Equipment Systems, 517-20(a-f)  
General, 517-10  
Life Safety Branch, 517-12  
Life Support Branch, 517-14(a-b)  
Power Sources, 517-30(a-e)  
Switching and Overcurrent Protection, 517-40(a-f)

**Health Care Facilities (Continued)**

- General, 517-A
- Definitions of Terms, 517-2
- General Area Wiring Systems, 517-B
- Grounding, 517-3
- Wiring Methods, 517-4
- Inhalation Anesthetizing Locations, 517-E
- Circuits in, 517-63(a-f)
- Hazardous Areas Defined, 517-60
- Low-Voltage Equipment and Instruments, 517-64(a-f)
- Other Equipment, 517-65(a-c)
- Wiring and Equip. In Nonhazardous or Above Hazardous Areas, 517-62(a-e)
- Wiring and Equip. Within Hazardous Areas, 517-61(a-d)

**Heat Generating Equipment, Art. 665****Heater Cords, Table 400-11, 422-8(a)****Heater Elements, Marking, 422-31****Heating Appliances (see Appliances)****Heating Cables, Art. 424****Heating, Fixed Electric Space, Art. 424****Heavy-Duty Lampholders**

- Branch Circuits, 210-24, Table 210-25
- Definition, 210-8
- Unit Loads, 220-2(b)

**Hermetic Type Refrigeration Compressors (see Air Conditioning and Refrigerating Equipment)****Hoists and Cranes, Art. 610**

- Disconnecting Means—Motors and Controllers, 430-112, 610-D
- Flexible Cords, 400-3

**Hoistway, Definition, Art. 100****Hood, Metal**

- Theaters, Assembly Halls, etc., 520-24

**Hoods for Comm. Cooking, lighting in, 410-4(c)****Hospitals (see Health Care Facilities)****Identification**

- Flexible Cords
- Grounded Conductor, 400-13
- Grounding Conductor, 400-14
- Grounded Conductors, Art. 200

**Identified, Definition, Art. 100****Immersion Heaters, Portable Types, 422-9****Incandescent Lamps (see also Hazardous Locations)**

- Guards
- Aircraft Hangars, 513-5(a)
- Garages, 511-6(b), (c)
- Projection Booths, 540-16
- Theater Dressing Rooms, 520-72
- Medium-base Lampholders, 410-49
- Mogul-base Lampholders, 410-49
- Resistors, 470-8
- Snap Switches for, 380-14

**Independent**

- Emergency Lighting Supply, 700-15(a)
- Emergency Power Supply, 700-15(b)
- Supports, Services, Over Buildings, 230-25
- Wiring, Emergency Circuits, 700-17
- X-ray Control, 660-14

**Individual Branch Circuit(s)**

- Definition, under Branch Circuit, Art. 100
- May Supply Any Load, 210-24
- Overcurrent Protection, Single Appliance, 210-20(b)

**Induced Currents, Metal Enclosures, 300-20****Induction and Dielectric Heating, Art. 665**

- Guarding and Grounding, 665-D
- Output, 665-9, 665-10, 665-18
- Power Supply, 665-B, 665-C
- Therapeutic, 665-E

**Inductive Loads**

- Switches, Types, Ratings, Lighting Fixtures, 380-14
- Motors, 430-83, 430-109
- Signs, 600-2(b)

**Infrared Lamp Heating Appliances**

- Branch Circuits, 210-24(c-d), 424-3(a), Exc.
- General Rules, 422-15
- Overcurrent Protection, 422-27(c)

**Inserting Conductors in Raceways, 300-18****Inserts**

- Cellular Concrete Floor Raceways, 358-7
- Cellular Metal Floor Raceways, 356-10
- Underfloor Raceways, 354-14

**In Sight From**

- Motors, Motor Controllers, 430-4
- Room Air Conditioners, 422-43, 440-22(b-2), Exc. 1
- Signs, 600-2(a)

**Institutions, Emergency Lighting, Art. 700****Instrument Transformers, Grounding, 250-L****Instruments, Meters, Relays**

- Grounding, 250-L
- Hazardous Locations, Class 1, 501-3

**Insulating Joints, Fixtures on Metal, Metal Lath, Ceilings, Walls, 410-93****Insulating Links, Metal Pull Chains, Lighting Fixtures, 410-95(b)****Insulation**

- Conductor, Art. 310
- General, 310-2, 310-3, 310-12
- Hazardous Locations, Class I Installations, 501-13
- Motion-Picture Projectors, 540-14
- Theaters, Assembly Halls, etc., 520-42
- Double, 250-45
- Fixture Wire, 402-3, Table 402-6
- Flexible Cords, Table 400-11, 400-C
- Over 300 Volts, 400-8
- Heating Cables, 424-E
- Service Conductors, 230-4, 230-22, 230-30, 230-40
- Splices and Joints, 110-14

**Insulators, Open Wiring, Art. 320****Intercommunication Systems, Art. 800 (see also Hazardous Locations)****Intermittent Duty, Definition, Art. 100****Interpretation(s), 90-6, Official, How to Obtain, Part D, Appendix****Interrupting Capacity, 110-9, 110-10, 240-23(c), 230-98, 240-25(e)****Intrinsically Safe Equipment, Hazardous Locations, 500-1****Introduction, Art. 90****Irons, Smoothing, 422-13****Isolated**

**Isolated (Continued)**

Definition, Art. 100

**Isolating** (see also Guarding and Guards)

Means, Over 600 Volts, 710-22

Switch, Definition, Art. 100

**Isolation by Elevation**

Circuits over 600 Volts, 710-34(f)

**Joints** (see also Splices and Taps)

Grounding Conductor, 250-91(a)

Insulation, Fixtures, 410-93

Insulation of, 110-14

Strain at, Fixtures, 400-10

**Joists**

Boxes on, 370-13

Concealed Knob and Tube Work, Attics,  
Roof Spaces, 324-8

Holes through or Notches in, 300-8

Metal-clad Cable

Exposed, 334-12

In Accessible Attics, 334-13

Nonmetallic Sheathed Cable, in Base-  
ments, 336-8

Open Wiring, Crossing, 320-12

**Jumpers, Bonding**Conduit Joints, Hazardous Locations,  
500-1Expansion Joints, Telescoping Sections  
of Raceways, 250-77

Grounding-Type Receptacles, 250-74

Material, Size and Attachment, 250-79

Service Equipment, 250-72, 250-79(c)

**Junction Boxes** (see also Boxes and Pull  
Boxes)

Accessibility, 370-19

Cellular Concrete Floor Raceways, 358-5

Cellular Metal Floor Raceways, 356-9

Covers, 370-15, 370-18(c)

Deicing and Snow Melting Cables, 426-  
27Motor Controllers and Disconnects, 430-  
10

Nonheating Cable Leads, 424-43

Separation, from Motors, 430-145(b)

Size,

Conductors No. 6 and Larger, 370-18

Conductors No. 6 and Smaller, 370-6

Construction Specifications, 370-C

Swimming Pools, 680-21

Supports, 370-13

Switch Enclosures, 373-8

Underfloor Raceways, 354-13

**Knife Switches**

Connection, 380-7

Construction Specifications, 380-B

Enclosures, 380-3

Position, 380-6

Ratings, 380-13

**Knob and Tube Work, Art. 324****Knockout(s)**

Bonding Service Equipment, 250-72(d)

Openings to be Closed, 370-7, 370-8

**Lacquers and Paints**

Application, Art. 516

Atmospheres, 500-2, 500-4, Art. 501

**Lamp(s) (Lighting Fixtures), Art.  
410** (see also Hazardous Loca-  
tions)

Arc (see Arc Lamps)

Clothes Closets, in, 410-8

Electric Discharge, 410-P, 410-Q

Fluorescent, Art. 410

Guards (see Guarding and Guards)

Handlamps (see Handlamps)

**Lamp(s), etc. (Continued)**

Incandescent, Art. 410

Bases for, 410-49

As Resistors, 470-8

Infrared (see Infrared Lamps)

Mercury-Vapor, Enclosure of Resistors  
and Regulators, 410-50

Motion-Picture Projectors

Nonprofessional Type, 540-33

Professional Type, 540-14, 540-16

Motion-Picture Studios, in

Film Storage Vaults, 530-51

Stages, 530-16, 530-17

Viewing, Cutting Tables, 530-41

Outdoor, Location, 730-26

Portable

Flexible Cords for, 400-3

Motion-Picture Studios, in, 530-16, 530-  
17

Show-Windows, 400-6

Theaters, Assembly Halls

Border and Proscenium, 520-44

Dressing Rooms, 520-72

Festoons, 520-65

Footlights, 520-43

Scene Docks, in, 520-47

Stage, Arc, 520-61

Switchboards, Pilot Lights, 520-53

Wattage Marking, Flush and Recessed  
Fixtures, 410-68**Lampholders**

Branch Circuits Supplying

15-20 amps, Medium-Base, 210-24(a)

30-50 amps, Heavy-Duty, 210-24(b),  
(c), (d)

Circuits Less Than 50V, for, 720-5

Construction, 410-H

Damp or Wet Locations, 410-4, 410-43

Double-Pole Switched, 410-42

Heavy-Duty,

Defined, 210-8

Unit Loads, 220-2(b)

Infrared Lamps, 422-15

Outdoor Lighting, 730-25

Pendant

Not in Clothes Closets, 410-8

Not in Theater Dressing Rooms, 520-71

Screw-shell Types for Lamps only, 410-41

Signs and Outline Lighting, 600-22

Unswitched Over Highly Combustible  
Material, 410-6**Laundry Outlets, Dwellings** 210-22(b),  
220-3(b)**Length(s)**

Busways used as Branch Circuits, 364-13

Free Conductors at Outlets and Switches,  
300-14, 424-43, 426-25Nonmetallic Flexible Tubing with Open  
Wiring, 320-7Nonmetallic Rigid Conduit, 347-16(a),  
(b)

Pull and Junction Boxes, 370-18(a) (1)

Rigid Metal Conduit, 346-14(a)

Space Heating Cable Nonheating  
Leads, 424-34

Taps,

Cooking Appliances, 210-19(c), Exc. 5

Feeders, 10-ft. Rule, 240-15, Exc. 5;

25-ft. Rule, 240-15, Exc. 6 and 7

Individual Lampholders or Fixtures,  
210-19(c), Exc. 2(a)

Individual Outlets, 210-19(c), Exc. 2(b)

Motor Feeders, 25-ft. Rule, 430-59

**Light(s)** (see also Lamps and Lighting)

Border, Cables for, Theaters, 520-44(b)

From Railway Conductors, 110-19

Scenery, Theaters, Halls, 520-63

**Lighting**

- Branch Circuit(s), Calculation of Load, 220-2
- Emergency, Art. 700
- Feeders, Calculation of Load, 220-4
- Fixtures (see Lighting Fixtures)
- Outlet, Def., Art. 100
- Lighting Fixtures, Art. 410** (see also Hazardous Locations)
  - Autotransformers, Ballasts Supplying Fluorescent Fixtures, 410-76
  - Supplying Circuits, 200-4
  - Auxiliary Equipment, 410-75
  - Boxes, Canopies, Pans, 410-C
  - Branch Circuits,
    - Sizes, 210-23, 210-24
    - Unit Loads, 220-2(a), (b)
    - Voltages, 210-6, 410-73
  - Clothes Closets, 410-8
  - Combustible Material, Near, 410-5
  - Connection,
    - Fluorescent, 410-14
    - General, 410-25
  - Construction of, 410-F, 410-N
  - Corrosive (see Damp, etc.)
  - Coves, Adequate Space, 410-9
  - Damp, Wet, or Corrosive Locations, 410-4, 410-43
  - Ducts or Hoods, in, 410-4(c)
  - Electric Discharge Lighting
    - Systems 1000 V or less, 410-P;
    - Systems over 1000 V, 410-Q;
    - Voltages-Dwelling Occupancies, 410-73
  - Fluorescent, 410-P, 410-Q
    - Autotransformers in Ballasts, 410-76
    - Ballast Protection, 410-71(e)
    - Connection, 410-14
  - Flush, 410-M
  - Grounding, 410-R
  - Live Parts, 410-3
  - Location, 410-B
  - Motion-Picture Studios, Art. 530
  - Outdoor (see Damp, etc.)
  - Overcurrent Protection, Wires and Cords, 240-5(a), Exc. 2
  - Polarization, 410-27
  - Raceways, 410-26
  - Recessed, 410-M
  - Show Windows, 410-7
  - Supports, 410-D
  - Swimming Pools, 680-20
  - Theaters and Assembly Halls, Art. 520
  - Wet (see Damp, etc.)
  - Wiring, 410-E

**Lightning Arresters** (see also Lightning Protection and Rods), Art. 280

- Antenna Discharge Systems, 810-20
- Connections at Services, 230-73
- Grounding, 250-M
- Industrial Stations, 280-A
- Radio and Television Equipment
  - Receiving Stations (Antenna Discharge Units), 810-20
  - Transmitting Stations, 810-57
- Services Over 600 Volts, 230-107

**Lightning Protection** (see also Lightning Arresters and Rods)

- Communication Circuits, 800-12
- Hazardous Locations, 501-16(c), 502-3

**Lightning Rods** (see also Lightning Arresters and Protection)

- As a Ground, 250-86
- Spacing from Conductor Enclosures and Equipment, 250-46

**Lint, Flyings** (see Hazardous Locations)**Liquid-Tight Flexible Metal Conduit, Art. 351****Live Parts** (see also Enclosures, Guarding)

- Appliances, Disconnecting Means, 422-D
- Capacitors, Guarding, 460-11
- Generators, Protection, 445-6
- Guarding, General, 110-17
- Hazardous Locations, 501-15, 502-15, 503-16
- Lamp Terminals, Lampholders, 410-80
- Lighting Fixtures, Lampholders, Lamps, Receptacles, Rosettes, 410-3
- Lighting Systems, Electric Discharge,
  - 1000 Volts or less, 410-P, Over
  - 1000 Volts, 410-Q
- Motors and Motor Controllers, 430-K
- Transformers, Guarding, 450-7

**Load(s)**

- Appliances, Household Cooking, Demand Table, 220-5
- Branch Circuits, Calculations, Art. 220; Part B, Chap. 9
- Mobile Homes, 550-11
- Branch Circuits, Maximum, 210-23, Table 210-25
- Branch Circuits, Permissible, 210-24, Table 210-25
- Clothes Dryers, 220-4(o), Demand, Table 220-6(b)
- Feeders, Calculations, Art. 220; Part B, Chap. 9
- Mobile Home Parks, 550-22
- Mobile Homes, 550-11
- Motors, Conductors, 430-B
- Stage Equipment, Circuit Loads, Theaters, Assembly Halls, 520-41

**Location(s)**

- Capacitors, 460-2
- Crane and Hoist Disconnecting Means, 610-D
- Definition, Art. 100
- Electric Discharge Lighting Transformers (over 1000 Volts), 410-84
- Elevator Motor Disconnecting Means, 620-51(b)
- Foreign Pipes, Accessories, Transformer Vaults, 450-47
- Generators, 445-1
- Grounding Connections at Electrodes, 250-112
- Hazardous (see Hazardous Locations)
- Junction Boxes, 370-19
- Lamps Outdoors, 730-26
- Lighting Fixtures, 410-B
- Lightning Arresters,
  - Indoors, 280-21
  - Outdoors, 280-22
- Mobile Home Disconnecting Means and Branch-Circuit Protective Equipment, 550-4
- Motion-Picture Projection Equipment, 540-17
- Motors, 430-14
- Motor Disconnecting Means, 430-H
- Motor Feeder Taps, 430-59
- Overcurrent Devices, 240-B
- Protective Devices for Communication Circuits, 800-2(a)
- Recreational Vehicle Disconnecting Means and Branch-Circuit Protective Equipment, 551-9(c)
- Resistors and Reactors, 470-1
- Service Disconnecting Means, 230-70(b)
- Service Heads, 230-51
- Service Overcurrent Protection, 230-91, 92, 93
- Splices and Taps, Auxiliary Gutters, 374-8(a)
- Sign Switches, 600-2(a)



**Locations (Continued)**

- Swimming Pool Junction Boxes and Transformer Enclosures, 680-21
- Switchboards, 384-4, 384-6
- System Ground Connection, 250-52
- Transformers and Vaults, 450-2
- Ventilation Openings for Transformer Vaults, 450-45(a)
- Wet (see Wet Locations)

**Locked-Rotor, Motor Current**

- Code Letters, 430-7
- Conversion Table, 430-151
- Refrigeration Compressors, 440-3(a)

**Locknuts, Double Where Required**

- Over 250 Volts to Ground, 250-76(b)
- Wholly Insulated Bushings Used, 373-6(b)

**Low-Energy Power Circuit, Art. 725**

- Definition, Art. 100

**Low-Energy, Remote-control, Low-Voltage Power and Signal Circuits, Art. 725****Lugs**

- Connection to Terminals, General, 110-14
- Solderless Type at Electrodes, 250-115;
- Connection of Service Conductors, 230-72

**Made Electrodes (see Electrodes, also Grounding)****Marinas and Boatyards, Art. 555**

- Feeders and Services, 555-5
- Grounding, 555-7
- Receptacles
  - Branch Circuits for, 555-4
  - Ground-Fault Protection of, 555-3
  - Locking and Grounding Types, 555-3
  - Single, required, 555-3
- Wiring Methods for, 555-6

**Markings (see articles on wiring and equip. involved)****Mechanical Execution of Work, 110-12****Mercury-Vapor Lamps, Enclosures for, 410-50****Metal-Clad Cable, MC and AC Series, Art. 334**

- Accessible Attics, Type AC Cable in, 334-13
- Anti-Short Bushings, at Ends, 334-10(b)
- Bends, 334-9
- Conductors, 334-5
- Construction, 334-4
- Definition, 334-1
- Exposed Work, 334-12
- Marking, 334-3
- Supports, 334-8
- Through Studs, Joists, and Rafters, 300-8
- Uses, 334-6
- Voltages, 334-2

**Metal-Enclosed Switchgear, 230-101(h), 230-106****Metal Frame of Building**

- Grounding Electrode, 250-82(a)
- Resistance to Ground, 250-84

**Metal Hood, Stage Switchboard, 520-24****Metal Working Machine Tools, Art. 670****Metal Siding, Grounding of, 250-44****Metallic Outlet Boxes (see Boxes)****Metallic Raceways (see Raceways)****Metals, Dissimilar, 346-1, 348-1****Meter(s)**

- Cases, Grounding, 250-123, 250-124
- Connection and Location at Services, 230-73, 230-94
- Grounding to Circuit Conductor, 250-61
- Hazardous Locations, Class I, 501-3

**Mineral-Insulated-Metal Sheathed Cable, Art. 330**

- Bends, 330-7
- Construction Specifications, 330-C
- Definition and Description, 330-1
- Fittings, 330-9
- Insulation and Resistance, 330-10
- Supports, 330-4
- Terminating Seals, 330-8
- Through Studs, Joists, etc., 330-5, 300-8
- Use, 330-2
- Wet Locations, 330-6, 300-5(c)

**Mobile Home Parks, Art. 550, 550-B**

- Definition of, 550-2
- Distribution Systems Permitted, 550-21
- Park Electrical Wiring System
  - Calculated Load, 550-22(a)
  - Feeder and Service Demand Factors, Table 550-22
  - Per Mobile Home Service, 550-22(a)
- Definition, 550-2
- Mobile Home Lot, Definition, 550-2
- Mobile Home Service Equipment, 550-23(a)
- Definition, 550-2

**Mobile Homes, Art. 550**

- Appliances, 550-7(a)
- Branch Circuits, 550-5
- Branch-Circuit Protective Equipment, 550-4(b)
- Calculations of Loads, 550-11
- Definition, 550-2
- Disconnecting Means, 550-4(a)
- Expandable and Dual Units, Wiring, 550-12
- Grounding, 550-9
- Insulated Neutral Required, 550-9(a)
- Lighting Fixtures, 550-7(b)
- Nameplates, 550-4(d)
- Outdoor Outlets, 550-13
- Power Supplies, 550-3
- Receptacle Outlets, Types, Where Required, 550-6
- Testing, 550-10
- Wiring Methods and Materials, 550-8

**Mogul Lampholders, 410-49****Monorails, 610-1****Motion-Picture**

- Projectors, Art. 540, 520-2
- Grounding, 250-43
- Studios, Art. 530
- Theaters, Assembly Halls, etc., Art. 520

**Motor(s), Art. 430**

- Air Conditioning Units, 422-F, Art. 440
- Appliances, Motor Driven, Art. 430-H
- Branch Circuits, 430-B
  - Combination Loads, 430-25, 430-63
  - Continuous Duty, 430-22
  - Intermittent Duty, 430-22
  - Single Motor, 430-22
  - Taps, 430-53, 430-59
  - Two or More, 430-24
  - Wound Rotor Secondary, 430-22
- Capacitor

**Motor(s)** (*Continued*)

Circuits, 460-8, 460-9  
 Rating, 460-7  
 Circuits, 430-B  
 Code Letters, Table 430-7(b)  
 Coded and Noncoded, Setting of Branch  
 Circuit Devices, Table 430-152  
 Combined Overcurrent Protection (Start-  
 ing and Running) 430-55  
 Conductor(s), 430-B  
 Control Circuits, 430-F  
 Controllers, 430-G  
 Hazardous Locations, 501-6, 502-6, 503-  
 4  
 Current, Full Load  
 Alternating Current  
 Single Phase, Table 430-148  
 Three Phase, Table 430-150  
 Two Phase, Table 430-149  
 Direct Current, Table 430-147  
 Curtain, Theaters, Assembly Halls, 520-48  
 Disconnecting Means, 430-H  
 Disconnects and Controllers not as Junc-  
 tion Boxes, 430-10  
 Fault Protection, 430-D, 430-E  
 Feeder demand Factor, 430-26  
 Feeders, Calculation of Load, 220-4  
 Fuseholder, Size of, 430-57  
 General, 430-A  
 Grounding, 250-E, 430-L  
 Grouped, 430-24, 42, 53, 87, 112  
 Guarding, 430-133  
 Hazardous Locations, 501-8, 502-8, 503-6  
 In Sight from, Defined, Rule for Dis-  
 connects, 430-4  
 Liquids, Protection from, 430-11 (see also  
 Hazardous Locations)  
 Live Parts, Protection, 430-133  
 Location, 430-14  
 Maintenance and Ventilation, 430-14  
 Marking, 430-7; Terminals, 430-9  
 Metal Working Machine Tools, Art. 670  
 Multispeed,  
 Branch Circuits, 430-22(a)  
 Locked Rotor Code Letters, 430-7(b)  
 (1)  
 Marking, 430-7  
 Running Protection, 430-32(a) (1),  
 430-32(c) (1)  
 Over 600 Volts, 430-J  
 Overcurrent (Overload) Protection, 430-  
 C  
 Overheating, Dust, Accumulations, 430-  
 16  
 Part Winding Described, 430-3  
 Projectors, Motion-Picture, 540-12  
 Restarting, Automatic, 430-43  
 Short Circuit Protection, 430-D, 430-E  
 Starting, Shunting, 430-35  
 Terminal Housings, Size, 430-12  
 Three Running Overcurrent Units, Table  
 430-37  
 Ultimate Trip Current, 430-32(a-2)  
 Ventilation and Maintenance, 430-14  
 Welders, Arc. Motor-Generator, 630-C  
 Wiring Diagram, Branch Circuit, 430-  
 1(a)  
 Wiring Space, 430-10  
**Motor-Circuit Switch**, Definition, Art.  
 100  
**Motor-Generator Arc Welders**, 630-C  
**Mounting of Equipment**, 110-13, 300-11,  
 380-10(b), 410-52(c)  
**Moving Walks** (see Elevators), Art. 620  
**Multioutlet Assembly**, Art. 353  
 Calculation of Load, 220-2  
 Definition, Art. 100

**Multiple Circuit Connections**, 250-62

**Multiple Conductors (Conductors in  
 Parallel)**, 250-79(c), 250-95, 300-  
 20, 310-10

**Multiple Fuses (Fuses in Parallel)**,  
 Not Permitted, 240-14

**Multispeed Motors**

Branch Circuits, 430-22(a)  
 Locked-Rotor Code Letters, 430-7(b)  
 Marking, 430-7  
 Running Protection, 430-32(a), 430-32(c)

**Nameplate** (see articles on wiring and  
 equip. involved)

**Neat Installation**, 110-12**Neutral**

Bare, where Permitted, 230-30, Exc., 230-  
 40(a) Exc.  
 Bonding to Service Equipment, 250-72(a)  
 Common Feeder, 215-5  
 Equipment, Grounding to, 250-61  
 Feeder Load, 220-4(e)  
 Feed-Through Connections, 300-13  
 Grounding of, for AC systems, 250-5,  
 250-25, 250-26; for DC, 250-3, 250-  
 22  
 Identification, Art. 200  
 Ranges and Dryers, Grounding, 250-60  
 Switchboards, Connections, 384-3(b)  
 Uninsulated, where Permitted, 230-30,  
 338-3(b)

**Night Clubs**, Art. 520

**Nipples, Conduit, Fill Permitted**, Note  
 3 Preceding Table 1, Chap. 9

**Nonautomatic**, Definition, Art. 100

**Nonelectrical Equipment**, Ground-  
 ing, 250-44

**Nongrounding-Type Receptacles**, Re-  
 placements, 210-21(b)

**Nonmetallic Boxes** (see Boxes)

Covers for, 370-15(a)  
 Ungrounded Metallic Fixtures, Lamp-  
 holders, Faceplates within reach of  
 grounded surfaces, 410-95(a)

**Nonmetallic Extensions**

Description, 342-1  
 Fittings, 342-6  
 Installation  
 As Aerial Cable, 342-7(b)  
 As Surface Extensions, 342-7(a)  
 Permitted Uses, 342-3  
 Prohibited Uses, 342-4  
 Splices and Taps, 342-5

**Nonmetallic Rigid Conduit** (see Rigid  
 Nonmetallic Conduit)

**Nonmetallic Sheathed Cable**, Art. 336

Accessible Attics, 336-9, 334-13  
 Bends, 336-10  
 Construction, 336-2  
 Definition, 336-1  
 Exposed Work, 336-6  
 Insulating Devices, 336-11  
 Marking, 336-2(c)  
 Supports, 336-5  
 Through Studs, Joists, Rafters, 300-8,  
 336-7  
 Unfinished Basements, 336-8  
 Uses, 336-3

**Nontamperable** (see Tamperability)

**Occupancy, Lighting Loads**, Table 220-  
 2(a)

**Official Interpretations**, Obtaining,  
 Part D, Appendix

**Openings in Equipment to be Closed**, 370-8, 373-4**Open Wiring on Insulators**, Art. 320

- Accessible Attics, 320-13, 324-8
- Conductor Separation, 320-6
- Conductor Types Permitted, 320-4
- Definition, 320-1
- Drip Loops, 320-14
- Flexible Nonmetallic Tubing, 320-7
- Passing through Walls and Floors, 320-9
- Separation from Metal Work, 320-10
- Separation from Piping, 320-11
- Supports, 320-5
- Switches, 320-15
- Tie Wires, 320-8
- Use, 320-2

**Operable, Externally**, Definition, Art. 100**Operating Rooms, Hospital**, Art. 517

- Emergency Light and Power, Art. 700

**Organs**, Art. 650

- Electronic, 640-1

**Outdoor Receptacles**, 410-54**Outlet(s)**

- Boxes (see Boxes, Outlet)
- Definition, Art. 100
- Devices, Branch Circuits, 210-21
- Discontinued,
  - Cellular Concrete Floor Raceways, 358-11
  - Cellular Metal Floor Raceways, 356-7
  - Underfloor Raceways, 354-7
- Lighting, Definition, Art. 100
- Multioutlet Assembly, Art. 353
- Receptacle, Definition, Art. 100

**Outlet, Switch, and Junction Boxes and Fittings**, (see Boxes)**Outline Lighting**, Art. 600

- Definition, Art. 100
- Grounding, Conductor Size, 250-97

**Output Circuits**

- Amplifiers, 640-5
- Heat Generating Equip., 665-9, 665-10

**Outside Branch Circuits and Feeders**, Art. 730

- Calculation of Load
  - Branch Circuits, 730-3(a)
  - Feeders, 730-3(b)
- Circuit Entrances and Exits, Buildings, 730-11
- Conductors,
  - Clearance from buildings, 730-19
  - From Ground, 730-18
  - Covering, 730-4
  - Size, 730-5, 730-6
- Disconnection, 730-8
- Festoon Supports, 730-13
- Lighting Equipment on Poles, 730-7
- Mechanical Protection, 730-20
- Outdoor Lighting Equipment, 730-25, 730-26
- Overcurrent Protection, 730-9
- Spacing, Open Conductors, 730-14
- Supports
  - Festoons, 730-13
  - Open Conductors, 730-12
  - Over Buildings, 730-15
- Wiring on Buildings, 730-10

**Outside of Buildings**, When Services Considered, 230-45**Ovens, Wall-Mounted** (see also Cooking Units) (see also Ranges)

- Branch Circuits, 210-19, 210-24
- Connections, 422-17
- Definition, Art. 100

**Demand Loads**, Table 220-5**Grounding**, 250-57, 250-60**Overcurrent Protection**, Art. 240

- Air Conditioning and Refrigerating Equipment, 440-C
- Appliances, 422-27
- Busways, 364-8 thru 364-12
- Capacitors, 460-8(b)
- Circuit-Breakers, 240-G
- Circuits
  - Branch, 210-20
  - Capacitor, 460-8, 460-9
  - Less than 50 Volts, 720-8
  - Remote-control and Signal
    - Class 1 Systems, 725-18, 725-19
    - Class 2 Systems, 725-32, 725-41, -42
  - Low-Voltage Power, 725-22
- Cords, Flexible and Tinsel, 400-9
- Cranes and Hoists, 610-E
- Current-Limiting Defined, 240-27
- Disconnecting and Guarding, 240-D
- Electric Space Heating Equipment, 424-22
- Elevators, Dumbwaiters, Escalators, and Moving Walks, 620-G
- Emergency Systems, 700-E
- Enclosures, 240-C
- Feeder Taps, 240-15
- Fixture Wires, 402-5
- Fuses and Fuseholders, 240-E, 240-F
- Generators, 445-4
- Grounded Conductor, not in, 240-12
- Induction and Dielectric Heating Equipment, 665-7, 665-15
- Installation, 240-A
- Location, 240-B
- Mobile Homes, 550-4
- Motion-Picture Studios, 530-18, 530-63
- Motors, Motor Circuits, Controllers
  - Branch Circuits, 430-D
  - Capacitors, 460-8
  - Control Circuits, 430-72
  - Cutouts and Relays, Thermal, 430-40
  - Overloads, 430-C
  - Over 600 Volts, 430-123, 430-124
- Multiple Fuses and Circuit Breakers Not in Parallel, 240-14
- Occupant Access to, 240-16(d)
- Organs, 650-6
- Outside Branch Circuits and Feeders, 730-9
- Over 600 Volts, 710-C
- Panelboards, 384-15, 384-16
- Paralleled Fuses and Circuit Breakers 240-14
- Recreational Vehicles, 551-3(e), 551-9, 551-10
- Remote-Control, 240-5(a), Exc. 4, Art. 725
- Services
  - Entrance Conductor, 230-K
  - Over 600 Volts, 230-106
- Single Appliance, 210-20(b)
- Sound Recording Equipment, 640-10
- Supplementary, 240-30
- Switchboards, 384-2
- Theaters, Assembly Halls, Stage Switchboards, 520-23, 520-25, 520-52, 520-53, 520-62
- Transformers, 450-3, 450-5
- Vertical Position, Enclosures, 240-17(c)
- Welders
  - Resistance, 630-32
  - Transformer, 630-12
- X-Ray Equipment, 660-5

**Over 600 Volts**, General, Art. 710

- Braid-Covered Insulated Conductors,

**Over 600 Volts (Continued)**

- Open Runs, 710-4
- Circuit Conductors, 710-32
- Circuit Interrupting Devices
  - Circuit Breakers, 710-21(c)
  - Fuseholders and Fuses, 710-21(b)
  - Load Interrupters, 710-21(c)
- Elevation of Unguarded Live Parts, 710-34(f)
- Enclosure for Electrical Installations, 710-31
- Grounding, 710-7
- Grounding of Shielding Tape, 710-6
- Headroom above Working Spaces, 710-34(e)
- Illumination of Working Spaces, 710-34(d)
- Indoor Installations, 710-10
- Isolating Means, 710-22
- Metal-enclosed Equipment, 710-12
- Moisture, Mechanical Protection, Metal-sheathed Cables, 710-8
- Outdoor Installations, 710-11
- Shielding, Solid-Dielectric-Insulated Conductors, 710-5
- Wiring Methods, 710-3

**Pan(s)**

- Drip, for Generators, 445-3
- Fixture, 410-13

**Panelboard(s)**, Art. 384 (see also Hazardous Locations)

- Damp or Wet Locations, 384-17
- Enclosures, 384-18
- General, 384-13
- Grounding Terminations in, 384-27
- Lighting and Appliance Branch-Circuit, Definition, 384-14
- Number of Overcurrent Devices, 384-15
- Overcurrent Protection, 384-16
- Overcurrent Protection, General, 384-16
- Relative Arrangement of Switches and Fuses, 384-19
- Service Equipment, 384-16(a), 384-3(c), 230-J, 230-K
- Support for Bus-Bars, 384-3

**Part-Winding Motors**

- Code Letter Markings, 430-7(b) (5)

**Paralleled**

- Conductors, 250-79(c), 250-95, 300-20, 310-10

- Circuit Breakers and Fuses, 240-14

**Patching Tables**, Motion Picture, 530-D**Pendants**

- Clothes Closets, 410-8(b)
- Dressing Rooms, 520-71
- Flexible Cords, 400-3

**Pendant Conductors**, Lamps, 410-22**Periodic Duty**, Definition, Art. 100**Permission, Special**, Definition, Art. 100**Person, Qualified**, Definition, Art. 100**Phase Protection**, Elevators, 620-53**Pipe Electrodes**, 250-83(c)**Places of Public Assembly**, Art. 520**Plate Electrodes**, 250-83(b)**Plugging Boxes**, Motion-Picture Studios, 530-14**Polarity Identification**

- Conductors, 310-2(c)
- Systems and Circuits, Art. 200

**Polarization**

- Lighting Fixtures, Wiring, 410-27
- Receptacle Adapters, 410-55(b-3)

**Poles**

- Climbing Space, Conductors, 730-14
- Conductors, Mechanical, Protection, 230-32(b), 230-46, 730-20

**Portable**

- Appliance(s), Art. 422
- Definition, Art. 100
- Equipment
  - Appliance(s), Tool(s), Double Insulation, 250-45
  - Grounding, 250-45, 250-59
  - Grounding Conductor Size, Table 250-95
  - Handlamps, Construction, 410-37
  - Lamps (see Lamps)
  - Stage Equipment, 520-E
  - Switchboards, Theaters, Halls, etc., 520-D
  - Wiring, Motion Picture Studios, 530-16

**Positive-Pressure Ventilation**, 500-1, 500-4(b)**Power, Emergency Systems**, Art. 700**Power Factor Correction**, Capacitors, 460-7**Power Supply, Mobile Homes**, 550-3**Power Supply, Recreational Vehicles**, 551-11**Prefabricated Buildings**, Art. 390**Pressure Connector**, Definition, Art. 100**Pressure, Positive, Ventilation**, 500-1, 500-4(b)**Prevention of Fire Spread Through Fire Partitions**, 300-21**Projectors, Motion Picture**, Art. 540**Protection**

- Combustible Material, Appliances, 422-10
- Corrosion,
  - Aluminum-Sheathed Cable, 331-2
  - Conductors, 310-7
  - Electrical Metallic Tubing, 348-1
  - General Equipment, 300-5
  - MI Cable, 330-2
  - Rigid Metal Conduit, 346-1
  - Underfloor Raceways, 354-2
- Liquids, Motors, 430-11
- Live Parts, 110-17, 445-6, 450-7(c), (d)
- Motor-Running Overcurrent, 430-C
- Overcurrent (see Overcurrent Protection)
- Physical Damage (Injury),
  - Busways, 364-2
  - Capacitors, 460-3
  - Conductors, 300-4, 310-6
  - Electrical Metallic Tubing, 348-1
  - Liquid-tight Flexible Metal Conduit, 351-2(b)
  - Metal-Clad Cable, 334-6, 334-12(c), 334-13
  - Multioutlet Assembly 353-2
  - Nonmetallic Sheathed Cable, 336-6(b)
  - Open Wiring, 320-7, 320-12
  - Overcurrent Devices, 240-16(b)
  - Resistors and Reactors, 470-1
  - Rigid Nonmetallic Conduit, 347-3(c)
  - Space Heating Systems, 424-12
  - Surface Raceways, 352-1, 352-22
  - Transformers, 450-7(a)
  - UF Cable, 339-3(c)
  - Wireways, 362-2

**Protective Devices** (see Circuit Breakers; Fuses; Overcurrent Protection; Thermal Cutout)**Protective Equipment** (see Guarding and Guards)

- Public Address Systems**, Art. 640
  - Emergency Power Supply, Art. 700
- Public Assembly Places**, Art. 520
  - Emergency Lighting Systems, Art. 700
- Pull Boxes** (see also Boxes and Junction Boxes)
  - Accessibility, 370-19
  - Construction Specifications, 370-C
  - Sizes, No. 6 and Larger Conductors, 370-18
  - Sizes, No. 6 and Smaller Conductors, 370-6
- Qualified Person**, Definition, Art. 100
- Raceway(s)**
  - Bonding, 230-63, 250-G
  - Busways, Art. 364
  - Cellular Concrete Floor, Art. 358
  - Cellular Metal Floor, Art. 356
  - Conductors in Service, 230-43
  - Continuity
    - Electrical, 300-10, 300-13
    - Mechanical, 300-12
  - Definition, Art. 100
  - Electrical Metallic Tubing, Art. 348
  - Emergency Circuits, Independent, 700-17
  - Expansion Joints, 300-6(b), 347-9
  - Fixtures as, 410-26
  - Flexible Metal Conduit, Art. 350
  - Grounding, 230-63(b), 250-D
    - Short sections, 250-33, 250-56
  - Induced Currents, 300-20
  - Inserting Conductors, 300-18
  - Insulating Bushings, 300-16, 373-6(b)
  - Liquidtight Metal Conduit, Art. 351
  - Metal-Trough, Sound Recording, 640-4
  - Number of Conductors, 300-17
  - Rigid Metal Conduit, Art. 346
  - Secured, 300-11
  - Service (see Service Raceways)
  - Signal and Power Circuits, Low-Energy
    - Different Systems, 725-16
    - Separations of other Conductors, 725-42
    - Sizes, 725-15
  - Storage Battery Rooms, 480-7
  - Structural, Art. 357
  - Supporting Conductors, Vertical, 300-19
  - Temperatures, 300-6
  - Underfloor, Art. 354
  - Underground, Cable Under Building, 230-32(a-4), 300-7
  - Wireways, Art. 362
  - Wiring, Outside, 730-23
- Radiographic Equipment**, 660-12(a)
- Radio, Television Equipment**, Art. 810
- Radio, Television Distribution Equip.**, Art. 820
- Railway**
  - Conductors, Power and Light, 110-19
- Rainproof**, Definition, Art. 100
- Raintight**, Definition, Art. 100
- Ranges**, 422-17, 422-23
  - Branch Circuits
    - Calculation of Load, Table 220-5
    - Conductors, 210-19
    - Maximum Load, 210-23
  - Feeders, Calculation of Load, 220-4
  - Grounding Method, 250-60
  - Loads, Demand, Table 220-5
  - Receptacles, 210-21(b) (see also Cooking Units) (see also Ovens)
- Reactors** (see Resistors and Reactors)
- Readily Accessible**, Definition, Art. 100
- Reaming**, Ends of Rigid Metal Conduits, 346-7
- Re-bar Electrodes**, 250-82(d)
- Receptacle (Convenience Outlet)**, Def., Art. 100
- Receptacle Outlet**, Definition, Art. 100
- Receptacles, 410-K**
  - Branch Circuits, 210-21, 210-22
  - Definition, Art. 100
  - Disconnecting Means, 422-22
  - Faceplates, 410-52(b)
  - Grounding Type, 250-74, 410-55
  - Hazardous Locations, 501-12, 502-13, 503-11
  - Less Than 50 Volts, 720-6, 720-7
  - Marinas and Boatyards, 555-3
  - Minimum Ratings, 410-52(a)
  - Mobile Homes, 550-6
  - Nongrounding types, Replacements, 210-21(b)
  - Outdoor, 410-54
    - Ground-Fault Protection, residential occupancies, 210-22(d)
  - Outlets, Where Required, Dwellings, 210-22(b)
  - Recreational Vehicles, 551-8, -19
  - Show Windows, In, 210-22(e)
  - Swimming Pools, Near, 680-6
  - Terminals, Identification, 200-10
  - Theaters, Halls, etc., 520-23, 520-45
- Recessed Lighting Fixtures**
  - As raceways, 410-11, 410-26
  - Clearances, 410-64
  - Construction, 410-N
  - Temperatures, 410-63
  - Wiring, 410-65
- Recording Systems**, Art. 640
- Recreational Vehicle Parks**, Art. 551-B
  - Application and Scope, 551-40
  - Calculated Load, 551-44
    - Demand Factors, Table 551-44
  - Definition of Terms, 551-41
  - Distribution System (Type), 551-43
  - Grounding, 551-46, -48
  - Outdoor Equipment, Protection of, 551-49
  - Overcurrent Protection, 551-45
  - Overhead Conductors, 551-50
  - Receptacles
    - Types Required, 551-52
    - Where Required, 551-42
  - Recreational Vehicle Lot Service Equipment, 551-47
  - Underground Wiring, 551-51
- Recreational Vehicles** (Camping Trailers, Motor Homes, Travel Trailers, Truck Campers), Art. 551-A
  - Appliance Accessibility, 551-24
  - Attachment Plugs, 551-4(e), 551-13(c)
  - Batteries, 551-3(a), (d-e)
  - Bonding, 551-23
  - Branch Circuits Required, 551-7(a-b)
  - Calculations for Loads, 551-7(c)
  - Combination Electrical Systems (120/120 V) 551-4
  - Conductors, 551-3(b), 551-15
  - Connections
    - Grounding, 551-21, -22, -23
    - Splices and Terminals, 551-17
  - Definition of Terms, 551-2
  - Disconnecting Means, 551-9(c)
  - Distribution Panelboard, 551-9
  - Dual-Supply Source, 551-12
  - Fixtures, 551-20
  - Generator Installations, 551-5
  - Grounding, 551-21, -22
  - Insulated

**Recreational Vehicles (Continued)**

- Grounding Conductor Splices, 551-17
- Neutral, 551-21(c)
- Low-Voltage (12VDC) wiring, 551-3
  - (b-c), (e)
- Outlet Boxes, 551-15
- Overcurrent Protection
  - Batteries and 12 V wiring, 551-3(e)
  - Branch Circuit, 551-10
  - Distribution Panelboard, 551-9
- Power-Supply Assembly, 551-11
  - Connection of, 551-13
  - Length of, 551-13(b)
  - Location of, 551-13(e)
- Receptacles
  - General
    - Types Required, 551-19
    - Where Required, 551-8(a-b)
  - Low-Voltage (12 V), 551-4(e)
- Switches, 551-18
- Tags, Labels and Marking, 551-4(f), 551-13(d)
- Tests, 551-25
- Wiring Methods
  - General, 551-14
  - Low-Voltage (12V), 551-3(c)

**Refrigeration Compressor Motors and Controls, Art. 440****Regulators, Mercury Vapor Lamps, 410-50****Relays**

- Reverse-Current, Transformers, 450-5(b)
- Thermal, Motor Overcurrent Protection, 430-40

**Remote-Control, Low-Energy Power, and Signal Circuits**

- Class 1 System
  - Circuits Beyond Building, 725-20
  - Conductors
    - Different Systems, 725-16
    - Insulation, 725-14
    - Number in Raceways, 725-15
    - Overcurrent Protection, 725-18
    - Size, 725-13
  - Grounding, 725-21
  - Location, Overcurrent Devices, 725-19
  - Mechanical Protection, 725-17
  - Wiring Methods, 725-11
- Class 2 System
  - Installation, 725-E
  - Limits, Voltage and Current, 725-31
  - Overcurrent Protection, Mounting, 725-32
  - Transformer Leads, 725-34
  - Transformer Rating, 725-33
- Classifications
  - Class 1, 725-3(a)
  - Class 2, 725-3(b)
- Communication Cables, 725-7
- Low-energy Power Circuits, Defined, 725-4
- Low-Voltage Power Circuits, Defined, 725-5
  - Overcurrent Protection, 725-22
  - Transformer Ratings, 725-23
- Motors, 430-F
- Safety-Control Devices, 725-6

**Residential Occupancies (see Dwellings)****Resistance**

- Conductors, Copper, Aluminum, Table 8, Chap. 9
- Conversion Factors, Table 9, Chap. 9
- Insulation, General Provisions, 110-20
- Welders, 630-D

**Resistance-to-Ground, Electrodes, 250-84****Resistors and Reactors, Art. 470**

- Combustible Material, on, near, 470-3
- Conductor Insulation, 470-7
- Contacts, Fixed, Movable, 470-4
- Incandescent Lamps as Resistors, 470-8
- Location, 470-1
- Mounting, 470-6
- Reactor Materials, 470-5
- Space Separation, 470-2

**Rheostats, Construction Specifications, 430-82(c)****Rigid Metal Conduit, Art. 346**

- Bends
  - How Made, 346-10
  - Number, 346-11
- Bushings, 346-8
- Cinder Fill, 346-3
- Construction Specifications, 346-B
- Couplings and Connectors, 346-9
- Expansion Joints, 300-6(b)
- Minimum Size, 346-5
- Number of Conductors, 346-6, Table 1, Chap. 9
- Reaming Ends, 346-7
- Supports, 346-12, Table 346-12
- Use, 346-1
- Wet Locations, 346-4

**Rigid Nonmetallic Conduit, Art. 347**

- Bends
  - How Made, 347-13
  - Number, 347-14
- Boxes and Fittings, 370-3, 370-7(c)
- Bushings, 347-12
- Construction Specifications, 347-16
- Description, 347-1
- Expansion Joints, 347-9, 300-6(b)
- Joints, 347-6
- Minimum Size, 347-10
- Number of Conductors, 347-11
- Supports, 347-8, Table 347-8
- Trimming Ends, 347-5
- Use permitted, 347-2
- Use prohibited, 347-3

**Rod Electrodes, 250-83(d)****Room Air Conditioners, 422-F, 440-22 (b-2) Exc. 1****Rosettes, 410-L**

- Overcurrent Protection, 240-17(d)

**Running Protection, Motors and Conductors, 430-C****Running Threads, 346-9(b)****Screw-Shells**

- Identification, Polarity, 200-8, 410-27
- Terminals, 200-10
- Lampholders, 410-G

**Sealable Equipment, Definition, Art. 100****Sealed Hermetic-Type Compressor (see Air Conditioning and Refrigerating Equipment)****Sealing, Conduit Systems (see also Hazardous Locations)**

- Temperature Changes, 300-6(a)
- Underground Services, 230-33

**Secondary Ties, Transformers, 450-5****Separately Derived Systems, Grounding, 250-26****Service(s), Art. 230**

- Definition, Art. 100
- Emergency Systems, 700-9

**Service(s) (Continued)**

- Farm, 220-4(n)
- Ground Fault Interrupters, 230-95
- Insulation, Size, 230-B
- Lateral, Def., Art. 100
- Number, 230-2
- Over 600V, 230-L
- Supply to Building Through Another, 230-3
- Underground, 230-D

**Service Cables, Art. 338**

- Buildings, 230-50
- Definition, Art. 100
- Installation, Art. 338
- Mechanical Protection, 230-46
- Service Head, 230-51
- Terminating, Service Equipment, 230-53
- Underground, 230-D, 310-6

**Service Drops**

- Clearance, Over Roofs, from Ground, Building Openings, 230-24
- Connections, Service Head, 230-51
- Definition, Art. 100
- Means of Attachment, 230-27
- Minimum Size, 230-23
- Number, 230-2, 230-21
- Point of Attachment, 230-26
- Supports Over Buildings, 230-25
- Termination, 230-24, 230-26, 230-51

**Service-Entrance Cable, Art. 338**

- Installation Methods, 338-4
- Marking, 338-5
- Use
  - Buried Conductors, 310-6
  - Branch Circuits or Feeders, 338-3
  - Service-Entrance Conductors, 338-2, Art. 230

**Service-Entrance Conductors, 230-E**

- Considered Outside of Buildings, when, 230-45
- Definition, Art. 100
- Disconnecting Means, 230-J
- Insulation, 230-40
- Mechanical Protection, 230-46
- Outside of Building, 230-45
- Over 600V, 230-L
- Overcurrent Protection, 230-90, 230-106
- Size, 230-41
- Service Head, 230-51
- Splices, 230-42
- Underground, 230-D
- Wiring Methods, 230-44

**Service-Entrance Equipment (Disconnecting Means and Overcurrent Protection)**

- Definition, Art. 100
- Disconnecting Means, 230-J
  - Approved Type, 230-70(c)
  - Connections ahead of, 230-73
  - Connections to Terminals, 230-72
- Disconnection of Grounded Conductor, 230-70(i)
- Electrically Operated, 230-94(f)
- Externally Operable, 230-70(e)
- Ground-Fault, Interrupter at, 230-95
- Indicating, 230-70(f)
- Interrupting Capacity, 230-98
- Location, 230-70(b)
- Multiple Occupancy Buildings, 230-70(b)
- Over 600V, 230-103
- Rating, 230-71
- Safeguard, Emergency Supply, 230-74
- Simultaneous Openings, 230-70(h)
- Six Switch Rule, 230-70(g)
- Two or More Buildings, Single Management, 230-76

**Service-Entrance Equip. (Continued)**

- Grounding, Bonding, Guarding, 230-H, 250-71, 250-72
- Overcurrent Protection, 230-K
  - Location, 230-91, 230-92
  - Over 600V, 230-106
  - Relative Location, 230-94
  - Specific Circuits, 230-93
  - Two or More Buildings, Single Management, 230-90(c)
- Ungrounded Conductors, 230-90(a)
- Panelboards, as, 384-B

**Service Raceways**

- Arranged to Drain, Raintight, 230-52, 230-101(g)
- Conductors, Others permitted in, 230-43
- Definition, Art. 100
- Grounding and Bonding, 230-63(b) (c), 250-71, 250-72
- Service Head, 230-51
- Terminating at Service Equipment, 230-53
- Underground, 230-D

**Service Stations, Gasoline, Art. 514****Shielded Nonmetallic-Sheathed Cable (Type SNM), Art. 337**

- Bends, 337-5
- Construction, 337-8
- Definition, 337-2
- Fittings, 337-7
- Handling, 337-6
- Marking, 337-9
- Uses Permitted, 337-4

**Shielding (see Guarding and Guards)****Short-Time Duty, Definition, Art. 100****Show Cases, Wall Cases, 410-23(c)****Show Window(s)**

- Cords, Flexible, 400-6
- Definition, Art. 100
- Lighting Fixtures, 410-7
- Branch Circuits, 220-2
- Feeders, 220-4
- Receptacles
  - Floor, 370-17
  - Where required, 210-22(e)
- Signs, Outline Lighting, 600-34(e)

**Sidelights, Borders and Proscenium, 520-44****Sign(s)**

- Electric, Definition, Art. 100
- Discharge, Lighting, Electric, 410-P, 410-Q
- Grounding, 250-43(f)
- Outline Lighting, Art. 600
- Size of Conductors (see Conductors)

**Signal Circuit(s)**

- Definition, Art. 100
- Installation Requirements, Art. 725

**Smoothing Irons, 422-13****Snap Switches**

- Accessibility, Grouping, 380-8
- Adjacent, Over 300V, 380-8
- Definition, Art. 100 under Switches
- Motors, 430-83, 430-109
- Panelboards, 384-16, 384-19
- Ratings
  - Inductive Loads, 380-14(a-1), (b-2)
  - Noninductive Loads, 380-14(a-2), (b-1)
  - Tungsten-Filament Loads, 380-14(a-2), (b-3)
- Residential Garages, Outbuildings, Sup-

**Snap Switches (Continued)**

ply Conductors, 230-76

Signs, 600-2

**Solderless (Pressure) Connector, Definition, Art. 100****Sound Recording**

Equipment, Art. 640

Motion Picture Projectors, 540-50

Theaters, Assembly Halls, etc., 520-3

**Space**

Cabinets, Cutout Boxes, 373-7, 373-9, 373-11

Lightning Rods, Conductor Enclosures, Equipment, 250-46

Outside Branch Circuits, Feeders, 730-14  
Over 600 Volts, Separation, 230-101, 710-33

Service Conductors, 230-47, 230-48

Working Space About Electrical Equip., 110-16

**Space Heating, Fixed, Art. 424****Spacing Between Bare Metal Parts, Table 384-26****Special Permission, Definition, Art. 100****Splices and Taps**

Antennas, 810-14

Auxiliary Gutters, 374-8

Cable Heating, 424-40

Cellular Concrete Floor Raceways, 358-10

Cellular Metal Floor Raceways, 356-6

Concealed Knob and Tube, 324-11

Continuous Rigid Cable Supports, 318-4(j)

Deicing, Snow-Melting, 426-27

Fixtures, 410-25

Flat Cable Assemblies, 363-10

Flexible Cords, 400-5

General Provisions, 110-14

Nonmetallic Extensions, 342-5

Open Wiring, 320-5(a-2)

Space Heating Cables, 424-40

Structural Raceways, 357-7

Underfloor Raceways, 354-6

Wireways, 362-6

**Stage Equipment**

Fixed, Theaters, Assembly Halls, etc., 520-C

Portable, Theaters, Halls, etc., 520-E

**Stage Motion Picture, 530-B**

Switchboard, 520-B, 520-D

**Stand-By Power Generation Systems, Art. 750 (see also Emergency Systems, Art. 700)**

Approval, 750-3

Capacity, 750-6

Control and Transfer, 750-7

Generator, 750-5

Protection, 750-8

Tests, 750-4

Wiring, 750-9

**Steel Siding (see Metal Siding)****Storage Batteries, Art. 480**

Aircraft Hangars, 513-9

Battery Rooms, 480-7

Emergency Systems, 700-7, 700-22

Garages, 511-7

Recreational Vehicles, 551-3

Sound Recording Equipment, 640-9, 640-10

**Structural Raceways, Art. 357**

Definitions, 357-1

Installation, 357-A

**Structural Raceways (Continued)**

Construction, 357-B

Use, 357-2

**Substations, Motion Picture Studios, 530-F****Support(s) (see Articles on wiring and equip. involved)****Suppressors, Radio Noise, 810-4****Surface Raceway, Art. 352****Surge Protection, 502-3 (see also Lightning Protection)****Swimming and Wading Pools, Art. 680**

Approval of Equipment, 680-2

Bonding, 680-22

Cord-Connected Equipment, 680-7

Definitions, 680-4

Ground-Fault Circuit-Interrupters

Definition of, 680-4

Junction Boxes for, 680-21

Receptacles, for, 680-6

Storable Pool Wiring, Required for, 680-31

Wiring to, 680-21(b)

Grounding, 680-23, -24

Junction Boxes and Enclosures, 680-21

Overhead Conductor Clearances, 680-8

Receptacles, Location and Protection, 680-6

Storable Pool

Definition of, 680-4

Circuits to, protected by Ground-Fault Circuit-Interrupters, 680-31

Pumps for, 680-30

Transformers, 680-5(a-b), 680-20(a-2), 680-21(b)

Underwater Lighting Fixtures, 680-20

**Switch(es), Art. 380 (see also Hazardous Locations)**

Accessibility and Grouping, 380-8

Air Conditioning and Refrigerating Equipment, 440-B

AC General Use Snap Switch, Def., Art. 100

AC-DC Snap Switch, Def., Art. 100

Appliances, 422-24

Disconnecting Means

Appliances, 422-D

Motors, Controllers, 430-86, 430-H

Services, 230-70

Emergency Systems, 700-D

Foot

Heat Generating Equipment, 665-12(b)

X-ray Equipment, 660-B

General Use, Art. 380

Definition, Art. 100

Identification, 110-22

Isolating

Definition, Art. 100

Lightning Arresters, 280-25

Motors Over 100 HP, 430-109, Exc. 4

Services Over 600 Volts, 230-104

Knife, Art. 380

Limit

Cranes and Hoists, 610-34

Manually Operable, Art. 380, 430-86

Motor Controllers, 430-G

Definition, 430-81(a)

Motor Circuit, Definition, Art. 100

Panelboards, 384-16(b), 384-19

Service, 230-J

Signs, Outline Lighting, 600-2, 600-35

Snap, Art. 380

Theaters, Assembly Halls, Dressing Rooms, etc., 520-73



**Switch(es)** (*Continued*)

Time, Connection, 230-73, 230-94  
Unit, Appliances, 422-24

**Switchboard(s)**, Art. 384

Clearances  
  Around, 384-8, 110-16  
  From Ceiling, 384-7  
Conductor Covering, 384-9  
Construction Specifications, 384-C  
Easily Ignitable Materials, Near, 384-6  
Grounding Frames, 384-11  
Grounding Instruments, 384-12  
Guarding Live Parts, 110-17  
Illumination, 110-16(e)  
Location, 384-4  
Portable, Theater Stages, 520-D  
Support, bus-bars, conductors, 384-3  
Wet Locations, 384-5  
Working Spaces about, 110-16

**Switchgear, Metal-Enclosed**, 230-101(h), 230-106**Tables**

Ampacities  
  Crane and Hoist Motor Conductors, Table 610-14(a)  
  Fixture Wire, Table 402-4  
  Flexible Cord, Table 400-9(b)  
  General Conductors,  
    Aluminum or Copper-Clad Aluminum, in Raceways or Cables, Table 310-14  
    Aluminum or Copper-Clad Aluminum, Single Conductor in Free Air, Table 310-15  
  Copper, in Raceways or Cables, Table 310-12  
  Copper, Single Conductor in free air, Table 310-13  
  Correction Factors, Note 13 to Tables 310-12 thru 310-15  
  Simplified Wiring, Table 310-21  
  Wound-rotor Secondaries, Table 430-23(c)  
Bare Metal Parts, Spacings Between (Switchboards and Panelboards) Table 384-26  
Branch-Circuit Requirements, Table 210-25  
Calculation of Feeder Loads by Occupancies, Table 220-4(b)  
Conductor(s)  
  Application, Table 310-2(a)  
  Deflection, Min. Bending Space, in Cabinets, Cutout Boxes, Table 373-6(a)  
  Dimensions  
    Asbestos, Varnished Cambric, Table 7, Chap. 9  
    Lead-covered, Table 6, Chap. 9  
    Rubber, Thermoplastic-Covered, Table 5, Chap. 9  
  DC to AC (60 Cycle) Resistance Conversion, Table 9, Chap. 9  
  Fixture Wires, Types, Table 402-6  
  Flexible Cords, Types, Table 400-11  
  Grounding, Size,  
    For Grounded Systems, Table 250-94(a)  
    For Grounding Interior Equipment, Table 250-95  
    For Ungrounded Systems, 250-94(b)  
  Insulations, Table 310-2(b)  
  Number in Box,  
    Cu., in. Dimensions for Combinations, Table 370-6(b)  
    Deep Boxes, Table 370-6(a-1)  
    Shallow Boxes, Table 370-6(a-2)

**Tables** (*Continued*)

Over 600V to 5000V  
  Asbestos and Varnished Cambric, Single-Conductors, Table 310-2(e) (4)  
  Rubber-covered, Table 310-2(e) (1)  
  Shielding, Rubber-Insulated Conductors, Table 710-5  
  Varnished Cambric, multiple-Conductor cables, Table 310-2(e) (3)  
  Varnished Cambric, single-conductors, Table 310-2(e) (2)  
  Voltage Marking, 310-12  
  Properties, Table 8, Chap. 9  
  Support, Vertical Raceways, 300-19(a)  
Conduit or Tubing  
  Combination of Conductors, percent Area Fill, Table 1, Chap. 9  
  Dimensions, Table 4, Chap. 9  
  Flexible Metal ( $\frac{3}{8}$  in.), Table 350-3  
  Liquidtight Flexible Metal, 351-4(b)  
  Number of Conductors Permitted, Tables 1 to 8, Chap. 9, See 346-6, and 347-11  
  Radius of Bends, Table 346-10(a), 346-10(b)  
  Supports  
    Rigid Metal Conduit, Table 346-12  
    Rigid Nonmetallic Conduit, Table 347-8  
Continuous Rigid Cable Supports, Table 318-6(a)  
Cooking Appliances  
  Commercial, 220-6(a)  
  Household, 220-5  
General Lighting Unit Loads by Occupancies, Table 220-2(a)  
Gutters, Sheet-Metal Thickness, Table 374-9(d)  
Hazardous Chemicals by Groups, Table 500-2(c)  
Household Clothes Dryers, Demand Loads, Table 220-6(b)  
Household Ranges and Similar Cooking Appliances, Demand Loads, Table 220-5  
Identification Numbers, Table 500-2(b)  
Live Parts, Separation  
  Over 600V  
    Air Separation, Indoors, Table 710-33  
    Elevation, 710-34(f)  
    Working Space, 710-34(a)  
  Working Clearances, Table 110-16(a)  
Mobile Home Park Demand Factors for Feeders and Services, Table 550-22  
Motors  
  Full-Load Currents  
    AC Single-Phase, Table 430-148  
    AC 3-Phase, Table 430-150  
    AC 2-Phase, 430-149  
    DC, Table 430-147  
    Locked Rotor Current Conversion, Table 430-151  
    Locked Rotor, Code Letters, Table 430-7(b)  
    Maximum Rating or Setting, Br. Cir. Protective Devices, Table 430-152  
    Number and Location, Overcurrent Units, Table 430-37  
    Terminal Housing Tables, 430-12(b), 430-12(c) (1), 430-12(c) (2)  
  Multifamily Dwellings,  
    Common Demand Factors, Table 220-9  
  Optional Load Calculations, One-family Residences, Table 220-7, 220-8  
  Radio and TV Equipment, Antenna Sizes  
    Amateur Stations, Table 810-52

**Tables (Continued)**

- Receiving Stations, Table 810-16(a)
- Recreational Vehicle Park Demand Factors for Feeders and Services, Table 551-44
- Simplified Wiring, Table 310-21
- Temperatures for, Table 310-20(c)

**Tamperability**

- Air Circuit Breakers, 240-25(d)
- Type S Fuses, 240-22(d)

**Taps (see also Splices and Taps)**

- Branch-Circuit
  - Cooking Appliances, 210-19(c), Exc. 1
  - Individual Fixtures or Lampholders, 210-19(c), Exc. 2(a)
- Busways, 364-11, Exc. 1
- Feeders
  - 10-ft. Rule, 240-15, Exc. 5
  - 25-ft. Rule, 240-15, Exc. 6 and 7
  - Motor, 430-59
- Service-entrance Conductors, 230-42

**Telegraph Systems, Art. 800****Telephone Exchanges, Circuit Load, 220-2(c), Exc. 4****Telephone Systems, Art. 800****Television, Radio Equipment, Art. 810****Television Studios, Art. 520, Art. 530****Television & Radio Distribution Systems, Community Antenna, Art. 820****Temperature Limitation, Conductors in Outlet Boxes for Fixtures, 410-11****Temporary Wiring, Art. 305**

- Branch Circuits, 305-2(c)
- Disconnecting Means, 305-2(f)
- Earth Returns Prohibited, 305-2(e)
- Feeders, 305-2(b)
- Grounding, 305-3
- Receptacles, 305-2(d)
  - On Construction Sites, 210-7
- Services, 305-2(a)

**Terminal Housing, 430-145****Terminals**

- Connections to, General, 110-14, 250-113
- Electric Discharge Tubing, Signs, Outline Lighting, 600-34
- Identification
  - Motors, Controllers, 430-9
  - Polarity, 200-9, 200-10

**Tests**

- Deicing and Snow Melting Systems, 426-29
- Emergency Systems, 700-4
- Insulation Resistance,
  - General, 110-20
  - Mineral-Insulated Cable, 330-10
  - Space-Heating Cables, 424-45
- Mobile Homes, 550-10
- Recreational Vehicles, 551-25

**Theaters**

- Arc Lamps, 410-51
- Assembly Halls, Art. 520
- Emergency Lighting Systems, Art. 700
- Grounding, Electrical Fixed Equip., 250-43

**Therapeutic Equipment, Inductive and Dielectric Heat Generating, 665-E****Thermal**

- Cutout, Definition, Art. 100
- Disconnecting Means, 240-18
- Devices
  - Motors, 430-40
  - Overcurrent Protection, 240-8

**Thermal (Continued)**

- Protection, Definition, Art. 100
- Protector, Definition, Art. 100

**Thermally Protected (Thermal Protection), Marking on Motors, 430-7(a) (b)****Three Running Overcurrent Units, motors, Table 430-37****Tools, Metal Working Machine, Art. 670****Tools, Motor Operated, Grounding and Double Insulation, 250-45(c), 250-45(d)****Transformers, Transformer Vaults, Art. 450 (see also Hazardous Locations)**

- Arc Welders, 630-B
- Capacitors, 460-5
  - Installation, Art. 450
- X-ray Equipment, 660-D
- Electric Discharge Lighting Systems
  - 1000 Volts or Less, 410-P
  - More than 1000 Volts, 410-Q
- Instrument, Grounding, 250-L
  - Connections at Services, 230-73
- Isolating, in Anesthetizing Locations, 517-63
- Location, 450-2
- Overcurrent Protection, 450-3
- Power and Signal Circuits, Remote-control, 725-23, 725-33, 725-41, 725-42
- Remote-Control Circuits, for, 430-74(b), 725-23, 725-33
- Signs and Outline Lighting, 600-32
- Two-winding, Underwater Lighting Transformers, 680-5(a)
- Vaults, 450-C
- X-ray Equipment, 660-D

**Transmitting Stations, Radio and Television, 810-C****Trays, Storage Batteries, 480-6(b)****Tubing (see also Conduit)**

- Electric Discharge, Sign and Outline Lighting, 600-33, 600-34
- Electrical Metallic, Art. 348

**TV & Radio, Arts. 810 and 820****Underfloor Raceways, Art. 354**

- Conductors,
  - Number, 354-5
  - Size, 354-4
- Connections to Cabinets, Wall Outlets, 354-15
- Covering, 354-3
- Dead Ends, 354-10
- Discontinued Outlets, 354-7
- Fittings at Angles, 354-12
- Inserts, 354-14
- Junction Boxes, 354-13
- Low Points, Avoid, 354-11
- Markers, Where Required, 354-9
- Splices and Taps, Junction Boxes, 354-6
- Use, 354-2

**Underground Feeder and Branch-Circuit Cable (Type UF), Art. 339**

- Description and Marking, 339-1
- Overcurrent Protection, 339-4
- Use, 339-3

**Underground Services, 230-D****Underground Wiring, (see also Hazardous Locations)**

- Buried Conductors, Types USE, UF, 310-6, 339-3
- Conductor Types in Raceways, 310-5

**Underground Wiring** (*Continued*)

- Direct Burial in Earth, 310-6
- Over 600V, 710-3(b)
- Rigid Metal Conduit, 346-1
- Rigid Nonmetallic Conduit, 347-2
- Services, 230-30
- Wet Locations, 310-5

**Underplaster Extensions**, Art. 344**Unit Equipments**, Emergency Lighting, 700-22**Unused Openings**

- Boxes and Fittings, 370-8
- Cabinets and Cutout Boxes, 373-4

**Utilization Equipment**, Def., Art. 100**Vapors, Flammable** (see Hazardous Locations)**Varying, Duty**, Definition, Art. 100**Vaults**

- Capacitors, 460-2
- Film Storage, 530-E
- Service Over 600 Volts, 230-106, 710-31
- Transformers, 450-C

**Vehicle, Electric**, Charging, 511-8**Ventilated**, Definition, Art. 100**Ventilating Ducts**, Wiring, 300-21, 300-22**Ventilating Piping for Motors, etc.**

- Hazardous Locations,
- Class II Installations, 502-9
- Class III Installations, 503-7

**Ventilation**

- Battery Rooms, 480-7(b)
- Generators, 445-1 (see also Hazardous Locations)
- Motion Picture Projectors, 540-18
- Motors, 430-14(a), 430-16
- Positive-Pressure, 500-1, 500-4(b)
- Transformers, 450-8, 450-45

**Viewing Tables, Motion Picture**, 530-D**Voltage and Volts**

- Branch Circuits, Limits, 210-6
- Circuit, Definition, Art. 100
- Drop
  - Branch Circuits, 210-6(d)
  - Feeders, 215-3
- Electric Discharge Lighting, under 1000 Volts, 410-P; Over 1000 Volts, 410-Q
- General Provisions, 110-5
- Ground, to, Definition, Art. 100
- Less than 50, Circuits and Equip., Art. 720
- Limitations, Elevators, Dumbwaiters, Escalators, Moving Walks, 620-2
- Over 600V Circuits and Equip., Art. 710
- Swimming Pool Underwater Lighting Fixtures, 680-20
- Wiring Methods, 300-2

**Wall or Show Cases**, Conductors, 410-23**Wall-Mounted Ovens** (see Ovens, Wall-Mounted, Ranges, Cooking Units)**Warning Signs (Labels)**, At Equipment

- Induction and Dielectric Heating, 665-25
- Locked Room or Enclosure with Live Parts over 600V, 710-34(c)
- Services over 600V, 230-102
- Transformers, 450-7(d)

**Water Heaters, Protection**, 422-14**Water Pipe**

- As Grounding Electrode, 250-81
- Connections, 250-112, 250-113
- Resistance, 250-84

**Watertight**, Definition, Art. 100**Weatherproof**, Definition, Art. 100**Welders, Electric**, Art. 630

- Motor-Generator Arc, 630-C
- Resistance, 630-D
- Transformer Arc, 630-B

**Wet Locations** (see Damp or Wet Locations)

- Conductors, Types, 310-5
- Definition, Art. 100
- Electrical Metallic Tubing, 348-4
- Enameled Equipment, 300-5(a)
- Mounting of Equipment, 300-5(c)
- Rigid Metal Conduit, 346-4
- Rigid Nonmetallic Conduit, 347-2
- Switchboards, 384-5
- Switches, 380-4

**Window, Show** (see Show Windows)**Wire in Concrete Footings, Electrodes**, 250-83(a)**Wire(s)** (see Conductors; Cords; Fixture Wire)**Wireways**, Art. 362

- Conductors
  - Maximum Size, 362-4
  - Number, 362-5
- Dead Ends, 362-9
- Definition, 362-1
- Extensions, 362-10
- Extensions thru Walls, 362-8
- Marking, 362-11
- Splices and Taps, 362-6
- Supports, 362-7
- Use, 362-2

**Wiring Methods**, Types (see Table of Contents)**Wiring Methods, Gen'l Requirements**, Art. 300 (see also Hazardous Locations)

- Ducts, 300-21, 300-22
- Mobile Homes, 550-8
- Recreational Vehicles, 551-3(c), 551-14
- Temporary, Art. 305
- Theaters and Assembly Halls, 520-4

**Working Space**

- About Electrical Equipment, Horizontal Dimensions, Clear Spaces, Elevation of Equipment, General, 110-16

- Adjacent to Live Parts, Circuits over 600 Volts, 710-33, 710-34

- Service Overcurrent Devices, for, 230-96

**Workmanlike Installation**, 110-12**X-Ray Equipment**, Art. 660

- Control, 660-B
- Guarding and Grounding, 660-D
- Installation, 660-A
- Transformers and Capacitors, 660-C
























Boston Public Library

Copley Square

General Library



The Date Due Card in the pocket indicates the date on or before which this book should be returned to the Library. Please do not remove cards from this pocket.



